
LOKEE TESTING

Laboratory

United States
Environmental Protection Agency
Wood Heater Certification Test Report

JOTUL U.S.A., INC.
F500

Volume 1 of 1

13235 PRAIRIE CIRCLE EAST, SUMNER, WASHINGTON 98390
TELEPHONE: 360-897-9685

United States
Environmental Protection Agency
Wood Heater Certification Test Report

Jotul U.S.A., Inc.
400 Riverside Street
P. O. Box 1157
Portland, ME 04104

F500

Volume 1

Report By:

Chip Wadington
Deborah Wadington
Joy Venton

CONFIDENTIAL

RELEASED ONLY BY
AUTHORIZED PERSONNEL

May 31, 2002

TABLE OF CONTENTS

<u>Page(s)</u>		<u>Section(s)</u>
Introduction		
	Title Page	i
	Table of Contents	ii
	Test Report (Data) Page Number Index	iii-iv
	Individual Test Run Page Number Index	v
	Test Series Information and Discussion	vi
	Stove Storage Information	vii
	Stack Measurements and Sampling Port Locations	viii
	Stove / Catalysts Aging Data	ix
	Scheduling Information	varies
Summary and Discussion of Results		
	Emission Test Summary	Data Summary 1
	Emission Graph	1
	Data Summary	2, 3
Individual Test Runs (Raw Data)		
	See Introduction, Individual Test	
	Run Page Index for a complete,	<0.80 kg/hr varies
	sequential list of data and data	0.8 - 1.25 kg/hr varies
	sequence in the individual test runs	1.25 - 1.90 kg/hr varies
		>1.90 kg/hr varies
		Fan Confirmation (if necessary) varies
		Insert Confirmation (if necessary) varies
Calibration Data		
	See Test Report (data) Page Number	
	Index, Item 14, for a complete, sequential	Cal Data varies
	listing of the data in this section.	
Stove Q C		
	Stove Q C	Stove Q C varies
	Firebox Volume Dimensions	
	Manufacturer's Drawings	
Manual		
	Manufacturer's Written Test	Manual varies
	Instructions (if provided)	
	Manufacturer's Operation Manual	
Appendices		
	A: - Example Calculations	Appendix A varies
	B: - Installation Description and Operating Instructions	Appendix B varies
Efficiencies		
	A. Data Summary	Efficiencies varies
	B. Individual Run Data	
Photos		
	Photos of wood loads in and out	Photograph Pages varies
	of the test unit.	

2. Post Certification Test	Cal Data	Pages 16 & 17
3. Transfer Standard Calibration	Cal Data	Pages 18-23
4. Wet Test Meter Calibration	Cal Data	Page 24
I. Tracer Gas Rotameter	Cal Data	Pages 25-26
J. Combustion Gas (CO ₂ , O ₂ , CO) Train Response Check	Cal Data	Page 27
K. Tracer Gas (SO ₂) Train Response Check	Cal Data	Page 27
L. CO Analyzer		
1. Calibration	Cal Data	Pages 28 & 29
2. Zero/Span Control Chart	Cal Data	Page 30
3. Pre and Post Test Zero/Span	Individual Test Runs	Data Sheet # 15-3
M. CO ₂ Analyzer		
1. Calibration	Cal Data	Pages 31 & 32
2. Zero/Span Control Chart	Cal Data	Page 33
3. Pre and Post Test Zero/Span	Individual Test Runs	Data Sheet # 15-1
N. O ₂ Analyzer (Optional)		
1. Calibration	Cal Data	Pages 34 & 35
2. Zero/Span Control Chart	Cal Data	Page 36
3. Pre and Post Test Zero/Span	Individual Test Runs	Data Sheet # 15-2
O. SO ₂ Analyzer		
1. Calibration	Cal Data	Pages 37 & 38
2. Zero/Span Control Chart	Cal Data	Page 39
3. Pre and Post Test Zero/Span	Individual Test Runs	Data Sheet # 15-4
P. Calibration Gas Certificates of Analysis		
1. Pre and Post Test Zero/Span Audits	Individual Test Runs	Data Sheets #15-1 - 15-4
2. Method 3 Verification of Analysis (CO ₂ , O ₂ , CO, N ₂)	Cal Data	Varies
3. Method 6 Verification of Analysis (SO ₂ , N ₂)	Cal Data	Varies
15. Quality Checks		
A. Leak Checks		
1. Particulate Sampling Train	Individual Test Runs	Data Sheet #2
2. SO ₂ Injection System	Individual Test Runs	Data Sheet #16
3. Combustion Gas (CO ₂ , O ₂ , CO) (CEM) Train	Individual Test Runs	Data Sheet #16
4. Tracer Gas (SO ₂) Train	Individual Test Runs	Data Sheet #16
B. Proportional Checks	Individual Test Runs	Table 5-Computer Printout
16. Sample Calculations		
A. Weighted Average Emission Rate	Data Summary	Weighted Average Calc Sheet
B. Dry Burn Rate	Individual Test Runs	Data Sheet # 8
C. [Vm] - [Vm (std)]	Individual Test Runs	Data Sheet # 7 (Particulate Calc Sheet)
D. Total Gas Flow Rate (Qsd)	Individual Test Runs	Table 4-Computer Printout
E. Proportionality Rate (PR)	Individual Test Runs	Table 5-Computer Printout
F. Particulate Emission Rate	Individual Test Runs	Table 4-Computer Printout
17. Raw Test Data	Individual Test Runs	Data Sheets # 1-16
18. Analytical Data		
A. Filter and Beaker Tares	Individual Test Runs	Data Sheets # 4-1, 4-2
B. Solvent Blanks	Individual Test Runs	Data Sheet # 5
C. Particulate Catches		
1. Gross	Individual Test Runs	Data Sheet # 3
2. Blanks	Individual Test Runs	Data Sheets # 5 & 6
3. Net	Individual Test Runs	Data Sheet # 6
4. Gr/dscf	Individual Test Runs	Data Sheet # 7
D. Constant Weight Weighing	Individual Test Runs	Data Sheet # 4-3

TEST SERIES INFORMATION

Unit name and model number: F500

Type of unit: Wood Heater

Manufacturer: Jotul U.S.A., Inc.
Address: 400 Riverside Steet
Portland, ME 04104

Contact: Roger Purington
Phone Number: 207-797-5912
Fax Number: 207-772-0523

Observers: None

Date Rcv'd: 09/18/2001 Aged: 04/25-26/2002 Tested: 05/15-21/2002

Tested by: LoKee Testing Lab using EPA Methods 28, 28A and 5H where applicable.

Test Location: 13235 Prairie Circle East
Sumner, WA 98390-7250
Test Site Elevation: 500 feet above sea level


LoKee's Field Team

Team Members: Chip Wadington
Deborah Wadington
Joy Venton

The following pages contain (1) test unit storage information, (2) a diagram showing the height and location of the stack components and sampling ports, and (3) copies of the certification test notices and cancellations sent to the EPA.

Model: F500

Date: 05/21/02



AGING DATA SHEET

UNIT: F500

DATE: 4-25-02

Hr #	DATE	TIME	TEMP	TEMP
			Fbox 1	Sec 2
1	4-25-02	1110	1028	1419
2	"	1210	671	665
3	"	1310	470	1166
4	"	1410	676	1188
5	"	1510	741	840
6	4-26-02	1210	1126	1315
7	"	1310	723	757
8	"	1410	474	1233
9	"	1510	636	1251
10	"	1610	722	901
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

Hr #	DATE	TIME	TEMP	TEMP
			1	2
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				
47				
48				
49				
50				

COMMENTS:

store lit 0830
store lit 0900

LOKEE TESTING LABORATORY.
 13235 PRAIRIE CIRCLE EAST, SUMNER, WA 98390-7250
 Phone (360)-897-9685

To: Robert C. Marshall, Jr., US EPA
From: Chip Wadington, LoKee Testing Laboratory
Subject: Wood Stove Certification Test Notification

This is to notify EPA that:

Manufacturer's Name: JOTUL USA INC.
Address: 400 Riverside Street
 Portland, Maine 04104

Contact: Shawn Malloy
Phone: 1-207-797-5912

has scheduled the **F-500** for certification testing at LoKee according to the following:

Dates Scheduled	Date Notification Sent	Date Notification Canceled	Testing Activity (if any)
9/17-21/01	8/9/01		None
9/14-28/01	8/9/01		None
10/1-5/01	8/9/01		None
10/8-12/01	8/9/01		None
10/15/19/01	8/9/01		None
11/5-9/01	10/03/01		None
11/12-16/01	10/03/01		None
11/19-23/01	10/03/01		None
11/26-30/01	10/03/01		None
1/17,18/02	12/17/01		None
1/21-25/02	12/17/01		None
1/28-2/1/02	12/17/01		None
2/4-8/02	12/17/01		None



CPA

Wood Heater Emission Test Summary

Laboratory/Wood Heater Information


Stove Manufacturer: **Jotul**
 Model Identification: **F500**
 Stove Type> 1=cat,
 2=noncat, 3=pellet: **2**

Laboratory Name: **LoKee Testing Lab**
 Laboratory Contact: **CHIP WADINGTON**
 Telephone no.: **360-897-9685**

Test Dates: **5/15-21/2**

Test Methods Used
 Method 28/Other: **28**
 Sampling Method: **5H**

Run no.	Burn Rate (kg/hr)	Emission Rate (g/hr)	Heat Output (Btu/hr)	Wtd Avg (g/hr) 3.16
1	0.99	4.38	11938	
2	1.23	3.28	14832	
3	1.89	1.24	22790	
4	2.88	3.59	34728	
			NA	
			NA	
5	1.21	4.28	14590	
			NA	



DATA SUMMARY

Unit : Jotul U.S.A., Inc. - F500

	RUN #	1	4	3	2	5 Fan			
Particulate Emissions:									
Concentration:	grains/dscf:	.1830	.1142	.0314	.0630	.1529			
Emissions Rate	grams/hr:	4.39	3.28	1.24	3.59	4.28			
Emissions Factor	grams/kg:	4.43	2.66	0.65	1.25	3.54			
Front Half Catch	% of total	40.8	31.8	38.3	37.6	28.7			
Total Mass Captured	total catch:	1.3150	.7372	.1150	.1403	.9613			
Heat Output (EPA Default):									
	BTU/hr	11,951.4	14,864.3	22,832.1	34,690.8	14,588.4			
Fuel Burn Rates:									
	Average kg/hr (dry)	0.99	1.23	1.89	2.88	1.21			
Fuel Moisture Content:									
	Kindling (wet basis)	11.739	11.032	11.164	11.583	10.608			
	Pretest Fuel (wet basis)	17.041	16.730	16.817	17.460	16.823			
	Test Fuel (wet basis)	17.232	17.405	17.777	17.031	16.985			
Air to Fuel Ratio									
		N/A	N/A	N/A	N/A	N/A			
Average Stack Gas									
	Avg CO ₂	6.78	7.57	9.19	9.78	7.50			
	Avg O ₂	N/A	N/A	N/A	N/A	N/A			
	Avg CO	1.55	1.14	0.69	0.68	1.28			
	Avg Moisture	5.45	7.56	8.32	8.93	7.61			
Avg Stack Gas Emissions:									
	CO	g/Kg	194.05	137.02	74.68	69.54	152.53		
		g/hr	192.31	168.95	141.36	200.06	184.56		

	RUN #	1	4	3	2	5 Fan			
Avg Stack Gas Flow Rate									
EPA CMB	dscfm	6.16	7.38	10.14	14.67	7.19			
Tracer Gas	dscfm	6.114	6.910	9.481	11.485	7.034			
Draft (static)	in H ₂ O	-.036	-.044	-.054	-.061	-.044			
Proportionality Average	%	100	100	100	100	100			
Average Temperatures									
Stack Gas	°F	212	249	360	448	253			
Firebox	°F	594	668	765	849	651			
Secondary	°F	777	838	1092	1065	846			
Catalytic Combustor	°F	N/A	N/A	N/A	N/A	N/A			
Top	°F	298	355	437	502	360			
Left Side	°F	149	156	174	196	225			
Back	°F	239	263	301	325	260			
Right Side	°F	193	229	269	282	271			
Bottom	°F	217	229	306	284	242			
Temperature Change	°F	-72.6	-65.2	-36.4	-41.0	-45.8			
Test Chamber Environment									
Average Barometer	in. Hg	30.21	29.83	30.17	30.05	30.04			
Average Temperature	°F	77	75	75	79	76			
Ambient Moisture	% H ₂ O	1.10	1.35	1.50	1.15	1.25			
Relative Humidity	%RH	31.0	35.0	37.0	25.5	43.5			
Air Velocity	m/sec	0	0	0	0	0			
Fuel Weight and Burn Time									
Density (dry basis)	gm/cm ³	N/A	N/A	N/A	N/A	N/A			
Coal Bed Weight	lbs	4.1	4.2	4.0	4.1	4.0			
Pre Test Fuel (inc kindling)	lbs	47.9	50.1	49.9	48.4	51.3			
Test Fuel	lbs	16.5	17.0	16.5	17.2	16.6			
Burn Time	min	375	310	195	135	310			

Faint, illegible text on the left side of the page, possibly bleed-through from the reverse side.



Large blank white area on the right side of the page.

COMPUTER INPUT DATA SHEET #1

Client: JOTUL U.S.A., INC.

Address: 400 RIVERSIDE ST., P.O. BOX 1157
PORTLAND, MAINE 04104

Phone: (207) 797-5912 Fax: (207) 772-0523

Run No.: 1 Date of Test: 05-15-2002 Burn Rate: .991

Model No.: F500 min min-1.25 fan

Stove Type: Cat Non Cat Pellet 1.25-1.9 max Insert

Dry Gas Meter Y Factor: 1.000 Post Leak Rate: .007 cfm Time: 375 min.
(0.000) (Data Sheet #2) (0.000) (Data Sheet #2) (000) (Data Sheet #2)

Dry Gas Meter Volume: 113.770 cf
(00.000) (Data Sheet #2)

Stack Flow: 6.114 dscfm Δ H: .142 in. H₂O
(00.000) (Data Sheet #2) (0.000) (Data Sheet #2)

Maximum Vac.: 2.0 Barometric Pressure: 30.21 in. Hg
(0.0) (Data Sheet #2) (00.00) (Data Sheet #2)

H₂O Captured: 135.7 g
(00.0) (Data Sheet #3)

Front Half Catch % Of Total: 40.8 % Total Particulate Catch: 1,3150 g
(00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)

Flue Gas Moisture: 5.4470 %
(00.000) (Data Sheet #7)

Particulate Emission: .1830 gr/dscf
(0.0000) (Data Sheet #7)

Relative Humidity: 31.0 % RH Ambient Moisture: 1.10 % H₂O
(00.0) (Data Sheet #8) (0.00) (Data Sheet #8)

Pretest Fuel Wt.: 47.9 lbs. Coal Bed Wt.: 4.1 lbs. Test Fuel Wt.: 16.5 lbs.
(00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)

Heat Output (EPA Default): 11,951.4 BTU/hr
(00,000.0) (Data Sheet #8)

Kindling Fuel % Moisture (wet): 11.739 % Pretest Fuel % Moisture (wet): 17.041 %
(00.000) (Data Sheet #10) (00.000) (Data Sheet #10)

Test Fuel % Moisture (dry): 20.820 % Test Fuel % Moisture (wet): 17.232 %
(00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])

Fuel Higher Heating Value (dry): — BTU/lb.
(0000) (Data Sheet #11)

Stack Static Pressure: -.036 in. H₂O
(+/- .000) (Data Sheet #12)

Average Ambient Temperature: 77 °F Stove Temperature Change: -72.6 °F
(00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul U.S.A., Inc.

TEST No. : 1

MODEL: F500

DATE: 15-May-02

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
0	443.500	0.150	83	1.37	5.80	550
5	445.000	0.320	83	0.91	3.60	375
10	447.239	0.140	83	0.83	3.40	575
15	448.701	0.140	83	0.81	3.60	575
20	450.163	0.110	83	1.24	5.30	625
25	451.508	0.140	83	1.05	6.80	575
30	452.970	0.150	83	1.01	7.20	550
35	454.498	0.120	83	1.20	6.60	600
40	455.899	0.180	83	0.81	7.70	500
45	457.580	0.200	83	0.61	9.20	475
50	459.349	0.250	84	0.31	11.50	425
55	461.333	0.250	84	0.34	10.20	425
60	463.317	0.250	84	0.49	9.20	425
65	465.300	0.240	85	0.58	9.40	425
70	467.292	0.240	85	0.45	9.80	425
75	469.283	0.240	85	0.53	9.60	425
80	471.274	0.240	85	0.55	9.60	425
85	473.266	0.240	86	0.50	9.60	425
90	475.264	0.200	86	0.72	9.30	475
95	477.053	0.200	86	0.68	9.40	475
100	478.842	0.200	86	0.75	8.80	475
105	480.630	0.180	86	0.76	9.40	500
110	482.330	0.180	86	0.52	12.10	500
115	484.029	0.180	86	0.51	11.60	500
120	485.728	0.220	86	0.45	11.70	450
125	487.616	0.220	87	0.32	11.30	450
130	489.511	0.220	87	0.19	11.80	450
135	491.405	0.140	87	0.82	9.00	550
140	492.956	0.160	87	0.64	9.20	525
145	494.581	0.180	87	0.65	9.10	500
150	496.286	0.130	87	1.30	6.60	575
155	497.770	0.120	87	1.41	6.40	600
160	499.191	0.110	87	1.65	6.20	625
165	500.556	0.100	88	1.97	6.00	650
170	501.874	0.110	88	2.20	5.70	625
175	503.244	0.110	89	2.19	5.70	625
180	504.619	0.110	89	2.25	5.50	625
185	505.993	0.110	89	2.18	5.50	625
190	507.368	0.110	89	2.17	5.60	625
195	508.743	0.120	89	2.17	5.60	600
200	510.175	0.110	89	2.16	5.60	625
205	511.550	0.120	89	2.21	5.60	600
210	512.982	0.120	89	2.21	5.60	600
215	514.415	0.120	89	2.23	5.60	600

220	515.847	0.110	89	2.22	5.60	625
225	517.222	0.110	89	2.22	5.60	625
230	518.597	0.110	89	2.20	5.60	625
235	519.972	0.110	89	2.22	5.40	625
240	521.346	0.110	89	2.25	5.50	625
245	522.721	0.110	89	2.21	5.40	625
250	524.096	0.110	89	2.17	5.40	625
255	525.471	0.110	89	2.11	5.40	625
260	526.846	0.110	89	2.20	5.50	625
265	528.221	0.110	89	2.20	5.60	625
270	529.596	0.110	89	2.18	5.60	625
275	530.971	0.100	89	2.17	5.50	650
280	532.293	0.100	89	2.14	5.50	650
285	533.615	0.100	89	2.00	5.50	650
290	534.937	0.100	89	2.00	5.50	650
295	536.259	0.100	89	2.13	5.40	650
300	537.581	0.100	89	2.17	5.40	650
305	538.903	0.100	89	2.16	5.40	650
310	540.226	0.100	89	2.18	5.40	650
315	541.548	0.100	89	2.25	5.50	650
320	542.870	0.100	89	2.33	5.70	650
325	544.192	0.100	89	2.31	5.60	650
330	545.514	0.100	89	2.14	5.30	650
335	546.836	0.100	89	2.13	5.30	650
340	548.158	0.100	89	2.08	5.20	650
345	549.480	0.100	89	2.14	5.30	650
350	550.802	0.100	89	2.11	5.30	675
355	552.076	0.100	89	2.19	5.40	675
360	553.349	0.100	89	2.15	5.30	675
365	554.622	0.110	89	2.14	5.20	625
370	555.997	0.100	89	2.02	5.10	675
375	557.270	0.100	89	2.02	5.00	675
380						

TABLE 2---RAW DATA

CLIENT : Jotul U.S.A., Inc.

TEST No. 1

MODEL: F500

DATE: 15-May-02

METER CAL. FACTOR (Y) -----	1	Wt. WOOD BURNED (LB) -----	16.5	Lbs
BAROMETRIC PRESS. (Pb) -----	30.21 in Hg	WET, FUEL MOISTURE % -----	17.232	%
LEAK RATE POST (Lp) -----	0.007 cfm	Wt. PART. COLLECTED -----	1.315	g
WATER VOL. (V1c) -----	135.7 Ml	METER VOLUME Vm -----	113.77	mcf
TEST TIME (MIN) -----	375 min	HC MOLE FRACTION -----	0.0132	

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul U.S.A., Inc. TEST No. 1

MODEL: F500 DATE: 15-May-02

AVG DELTA		AVG PRCNT		
H	----- 0.14 in H2O	CO	----- 1.55	%

AVG METER		AVG PRCNT		
TEMP. Tm	----- 87 deg F	CO2	----- 6.78	%

AVG PPM		AVG BAL		
SO2	----- 577 PPM	CO2/CO	----- 4.37	%

TABLE 4 ----- CALCULATIONS

CLIENT : Jotul U.S.A., Inc.

TEST No. 1

MODEL: F500

DATE: 15-May-02

STD SAMPLE		STACK GAS	
VOL. Vm(std) -----	110.89 dscf	FLOW Qsd -----	369.734 dscf/Hr
			&
			6.16 dscf/min
VOL. WATER		PARTICULATE	
VAPOR Vw(std) ----	6.387 scf	CONCTR. Cs -----	0.0119 g/dscf
PRCNT		PARTC. EMISS.	
MSTR Bws -----	5.45 %	RATE E -----	4.39 g/Hr
BURN		MOLES OF GAS	
RATE BR -----	0.99 Kg/Hr	PER Lb WOOD Nt --	0.44 Lb-mole/Lb
CO EMISSION		PART. EMISS.	
RATE -----	192.31 g/Hr	RATE -----	4.43 g/Kgdry
	&		fuel
	194.05 g/Kgdry		
	fuel		

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul U.S.A., Inc.

TEST No. : 1

MODEL: F500

DATE: 15-May-02

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	810.4	97	100
10	825.1	99	
15	825.8	99	
20	825.8	99	
25	825.7	99	
30	825.8	99	
35	825.5	99	
40	825.7	99	
45	825.7	99	
50	824.8	99	
55	827.0	99	
60	827.0	99	
65	825.8	99	
70	828.8	100	
75	828.3	100	
80	828.3	100	
85	828.0	100	
90	829.7	100	
95	830.3	100	
100	830.3	100	
105	829.8	100	
110	830.4	100	
115	830.0	100	
120	830.0	100	
125	829.4	100	
130	831.7	100	
135	831.3	100	
140	831.8	100	
145	831.9	100	
150	831.4	100	
155	832.0	100	
160	831.3	100	
165	831.1	100	
170	833.8	100	
175	832.6	100	
180	834.9	100	
185	834.3	100	
190	834.9	100	
195	834.9	100	
200	834.7	100	
205	834.9	100	
210	834.7	100	
215	835.3	100	
220	834.7	100	

225	834.9	100
230	834.9	100
235	834.9	100
240	834.3	100
245	834.9	100
250	834.9	100
255	834.9	100
260	834.9	100
265	834.9	100
270	834.9	100
275	834.9	100
280	834.8	100
285	834.8	100
290	834.8	100
295	834.8	100
300	834.8	100
305	834.8	100
310	835.4	100
315	834.8	100
320	834.8	100
325	834.8	100
330	834.8	100
335	834.8	100
340	834.8	100
345	834.8	100
350	834.8	100
355	835.4	100
360	834.8	100
365	834.8	100
370	834.9	100
375	834.8	100
380		
385		

METER BOX DATA SHEET PAGE # 2

Page: 1 of 4

UNIT: F500 RUN: 1 DATE: 05-15-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .003 cfm _____ " Hg @ _____ cfm

15 " Hg @ .007 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1,500

ROTO: PRESS: <u>.16</u>			SAMPLING RATIO: <u>21</u> : 1				BP: <u>30.21</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
0	1205	443.500	—	6.308	.15	83	550	83	1.0
5	10	445.000	—	9.251	.32	83	375	83	2.0
10	15	447.239	447.239	6.033	.14	83	575	83	2.0
15	20	448.701	448.701	6.033	.14	83	575	83	2.0
20	25	450.163	450.163	5.551	.11	83	625	83	2.0
25	30	451.508	451.508	6.033	.14	83	575	83	2.0
30	35	452.970	452.970	6.308	.15	83	550	83	2.0
35	40	454.498	454.498	5.782	.12	83	600	83	2.0
40	45	455.899	455.899	6.938	.18	83	500	83	2.0
45	50	457.580	457.580	7.303	.20	83	475	83	2.0
50	55	459.349	459.349	8.148	.25	84	425	84	2.0
55	1300	461.333	461.333	8.148	.25	84	425	84	2.0
ROTO PRESS: <u>.15</u>			TOTALS:		81.836	2.15	998	BP.: 30.21	
60	1305	463.317	463.317	8.147	.25	84	425	84	2.0
65	10	465.300	465.300	8.133	.24	85	425	85	2.0
70	15	467.292	467.292	8.133	.24	85	425	85	2.0
75	20	469.283	469.283	8.133	.24	85	425	85	2.0
80	25	471.274	471.274	8.133	.24	85	425	85	2.0
85	30	473.266	473.266	8.133	.24	86	425	86	2.0
90	35	475.264	475.264	7.263	.20	86	475	86	2.0
95	40	477.053	477.053	7.263	.20	86	475	86	2.0
100	45	478.842	478.842	7.263	.20	86	475	86	2.0
105	50	480.630	480.630	6.900	.18	86	500	86	2.0
110	55	482.330	482.330	6.900	.18	86	500	86	2.0
115	1400	484.029	484.029	6.900	.18	86	500	86	2.0
			TOTALS:		91.301	2.59	1026	MAX VACC =	
TOTAL Cu Ft. <u>/</u>			TOTALS:		173.137	4.74	2024	AVG. BP: <u>/</u>	

METER BOX DATA SHEET PAGE # 2

Page: 2 of 4

UNIT: F500 RUN: 1 DATE: 05-15-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .003 cfm _____ " Hg @ _____ cfm

15 " Hg @ .007 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1,500

ROTO: PRESS: <u>.14</u>		SAMPLING RATIO: <u>21</u>		: 1		BP: <u>30.21</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
120	1405	485.728	485.728	7.666	.22	86	450	86	2.0
125	10	487.616	487.616	7.652	.22	87	450	87	2.0
130	15	489.511	489.511	7.652	.22	87	450	87	2.0
135	20	491.405	491.405	6.261	.14	87	550	87	2.0
140	25	492.956	492.956	6.559	.16	87	525	87	2.0
145	30	494.581	494.581	6.887	.18	87	500	87	2.0
150	35	496.286	496.286	5.989	.13	87	575	87	2.0
155	40	497.770	497.770	5.739	.12	87	600	87	2.0
160	45	499.191	499.191	5.510	.11	87	625	87	2.0
165	50	500.556	500.556	5.288	.10	88	650	88	2.0
170	55	501.874	501.874	5.500	.11	88	625	88	2.0
175	1500	503.244	503.244	5.490	.11	89	625	89	2.0
ROTO PRESS: <u>.14</u>		TOTALS:		76.193	1.82	1047	BP: <u>30.21</u>		
180	1505	504.619	504.619	5.490	.11	89	625	89	2.0
185	10	505.993	505.993	5.490	.11	89	625	89	2.0
190	15	507.368	507.368	5.490	.11	89	625	89	2.0
195	20	508.743	508.743	5.718	.12	89	600	89	2.0
200	25	510.175	510.175	5.490	.11	89	625	89	2.0
205	30	511.550	511.550	5.718	.12	89	600	89	2.0
210	35	512.982	512.982	5.718	.12	89	600	89	2.0
215	40	514.415	514.415	5.718	.12	89	600	89	2.0
220	45	515.847	515.847	5.490	.11	89	625	89	2.0
225	50	517.222	517.222	5.490	.11	89	625	89	2.0
230	55	518.597	518.597	5.490	.11	89	625	89	2.0
235	1600	519.972	519.972	5.490	.11	89	625	89	2.0
				TOTALS:	66.792	1.36	1068	MAX VACC =	
TOTAL Cu Ft.				TOTALS:	142.985	3.18	2115	AVG. BP:	

METER BOX DATA SHEET PAGE # 2

Page: 3 of 4

UNIT: 1 F500 RUN: 1 DATE: 05-15-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .003 cfm _____ " Hg @ _____ cfm

15 " Hg @ .007 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO PRESS: <u>.14</u>			SAMPLING RATIO: <u>21</u> : 1				BP: <u>30.21</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
240	1605	521.346	521.346	5.490	.11	89	625	89	2.0
245	10	522.721	522.721	5.490	.11	89	625	89	2.0
250	15	524.096	524.096	5.490	.11	89	625	89	2.0
255	20	525.471	525.471	5.490	.11	89	625	89	2.0
260	25	526.846	526.846	5.490	.11	89	625	89	2.0
265	30	528.221	528.221	5.490	.11	89	625	89	2.0
270	35	529.596	529.596	5.490	.11	89	625	89	2.0
275	40	530.971	530.971	5.279	.10	89	650	89	2.0
280	45	532.293	532.293	5.279	.10	89	650	89	2.0
285	50	533.615	533.615	5.279	.10	89	650	89	2.0
290	55	534.937	534.937	5.279	.10	89	650	89	2.0
295	1700	536.259	536.259	5.279	.10	89	650	89	2.0
ROTO PRESS: <u>.14</u>			TOTALS: <u>64.825</u>		<u>1.27</u>	<u>1068</u>	BP: <u>30.21</u>		
300	1705	537.581	537.581	5.279	.10	89	650	89	2.0
305	10	538.903	538.903	5.279	.10	89	650	89	2.0
310	15	540.224	540.224	5.279	.10	89	650	89	2.0
315	20	541.548	541.548	5.279	.10	89	650	89	2.0
320	25	542.870	542.870	5.279	.10	89	650	89	2.0
325	30	544.192	544.192	5.279	.10	89	650	89	2.0
330	35	545.514	545.514	5.279	.10	89	650	89	2.0
335	40	546.836	546.836	5.279	.10	89	650	89	2.0
340	45	548.158	548.158	5.279	.10	89	650	89	2.0
345	50	549.480	549.480	5.279	.10	89	650	89	2.0
350	55	550.802	550.802	5.083	.10	89	675	89	2.0
355	1800	552.076	552.076	5.083	.10	89	675	89	2.0
			TOTALS: <u>62.956</u>		<u>1.20</u>	<u>1068</u>	MAX VACC =		
TOTAL Cu Ft. <u>/</u>			TOTALS: <u>127.781</u>		<u>2.47</u>	<u>2136</u>	AVG. BP: <u>/</u>		

METER BOX DATA SHEET PAGE # 2

Page: 4 of 4

UNIT: F500 RUN: 1 DATE: 5-15-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .003 cfm _____ " Hg @ _____ cfm

15 " Hg @ .007 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.14</u>			SAMPLING RATIO: <u>21</u> : 1				BP: <u>30.21</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
360	<u>1805</u>	<u>553.349</u>	<u>553.349</u>	<u>5,083</u>	<u>.10</u>	<u>89</u>	<u>675</u>	<u>89</u>	<u>2.0</u>
365	<u>10</u>	<u>554.622</u>	<u>554.622</u>	<u>5,490</u>	<u>.11</u>	<u>89</u>	<u>625</u>	<u>89</u>	<u>2.0</u>
370	<u>15</u>	<u>555.997</u>	<u>555.997</u>	<u>5,083</u>	<u>.10</u>	<u>89</u>	<u>675</u>	<u>89</u>	<u>2.0</u>
375	<u>20</u>	<u>557.270</u>	<u>557.270</u>	<u>5,083</u>	<u>.10</u>	<u>89</u>	<u>675</u>	<u>89</u>	<u>2.0</u>
380									
385				<u>20.739</u>	<u>.41</u>	<u>354</u>			
390									
395									
400									
405									
410									
415									
ROTO PRESS:			TOTALS:				BP.:		
420									
425									
430									
435									
440									
445									
450									
455									
460									
465									
470				<u>464.642</u>		<u>6631</u>	<u>76</u>		
475					<u>10.80</u>	<u>87</u>			
			TOTALS:				MAX VACC = <u>2.0</u>		
TOTAL Cu Ft.		<u>113.770</u>	TOTALS:		<u>6.114</u>	<u>.142</u>	<u>547</u>	AVG. BP: <u>30.21</u>	

76

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT : F500 RUN : 1 DATE : 05-15-02

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	720.6	594.3	487.0	886.6
INITIAL WT	617.6	587.1	483.9	864.2
NET WT GRAMS	103.0	7.2	3.1	22.4

TOTAL CATCH : 135.7 GRAMS H₂O

FRONT HALF

FILTER #	117F	
FINAL WT g	1.0408	•
INITIAL WT g	.6793	•
NET WT g	.3615	•

BEAKER #	44
DESC.	ACETONE
FINAL WT g	106.2302
INITIAL WT g	106.0544
NET WT g	.1758
VOL. DESC. ml	125

BACK HALF

FILTER #	118B	
FINAL WT g	.5999	•
INITIAL WT g	.4430	•
NET WT g	.1569	•

BEAKER #	47	48	49	50	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	107.4663	97.8136	108.4573	96.5870	
INITIAL WT g	107.0421	97.7560	108.3626	96.5390	
NET WT g	.4242	.0576	.0947	.0480	.1427
VOL. DESC ml	200	75	200	125	(325)

FILTER TARE WEIGHTS DATA SHEET #4-1

Into Dessicator : _____ Date : 01/29/02 Time : 1125 By : DKW
 Manufacturer S & S Grade : #25 Glass Front Size : 11 cm Lot No. : ZB921
 Back Size : 8.2 cm Lot No. : ZB911

DATE: <u>02-07</u> BY: <u>DKW</u>			DATE: <u>02-10</u> BY: <u>DKW</u>			DATE: _____	BY: _____
FILTER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME	
111F	.6782	0934	<u>.6780</u>	1939	JOTUL C450		R-2
112F	.6755	0935	<u>.6751</u>	1940	" "		R-3
113F	.6721	0935	<u>.6719</u>	1941	" "		R-4
114F	.6843	0936	<u>.6844</u>	1942	" "		R-5
115F	.6699	0937	<u>.6700</u>	1943	" "		R-6
116F	.6696	0938	<u>.6694</u>	1943	" "		R-7
117F	.6796	0939	<u>.6793</u>	1944	JOTUL F500		R-1
118F	.6715	0940	<u>.6718</u>	1945	" "		R-2
119F	.6743	0941	<u>.6746</u>	1946	" "		R-3
120F	.6844	0942	<u>.6843</u>	1947	" "		R-4

111B	.4462	0943	<u>.4464</u>	1948	JOTUL C450		R-2
112B	.4448	0944	<u>.4451</u>	1949	" "		R-3
113B	.4466	0945	<u>.4464</u>	1949	" "		R-4
114B	.4305	0946	<u>.4307</u>	1950	" "		R-5
115B	.4234	0947	<u>.4236</u>	1951	" "		R-6
116B	.4444	0948	<u>.4445</u>	1952	" "		R-7
117B	.4431	0949	<u>.4430</u>	1953	JOTUL F500		R-1
118B	.4293	0950	<u>.4294</u>	1954	" "		R-2
119B	.4441	0951	<u>.4439</u>	1955	" "		R-3
120B	.4427	0952	<u>.4425</u>	1955	" "		R-4

Checked by: C Washington Date: 2-10-02 Time: 2000

BALANCE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	WB	DB	% RH
02-07	0910	DKW		74	47
02-10	1905	DKW		74	45

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: F500

RUN: 1

DATE: 05-15 -02

Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
46	05-16	1825	BW	106.2305	05-18	1908	BW	106.2302	05-19	1504	BW				
47	05-17	1125	BW	107.4663	05-18	1909	BW	107.4663	05-19	1505	BW				
48	05-18	1930	BW	97.8135	05-20	0859	BW	97.8136	05-21	0934	BW				
49	05-16	1825	BW	108.4571	05-18	1910	BW	108.4573	05-19	1506	BW				
50	05-16	1825	BW	96.5867	05-18	1911	BW	96.5870	05-19	1507	BW				

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
117F	5-15	1900	CP	1.0465	05-16	1433	BW	1.0444	05-17	1602	BW	1.0432	05-18	1912	BW
				1.0412	05-19	1509	BW	1.0408	05-20	0900	BW				
117B	6-15	1900	CP	.6018	05-16	1435	BW	.5996	05-17	1603	BW	.5999	05-18	1913	BW

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	05-16	1430	BW	76	48
2	05-17	1600	BW	75	48
3	05-18	1905	BW	77	49
4	05-19	1506	BW	77	48
5	05-20	0855	BW	77	47

Weighing Session	Date	Time	By	DB	%RH
6	05-21	0930	BW	78	49
7					
8					
9					
10					

Dates: From 11-20-2001
Through 02-16-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius
Model: A1205
SN : 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	Wet Bulb	%RH
99.9998	10.0002	1.0003	.1000	SKW	11-20	0945	78		48
100.0000	10.0000	1.0001	.0999	SKW	11-21	1000	75		49
99.9998	9.9998	1.0000	.1001	SKW	11-22	1050	75		49
100.0003	9.9999	1.0000	.0999	SKW	11-26	1150	74		47
100.0001	9.9997	1.0000	.1000	SKW	11-27	1155	74		48
100.0001	10.0000	.9997	.0999	SKW	11-28	1220	72		48
99.9999	10.0001	1.0000	.1000	SKW	11-28	1930	73		48
99.9998	10.0000	.9999	.0999	SKW	11-29	1015	75		46
99.9998	10.0000	.9997	.0998	SKW	11-29	1925	73		46
100.0000	10.0001	.9998	.0999	SKW	11-30	1355	74		45
99.9999	9.9999	1.0000	.1000	SKW	12-01	1210	77		45
100.0003	10.0000	.9997	.1000	SKW	01-08	2045	78		47
100.0001	10.0000	.9998	.1000	SKW	01-09	1600	78		48
99.9999	9.9999	.9999	.1000	SKW	01-12	1900	74		46
99.9998	9.9999	.9997	.1000	SKW	01-13	1730	72		43
100.0000	10.0001	1.0000	.1001	SKW	01-14	1355	78		45
99.9998	9.9999	.9999	.1000	SKW	01-26	1745	72		47
99.9998	10.0000	1.0000	.0999	SKW	01-28	1705	74		44
100.0003	10.0000	1.0000	.0998	SKW	01-29	1130	70		47
99.9998	9.9997	1.0000	.1000	SKW	01-29	2300	71		44
100.0002	10.0000	1.0000	.1000	SKW	01-30	2200	75		45
99.9999	9.9999	.9999	.1000	SKW	01-31	2205	74		47
100.0001	9.9999	1.0000	.1000	SKW	02-02	0700	75		45
100.0002	9.9999	1.0001	.1000	SKW	02-04	1045	73		47
100.0000	10.0000	.9998	.0997	SKW	02-06	0905	73		47
100.0001	10.0000	1.0000	.1000	SKW	02-07	0910	74		47
100.0002	10.0001	1.0000	.0999	SKW	02-07	1235	77		48
99.9999	10.0000	.9999	.0998	SKW	02-08	1110	72		49
99.9998	9.9999	1.0000	.0999	SKW	02-09	1045	70		49
99.9997	10.0000	.9999	.0999	SKW	02-10	0920	74		48
99.9997	10.0001	.9999	.0999	SKW	02-10	1905	76		45
99.9999	9.9999	1.0000	.0997	SKW	02-11	1935	73		43
99.9998	9.9997	1.0000	.0999	SKW	02-13	1740	75		41
99.9997	10.0000	.9999	.1000	SKW	02-14	1015	74		38
99.9998	9.9999	1.0000	.1000	SKW	02-14	2010	74		43
100.0000	10.0000	1.0000	.1000	SKW	02-15	1150	74		41
99.9998	9.9999	.9999	.1000	SKW	02-16	1045	78		41

♡

Dates: From 02-16-2002
Through 05-17-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius
Model: A1205
SN : 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Wet Bulb	Dry Bulb	% RH
100.0000	9.9999	1.0000	.0999	BW	02-16	1845		77	46
100.0000	9.9999	.9999	.0998	BW	02-17	1555		77	47
100.0001	9.9999	.9999	.0997	BW	02-18	0940		77	47
100.0000	10.0000	.9999	.1000	BW	02-19	1025		78	46
100.0000	9.9999	1.0000	.0999	BW	02-20	0915		75	42
100.0003	10.0000	1.0000	.0999	BW	03-14	1020		78	45
99.9999	9.9998	.9998	.0998	BW	03-15	1725		77	45
99.9999	10.0000	1.0002	.0999	BW	03-16	1820		77	38
100.0001	9.9999	1.0001	.1000	BW	03-16	2130		78	43
99.9999	9.9999	.9998	.0998	BW	03-17	1550		77	43
99.9999	10.0000	1.0001	.0999	BW	03-17	2045		77	39
99.9998	10.0000	1.0000	.1000	BW	03-18	1100		77	39
100.0000	9.9999	.9999	.0999	BW	03-19	1800		76	42
100.0001	10.0000	1.0001	.1000	BW	03-20	1835		77	45
99.9999	10.0001	.9999	.0999	BW	03-21	2235		78	45
99.9998	9.9999	1.0000	.1000	BW	03-24	2205		78	42
99.9998	10.0000	1.0000	.1001	BW	03-25	1000		78	41
99.9997	10.0000	1.0001	.1000	BW	04-04	1300		78	49
99.9998	10.0000	1.0000	.0999	BW	04-05	1210		78	49
99.9997	10.0000	.9999	.0998	BW	04-05	2230		78	49
99.9999	10.0001	1.0000	.0998	BW	04-08	1135		78	47
99.9997	10.0000	1.0000	.0999	BW	04-08	1910		78	49
99.9997	9.9998	.9999	.1000	BW	04-09	2150		77	48
99.9999	10.0000	1.0000	.0999	BW	04-10	2205		78	48
100.0000	10.0001	.9999	.0999	BW	04-11	0940		76	49
99.9997	9.9998	1.0000	.0999	BW	04-11	1705		78	48
99.9999	9.9999	.9999	.0998	BW	04-11	2230		78	48
99.9999	10.0001	.9999	.0999	BW	04-12	0950		78	47
100.0000	9.9998	1.0000	.0999	BW	04-12	1810		78	48
100.0000	9.9999	.9999	.0998	BW	04-12	2205		78	47
100.0000	9.9999	.9999	.0999	BW	04-13	1720		78	48
99.9998	10.0000	1.0000	.0998	BW	04-13	2325		78	46
99.9999	10.0001	1.0001	.1000	BW	04-14	1740		78	44
99.9998	10.0000	1.0001	.0999	BW	04-16	1925		75	44
99.9997	9.9999	1.0000	.1000	BW	04-19	1350		78	41
100.0000	10.0001	.9998	.0999	BW	04-20	1210		75	41
99.9998	9.9998	1.0001	.0997	BW	05-16	1430		76	48
99.9999	9.9999	1.0000	.0999	BW	05-17	1600		75	48



BLANK PROCESSING DATA SHEET # 5

UNIT: F500 RUN: 1 DATE: 05-15-02

BLANKS DONE: 02-20-2002

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	McKESSON WATER PRODUCTS CO. CERTIFIED DISTILLED
FINAL WEIGHT	108.9015	106.3081	106.9664
TARE WEIGHT	108.9007	106.3064	106.9660
NET WEIGHT	.0008 ✓	.0017 ✓	.0004 ✓

TARE BEAKERS INTO DESC: TIME: 1205 DATE: 02-15-2002

DATE: 02-16 BY: ML DATE: 02-17 BY: ML DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9002	1849	108.9007 ✓	1611 ✓		
B	106.3068	1850	106.3064 ✓	1612 ✓		
C	106.9661	1851	106.9660 ✓	1613 ✓		

FINAL BEAKERS INTO DESC: TIME: 1125 DATE: 02-18-2002

DATE: 02-19 BY: ML DATE: 02-20 BY: ML DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9016	1027	108.9015 ✓	0917 ✓		
B	106.3084	1028	106.3081 ✓	0918 ✓		
C	106.9664	1029	106.9664 ✓	0919 ✓		

TARE QC

DATE	TIME	BY	WB	DB	%
02-16	1845	ML	}	77	46
02-17	1555	ML		77	47

FINAL QC

DATE	TIME	BY	WB	DB	%
02-19	1025	ML	}	78	46
02-20	0915	ML		75	42

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: F500 RUN: 1 DATE: 05-15-02

BLANK CALCULATIONS

Acetone : $\frac{.0008 \text{ g}}{200 \text{ ml}} = \frac{.000004}{\text{ml}}$ g/ml
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = \frac{.000023}{\text{ml}}$ g/ml
 Distilled Water : $\frac{.0004 \text{ g}}{200 \text{ ml}} = \frac{.000002}{\text{ml}}$ g/ml

FRONT HALF CATCH

FILTERS : $\frac{.3615 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ # of Filters} \cdot (.0000 \text{ g})}{\text{Blank Value / Filter}} = \underline{.3615 \text{ g}}$

BEAKERS : $\frac{.1758 \text{ g}}{\text{Total Catch}} - \frac{125 \text{ ml Acetone} \cdot (.000004 \text{ g})}{\text{Blank Value / ml Acetone}} = \underline{.1753 \text{ g}}$

TOTAL FRONT HALF CATCH : .5368 g

BACK HALF CATCH

FILTERS : $\frac{.1569 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ # of Filters} \cdot (.0000 \text{ g})}{\text{Blank Value / Filter}} = \underline{.1569 \text{ g}}$

BEAKERS :
 Acetone : $\frac{.4242 \text{ g}}{\text{Total Catch}} - \frac{200 \text{ ml Acetone} \cdot (.000004 \text{ g})}{\text{Blank Value / ml Acetone}} = \underline{.4234 \text{ g}}$

Extract : $\frac{.0576 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Dichloromethane} \cdot (.000023 \text{ g})}{\text{Blank Value / Dichloromethane}} = \underline{.0559 \text{ g}}$

Water : $\frac{.1427 \text{ g}}{\text{Total Catch}} - \frac{325 \text{ ml Water} \cdot (.000002 \text{ g})}{\text{Blank Value / Water}} = \underline{.1420 \text{ g}}$

TOTAL BACK HALF CATCH : .7782 g

TOTAL CATCH : 1.3150 g

% FRONT HALF : 40.8 %

CALCULATIONS DATA SHEET # 7

UNIT: F500 RUN: 1 DATE: 05-15-02

$$1) Vm (std) = \frac{(113.770 Vm) (17.64) (1.000 mcf) \left(30.21 \text{ " Hg} + \frac{.142 \text{ " H}_2\text{O}}{13.6} \right)}{(547 \text{ TmA})} = \frac{110.8766}{000.0000} \text{ dscf}$$

$$2) Vw (std) = (.04707) (135.7 \text{ ml H}_2\text{O}) = \frac{6.3874}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(6.3874 \text{ scf})}{(6.3874 \text{ scf} + 110.8766 \text{ dscf})} = \frac{.0545}{.0000} \text{ Bws} \times 100 = \frac{5.4470}{00.0000} \% \text{ H}_2\text{O}$$

$$4) Cs = \frac{(1.3150 \text{ g.})}{(110.8766 \text{ dscf})} (15.43) = \frac{.1830}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(1.3150 \text{ g.})}{(110.8766 \text{ dscf})} (6.114 \text{ dscfm}) (60) = \frac{4.3507}{00.0000} \text{ g / hr}$$

<p>Vm = total cubic feet pulled on meter box during test mcf = meter correction factor (Y factor) of meter box used for test " Hg = average barometric pressure during test " H₂O = average delta H for test TmA = average meter temperature for test in degrees Absolute ml H₂O = total water caught during test g. = total particulate catch for test dscfm = average stack flow during test</p>	<p>(000.000 Vm) (0.000 mcf) (00.00 " Hg) (.000 " H₂O) (000 TmA) (000.0 ml H₂O) (00.0000 g.) (00.000 dscf)</p>
<p>(p. 2) (p. 2) (p. 2) (p. 2) (p. 2) (p. 3) (p. 6) (p. 2)</p>	<p>(p. 2) (p. 2) (p. 2) (p. 2) (p. 2) (p. 3) (p. 6) (p. 2)</p>

TEST DATA SHEET # 8

UNIT : F500 RUN : 1 DATE : 05-15-02

Test Chamber Air Velocity Start : 0 Stop : 0 Avg.: 0

Wet Bulb / Dry Bulb

Pre : WB : 62 DB : 79 = 36 % RH 1.2 % H₂O

Post : WB : 61 DB : 83 = 26 % RH 1.0 % H₂O

Average : 31.0 % RH 1.1 % H₂O

Empty Stove Weight (lbs) : _____ w/ stack & oil seal : Wet : _____ Dry : 0.0

Kindling Weight (lbs) : Paper : .1 Wood : 4.7

Preburn Fuel Weight : 13.1 + 15.5 + 12.1 + 2.5 Total : 43.2

Kindling & Preburn Fuel Weight (wood only) (lbs) : Total : 47.9

Coal Bed Wt Range (lbs) : 4.1 - 3.3 Scale : 4.1 - 3.3

Upper : .25 x fuel weight : Always round DOWN to nearest tenth
 Lower : .20 x fuel weight : Always round UP to nearest tenth Actual Coal Bed Weight : 4.1

Maximum Coal Bed Removal (lbs) : $((\frac{4.1}{\text{Upper}} + \frac{3.3}{\text{Lower}}) \div 2) \cdot 25 = \frac{.90}{\text{round down to nearest tenth}}$

Test Fuel (.75" x 1.5" x 5" spacers) = 16 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	3	6.7	40.6
4" x 4"	17	2	9.8	59.4

Test Fuel Weight : 16.5 lbs

Estimated Dry Burn Rate : $\frac{16.5 - (16.5 \times .17232)}{2.2046} \times \frac{60}{375} = \frac{.991}{\text{TIME}}$ kg / hr

Estimated BTU's/hr : $19,140 \times \frac{63}{100} \times \frac{.991}{\text{DBR}} = \frac{11,951.4}{\text{DBR}}$ BTU's/hr

EPA Default Efficiencies : Non-cat : 63 Cat : 72 Pellet : 78

WOOD STOVE OPERATING DATA PAGE #9

Unit: F500 Run: L Date: 05-15-02

FIRE STARTED: 0800

WARM UP AND PREBURN:

PRIMARY AIR: Set wide open for all warm-up / preburn fuel charges. Then set to closed at start of preburn.

SECONDARY AIR: N/A CAT BYPASS: N/A

CHARCOAL BED PREPARATION:

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 30 sec.

TEST:

DOOR wide open during loading 0 min. 50 sec.

PRIMARY AIR: Opened full for first 5 min., then set to run setting of closed.

SECONDARY AIR: N/A CAT BYPASS: N/A

FAN:

ON / ~~OFF~~ during warm-up

~~ON~~ / OFF during preburn

ON / ~~OFF~~ first 30 minutes of test

~~ON~~ / OFF balance of test run

Fan speed set at Low

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER: N/A BRAND: N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 12 or 16 inches.

1st warm up / pre-burn fuel charge (13.1 lbs.) added at 0812

2nd warm up / pre-burn fuel charge (15.3 lbs.) added at 0912

3rd warm up / pre-burn fuel charge (12.1 lbs.) added at 1015

4th warm up / pre-burn fuel charge (2.5 lbs.) added at 1100

5th warm up / pre-burn fuel charge (____ lbs.) added at _____

TEST DATA SHEET #10

Unit : F500 Run : 1 Date : 05-15 -02

Room Temperature : 72 °F Correction Factor : 0

Uncorrected Values are corrected for room temperature : Yes No

Time Test Fuel moisture reading taken : 1030

Calibration Checks : X Y 12.0 12.1 22.0 22.0

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	14.0	14.9	12.0	12.8	11.5	12.2	13.300
2									
3									
4	2"x4"x8'	P	20.0	21.4	18.5	19.8	19.0	20.3	20.500
5	2"x4"x8'	P	18.0	19.2	18.0	19.2	18.0	19.2	19.200
6	2"x4"x8'	P	21.0	22.5	21.0	22.5	21.0	22.5	22.500
7	2"x4"x8'	P	17.5	18.7	18.0	19.2	20.5	22.0	19.967
8	2"x4"x8'	P							82.167
9									
10									
11									
12	2x4x17	T	17.5	18.7	18.5	19.8	18.5	19.8	19.433
13	"	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200
14	"	T	23.5	25.2	23.0	24.7	23.5	25.2	25.033
15	4x4x17"	T	19.0	20.3	19.0	20.3	19.0	20.3	20.300
16	"	T	19.0	20.3	19.0	20.3	18.5	19.8	20.133
17									104.099
18									
19									
20	Spacers	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	13.300 %	20.542 %	20.820 %
Wet Moisture % :	11.739 %	17.041 %	17.232 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

GAS DATA SHEET # 12

WEIGHT: 4.1
 UNIT: F500

RUN: 1 DATE: 05-15-02 PAGE: 4 of 4

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL WB	STACK	STATIC	SO ₂ PPM
0	20.6	16.5	-	.233	5.8	.548	13.7	.136	1.37					243	-0.35	550
5	20.0	15.9	.6	.145	3.4	.662	16.6	.090	.91					302	-0.51	375
10	19.7	15.6	.3	.138	3.4	.672	16.8	.082	.83					216	-0.40	575
15	19.4	15.3	.3	.144	3.6	.667	16.7	.080	.81					199	-0.38	575
20	19.1	15.0	.3	.215	5.3	.595	14.9	.123	1.24					201	-0.38	625
25	18.6	14.5	.5	.275	6.8	.532	13.3	.104	1.05					227	-0.44	575
30	18.1	14.0	.5	.290	7.2	.520	13.0	.100	1.01					244	-0.46	550
35	17.6	13.5	.5	.267	6.4	.540	13.5	.119	1.20					244	-0.45	600
40	17.1	13.0	.5	.311	7.7	.488	12.2	.080	.81					260	-0.48	500
45	16.6	12.5	.5	.370	9.2	.429	10.7	.060	.61					273	-0.50	475
50	15.9	11.8	.7	.461	11.5	.361	9.0	.030	.31					310	-0.50	425
55	15.3	11.2	.6	.410	10.2	.396	9.9	.033	.34					322	-0.56	425
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	3041	-1.541	*****
60	14.7	10.6	.6	.370	9.2	.431	10.8	.048	.49					315	-0.55	425
65	14.2	10.1	.5	.377	9.4	.428	10.7	.057	.58					315	-0.55	425
70	13.7	9.6	.5	.396	9.8	.409	10.2	.044	.45					317	-0.56	425
75	13.1	9.0	.6	.386	9.6	.413	10.3	.052	.53					318	-0.56	425
80	12.6	8.5	.5	.388	9.6	.413	10.3	.054	.55					317	-0.56	425
85	12.1	8.0	.5	.386	9.6	.412	10.3	.049	.50					314	-0.55	425
90	11.6	7.5	.5	.372	9.3	.422	10.6	.071	.72					360	-0.53	475
95	11.3	7.2	.3	.378	9.4	.418	10.5	.067	.68					296	-0.52	475
100	10.8	6.7	.5	.353	8.8	.437	10.9	.074	.75					289	-0.51	475
105	10.4	6.3	.4	.379	9.4	.413	10.3	.075	.76					289	-0.51	500
110	10.0	5.9	.4	.485	12.1	.329	8.2	.051	.52					291	-0.51	500
115	9.5	5.4	.5	.467	11.6	.349	8.7	.050	.51					298	-0.52	500
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	3659	-1.643	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	6700	-1.184	*****

GAS DATA SHEET # 12

WEIGHT: 4.1

UNIT: F500

RUN: 1 DATE: 05-15-02 PAGE: 2 of 4

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL WB	STACK	STATIC	SO ₂ PPM
120	9.0	4.9	.5	.470	11.7	.341	8.5	.044	.45					308	.054	450
125	8.6	4.5	.4	.453	11.3	.355	8.9	.031	.32					314	.054	450
130	8.2	4.1	.4	.476	11.8	.342	8.5	.018	.19					314	.055	450
135	7.8	3.7	.4	.363	9.0	.422	10.6	.081	.82					276	.050	550
140	7.5	3.4	.3	.371	9.2	.421	10.5	.063	.64					273	.050	525
145	7.3	3.2	.2	.367	9.1	.428	10.7	.064	.65					266	.048	500
150	7.1	3.0	.2	.264	6.6	.509	12.7	.129	1.30					241	.043	575
155	7.0	2.9	.1	.259	6.4	.513	12.8	.140	1.41					226	.040	600
160	6.9	2.8	.1	.249	6.2	.517	12.9	.164	1.65					211	.037	625
165	6.8	2.7	.1	.241	6.0	.522	13.1	.196	1.97					199	.035	650
170	6.7	2.6	.1	.230	5.7	.531	13.3	.220	2.20					194	.034	625
175	6.6	2.5	.1	.229	5.7	.532	13.3	.216	2.19					189	.033	625
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	3011	-533	*****
180	6.5	2.4	.1	.220	5.5	.543	13.6	.225	2.25					185	.032	625
185	6.4	2.3	.1	.223	5.5	.539	13.5	.218	2.18					181	.031	625
190	6.4	2.3	.1	.224	5.6	.537	13.4	.217	2.17					178	.030	625
195	6.2	2.1	.2	.225	5.6	.537	13.4	.217	2.17					175	.030	600
200	6.1	2.0	.1	.226	5.6	.536	13.4	.216	2.16					174	.029	625
205	6.0	1.9	.1	.227	5.6	.533	13.3	.221	2.21					172	.029	600
210	6.0	1.9	.1	.227	5.6	.533	13.3	.221	2.21					171	.028	600
215	5.9	1.8	.1	.227	5.6	.532	13.3	.223	2.23					169	.028	600
220	5.8	1.7	.1	.225	5.6	.534	13.4	.222	2.22					168	.027	625
225	5.7	1.6	.1	.225	5.6	.534	13.4	.222	2.22					167	.027	625
230	5.7	1.6	.1	.222	5.5	.542	13.6	.220	2.20					167	.027	625
235	5.6	1.5	.1	.219	5.4	.546	13.7	.222	2.22					165	.027	625
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	2072	-345	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	5083	-878	*****

WEIGHT: 4.1

GAS DATA SHEET # 12

UNIT: F500

RUN: DATE: 05-15-02 PAGE: 3 of 4

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL WB	STACK	STATIC	SO ₂ PPM
240	5.5	1.4	.1	.222	5.5	.543	13.6	.225	2.25					164	-026	625
245	5.4	1.3	.1	.217	5.4	.544	13.6	.221	2.21					163	-026	625
250	5.4	1.3	0	.217	5.4	.544	13.6	.217	2.17					162	-026	625
255	5.3	1.2	.1	.218	5.4	.544	13.6	.211	2.11					161	-025	625
260	5.3	1.2	0	.222	5.5	.539	13.5	.220	2.20					160	-025	625
265	5.2	1.1	.1	.222	5.5	.539	13.5	.220	2.20					160	-025	625
270	5.1	1.0	.1	.224	5.6	.537	13.4	.218	2.18					159	-024	625
275	5.0	.9	.1	.224	5.6	.536	13.4	.217	2.17					158	-024	650
280	5.0	.9	0	.222	5.5	.541	13.5	.214	2.14					158	-024	650
285	4.9	.8	.1	.223	5.5	.547	13.7	.199	2.00					157	-024	650
290	4.8	.7	.1	.221	5.5	.553	13.8	.199	2.00					157	-024	650
295	4.8	.7	0	.217	5.4	.552	13.8	.213	2.13					156	-023	650
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	1915	-2916	*****
300	4.8	.7	0	.217	5.4	.550	13.8	.217	2.17					155	-023	650
305	4.7	.6	.1	.217	5.4	.550	13.8	.216	2.16					155	-023	650
310	4.7	.6	0	.218	5.4	.549	13.7	.218	2.18					154	-023	650
315	4.6	.5	.1	.222	5.5	.543	13.6	.225	2.25					154	-023	650
320	4.6	.5	0	.228	5.7	.537	13.4	.233	2.33					154	-023	650
325	4.6	.5	0	.226	5.6	.539	13.5	.231	2.31					154	-023	650
330	4.5	.4	.1	.215	5.3	.552	13.8	.214	2.14					154	-023	650
335	4.5	.4	0	.214	5.3	.555	13.9	.213	2.13					153	-023	650
340	4.4	.3	.1	.211	5.2	.560	14.0	.207	2.08					153	-023	650
345	4.4	.3	0	.213	5.3	.556	13.9	.214	2.14					152	-022	650
350	4.3	.2	.1	.212	5.3	.559	14.0	.210	2.11					151	-021	675
355	4.3	.2	0	.216	5.4	.554	13.9	.219	2.19					151	-021	675
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	1840	-271	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	3755	-567	*****

TEMPERATURE DATA SHEET # 14

UNIT: F500

RUN: | DATE: 05-15-02 PAGE 3 of 4

TIME	TOP	LT SIDE	BACK	RT SIDE	BOTTOM	FIREBOX	SEC/CAT	AMBIENT	FURNACE	SAMPLE	SAMP IMP	C-GAS	GAS IMP	SO ₂ IMP
240	1605	147	235	195	213	615	601	77	1314	236	55	241	37	37
245	10	145	234	194	213	610	601	77	1313	236	57	241	37	37
250	15	145	233	192	212	603	598	77	1312	235	57	241	36	37
255	20	145	231	191	212	603	594	77	1311	236	58	241	38	37
260	25	142	230	190	211	604	592	77	1311	235	58	241	38	37
265	30	141	229	188	209	605	593	77	1310	236	58	242	38	38
270	35	147	229	187	209	603	588	76	1310	235	58	243	38	37
275	40	143	229	186	210	602	584	77	1313	236	57	243	38	36
280	45	144	229	186	208	601	581	77	1318	237	58	243	36	37
285	50	143	229	184	210	597	581	78	1322	237	58	244	37	36
290	55	145	228	183	210	590	572	78	1325	237	59	243	38	36
295	1700	144	227	183	209	585	567	78	1326	237	59	244	37	35
TOTAL	2668	1731	2763	2259	2526	7218	7052	926	*****	*****	*****	*****	*****	*****
300	1705	142	227	182	208	581	566	78	1327	237	59	245	37	35
305	10	142	226	181	209	580	563	78	1327	237	59	244	37	35
310	15	143	224	181	208	575	561	78	1328	237	59	244	36	35
315	20	141	224	180	208	573	564	79	1327	237	59	244	36	36
320	25	142	224	180	207	575	560	79	1327	237	59	244	36	36
325	30	142	223	180	209	569	565	79	1327	238	61	244	36	36
330	35	140	222	180	206	560	554	79	1326	237	61	244	36	34
335	40	138	222	180	206	551	553	79	1326	237	61	244	36	35
340	45	140	220	180	205	542	553	79	1325	237	61	244	36	35
345	50	139	218	180	205	539	551	79	1325	237	62	244	36	35
350	55	141	217	180	206	538	548	80	1323	237	61	244	36	34
355	1800	142	217	180	207	542	533	81	1320	237	61	243	35	35
TOTAL	2544	1612	2664	2164	2484	6725	6671	948	*****	*****	*****	*****	*****	*****
TOTAL	5212	3423	5427	4423	5010	13943	13723	1874	*****	*****	*****	*****	*****	*****

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 05-15-2002

Analyte : CO₂ (15-1)

Unit : F500 Run # : 1

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO₂ Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 12.49 % CO₂ Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE Date : 02-15-02

Analyzer : Make : HORIBA Model : PIR-2000 SN : 407069
 Range : 0 - 25.0 % CO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 25.0 % CO₂
 EPA Control Limits = ± 2.5% of 25.0 % CO₂ = ± 0.625 % CO₂
 Method 28 A = ± .2 % of 25.0 % CO₂ = ± .05 % CO₂

PRE RUN Audit : by : D. Wadlington Time : 1055 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	-.022	-.022	-.087
SPAN	50.0	.500	12.49	50.0	.500	12.442	-.048	-.194

POST RUN Audit : by : D. Wadlington Time : 1845 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	-.047	-.047	-.187
SPAN	50.0	.500	12.49	50.1	.501	12.466	-.024	-.094

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05-15-2002

Analyte : O₂ (15-2)

Unit : F500

Run # : 1

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂ Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 12.50 % O₂ Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : TELEDYNE Model : 320 A

SN : 37400

Range : 0 - 25.0 % O₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % O₂

EPA Control Limits = $\pm 2.5\%$ of 25.0 % O₂ = $\pm 0.625 % O_2$

Method 28 A = $\pm .2 %$ of 25.0 % O₂ = $\pm .05 % O_2$

PRE RUN Audit : by : S. Wadsworth Time : 1055 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	-0.065	-0.065	-0.259
SPAN	12.50	.500	12.50	12.50	.500	12.513	+0.013	+0.053

POST RUN Audit : by : S. Wadsworth Time : 1845 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.002	-0.014	-0.014	-0.057
SPAN	12.50	.500	12.50	12.50	.501	12.538	+0.038	+0.154

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date : 05-15-2002

Analyte : CO (15-3)

Unit : F500

Run # : 1

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 4.80 % CO Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 408005

Range : 0 - 10.0 % CO

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 10.0 % CO

EPA Control Limits = ± 2.5% of 10.0 % CO = ± 0.25 % CO

Method 28 A = ± .2 % of 10.0 % CO = ± .02 % CO

PRE RUN Audit : by : D. Wadlington Time : 1055 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.014	+ .014	+ .141
SPAN	48.0	.480	4.80	48.0	.480	4.793	- .007	- .066

POST RUN Audit : by : D. Wadlington Time : 1845 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.024	+ .024	+ .240
SPAN	48.0	.480	4.80	48.0	.480	4.793	- .007	- .066

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05-15-2002

Analyte : SO₂ (15-4)

Unit : F500

Run # : 1

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC62184 Conc. : 1290 ppm SO₂ Cyl. Press. : 1350 PSI

Certified by : AIR LIQUIDE

Date : 01-29-01

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 403019

Range : 0 - 2500 ppm SO₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂

EPA Control Limits = $\pm 2.5\%$ of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : D. Wadlington Time : 1055 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	5.892	+5.892	+ .236
SPAN	51.6	.516	1290	51.6	.516	1292.236	+2.236	+ .089

POST RUN Audit : by : D. Wadlington Time : 1840 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	-.001	3.399	+3.399	+ .136
SPAN	51.6	.516	1290	51.5	.515	1289.743	-.257	-.010

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : F500 RUN : 1 DATE : 05-15-02

Thermocouple Check:

T/C # 1	<u>—</u>	°F	T/C # 13	<u>54.3</u>	°F
T/C # 2	<u>—</u>	°F	T/C # 14	<u>54.0</u>	°F
T/C # 3	<u>54.0</u>	°F	T/C # 15	<u>54.5</u>	°F
T/C # 4	<u>53.3</u>	°F	T/C # 16	<u>57.5</u>	°F
T/C # 5	<u>51.7</u>	°F	T/C # 17	<u>57.6</u>	°F
T/C # 6	<u>52.5</u>	°F	T/C # 18	<u>54.4</u>	°F
T/C # 7	<u>52.0</u>	°F	T/C # 19	<u>53.6</u>	°F
T/C # 8	<u>52.4</u>	°F	T/C # 20	<u>59.4</u>	°F
T/C # 9	<u>52.3</u>	°F	T/C # 21	<u>—</u>	°F
T/C # 10	<u>52.6</u>	°F	T/C # 22	<u>—</u>	°F
T/C # 11	<u>50.8</u>	°F	T/C # 23	<u>54.8</u>	°F
T/C # 12	<u>55.2</u>	°F	T/C # 24	<u>—</u>	°F

Thermocouple Readout:

Pretest zero and span check and calibration

post test zero and span

% difference

ZERO : .1 °F Adj. to 0.0 °F

ZERO 4.0 °F Adj. to + .200 %

SPAN : 1999.3 °F Adj. to 2000.0 °F

SPAN 1999.9 °F Adj. to -.005 %

Thermocouple Readout Pretest Linearity Check:

0	= <u>0.0</u> °F	200	= <u>202.6</u> °F	400	= <u>399.4</u> °F
600	= <u>601.6</u> °F	800	= <u>801.8</u> °F	1000	= <u>1000.7</u> °F
1200	= <u>1198.3</u> °F	1400	= <u>1399.2</u> °F	1600	= <u>1599.7</u> °F
1800	= <u>1800.0</u> °F	2000	= <u>2000.0</u> °F		

Sample Train Leak Check

Pre X

Post ✓

C-gas Train Leak Check

Pre X

Post X

SO₂ Train Leak Check

Pre X

Post ✓

Static Gauge Zero Check


Pre ✓

Post ✓

Scale Check Pre : 15.7 - 5.7

Post : 13.4 - 3.4

Stack Cleaned Prior to Test Run : YES X NO —



COMPUTER INPUT DATA SHEET #1

Client: JOTUL U.S.A., INC.

Address: 400 RIVERSIDE ST., P.O. BOX 1157

PORTLAND, MAINE 04104

Phone: (207) 797-5912 Fax: (207) 772-0523

Run No.: 4 Date of Test: 05-20-2002 Burn Rate: 1.233

Model No.: F500 min min-1.25 fan

Stove Type: Cat Non Cat Pellet 1.25-1.9 max insert

Dry Gas Meter Y Factor: 1.000 Post Leak Rate: .001 cfm Time: 310 min.
(0.000) (Data Sheet #2) (.000) (Data Sheet #2) (000) (Data Sheet #2)

Dry Gas Meter Volume: 103.128 cf
(00.000) (Data Sheet #2)

Stack Flow: 6.910 dscfm Δ H: .169 in. H₂O
(00.000) (Data Sheet #2) (.000) (Data Sheet #2)

Maximum Vac.: 3.0 Barometric Pressure: 29.83 in. Hg
(0.0) (Data Sheet #2) (00.00) (Data Sheet #2)

H₂O Captured: 173.2 g
(00.0) (Data Sheet #3)

Front Half Catch % Of Total: 31.8 % Total Particulate Catch: .7372 g
(00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)

Flue Gas Moisture: 7.5651 %
(00.000) (Data Sheet #7)

Particulate Emission: .1142 gr/dscf
(0.0000) (Data Sheet #7)

Relative Humidity: 35.0 % RH Ambient Moisture: 1.35 % H₂O
(00.0) (Data Sheet #8) (0.00) (Data Sheet #8)

Pretest Fuel Wt.: 50.1 lbs. Coal Bed Wt.: 4.2 lbs. Test Fuel Wt.: 17.0 lbs.
(00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)

Heat Output (EPA Default): 14,864.3 BTU/hr
(00,000.0) (Data Sheet #8)

Kindling Fuel % Moisture (wet): 11.032 % Pretest Fuel % Moisture (wet): 16.730 %
(00.000) (Data Sheet #10) (00.000) (Data Sheet #10)

Test Fuel % Moisture (dry): 21.073 % Test Fuel % Moisture (wet): 17.405 %
(00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])

Fuel Higher Heating Value (dry): - BTU/lb.
(0000) (Data Sheet #11)

Stack Static Pressure: -.044 in. H₂O
(+/- .000) (Data Sheet #12)

Average Ambient Temperature: 75 °F Stove Temperature Change: -65.2 °F
(00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul U.S.A., Inc.

TEST No. : 4

MODEL: F500

DATE: 20-May-02

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
0	653.000	0.150	84	1.05	5.80	525
5	654.500	0.450	84	0.39	14.60	300
10	657.212	0.150	84	0.68	3.00	525
15	658.764	0.130	85	0.73	3.00	550
20	660.251	0.130	85	0.81	3.20	550
25	661.738	0.120	85	0.90	4.00	575
30	663.161	0.160	85	0.59	7.70	500
35	664.796	0.150	85	0.79	7.40	525
40	666.354	0.200	85	0.25	11.30	450
45	668.171	0.220	85	0.24	12.50	425
50	670.094	0.220	85	0.19	12.50	425
55	672.018	0.220	85	0.19	11.70	425
60	673.942	0.220	85	0.13	11.60	425
65	675.863	0.220	85	0.13	11.70	425
70	677.785	0.220	85	0.12	12.00	425
75	679.707	0.220	85	0.20	11.70	425
80	681.628	0.220	85	0.16	12.10	425
85	683.550	0.220	85	0.13	12.50	425
90	685.471	0.220	86	0.11	13.10	425
95	687.400	0.200	86	0.16	11.80	450
100	689.222	0.200	86	0.17	10.40	450
105	691.044	0.200	86	0.19	9.90	450
110	692.865	0.200	86	0.23	9.80	450
115	694.687	0.200	86	0.29	9.90	450
120	696.509	0.200	86	0.27	10.20	450
125	698.331	0.200	86	0.16	11.00	450
130	700.152	0.200	86	0.19	11.50	450
135	701.974	0.180	86	0.47	10.30	475
140	703.700	0.150	86	0.74	8.00	525
145	705.262	0.130	86	0.87	7.60	550
150	706.753	0.150	86	1.17	6.90	525
155	708.315	0.130	86	1.39	6.60	550
160	709.806	0.150	86	1.44	6.50	525
165	711.368	0.150	86	1.49	6.50	525
170	712.930	0.150	86	1.67	6.40	525
175	714.492	0.160	86	1.74	6.30	500
180	716.132	0.160	85	1.87	6.10	500
185	717.771	0.150	85	1.68	6.20	525
190	719.333	0.150	85	1.69	6.20	525
195	720.895	0.150	85	1.71	6.10	525
200	722.457	0.150	85	1.82	6.10	525
205	724.019	0.150	85	2.08	5.90	525
210	725.581	0.150	85	2.11	5.70	525
215	727.143	0.150	85	2.24	5.50	525

220	728.705	0.150	85	2.56	5.20	525
225	730.266	0.150	85	2.55	5.20	525
230	731.828	0.150	85	2.25	5.50	525
235	733.390	0.150	85	2.49	5.20	525
240	734.952	0.150	85	2.45	5.20	525
245	736.514	0.150	85	1.75	5.50	525
250	738.076	0.130	85	1.58	5.60	550
255	739.567	0.150	85	1.65	5.50	525
260	741.129	0.150	85	1.48	5.30	525
265	742.691	0.150	85	1.51	5.20	525
270	744.252	0.150	85	1.60	5.10	525
275	745.814	0.150	85	1.56	5.10	525
280	747.376	0.130	85	1.64	4.90	550
285	748.867	0.130	85	1.82	4.90	550
290	750.358	0.130	85	1.81	5.30	550
295	751.849	0.120	85	1.89	4.90	575
300	753.276	0.120	85	1.85	4.80	575
305	754.702	0.120	85	1.85	4.80	575
310	756.128	0.120	85	1.85	4.90	575
315						

TABLE 2---RAW DATA

CLIENT : Jotul U.S.A., Inc.

TEST No. 4

MODEL: F500

DATE: 20-May-02

METER CAL. FACTOR (Y) -----	1	Wt. WOOD BURNED (LB) -----	17.0	Lbs
BAROMETRIC PRESS. (Pb) -----	29.83 in Hg	WET, FUEL MOISTURE % -----	17.405	%
LEAK RATE POST (Lp) -----	0.001 cfm	Wt. PART. COLLECTED -----	0.7372	g
WATER VOL. (V1c) -----	173.2 ML	METER VOLUME Vm -----	103.128	mcf
TEST TIME (MIN) -----	310 min	HC MOLE FRACTION -----	0.0132	

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul U.S.A., Inc. TEST No. 4

MODEL: F500 DATE: 20-May-02

AVG DELTA		AVG PRCNT		
H	----- 0.17 in H2O	CO	----- 1.14	%

AVG METER		AVG PRCNT		
TEMP. Tm	----- 85 deg F	CO2	----- 7.57	%

AVG PPM		AVG BAL		
SO2	----- 500 PPM	CO2/CO	----- 6.64	%

TABLE 4 ----- CALCULATIONS

CLIENT : Jotul U.S.A., Inc.

TEST No. 4

MODEL: F500

DATE: 20-May-02

STD SAMPLE		STACK GAS		
VOL. Vm(std) -----	99.63 dscf	FLOW Qsd -----	442.853	dscf/Hr
			7.38	& dscf/min
VOL. WATER		PARTICULATE		
VAPOR Vw(std) ----	8.153 scf	CONCTRT. Cs -----	0.0074	g/dscf
PRCNT		PARTC.EMISS.		
MSTR Bws -----	7.56 %	RATE E -----	3.28	g/Hr
BURN		MOLES OF GAS		
RATE BR -----	1.23 Kg/Hr	PER Lb WOOD Nt --	0.42	Lb-mole/Lb
CO EMISSION		PART.EMISS.		
RATE -----	168.95 g/Hr	RATE -----	2.66	g/Kgdry
	&			fuel
	137.02 g/Kgdry			
	fuel			

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul U.S.A., Inc.

TEST No. : 4

MODEL: F500

DATE: 20-May-02

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	762.4	96	100
10	788.3	100	
15	788.2	100	
20	790.3	100	
25	790.3	100	
30	790.7	100	
35	790.1	100	
40	790.5	100	
45	790.3	100	
50	790.0	100	
55	790.4	100	
60	790.4	100	
65	789.1	100	
70	789.5	100	
75	789.5	100	
80	789.1	100	
85	789.5	100	
90	788.4	100	
95	791.0	100	
100	791.0	100	
105	791.0	100	
110	790.6	100	
115	791.0	100	
120	791.0	100	
125	791.0	100	
130	790.6	100	
135	791.0	100	
140	790.9	100	
145	791.1	100	
150	791.0	100	
155	791.1	100	
160	791.0	100	
165	791.1	100	
170	791.1	100	
175	791.1	100	
180	791.8	100	
185	792.0	100	
190	792.5	100	
195	792.5	100	
200	792.5	100	
205	792.5	100	
210	792.5	100	
215	792.5	100	
220	792.5	100	

225	792.0	100
230	792.5	100
235	792.5	100
240	792.5	100
245	792.5	100
250	792.5	100
255	792.5	100
260	792.5	100
265	792.5	100
270	792.0	100
275	792.5	100
280	792.5	100
285	792.5	100
290	792.5	100
295	792.5	100
300	792.9	100
305	792.4	100
310	792.4	100
315		
320		

METER BOX DATA SHEET PAGE # 2

Page: 1 of 3

UNIT: F500 RUN: 4 DATE: 05-20-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .006 cfm _____ " Hg @ _____ cfm

22 15 " Hg @ .001 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO PRESS: <u>.14</u>			SAMPLING RATIO: <u>21.5</u> : 1				BP: <u>29.80</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
0	1355	653.000	—	6.506	.15	84	525	84	2.0
5	1400	654.500	—	11.385	.45	84	300	84	3.0
10	05	657.212	657.212	6.506	.15	84	525	84	2.0
15	10	658.764	658.764	6.199	.13	85	550	85	2.0
20	15	660.251	660.251	6.199	.13	85	550	85	2.0
25	20	661.738	661.738	5.929	.12	85	575	85	2.0
30	25	663.161	663.161	6.819	.16	85	500	85	2.0
35	30	664.796	664.796	6.494	.15	85	525	85	2.0
40	35	666.354	666.354	7.576	.20	85	450	85	2.0
45	40	668.171	668.171	8.022	.22	85	425	85	2.0
50	45	670.094	670.094	8.022	.22	85	425	85	2.0
55	50	672.018	672.018	8.022	.22	85	425	85	2.0
ROTO PRESS: <u>.14</u>			TOTALS:	87.679	2.30	1017	BP: <u>29.83</u>		
60	1455	673.942	673.942	8.030	.22	85	425	85	2.0
65	1500	675.863	675.863	8.030	.22	85	425	85	2.0
70	05	677.785	677.785	8.030	.22	85	425	85	2.0
75	10	679.707	679.707	8.030	.22	85	425	85	2.0
80	15	681.628	681.628	8.030	.22	85	425	85	2.0
85	20	683.550	683.550	8.030	.22	85	425	85	2.0
90	25	685.471	685.471	8.015	.22	86	425	86	2.0
95	30	687.400	687.400	7.570	.20	86	450	86	2.0
100	35	689.222	689.222	7.570	.20	86	450	86	2.0
105	40	691.044	691.044	7.570	.20	86	450	86	2.0
110	45	692.865	692.865	7.570	.20	86	450	86	2.0
115	50	694.687	694.687	7.570	.20	86	450	86	2.0
			TOTALS:	94.045	2.54	1026	MAX VACC =		
TOTAL Cu Ft.			TOTALS:	181.724	4.84	2043	AVG. BP:		

METER BOX DATA SHEET PAGE # 2

Page: 2 of 3

UNIT: F500 RUN: 4 DATE: 05-20-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .006 cfm _____ " Hg @ _____ cfm

15 " Hg @ .001 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO PRESS: <u>.14</u>		SAMPLING RATIO: <u>21.5</u> : 1					BP: <u>29.83</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
120	1555	696.509	696.509	7.570	.20	86	450	86	2.0	
125	1600	698.331	698.331	7.570	.20	86	450	86	2.0	
130	05	700.152	700.152	7.570	.20	86	450	86	2.0	
135	10	701.974	701.974	7.172	.18	86	475	86	2.0	
140	15	703.700	703.700	6.489	.15	86	525	86	2.0	
145	20	705.262	705.262	6.194	.13	86	550	86	2.0	
150	25	706.753	706.753	6.489	.15	86	525	86	2.0	
155	30	708.315	708.315	6.194	.13	86	550	86	2.0	
160	35	709.806	709.806	6.489	.15	86	525	86	2.0	
165	40	711.368	711.368	6.489	.15	86	525	86	2.0	
170	45	712.930	712.930	6.489	.15	86	525	86	2.0	
175	50	714.492	714.492	6.813	.16	86	500	86	2.0	
ROTO PRESS: <u>.14</u>		TOTALS:		81.528	1.95	1032	BP: <u>29.83</u>			
180	1655	716.132	716.132	6.813	.16	85	500	85	2.0	
185	1700	717.771	717.771	6.489	.15	85	525	85	2.0	
190	05	719.333	719.333	6.489	.15	85	525	85	2.0	
195	10	720.895	720.895	6.489	.15	85	525	85	2.0	
200	15	722.457	722.457	6.489	.15	85	525	85	2.0	
205	20	724.019	724.019	6.489	.15	85	525	85	2.0	
210	25	725.581	725.581	6.489	.15	85	525	85	2.0	
215	30	727.143	727.143	6.489	.15	85	525	85	2.0	
220	35	728.705	728.705	6.489	.15	85	525	85	2.0	
225	40	730.266	730.266	6.489	.15	85	525	85	2.0	
230	45	731.828	731.828	6.489	.15	85	525	85	2.0	
235	50	733.390	733.390	6.489	.15	85	525	85	2.0	
		TOTALS:		78.192	1.81	1020	MAX VACC =			
TOTAL Cu Ft.		TOTALS:		159.720	3.76	2052	AVG. BP:			

METER BOX DATA SHEET PAGE # 2

Page: 3 of 3

UNIT: F500 RUN: 4 DATE: 05-20-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .006 cfm _____ " Hg @ _____ cfm

15 " Hg @ .001 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.14</u>			SAMPLING RATIO: <u>21.5</u> : 1				BP: <u>29.83</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
240	1755	734.952	734.952	6.489	.15	85	525	85	2.0	
245	1800	736.514	736.514	6.489	.15	85	525	85	2.0	
250	05	738.076	738.076	6.194	.13	85	550	85	2.0	
255	10	739.567	739.567	6.489	.15	85	525	85	2.0	
260	15	741.129	741.129	6.489	.15	85	525	85	2.0	
265	20	742.691	742.691	6.489	.15	85	525	85	2.0	
270	25	744.252	744.252	6.489	.15	85	525	85	2.0	
275	30	745.814	745.814	6.489	.15	85	525	85	2.0	
280	35	747.376	747.376	6.194	.13	85	550	85	2.0	
285	40	748.867	748.867	6.194	.13	85	550	85	2.0	
290	45	750.358	750.358	6.194	.13	85	550	85	2.0	
295	50	751.849	751.849	5.924	.12	85	575	85	2.0	
ROTO PRESS: <u>.14</u>			TOTALS: 76.123		1.69	1020	BP: <u>29.83</u>			
300	1855	753.276	753.276	5.924	.12	85	575	85	2.0	
305	1900	754.702	754.702	5.924	.12	85	575	85	2.0	
310	05	756.128	756.128	5.924	.12	85	575	85	2.0	
315	10			17.772	.36	255				
320										
325										
330										
335										
340										
345										
350										
355						5370	463.			
			TOTALS: 435.339		10.650	85	MAX VACC =		3.0	
TOTAL Cu Ft. <u>103.128</u>			TOTALS: 6.910		.169	(545)	AVG. BP: <u>29.83</u>			

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT: F500 RUN: 4 DATE: 05-20-02

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	768.0	601.5	486.2	921.5
INITIAL WT	623.8	591.4	483.8	905.0
NET WT GRAMS	144.2	10.1	2.4	16.5

TOTAL CATCH : 173.2 GRAMS H₂O

FRONT HALF

FILTER #	120F	
FINAL WT g	.8345	.
INITIAL WT g	.6843	.
NET WT g	.1502	.

BEAKER #	166
DESC.	ACETONE
FINAL WT g	96.5970
INITIAL WT g	96.5125
NET WT g	.0845
VOL. DESC. ml	150

BACK HALF

FILTER #	120B	
FINAL WT g	.5016	.
INITIAL WT g	.4425	.
NET WT g	.0591	.

BEAKER #	67	68	69	70	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	106.4365	94.2367	109.0814	107.5621	
INITIAL WT g	106.2276	94.1606	108.9969	107.4845	
NET WT g	.2089	.0761	.0845	.0776	.1621
VOL. DESC ml	150	75	200	185	(385)

FILTER TARE WEIGHTS DATA SHEET #4-1

Into Dessicator : _____ Date : 01/29/02 Time : 1125 By : DKW
 Manufacturer S & S Grade : # 25 Glass Front Size : 11 cm Lot No. : ZB921
 Back Size : 8.2 cm Lot No. : ZB911

DATE: <u>02-07</u>			DATE: <u>02-10</u>			DATE: _____	
FILTER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME	
111F	.6782	0934	<u>.6780</u>	1939	JOTUL C450	R-2	
112F	.6755	0935	<u>.6751</u>	1940	" "	R-3	
113F	.6721	0935	<u>.6719</u>	1941	" "	R-4	
114F	.6843	0936	<u>.6844</u>	1942	" "	R-5	
115F	.6699	0937	<u>.6700</u>	1943	" "	R-6	
116F	.6696	0938	<u>.6694</u>	1943	" "	R-7	
117F	.6796	0939	<u>.6793</u>	1944	JOTUL F500	R-1	
118F	.6715	0940	<u>.6718</u>	1945	" "	R-2	
119F	.6743	0941	<u>.6746</u>	1946	" "	R-3	
120F	.6844	0942	<u>.6843</u>	1947	" "	R-4	

111B	.4462	0943	<u>.4464</u>	1948	JOTUL C450	R-2
112B	.4448	0944	<u>.4451</u>	1949	" "	R-3
113B	.4466	0945	<u>.4464</u>	1949	" "	R-4
114B	.4305	0946	<u>.4307</u>	1950	" "	R-5
115B	.4234	0947	<u>.4236</u>	1951	" "	R-6
116B	.4444	0948	<u>.4445</u>	1952	" "	R-7
117B	.4431	0949	<u>.4430</u>	1953	JOTUL F500	R-1
118B	.4293	0950	<u>.4294</u>	1954	" "	R-2
119B	.4441	0951	<u>.4439</u>	1955	" "	R-3
120B	.4427	0952	<u>.4425</u>	1955	" "	R-4

Checked by: C Washington Date: 2-10-02 Time: 2000

BALANCE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	WB	DB	% RH
02-07	0910	DKW		74	47
02-10	1905	DKW		76	45

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: F500 RUN: 4 DATE: 05-20-02 Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
66	05-21	1220	<i>RM</i>	96.5968	05-22	1230	<i>RM</i>	96.5970	05-22	1923	<i>RM</i>				
67	05-21	1915	<i>RM</i>	106.4367	05-22	1924	<i>RM</i>	106.4365	05-23	2107	<i>RM</i>				
68	05-21	1915	<i>RM</i>	94.2370	05-22	1925	<i>RM</i>	94.2367	05-23	2108	<i>RM</i>				
69	05-21	1220	<i>RM</i>	109.0815	05-22	1231	<i>RM</i>	109.0814	05-22	1926	<i>RM</i>				
70	05-21	1220	<i>RM</i>	107.5624	05-22	1232	<i>RM</i>	107.5621	05-22	1927	<i>RM</i>				

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
120F	5-20	2000	<i>CP</i>	.8344	05-21	0943	<i>RM</i>	.8345	05-22	1206	<i>RM</i>				
120B	5-20	2000	<i>CP</i>	.5029	05-21	0945	<i>RM</i>	.5018	05-22	1207	<i>RM</i>	.5016	05-22	1928	<i>RM</i>

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	05-21	0930	<i>RM</i>	78	49
2	05-22	1155	<i>RM</i>	78	48
3	05-22	1920	<i>RM</i>	79	49
4	05-23	2105	<i>RM</i>	77	48
5					

Weighing Session	Date	Time	By	DB	%RH
6					
7					
8					
9					
10					

Dates: From 11-20-2001
Through 02-16-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius
Model: A1205
SN : 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	Wet Bulb	%RH
99.9998	10.0002	1.0003	.1000	SKW	11-20	0945	78		48
100.0000	10.0000	1.0001	.0999	SKW	11-21	1000	75		49
99.9998	9.9998	1.0000	.1001	SKW	11-22	1050	75		49
100.0003	9.9999	1.0000	.0999	SKW	11-26	1150	74		47
100.0001	9.9997	1.0000	.1000	SKW	11-27	1155	74		48
100.0001	10.0000	.9997	.0999	SKW	11-28	1220	72		48
99.9999	10.0001	1.0000	.1000	SKW	11-28	1930	73		48
99.9998	10.0000	.9999	.0999	SKW	11-29	1015	75		46
99.9998	10.0000	.9997	.0998	SKW	11-29	1925	73		46
100.0000	10.0001	.9998	.0999	SKW	11-30	1355	74		45
99.9999	9.9999	1.0000	.1000	SKW	12-01	1210	77		45
100.0003	10.0000	.9997	.1000	SKW	01-08	2045	78		47
100.0001	10.0000	.9998	.1000	SKW	01-09	1600	78		48
99.9999	9.9999	.9999	.1000	SKW	01-12	1900	74		46
99.9998	9.9999	.9997	.1000	SKW	01-13	1730	72		43
100.0000	10.0001	1.0000	.1001	SKW	01-14	1355	78		45
99.9998	9.9999	.9999	.1000	SKW	01-26	1745	72		47
99.9998	10.0000	1.0000	.0999	SKW	01-28	1705	74		44
100.0003	10.0000	1.0000	.0998	SKW	01-29	1130	70		47
99.9998	9.9997	1.0000	.1000	SKW	01-29	2300	71		44
100.0002	10.0000	1.0000	.1000	SKW	01-30	2200	75		45
99.9999	9.9999	.9999	.1000	SKW	01-31	2205	74		47
100.0001	9.9999	1.0000	.1000	SKW	02-02	0700	75		45
100.0002	9.9999	1.0001	.1000	SKW	02-04	1045	73		47
100.0000	10.0000	.9998	.0997	SKW	02-06	0905	73		47
100.0001	10.0000	1.0000	.1000	SKW	02-07	0910	74		47
100.0002	10.0001	1.0000	.0999	SKW	02-07	1235	77		48
99.9999	10.0000	.9999	.0998	SKW	02-08	1110	72		49
99.9998	9.9999	1.0000	.0999	SKW	02-09	1045	70		49
99.9997	10.0000	.9999	.0999	SKW	02-10	0920	74		48
99.9997	10.0001	.9999	.0999	SKW	02-10	1905	76		45
99.9999	9.9999	1.0000	.0997	SKW	02-11	1935	73		43
99.9998	9.9997	1.0000	.0999	SKW	02-13	1740	75		41
99.9997	10.0000	.9999	.1000	SKW	02-14	1015	74		38
99.9998	9.9999	1.0000	.1000	SKW	02-14	2010	74		43
100.0000	10.0000	1.0000	.1000	SKW	02-15	1150	74		41
99.9998	9.9999	.9999	.1000	SKW	02-16	1045	78		41

Dates: From 02-16-2002
Through 05-17-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius
Model: A1205
SN: 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Wet Bulb	Dry Bulb	% RH
100.0000	9.9999	1.0000	.0999	JKW	02-16	1845		77	46
100.0000	9.9999	.9999	.0998	JKW	02-17	1555		77	47
100.0001	9.9999	.9999	.0997	JKW	02-18	0940		77	47
100.0000	10.0000	.9999	.1000	JKW	02-19	1025		78	46
100.0000	9.9999	1.0000	.0999	JKW	02-20	0915		75	42
100.0003	10.0000	1.0000	.0999	JKW	03-14	1020		78	45
99.9999	9.9998	.9998	.0998	JKW	03-15	1725		77	45
99.9999	10.0000	1.0002	.0999	JKW	03-16	1820		77	38
100.0001	9.9999	1.0001	.1000	JKW	03-16	2130		78	43
99.9999	9.9999	.9998	.0998	JKW	03-17	1550		77	43
99.9999	10.0000	1.0001	.0999	JKW	03-17	2045		77	39
99.9998	10.0000	1.0000	.1000	JKW	03-18	1100		77	39
100.0000	9.9999	.9999	.0999	JKW	03-19	1800		76	42
100.0001	10.0000	1.0001	.1000	JKW	03-20	1835		77	45
99.9999	10.0001	.9999	.0999	JKW	03-21	2235		78	45
99.9998	9.9999	1.0000	.1000	JKW	03-24	2205		78	42
99.9998	10.0000	1.0000	.1001	JKW	03-25	1000		78	41
99.9997	10.0000	1.0001	.1000	JKW	04-04	1300		78	49
99.9998	10.0000	1.0000	.0999	JKW	04-05	1210		78	49
99.9997	10.0000	.9999	.0998	JKW	04-05	2230		78	49
99.9999	10.0001	1.0000	.0998	JKW	04-08	1135		78	47
99.9997	10.0000	1.0000	.0999	JKW	04-08	1910		78	49
99.9997	9.9998	.9999	.1000	JKW	04-09	2150		77	48
99.9999	10.0000	1.0000	.0999	JKW	04-10	2205		78	48
100.0000	10.0001	.9999	.0999	JKW	04-11	0940		76	49
99.9997	9.9998	1.0000	.0999	JKW	04-11	1705		78	48
99.9999	9.9999	.9999	.0998	JKW	04-11	2230		78	48
99.9999	10.0001	.9999	.0999	JKW	04-12	0950		78	47
100.0000	9.9998	1.0000	.0999	JKW	04-12	1810		78	48
100.0000	9.9999	.9999	.0998	JKW	04-12	2205		78	47
100.0000	9.9999	.9999	.0999	JKW	04-13	1720		78	48
99.9998	10.0000	1.0000	.0998	JKW	04-13	2325		78	46
99.9999	10.0001	1.0001	.1000	JKW	04-14	1740		78	44
99.9998	10.0000	1.0001	.0999	JKW	04-16	1925		75	44
99.9997	9.9999	1.0000	.1000	JKW	04-19	1350		78	41
100.0000	10.0001	.9998	.0999	JKW	04-20	1210		75	41
99.9998	9.9998	1.0001	.0997	JKW	05-16	1430		76	48
99.9999	9.9999	1.0000	.0999	JKW	05-17	1600		75	48

BLANK PROCESSING DATA SHEET # 5

UNIT: F500 RUN: 4 DATE: 05-20-02

BLANKS DONE: 02-20-2002

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT #011755	FISHER OPTIMA LOT #994669	McKESSON WATER PRODUCTS CO. CERTIFIED DISTILLED
FINAL WEIGHT	108.9015	106.3081	106.9664
TARE WEIGHT	108.9007	106.3064	106.9660
NET WEIGHT	.0008 ✓	.0017 ✓	.0004 ✓

TARE BEAKERS INTO DESC: TIME: 1205 DATE: 02-15-2002

DATE: 02-16 BY: DL DATE: 02-17 BY: DL DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9002	1849	108.9007	1611 ✓		
B	106.3068	1850	106.3064	1612 ✓		
C	106.9661	1851	106.9660	1613 ✓		

FINAL BEAKERS INTO DESC: TIME: 1125 DATE: 02-18-2002

DATE: 02-19 BY: DL DATE: 02-20 BY: DL DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9016	1027	108.9015	0917 ✓		
B	106.3084	1028	106.3081	0918 ✓		
C	106.9664	1029	106.9664	0919 ✓		

TARE QC

DATE	TIME	BY	WB	DB	%
02-16	1845	DL	}	77	46
02-17	1555	DL		77	47

FINAL QC

DATE	TIME	BY	WB	DB	%
02-19	1025	DL	}	78	46
02-20	0915	DL		75	42

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT : F500 RUN : 4 DATE : 05-20-02

BLANK CALCULATIONS

Acetone : $\frac{.0008 \text{ g}}{200 \text{ ml}} = .000004 \text{ g/ml}$
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = .000023 \text{ g/ml}$
 Distilled Water : $\frac{.0004 \text{ g}}{200 \text{ ml}} = .000002 \text{ g/ml}$

FRONT HALF CATCH

FILTERS : $\frac{.1502 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ (# of Filters)} \cdot (.0000 \text{ g})}{\text{Blank Value / Filter}} = .1502 \text{ g}$

BEAKERS : $\frac{.0845 \text{ g}}{\text{Total Catch}} - \frac{150 \text{ ml Acetone} \cdot (.000004 \text{ g})}{\text{Blank Value / ml Acetone}} = .0839 \text{ g}$

TOTAL FRONT HALF CATCH : .2341 g

BACK HALF CATCH

FILTERS : $\frac{.0591 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ (# of Filters)} \cdot (.0000 \text{ g})}{\text{Blank Value / Filter}} = .0591 \text{ g}$

BEAKERS :

Acetone : $\frac{.2089 \text{ g}}{\text{Total Catch}} - \frac{150 \text{ ml Acetone} \cdot (.000004 \text{ g})}{\text{Blank Value / ml Acetone}} = .2083 \text{ g}$

Extract : $\frac{.0761 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Dichloromethane} \cdot (.000023 \text{ g})}{\text{Blank Value / Dichloromethane}} = .0744 \text{ g}$

Water : $\frac{.1621 \text{ g}}{\text{Total Catch}} - \frac{385 \text{ ml Water} \cdot (.000002 \text{ g})}{\text{Blank Value / Water}} = .1613 \text{ g}$

TOTAL BACK HALF CATCH : .5031 g

TOTAL CATCH : .7372 g

% FRONT HALF : 31.8 %

CALCULATIONS DATA SHEET # 7

UNIT: F500 RUN: 4 DATE: 05-20-02

$$1) Vm(\text{std}) = \frac{(103.128 \text{ Vm})(17.64)(1.000 \text{ mcf}) \left(29.83'' \text{ Hg} + \frac{169'' \text{ H}_2\text{O}}{13.6} \right)}{(545 \text{ TmA})} = \frac{99.6123}{000.0000} \text{ dscf}$$

$$2) Vw(\text{std}) = (.04707)(173.2 \text{ ml H}_2\text{O}) = \frac{8.1525}{00.0000} \text{ scf}$$

$$3) \text{Asw} = \frac{(8.1525 \text{ scf})}{(8.1525 \text{ scf} + 99.6123 \text{ dscf})} = \frac{.0757}{.0000} \text{ Bws} \times 100 = \frac{7.5651}{00.0000} \% \text{ H}_2\text{O}$$

$$4) \text{Cs} = \frac{(17372 \text{ g.})}{(99.6123 \text{ dscf})} (15.43) = \frac{1142}{0.0000} \text{ gr / dscf}$$

$$5) \text{Estimated g / hr} = \frac{(17372 \text{ g.})}{(99.6123 \text{ dscf})} (6.910 \text{ dscfm})(60) = \frac{3.0683}{00.0000} \text{ g / hr}$$

Vm = total cubic feet pulled on meter box during test
 mcf = meter correction factor (Y factor) of meter box used for test
 " Hg = average barometric pressure during test
 " H₂O = average delta H for test
 TmA = average meter temperature for test in degrees Absolute
 ml H₂O = total water caught during test
 g. = total particulate catch for test
 dscfm = average stack flow during test

(p. 2)
 (0.000 Vm)
 (0.000 mcf)
 (00.00" Hg)
 (.000" H₂O)
 (.000 TmA)
 (000.0 ml H₂O)
 (00.0000 g.)
 (00.000 dscf)

TEST DATA SHEET # 8

UNIT: F500 RUN: 4 DATE: 05-20-02

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb

Pre : WB : 62 DB : 78 = 39 % RH 1.3 % H₂O

Post : WB : 67 DB : 88 = 31 % RH 1.4 % H₂O

Average : 35.0 % RH 1.35 % H₂O

Empty Stove Weight (lbs) : _____ w/ stack & oil seal : Wet : _____ Dry : 0.0

Kindling Weight (lbs) : Paper : .1 Wood : 3.1

Preburn Fuel Weight : 16.5 + 14.5 + 13.3 + 2.7 Total : 47.0

Kindling & Preburn Fuel Weight (wood only) (lbs) : Total : 50.1

Coal Bed Wt Range (lbs) : 4.2 - 3.4 Scale : 4.2 - 3.4

Upper : .25 x fuel weight : Always round DOWN to nearest tenth
 Lower : .20 x fuel weight : Always round UP to nearest tenth Actual Coal Bed Weight : 4.2

Maximum Coal Bed Removal (lbs) : $((\frac{4.2}{\text{Upper}} + \frac{3.4}{\text{Lower}}) \div 2) \cdot 25 = \frac{9}{\text{round down to nearest tenth}}$

Test Fuel (.75" x 1.5" x 5" spacers) = 16 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	3	7.0	41.2
4" x 4"	17	2	10.0	58.8

Test Fuel Weight : 17.0 lbs

Estimated Dry Burn Rate :

$$\frac{17.0 - (17.0 \times .17405)}{2.2046} \times \frac{60}{310} = \underline{1.233} \text{ kg / hr}$$

Estimated BTU's/hr : $19,140 \times \frac{63}{100} \times \frac{1.233}{\text{DBR}} = \underline{14,864.3} \text{ BTU's/hr}$

EPA Default Efficiencies : Non-cat : 63 Cat : 72 Pellet : 78

WOOD STOVE OPERATING DATA PAGE #9

Unit: F500 Run: 4 Date: 05-20-02

FIRE STARTED: 0900

WARM UP AND PREBURN:

PRIMARY AIR: Set wide open for all warm-up / preburn fuel charges. Then set to 1/8" at start of preburn.

SECONDARY AIR: N/A CAT BYPASS: N/A

CHARCOAL BED PREPARATION:

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 30 sec.

TEST:

DOOR wide open during loading ~~0~~ min. 45 sec.

PRIMARY AIR: Opened full for first 5 min., then set to run setting of 1/8".

SECONDARY AIR: N/A CAT BYPASS: N/A

FAN:

~~ON~~ / ~~OFF~~ during warm-up

~~ON~~ / ~~OFF~~ first 30 minutes of test

Fan speed set at Low

~~ON~~ / ~~OFF~~ during preburn

~~ON~~ / ~~OFF~~ balance of test run

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER: N/A BRAND: N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 12 or 16 inches.

1st warm up / pre-burn fuel charge (16.5 lbs.) added at 0920

2nd warm up / pre-burn fuel charge (14.5 lbs.) added at 1050

3rd warm up / pre-burn fuel charge (13.3 lbs.) added at 1200

4th warm up / pre-burn fuel charge (2.7 lbs.) added at 1250

5th warm up / pre-burn fuel charge (____ lbs.) added at _____

TEST DATA SHEET #10

Unit : F500 Run : 4 Date : 05-20-02

Room Temperature : 72 °F Correction Factor : 0

Uncorrected Values are corrected for room temperature : Yes _____ No

Time Test Fuel moisture reading taken : 1200

Calibration Checks : X Y 12.0 12.2 22.0 22.0

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	11.5	12.2	11.5	12.2	12.0	12.8	12.400
2									
3									
4	2"x4"x8'	P	18.0	19.2	18.5	19.8	18.5	19.8	19.600
5	2"x4"x8'	P	18.0	19.2	18.0	19.2	18.5	19.8	19.400
6	2"x4"x8'	P	18.0	19.2	18.0	19.2	18.0	19.2	19.200
7	2"x4"x8'	P	21.5	23.1	20.0	21.4	20.5	22.0	22.167
8	2"x4"x8'	P							80.367
9									
10	2x4x17	T	17.5	18.7	17.5	18.7	18.0	19.2	18.867
11	"	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200
12	"	T	23.5	25.2	23.5	25.2	23.5	25.2	25.200
13	4x4x17	T	19.5	20.9	19.5	20.9	20.0	21.4	21.067
14	"	T	19.0	20.3	20.0	21.4	20.0	21.4	21.033
15									105.367
16									
17									
18									
19									
20	Spacers	T	18.5	19.8	18.0	19.2	18.0	19.2	19.400

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	12.400 %	20.092 %	21.073 %
Wet Moisture % :	11.032 %	16.730 %	17.405 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

WEIGHT: 4.2
 UNIT: F500

GAS DATA SHEET # 12

RUN: 4 DATE: 05-20-02 PAGE: 1 of 3

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL WB	STACK	STATIC	SO ₂ PPM
0	21.2	17.0	-	.234	5.8	.556	13.9	.104	1.05					233	.037	525
5	20.6	16.4	.6	.585	14.6	.241	6.0	.038	.39					336	.058	300
10	20.3	16.1	.3	.124	3.0	.687	17.2	.067	.68					240	.044	525
15	20.0	15.8	.3	.123	3.0	.690	17.3	.072	.73					212	.040	550
20	19.8	15.6	.2	.130	3.2	.683	17.1	.080	.81					203	.038	550
25	19.4	15.2	.4	.160	4.0	.661	16.6	.089	.90					274	.038	575
30	19.0	14.8	.4	.309	7.7	.500	12.5	.058	.59					232	.045	500
35	18.4	14.2	.6	.298	7.4	.510	12.8	.078	.79					246	.048	525
40	17.9	13.7	.5	.453	11.3	.382	9.5	.024	.25					294	.054	450
45	17.2	13.0	.7	.503	12.5	.344	8.6	.023	.24					323	.057	425
50	16.4	12.2	.8	.503	12.5	.343	8.6	.018	.19					338	.058	425
55	15.7	11.5	.7	.472	11.7	.369	9.2	.018	.19					339	.059	425
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	3270	.576	*****
60	15.1	10.9	.6	.468	11.6	.370	9.2	.012	.13					342	.059	425
65	14.5	10.3	.6	.469	11.7	.374	9.3	.012	.13					344	.059	425
70	14.0	9.8	.5	.484	12.0	.361	9.0	.011	.12					348	.059	425
75	13.3	9.1	.7	.472	11.7	.368	9.2	.019	.20					344	.059	425
80	12.8	8.6	.5	.485	12.1	.357	8.9	.015	.16					345	.059	425
85	12.3	8.1	.5	.503	12.5	.340	8.5	.012	.13					348	.059	425
90	11.6	7.4	.7	.526	13.1	.330	8.2	.010	.11					355	.060	425
95	10.9	6.7	.7	.474	11.8	.361	9.0	.015	.16					345	.058	450
100	10.6	6.4	.3	.418	10.4	.395	9.9	.016	.17					333	.056	450
105	10.2	6.0	.4	.400	9.9	.407	10.2	.018	.19					323	.055	450
110	9.8	5.6	.4	.396	9.8	.410	10.2	.022	.23					317	.055	450
115	9.4	5.2	.4	.399	9.9	.406	10.1	.028	.29					312	.055	450
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	4056	.693	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	7326	1.269	*****

GAS DATA SHEET # 12

WEIGHT: 4.4

UNIT: F500

RUN: 4

DATE: 05-20-02

PAGE: 2

of 3

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL WB	STACK	STATIC	SO ₂ PPM
120	9.0	4.8	.4	410	10.2	395	9.9	.026	.27					310	.055	450
125	8.7	4.5	.3	441	11.0	378	9.4	.015	.16					314	.053	450
130	8.3	4.1	.4	463	11.5	349	8.7	.018	.19					319	.055	450
135	7.9	3.7	.4	415	10.3	394	9.8	.046	.47					309	.054	475
140	7.6	3.4	.3	320	8.0	457	11.4	.073	.74					289	.054	525
145	7.5	3.3	.1	306	7.6	469	11.7	.086	.87					268	.048	550
150	7.3	3.1	.2	277	6.9	484	12.1	.116	1.17					254	.045	525
155	7.2	3.0	.1	266	6.6	496	12.4	.138	1.39					245	.044	550
160	7.1	2.9	.1	263	6.5	500	12.5	.143	1.44					237	.043	525
165	6.9	2.7	.2	261	6.5	501	12.5	.148	1.49					229	.041	525
170	6.8	2.6	.1	256	6.4	504	12.6	.167	1.67					225	.041	525
175	6.7	2.5	.1	252	6.3	508	12.7	.173	1.74					222	.040	500
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	3221	.575	*****
180	6.6	2.4	.1	246	6.1	513	12.8	.186	1.87					219	.040	500
185	6.5	2.3	.1	249	6.2	515	12.9	.167	1.68					213	.039	525
190	6.4	2.2	.1	248	6.2	514	12.9	.168	1.69					211	.038	525
195	6.3	2.1	.1	247	6.1	516	12.9	.170	1.71					208	.038	525
200	6.2	2.0	.1	245	6.1	517	12.9	.181	1.82					205	.037	525
205	6.0	1.8	.2	237	5.9	524	13.1	.207	2.08					203	.036	525
210	5.9	1.7	.1	230	5.7	531	13.3	.210	2.11					201	.036	525
215	5.8	1.6	.1	223	5.5	536	13.4	.224	2.24					199	.036	525
220	5.7	1.5	.1	211	5.2	543	13.6	.256	2.56					197	.035	525
225	5.6	1.4	.1	210	5.2	546	13.7	.255	2.55					194	.035	525
230	5.6	1.4	.0	220	5.5	542	13.6	.225	2.25					194	.035	525
235	5.4	1.2	.2	209	5.2	549	13.7	.249	2.49					192	.035	525
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	2436	.440	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	5657	-1.015	*****

WEIGHT: 4.2

UNIT: F500

GAS DATA SHEET #12

RUN: 4 DATE: 05-20-02 PAGE: 3 of 3

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	CO	WB	DB	% H ₂ O	CAL WB	STACK	STATIC	SO ₂ PPM
240 175	5.4	1.2	0	.208	5.2	.550	2.45					191	.035	525
245 180	5.3	1.1	.1	.221	5.5	.554	1.75					188	.033	525
250 05	5.2	1.0	.1	.225	5.6	.552	1.58					187	.033	550
255 10	5.0	.8	.2	.222	5.5	.555	1.64					186	.032	525
260 15	5.0	.8	0	.215	5.3	.567	1.48					185	.031	525
265 20	4.9	.7	.1	.210	5.2	.572	1.51					184	.031	525
270 25	4.8	.6	.1	.206	5.1	.572	1.60					183	.031	525
275 30	4.7	.5	.1	.204	5.1	.575	1.56					181	.030	525
280 35	4.7	.5	0	.199	4.9	.579	1.64					180	.030	550
285 40	4.6	.4	.1	.199	4.9	.575	1.82					179	.029	550
290 45	4.5	.3	.1	.201	5.3	.573	1.81					179	.029	550
295 50	4.4	.2	.1	.198	4.9	.574	1.89					178	.029	575
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	2201	-.373	*****
300 1855	4.3	.1	.1	.195	4.8	.578	1.85					177	-.029	575
305 1900	4.3	.1	0	.194	4.8	.578	1.85					176	-.028	575
310 05	4.2	0	.1	.197	4.9	.575	1.85					175	-.028	575
315 10														
320 15												528	.085	
325 20														
330 25														
335 30														
340 35														
345 40														
350 45														
355 50														463
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	15712	-2.742	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	249	-.044	*****

TEMPERATURE DATA SHEET # 14

UNIT: F500

RUN: 4

DATE: 05-20-02

PAGE 1

of 3

TIME	TOP	LT SIDE	BACK	RT SIDE	BOTTOM	FIREBOX	SEC/CAT	AMBIENT	FURNACE	SAMPLE	SAMP IMP	C-GAS	GAS IMP	SO ₂ IMP
0 135	329	173	303	282	291	724	616	77	1261	229	67	225	36	37
5 140	363	169	296	286	280	614	905	76	1267	232	44	236	36	36
10 05	336	159	286	282	286	574	601	75	1274	233	42	241	36	34
15 10	304	154	269	274	281	527	535	75	1284	235	44	246	37	35
20 15	290	148	261	267	276	504	540	73	1286	236	47	247	38	36
25 20	274	147	247	256	268	484	616	73	1315	237	45	247	37	36
30 25	296	142	239	250	262	477	795	73	1319	237	44	247	39	37
35 30	317	141	231	227	252	477	1019	72	1329	238	44	247	37	36
40 35	381	148	227	213	244	498	1275	73	1336	238	44	249	36	37
45 40	428	143	226	201	236	522	1300	73	1344	237	44	248	36	36
50 45	457	142	227	197	229	544	1261	72	1338	237	44	251	37	37
55 50	470	143	230	192	226	559	1282	72	1337	237	44	247	37	37
TOTAL	4245	1809	3042	2927	3131	6504	10745	884	*****	*****	*****	*****	*****	*****
60 1455	477	144	232	194	222	574	1186	72	1335	237	45	246	38	37
65 1500	483	146	235	195	217	593	1188	73	1334	238	45	246	38	37
70 05	491	145	240	196	215	610	1213	73	1333	238	45	247	38	37
75 10	499	154	246	198	211	633	1176	74	1327	237	45	247	36	37
80 15	502	151	249	199	209	648	1192	75	1328	237	46	248	36	36
85 20	509	155	253	201	208	663	1189	74	1329	238	46	249	37	37
90 25	519	158	261	204	206	689	1215	75	1330	237	46	250	35	36
95 30	515	159	266	207	205	705	1149	75	1328	237	46	250	36	37
100 35	503	161	270	212	205	716	1086	75	1328	237	46	248	36	38
105 40	491	164	273	216	204	724	1074	75	1328	237	47	247	36	38
110 45	480	161	274	220	204	732	1074	75	1328	236	47	246	36	38
115 50	474	164	277	223	205	741	1089	76	1327	236	47	246	36	37
TOTAL	5943	1862	3076	2465	2511	8028	13831	892	*****	*****	*****	*****	*****	*****
TOTAL	10188	3671	6118	5392	5642	14532	24516	1776	*****	*****	*****	*****	*****	*****

TEMPERATURE DATA SHEET # 14

UNIT: F500

RUN: 4

DATE: 05-20-02 PAGE 2

of 3

TIME	TOP	LT SIDE	BACK	RT SIDE	BOTTOM	FIREBOX	SEC/CAT	AMBIENT	FURNACE	SAMPLE	SAMP IMP	C-GAS	GAS IMP	SO ₂ IMP
120	155	472	280	228	207	751	1097	75	1325	236	47	245	36	37
125	160	474	281	230	206	757	1119	76	1324	236	47	245	36	37
130	165	486	282	232	209	767	1209	75	1323	236	48	245	36	37
135	168	483	285	240	210	774	1126	76	1325	236	48	246	36	37
140	169	457	286	242	210	773	1004	76	1327	235	48	245	36	37
145	20	429	287	244	214	774	915	76	1328	235	49	244	36	37
150	25	403	288	249	216	776	867	76	1328	234	50	240	36	36
155	30	385	287	250	219	776	826	76	1328	234	50	240	36	36
160	35	369	285	250	222	776	807	75	1327	233	49	241	36	36
165	40	355	285	253	225	772	797	76	1326	234	49	240	36	35
170	45	343	283	252	227	768	789	76	1325	234	49	240	36	35
175	50	336	283	252	228	764	779	75	1324	234	50	242	35	36
TOTAL		4992	3412	2922	2593	9228	11335	908	*****	*****	*****	*****	*****	*****
180	165	324	280	251	229	758	744	75	1322	233	51	242	36	36
185	170	314	281	250	231	748	705	75	1320	234	51	244	37	34
190	05	309	278	247	231	741	696	75	1325	234	49	245	37	35
195	10	302	277	246	233	736	691	74	1329	234	49	244	36	35
200	15	296	275	242	232	731	686	75	1331	234	49	244	36	34
205	20	291	276	242	233	723	674	74	1328	234	50	245	37	36
210	25	287	274	239	232	717	663	74	1325	234	50	244	37	35
215	30	279	271	236	232	714	651	75	1323	234	50	244	38	36
220	35	276	271	236	233	709	652	74	1323	234	50	245	37	37
225	40	272	268	233	232	704	645	74	1323	234	50	245	37	37
230	45	270	267	230	232	699	668	73	1325	234	50	246	38	37
235	50	268	260	229	232	694	647	73	1324	235	50	246	38	37
TOTAL		3486	3284	2881	2782	8674	8122	891	*****	*****	*****	*****	*****	*****
TOTAL		8480	6696	5803	5375	17902	19457	1799	*****	*****	*****	*****	*****	*****

TEMPERATURE DATA SHEET # 14

UNIT: F500

RUN: 4

DATE: 05-20-02

PAGE 3

of 3

TIME	TOP	LT SIDE	BACK	RT SIDE	BOTTOM	FIREBOX	SEC/CAT	AMBIENT	FURNACE	SAMPLE	SAMP IMP	C-GAS	GAS IMP	SO ₂ IMP
240 175	265	153	264	228	231	687	643	74	1325	234	50	246	37	37
245 180	258	156	262	223	228	678	621	76	1326	235	50	247	37	37
250 05	258	152	260	222	228	673	628	76	1327	235	51	247	37	35
255 10	255	150	256	223	229	666	620	77	1328	235	53	247	37	35
260 15	254	152	255	220	228	662	612	77	1328	236	54	248	37	36
265 20	251	151	253	219	229	658	584	77	1329	236	54	248	37	36
270 25	247	152	253	215	226	651	576	78	1330	236	55	248	36	36
275 30	246	148	251	214	227	641	569	78	1330	236	55	247	36	36
280 35	244	148	247	211	227	634	561	78	1329	236	54	248	36	36
285 40	240	149	248	211	228	630	566	79	1329	236	54	249	36	37
290 45	237	151	248	209	226	629	562	80	1327	236	53	249	36	36
295 50	237	151	247	211	225	628	562	81	1326	237	52	248	36	35
TOTAL	2992	1813	3044	2606	2732	7837	7104	931	*****	*****	*****	*****	*****	*****
300 185	234	148	246	209	224	620	556	82	1325	237	52	247	36	34
305 190	233	148	243	208	223	612	552	81	1325	237	52	247	35	35
310 05	232	149	243	205	223	609	554	82	1325	236	52	246	35	34
315 10														
320 15	699	445	732	622	670	1841	1662	245						
325 20														
330 25														
335 30										275.6	.			
340 35										210.4	.			
345 40										-65.2	ΔT			
350 45														
355 50									263					
TOTAL	22359	9801	16590	14423	14419	42112	52799	4751	*****	*****	*****	*****	*****	*****
TOTAL	355	156	263	229	229	668	838	75	*****	*****	*****	*****	*****	*****

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 05-20-2002 Analyte : CO₂ (15-1)
 Unit : F500 Run # : 4
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO₂ Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC12767 Conc. : 12.49 % CO₂ Cyl. Press. : 1420 PSI
 Certified by : AIR LIQUIDE Date : 02-15-02
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 407069
 Range : 0 - 25.0 % CO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 25.0 % CO₂
 EPA Control Limits = ± 2.5% of 25.0 % CO₂ = ± 0.625 % CO₂
 Method 28 A = ± .2 % of 25.0 % CO₂ = ± .05 % CO₂

PRE RUN Audit : by : A. Wadlington Time : 1335 Temp : 84 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	.003	+ .003	+ .013
SPAN	50.0	.500	12.49	49.6	.496	12.342	- .148	- .593

POST RUN Audit : by : A. Wadlington Time : 1925 Temp : 82 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	- .022	- .022	- .087
SPAN	50.0	.500	12.49	49.9	.499	12.417	- .073	- .294

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05-20-2002

Analyte : O₂ (15-2)

Unit : F500

Run # : 4

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂

Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 12.50 % O₂

Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : TELEDYNE Model : 320 A

SN : 37400

Range : 0 - 25.0 % O₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % O₂

EPA Control Limits = ± 2.5% of 25.0 % O₂ = ± 0.625 % O₂

Method 28 A = ± .2 % of 25.0 % O₂ = ± .05 % O₂

PRE RUN Audit : by : D. Wadlington Time : 1335 Temp : 84 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.003	.011	+.011	+.043
SPAN	12.50	.500	12.50	12.4	.496	12.413	-.087	-.349

POST RUN Audit : by : D. Wadlington Time : 1925 Temp : 82 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.002	-.014	-.014	-.057
SPAN	12.50	.500	12.50	12.5	.499	12.488	-.012	-.047

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date : 05-20-2002 Analyte : CO (15-3)
 Unit : F500 Run # : 4
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC12767 Conc. : 4.80 % CO Cyl. Press. : 1420 PSI
 Certified by : AIR LIQUIDE Date : 02-15-02
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 408005
 Range : 0 - 10.0 % CO Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 10.0 % CO
 EPA Control Limits = ± 2.5% of 10.0 % CO = ± 0.25 % CO
 Method 28 A = ± .2 % of 10.0 % CO = ± .02 % CO

PRE RUN Audit : by : J. Wadlington Time : 1335 Temp : 84 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.014	+0.014	+0.141
SPAN	48.0	.480	4.80	48.0	.480	4.793	-0.007	-0.066

POST RUN Audit : by : J. Wadlington Time : 1925 Temp : 82 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.004	+0.004	+0.041
SPAN	48.0	.480	4.80	48.1	.481	4.803	+0.003	+0.034

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05-20-2002 Analyte : SO₂ (15-4)
 Unit : F500 Run # : 4
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC62184 Conc. : 1290 ppm SO₂ Cyl. Press. : 1350 PSI
 Certified by : AIR LIQUIDE Date : 01-29-01
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 403019
 Range : 0 - 2500 ppm SO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = $\pm 2.5\%$ of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : A. Washington Time : 1330 Temp : 83 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	3.399	+3.399	+ .136
SPAN	51.6	.516	1290	51.1	.511	1279.771	-10.229	- .409

POST RUN Audit : by : A. Washington Time : 1920 Temp : 82 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	3.399	+3.399	+ .136
SPAN	51.6	.516	1290	51.3	.513	1284.757	-5.243	- .210

\pm Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : F500 RUN : 4 DATE : 05-20-02

Thermocouple Check:

T/C # 1	<u>—</u>	°F	T/C # 13	<u>67.2</u>	°F
T/C # 2	<u>—</u>	°F	T/C # 14	<u>66.0</u>	°F
T/C # 3	<u>67.1</u>	°F	T/C # 15	<u>67.2</u>	°F
T/C # 4	<u>62.3</u>	°F	T/C # 16	<u>60.8</u>	°F
T/C # 5	<u>61.0</u>	°F	T/C # 17	<u>60.1</u>	°F
T/C # 6	<u>61.4</u>	°F	T/C # 18	<u>74.2</u>	°F
T/C # 7	<u>61.3</u>	°F	T/C # 19	<u>63.4</u>	°F
T/C # 8	<u>61.2</u>	°F	T/C # 20	<u>52.0</u>	°F
T/C # 9	<u>61.7</u>	°F	T/C # 21	<u>—</u>	°F
T/C # 10	<u>61.8</u>	°F	T/C # 22	<u>—</u>	°F
T/C # 11	<u>60.2</u>	°F	T/C # 23	<u>64.4</u>	°F
T/C # 12	<u>70.4</u>	°F	T/C # 24	<u>—</u>	°F

Thermocouple Readout:

Pretest zero and span check and calibration

ZERO : 0.2 °F Adj. to 0.0 °F

SPAN : 1998.8 °F Adj. to 2000.0 °F

post test zero and span

% difference

ZERO 2.3 °F Adj. to .115 °F

SPAN 2004.1 °F Adj. to .205 °F

Thermocouple Readout Pretest Linearity Check:

0	= <u>0.0</u> °F	200	= <u>202.4</u> °F	400	= <u>399.8</u> °F
600	= <u>601.9</u> °F	800	= <u>802.0</u> °F	1000	= <u>1000.9</u> °F
1200	= <u>1198.4</u> °F	1400	= <u>1399.4</u> °F	1600	= <u>1599.8</u> °F
1800	= <u>1800.0</u> °F	2000	= <u>2000.0</u> °F		

Sample Train Leak Check

Pre ✓

Post ✓

C-gas Train Leak Check

Pre ✓

Post ✓

SO₂ Train Leak Check

Pre ✓

Post ✓

Static Gauge Zero Check


Pre X

Post ✓

Scale Check Pre : 15.6 - 5.6

Post : 14.0 - 4.0

Stack Cleaned Prior to Test Run : YES NO X



COMPUTER INPUT DATA SHEET #1

Client: JOTUL U.S.A., INC.

Address: 400 RIVERSIDE ST., P.O. BOX 1157
PORTLAND, MAINE 04104

Phone: (207) 797-5912 Fax: (207) 772-0523

Run No.: 3 Date of Test: 05-17-2002 Burn Rate: 1.893

Model No.: F500 min min-1.25 fan

Stove Type: Cat Non Cat Pellet 1.25-1.9 max insert

Dry Gas Meter Y Factor: 1.000 (0.000) (Data Sheet #2) Post Leak Rate: .007 cfm (0.000) (Data Sheet #2) Time: 195 min. (000) (Data Sheet #2)

Dry Gas Meter Volume: 57,534 cf (00.000) (Data Sheet #2)

Stack Flow: 9.481 dscfm ΔH : .137 in. H₂O (00.000) (Data Sheet #2)

Maximum Vac.: 2.0 (0.0) (Data Sheet #2) Barometric Pressure: 30.17 in. Hg (00.00) (Data Sheet #2)

H₂O Captured: 108.9 g (00.0) (Data Sheet #3)

Front Half Catch % Of Total: 38.3 % (00.0) (Data Sheet #6) Total Particulate Catch: .1150 g (0.0000) (Data Sheet #6)

Flue Gas Moisture: 8.3161 % (00.000) (Data Sheet #7)

Particulate Emission: .0314 gr/dscf (0.0000) (Data Sheet #7)

Relative Humidity: 37.0 % RH (00.0) (Data Sheet #8) Ambient Moisture: 1.50 % H₂O (0.00) (Data Sheet #8)

Pretest Fuel Wt.: 49.9 lbs. (00.0) (Data Sheet #8) Coal Bed Wt.: 4.0 lbs. (00.0) (Data sheet #8) Test Fuel Wt.: 16.5 lbs. (00.0) (Data sheet #8)

Heat Output (EPA Default): 22,832.1 BTU/hr (00,000.0) (Data Sheet #8)

Kindling Fuel % Moisture (wet): 11.164 % (00.000) (Data Sheet #10) Pretest Fuel % Moisture (wet): 16.817 % (00.000) (Data Sheet #10)

Test Fuel % Moisture (dry): 21.620 % (00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove]) Test Fuel % Moisture (wet): 17.777 % (00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])

Fuel Higher Heating Value (dry): — BTU/lb. (0000) (Data Sheet #11)

Stack Static Pressure: -.054 in. H₂O (+/- .000) (Data Sheet #12)

Average Ambient Temperature: 75 °F (00) (Data Sheet #14) Stove Temperature Change: -36.4 °F (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul U.S.A., Inc.

TEST No. : 3

MODEL: F500

DATE: 17-May-02

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
0	594.500	0.150	78	0.91	6.50	350
5	596.000	0.210	78	0.42	10.30	300
10	597.766	0.150	79	0.47	10.70	350
15	599.287	0.150	80	0.40	12.30	350
20	600.813	0.150	80	0.32	12.90	350
25	602.338	0.150	80	0.35	14.50	350
30	603.864	0.150	81	0.30	15.00	350
35	605.396	0.150	82	0.23	14.50	350
40	606.933	0.150	83	0.23	14.20	350
45	608.476	0.150	83	0.20	15.00	350
50	610.019	0.150	83	0.48	15.10	350
55	611.562	0.150	83	0.14	14.50	350
60	613.104	0.150	83	0.12	13.10	350
65	614.648	0.150	83	0.19	11.20	350
70	616.192	0.150	83	0.28	10.40	350
75	617.736	0.150	83	0.26	10.10	350
80	619.286	0.150	83	0.28	9.90	350
85	620.824	0.150	83	0.20	10.20	350
90	622.368	0.150	83	0.31	10.70	350
95	623.912	0.150	83	0.44	9.00	350
100	625.455	0.130	83	0.66	7.10	375
105	626.897	0.130	83	0.66	7.00	375
110	628.338	0.130	83	0.74	7.00	375
115	629.779	0.130	83	0.78	6.80	375
120	631.220	0.130	83	0.91	6.80	375
125	632.661	0.130	83	0.89	6.80	375
130	634.102	0.130	83	0.92	6.90	375
135	635.543	0.130	83	0.93	6.80	375
140	636.984	0.130	83	1.00	6.90	375
145	638.425	0.130	83	1.00	6.60	375
150	639.866	0.110	83	1.14	6.40	400
155	641.218	0.110	83	1.16	6.40	400
160	642.569	0.110	83	1.19	6.00	400
165	643.920	0.110	83	1.27	5.70	400
170	645.271	0.110	83	1.29	5.90	400
175	646.622	0.110	83	1.29	5.90	400
180	647.973	0.110	83	1.35	5.90	400
185	649.327	0.110	83	1.43	5.70	400
190	650.680	0.110	83	1.30	5.60	400
195	652.034	0.110	83	1.31	5.40	400
200						

TABLE 2---RAW DATA

CLIENT :	Jotul U.S.A., Inc.	TEST No.	3
MODEL:	F500	DATE:	17-May-02

METER CAL.		Wt. WOOD	
FACTOR (Y) -----	1	BURNED (LB) -----	16.5 Lbs
BAROMETRIC		WET, FUEL	
PRESS. (Pb) -----	30.17 in Hg	MOISTURE % -----	17.777 %
LEAK RATE		Wt. PART.	
POST (Lp) -----	0.007 cfm	COLLECTED -----	0.115 g
WATER		METER	
VOL. (V1c) -----	108.9 Ml	VOLUME Vm -----	57.534 mcf
TEST		HC MOLE	
TIME (MIN) -----	195 min	FRACTION -----	0.0132

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul U.S.A., Inc.

TEST No. 3

MODEL: F500

DATE: 17-May-02

AVG DELTA		AVG PRCNT		
H	----- 0.14 in H2O	CO	----- 0.69	%
AVG METER		AVG PRCNT		
TEMP. Tm	----- 82 deg F	CO2	----- 9.19	%
AVG PPM		AVG BAL		
SO2	----- 368 PPM	CO2/CO	----- 13.25	%

TABLE 4 ----- CALCULATIONS

CLIENT : Jotul U.S.A., Inc.

TEST No. 3

MODEL: F500

DATE: 17-May-02

STD SAMPLE		STACK GAS	
VOL. Vm(std) -----	56.51 dscf	FLOW Qsd -----	608.480 dscf/Hr
			&
			10.14 dscf/min
VOL. WATER		PARTICULATE	
VAPOR Vw(std) ----	5.126 scf	CONCTR. Cs -----	0.0020 g/dscf
PRCNT		PARTC. EMISS.	
MSTR Bws -----	8.32 %	RATE E -----	1.24 g/Hr
BURN		MOLES OF GAS	
RATE BR -----	1.89 Kg/Hr	PER Lb WOOD Nt --	0.38 Lb-mole/Lb
CO EMISSION		PART. EMISS.	
RATE -----	141.36 g/Hr	RATE -----	0.65 g/Kgdry
	&		fuel
	74.68 g/Kgdry		
	fuel		

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul U.S.A., Inc.

TEST No. : 3

MODEL: F500

DATE: 17-May-02

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	519.8	98	100
10	524.2	99	
15	525.6	99	
20	526.9	100	
25	526.5	99	
30	526.4	99	
35	527.5	100	
40	528.2	100	
45	529.8	100	
50	529.8	100	
55	529.8	100	
60	529.5	100	
65	530.1	100	
70	530.1	100	
75	530.1	100	
80	532.2	101	
85	528.1	100	
90	530.1	100	
95	530.1	100	
100	529.8	100	
105	530.5	100	
110	530.1	100	
115	530.1	100	
120	530.1	100	
125	530.1	100	
130	530.1	100	
135	530.1	100	
140	530.1	100	
145	530.1	100	
150	530.1	100	
155	530.5	100	
160	530.1	100	
165	530.1	100	
170	530.1	100	
175	530.1	100	
180	530.1	100	
185	531.3	100	
190	530.9	100	
195	531.3	100	
200			
205			

METER BOX DATA SHEET PAGE # 2

Page: 1 of 2

UNIT: F500 RUN: 3 DATE: 05-17-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .000 cfm _____ " Hg @ _____ cfm

15 " Hg @ .007 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1,506

ROTO: PRESS: <u>.14</u>			SAMPLING RATIO: <u>33</u> : 1				BP: <u>30.20</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
0	1145	594.500	—	10.000	.15	78	350	78	2.0	
5	50	596.000	—	11.667	.21	78	300	78	2.0	
10	55	597.766	597.766	9.982	.15	79	350	79	2.0	
15	1200	599.287	599.287	9.963	.15	80	350	80	2.0	
20	05	600.813	600.813	9.963	.15	80	350	80	2.0	
25	10	602.338	602.338	9.963	.15	80	350	80	2.0	
30	15	603.864	603.864	9.945	.15	81	350	81	2.0	
35	20	605.394	605.394	9.926	.15	82	350	82	2.0	
40	25	606.933	606.933	9.908	.15	83	350	83	2.0	
45	30	608.476	608.476	9.908	.15	83	350	83	2.0	
50	35	610.019	610.019	9.908	.15	83	350	83	2.0	
55	40	611.562	611.562	9.908	.15	83	350	83	2.0	
ROTO PRESS: <u>.14</u>			TOTALS:			121.041	1.86	970	BP: <u>30.18</u>	
60	1245	613.104	613.104	9.901	.15	83	350	83	2.0	
65	50	614.648	614.648	9.901	.15	83	350	83	2.0	
70	55	616.192	616.192	9.901	.15	83	350	83	2.0	
75	1300	617.736	617.736	9.901	.15	83	350	83	2.0	
80	05	619.286	619.286	9.901	.15	83	350	83	2.0	
85	10	620.824	620.824	9.901	.15	83	350	83	2.0	
90	15	622.368	622.368	9.901	.15	83	350	83	2.0	
95	20	623.912	623.912	9.901	.15	83	350	83	2.0	
100	25	625.455	625.455	9.241	.13	83	375	83	2.0	
105	30	626.897	626.897	9.241	.13	83	375	83	2.0	
110	35	628.338	628.338	9.241	.13	83	375	83	2.0	
115	40	629.779	629.779	9.241	.13	83	375	83	2.0	
			TOTALS:			116.172	1.72	996	MAX VACC =	
TOTAL Cu Ft.			TOTALS:			237.213	3.58	1966	AVG. BP:	

METER BOX DATA SHEET PAGE # 2

Page: 2 of 2

UNIT: F500

RUN: 3

DATE: 05-17-02

Meter Box: 5H

Y Factor: 1.000

Leak checks: 15 " Hg @ .000 cfm _____ " Hg @ _____ cfm

15 " Hg @ .007 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min.

Nozzle: Probe @ 3/8" od

Initial Volume: 1.500

ROTO PRESS: <u>.14</u>			SAMPLING RATIO: <u>33</u> : 1				BP: <u>30.18</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
120	1345	631.220	631.220	9.241	.13	83	375	83	2.0
125	50	632.661	632.661	9.241	.13	83	375	83	2.0
130	55	634.102	634.102	9.241	.13	83	375	83	2.0
135	1400	635.543	635.543	9.241	.13	83	375	83	2.0
140	05	636.984	636.984	9.241	.13	83	375	83	2.0
145	10	638.425	638.425	9.241	.13	83	375	83	2.0
150	15	639.866	639.866	8.664	.11	83	400	83	2.0
155	20	641.218	641.218	8.664	.11	83	400	83	2.0
160	25	642.569	642.569	8.664	.11	83	400	83	2.0
165	30	643.920	643.920	8.664	.11	83	400	83	2.0
170	35	645.271	645.271	8.664	.11	83	400	83	2.0
175	40	646.622	646.622	8.664	.11	83	400	83	2.0
ROTO PRESS: <u>.14</u>			TOTALS:		107.430	1.44	996	BP: <u>30.13</u>	
180	1445	647.973	647.973	8.649	.11	83	400	83	2.0
185	50	649.327	649.327	8.649	.11	83	400	83	2.0
190	55	650.680	650.680	8.649	.11	83	400	83	2.0
195	1500	652.034	652.034	8.649	.11	83	400	83	2.0
200	05								
205				34.596	.44	332			
210				142.026	1.88	1328			
215									
220									
225									
230						3294			
235							40.		
				TOTALS:	379.239	5.46	82	MAX VACC =	2.0
TOTAL Cu Ft.		57.534	TOTALS:		9.481	.137	(542)	AVG. BP:	30.17

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT: F500 RUN: 3 DATE: 05-17-02

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	706.7	595.1	445.7	905.7
INITIAL WT	616.7	589.9	483.9	893.8
NET WT GRAMS	90.0	5.2	1.8	11.9

TOTAL CATCH: 108.9 GRAMS H₂O

FRONT HALF

FILTER #	119F	
FINAL WT g	.7075	.
INITIAL WT g	.6746	.
NET WT g	.0329	.

BEAKER #	56
DESC.	ACETONE
FINAL WT g	104.1865
INITIAL WT g	104.1750
NET WT g	.0115
VOL. DESC. ml	75

BACK HALF

FILTER #	119B	
FINAL WT g	.4526	.
INITIAL WT g	.4439	.
NET WT g	.0087	.

BEAKER #	57	58	59	60	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	97.4507	96.9065	105.3698	106.7451	
INITIAL WT g	97.4141	96.8989	105.3593	106.7348	
NET WT g	.0366	.0076	.0105	.0103	.0208
VOL. DESC ml	125	75	150	165	(315)

FILTER TARE WEIGHTS DATA SHEET #4-1

Into Dessicator : _____ Date : 01/29/02 Time : 1125 By : DKW
 Manufacturer S & S Grade : # 25 Glass Front Size : 11 cm Lot No. : ZB921
 Back Size : 8.2 cm Lot No. : ZB911

DATE: <u>02-07</u> BY: <u>DKW</u>			DATE: <u>02-10</u> BY: <u>DKW</u>			DATE: _____	BY: _____
FILTER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME	
111F	.6782	0934	<u>.6780</u>	1939	JOTUL C450		R-2
112F	.6755	0935	<u>.6751</u>	1940	" "		R-3
113F	.6721	0935	<u>.6719</u>	1941	" "		R-4
114F	.6843	0936	<u>.6844</u>	1942	" "		R-5
115F	.6699	0937	<u>.6700</u>	1943	" "		R-6
116F	.6696	0938	<u>.6694</u>	1943	" "		R-7
117F	.6796	0939	<u>.6793</u>	1944	JOTUL F500		R-1
118F	.6715	0940	<u>.6718</u>	1945	" "		R-2
119F	.6743	0941	<u>.6746</u>	1946	" "		R-3
120F	.6844	0942	<u>.6843</u>	1947	" "		R-4

111B	.4462	0943	<u>.4464</u>	1948	JOTUL C450		R-2
112B	.4448	0944	<u>.4451</u>	1949	" "		R-3
113B	.4466	0945	<u>.4464</u>	1949	" "		R-4
114B	.4305	0946	<u>.4307</u>	1950	" "		R-5
115B	.4234	0947	<u>.4236</u>	1951	" "		R-6
116B	.4444	0948	<u>.4445</u>	1952	" "		R-7
117B	.4431	0949	<u>.4430</u>	1953	JOTUL F500		R-1
118B	.4293	0950	<u>.4294</u>	1954	" "		R-2
119B	.4441	0951	<u>.4439</u>	1955	" "		R-3
120B	.4427	0952	<u>.4425</u>	1955	" "		R-4

Checked by: C. Washington Date: 2-10-02 Time: 2000

BALANCE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	WB	DB	% RH
02-07	0910	DKW		74	47
02-10	1905	DKW		74	45

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: F500 RUN: 3 DATE: 05-17-02 Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
56	05-18	1930	RM	104.1880	05-20	0902	RM	104.1863	05-21	0936	RM	104.1865	05-22	1200	RM
57	05-18	1930	RM	97.4526	05-20	0903	RM	97.4506	05-21	0937	RM	97.4507	05-22	1201	RM
58	05-18	1930	RM	96.9089	05-20	0904	RM	96.9066	05-21	0938	RM	96.9065	05-22	1203	RM
59	05-19	1600	RM	105.3700	05-21	0939	RM	105.3698	05-22	1204	RM				
60	05-19	1600	RM	106.7447	05-21	0941	RM	106.7451	05-22	1205	RM				

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
119F	5-17	1530	Op	.7100	05-18	1921	RM	.7089	05-19	1515	RM	.7080	05-20	0905	RM
119B	5-17	1530	Op	.4528	05-21	0942	RM	.4526	05-19	1516	RM				

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	05-18	1905	RM	77	49
2	05-19	1500	RM	77	48
3	05-20	0855	RM	77	47
4	05-21	0930	RM	78	49
5	05-22	1155	RM	78	48

Weighing Session	Date	Time	By	DB	%RH
6					
7					
8					
9					
10					

Dates: From 11-20-2001
Through 02-16-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius
Model: A1205
SN : 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	Wet Bulb	%RH
99.9998	10.0002	1.0003	.1000	DKW	11-20	0945	78		48
100.0000	10.0000	1.0001	.0999	DKW	11-21	1000	75		49
99.9998	9.9998	1.0000	.1001	DKW	11-22	1050	75		49
100.0003	9.9999	1.0000	.0999	DKW	11-26	1150	74		47
100.0001	9.9997	1.0000	.1000	DKW	11-27	1155	74		48
100.0001	10.0000	.9997	.0999	DKW	11-28	1220	72		48
99.9999	10.0001	1.0000	.1000	DKW	11-28	1930	73		48
99.9998	10.0000	.9999	.0999	DKW	11-29	1015	75		46
99.9998	10.0000	.9997	.0998	DKW	11-29	1925	73		46
100.0000	10.0001	.9998	.0999	DKW	11-30	1355	74		45
99.9999	9.9999	1.0000	.1000	DKW	12-01	1210	77		45
100.0003	10.0000	.9997	.1000	DKW	01-08	2045	78		47
100.0001	10.0000	.9998	.1000	DKW	01-09	1600	78		48
99.9999	9.9999	.9999	.1000	DKW	01-12	1900	74		46
99.9998	9.9999	.9997	.1000	DKW	01-13	1730	72		43
100.0000	10.0001	1.0000	.1001	DKW	01-14	1355	78		45
99.9998	9.9999	.9999	.1000	DKW	01-26	1745	72		47
99.9998	10.0000	1.0000	.0999	DKW	01-28	1705	74		44
100.0003	10.0000	1.0000	.0998	DKW	01-29	1130	70		47
99.9998	9.9997	1.0000	.1000	DKW	01-29	2300	71		44
100.0002	10.0000	1.0000	.1000	DKW	01-30	2200	75		45
99.9999	9.9999	.9999	.1000	DKW	01-31	2205	74		47
100.0001	9.9999	1.0000	.1000	DKW	02-02	0700	75		45
100.0002	9.9999	1.0001	.1000	DKW	02-04	1045	73		47
100.0000	10.0000	.9998	.0997	DKW	02-06	0905	73		47
100.0001	10.0000	1.0000	.1000	DKW	02-07	0910	74		47
100.0002	10.0001	1.0000	.0999	DKW	02-07	1235	77		48
99.9999	10.0000	.9999	.0998	DKW	02-08	1110	72		49
99.9998	9.9999	1.0000	.0999	DKW	02-09	1045	70		49
99.9997	10.0000	.9999	.0999	DKW	02-10	0920	74		48
99.9997	10.0001	.9999	.0999	DKW	02-10	1905	76		45
99.9999	9.9999	1.0000	.0997	DKW	02-11	1935	73		43
99.9998	9.9997	1.0000	.0999	DKW	02-13	1940	75		41
99.9997	10.0000	.9999	.1000	DKW	02-14	1015	74		38
99.9998	9.9999	1.0000	.1000	DKW	02-14	2010	74		43
100.0000	10.0000	1.0000	.1000	DKW	02-15	1150	74		41
99.9998	9.9999	.9999	.1000	DKW	02-16	1045	78		41

♡

Dates: From 02-16-2002
Through 05-17-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius

Model: A1205

SN : 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Wet Bulb	Dry Bulb	% RH
100.0000	9.9999	1.0000	.0999	BW	02-16	1845		77	46
100.0000	9.9999	.9999	.0998	BW	02-17	1555		77	47
100.0001	9.9999	.9999	.0997	BW	02-18	0940		77	47
100.0000	10.0000	.9999	.1000	BW	02-19	1025		78	46
100.0000	9.9999	1.0000	.0999	BW	02-20	0915		75	42
100.0003	10.0000	1.0000	.0999	BW	03-14	1020		78	45
99.9999	9.9998	.9998	.0998	BW	03-15	1725		77	45
99.9999	10.0000	1.0002	.0999	BW	03-16	1820		77	38
100.0001	9.9999	1.0001	.1000	BW	03-16	2130		78	43
99.9999	9.9999	.9998	.0998	BW	03-17	1550		77	43
99.9999	10.0000	1.0001	.0999	BW	03-17	2045		77	39
99.9998	10.0000	1.0000	.1000	BW	03-18	1100		77	39
100.0000	9.9999	.9999	.0999	BW	03-19	1800		76	42
100.0001	10.0000	1.0001	.1000	BW	03-20	1835		77	45
99.9999	10.0001	.9999	.0999	BW	03-21	2235		78	45
99.9998	9.9999	1.0000	.1000	BW	03-24	2205		78	42
99.9998	10.0000	1.0000	.1001	BW	03-25	1000		78	41
99.9997	10.0000	1.0001	.1000	BW	04-04	1300		78	49
99.9998	10.0000	1.0000	.0999	BW	04-05	1210		78	49
99.9997	10.0000	.9999	.0998	BW	04-05	2230		78	49
99.9999	10.0001	1.0000	.0998	BW	04-08	1135		78	47
99.9997	10.0000	1.0000	.0999	BW	04-08	1910		78	49
99.9997	9.9998	.9999	.1000	BW	04-09	2150		77	48
99.9999	10.0000	1.0000	.0999	BW	04-10	2205		78	48
100.0000	10.0001	.9999	.0999	BW	04-11	0940		76	49
99.9997	9.9998	1.0000	.0999	BW	04-11	1705		78	48
99.9999	9.9999	.9999	.0998	BW	04-11	2230		78	48
99.9999	10.0001	.9999	.0999	BW	04-12	0950		78	47
100.0000	9.9998	1.0000	.0999	BW	04-12	1810		78	48
100.0000	9.9999	.9999	.0998	BW	04-12	2205		78	47
100.0000	9.9999	.9999	.0999	BW	04-13	1720		78	48
99.9998	10.0000	1.0000	.0998	BW	04-13	2325		78	46
99.9999	10.0001	1.0001	.1000	BW	04-14	1740		78	44
99.9998	10.0000	1.0001	.0999	BW	04-16	1925		75	44
99.9997	9.9999	1.0000	.1000	BW	04-19	1350		78	41
100.0000	10.0001	.9998	.0999	BW	04-20	1210		75	41
99.9998	9.9998	1.0001	.0997	BW	05-16	1430		76	48
99.9999	9.9999	1.0000	.0999	BW	05-17	1600		75	48

BLANK PROCESSING DATA SHEET # 5

UNIT: F500 RUN: 3 DATE: 05-17-02

BLANKS DONE: 02-20-2002

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	McKESSON WATER PRODUCTS CO. CERTIFIED DISTILLED
FINAL WEIGHT	108.9015	106.3081	106.9664
TARE WEIGHT	108.9007	106.3064	106.9660
NET WEIGHT	.0008 ✓	.0017 ✓	.0004 ✓

TARE BEAKERS INTO DESC: TIME: 1205 DATE: 02-15-2002

DATE: 02-16 BY: M DATE: 02-17 BY: B DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9002	1849	(108.9007)	1611 ✓		
B	106.3068	1850	(106.3064)	1612 ✓		
C	106.9661	1851	(106.9660)	1613 ✓		

FINAL BEAKERS INTO DESC: TIME: 1125 DATE: 02-18-2002

DATE: 02-19 BY: B DATE: 02-20 BY: M DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9016	1027	(108.9015)	0917 ✓		
B	106.3084	1028	(106.3081)	0918 ✓		
C	106.9664	1029	(106.9664)	0919 ✓		

TARE QC

DATE	TIME	BY	WB	DB	%
02-16	1845	B	}	77	46
02-17	1555	B		77	47

FINAL QC

DATE	TIME	BY	WB	DB	%
02-19	1025	B	}	78	46
02-20	0915	B		75	42

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: F500 RUN: 3 DATE: 05-17-02

BLANK CALCULATIONS

Acetone : $\frac{.0008 \text{ g}}{200 \text{ ml}} = .000004 \text{ g/ml}$
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = .000023 \text{ g/ml}$
 Distilled Water : $\frac{.0004 \text{ g}}{200 \text{ ml}} = .000002 \text{ g/ml}$

FRONT HALF CATCH

FILTERS : $\frac{.0329 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ } (.0000 \text{ g})}{\text{\# of Filters Blank Value / Filter}} = .0329 \text{ g}$

BEAKERS : $\frac{.0115 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Acetone } (.000004 \text{ g})}{\text{Blank Value / ml Acetone}} = .0112 \text{ g}$

TOTAL FRONT HALF CATCH : .0441 g

BACK HALF CATCH

FILTERS : $\frac{.0087 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ } (.0000 \text{ g})}{\text{\# of Filters Blank Value / Filter}} = .0087 \text{ g}$

BEAKERS :
 Acetone : $\frac{.0366 \text{ g}}{\text{Total Catch}} - \frac{125 \text{ ml Acetone } (.000004 \text{ g})}{\text{Blank Value / ml Acetone}} = .0361 \text{ g}$

Extract : $\frac{.0076 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Dichloromethane } (.000023 \text{ g})}{\text{Blank Value / Dichloromethane}} = .0059 \text{ g}$

Water : $\frac{.0208 \text{ g}}{\text{Total Catch}} - \frac{315 \text{ ml Water } (.000002 \text{ g})}{\text{Blank Value / Water}} = .0202 \text{ g}$

TOTAL BACK HALF CATCH : .0709 g

TOTAL CATCH : .1150 g

% FRONT HALF : 38.3 %

CALCULATIONS DATA SHEET # 7

UNIT: F500 RUN: 3 DATE: 05-17-02

$$1) Vm (std) = \frac{(57.534 Vm) (17.64) (1.000 mcf) \left(30.17 \text{ " Hg} + \frac{.137 \text{ " H}_2\text{O}}{13.6} \right)}{(542 TmA)} = \frac{56.5125}{000.0000} \text{ dscf}$$

$$2) Vw (std) = (.04707) (108.9 \text{ ml H}_2\text{O}) = \frac{5.1259}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(5.1259 \text{ scf})}{(5.1259 \text{ scf} + \frac{56.5125}{61.6334} \text{ dscf})} = \frac{.0832}{.0000} \text{ Bws} \times 100 = \frac{83.161}{00.0000} \% \text{ H}_2\text{O}$$

$$4) Cs = \frac{(.1150 \text{ g.})}{(56.5125 \text{ dscf})} (15.43) = \frac{.0314}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(.1150 \text{ g.})}{(56.5125 \text{ dscf})} (9.481) (60) = \frac{1.1576}{00.0000} \text{ g / hr}$$

- Vm = total cubic feet pulled on meter box during test (000.000 Vm)
- mcf = meter correction factor (Y factor) of meter box used for test (0.000 mcf)
- " Hg = average barometric pressure during test (00.00 " Hg)
- " H₂O = average delta H for test (.000 " H₂O)
- TmA = average meter temperature for test in degrees Absolute (000 TmA)
- ml H₂O = total water caught during test (000.0 ml H₂O)
- g. = total particulate catch for test (00.0000 g.)
- dscfm = average stack flow during test (00.000 dscf)

TEST DATA SHEET # 8

UNIT: F500 RUN: 3 DATE: 05-17-02

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb

Pre: WB: 62 DB: 80 = 34 % RH 1.2 % H₂O

Post: WB: 70 DB: 88 = 40 % RH 1.8 % H₂O

Average: 37.0 % RH 1.50 % H₂O

Empty Stove Weight (lbs): _____ w/ stack & oil seal: Wet: _____ Dry: 0.0

Kindling Weight (lbs): Paper: .2 Wood: 4.4

Preburn Fuel Weight: 16.5 + 14.6 + 11.5 + 2.9 Total: 45.5

Kindling & Preburn Fuel Weight (wood only) (lbs): Total: 49.9

Coal Bed Wt Range (lbs): 4.1 - 3.3 Scale: 4.1 - 3.3

Upper: .25 x fuel weight: Always round DOWN to nearest tenth
 Lower: .20 x fuel weight: Always round UP to nearest tenth Actual Coal Bed Weight: 4.0

Maximum Coal Bed Removal (lbs): $((\frac{4.1}{\text{Upper}} + \frac{3.3}{\text{Lower}}) + 2) \cdot 25 = \frac{.9}{\text{round down to nearest tenth}}$

Test Fuel (.75" x 1.5" x 5" spacers) = 16 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	3	6.2	37.6
4" x 4"	17	2	10.3	62.4

Test Fuel Weight: 16.5 lbs

Estimated Dry Burn Rate:

$$\frac{16.5 - (16.5 \times .17777)}{2.2046} \times \frac{60}{195} = \underline{1.893} \text{ kg/hr}$$

$$\text{Estimated BTU's/hr: } 19,140 \times \frac{63}{100} \times \frac{\text{TIME } 1.893}{\text{DBR}} = \underline{22,832.1} \text{ BTU's/hr}$$

EPA Default Efficiencies: Non-cat: 63 Cat: 72 Pellet: 78

WOOD STOVE OPERATING DATA PAGE #9

Unit : F500 Run : 3 Date : 05-17-02

FIRE STARTED: 0720

WARM UP AND PREBURN:

PRIMARY AIR : Set wide open for all warm-up / preburn fuel charges. Then set to 3/8" at start of preburn.

SECONDARY AIR : N/A CAT BYPASS : N/A

CHARCOAL BED PREPARATION :

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 20 sec.

TEST:

DOOR wide open during loading 0 min. 40 sec.

PRIMARY AIR : Opened full for first 5 min., then set to run setting of TBA.

SECONDARY AIR : N/A CAT BYPASS : N/A

FAN:

ON / ~~OFF~~ during warm-up

~~ON~~ / OFF during preburn

ON / ~~OFF~~ first 30 minutes of test

~~ON~~ / OFF balance of test run

Fan speed set at Low

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER : N/A BRAND : N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 12 or 16 inches.

1st warm up / pre-burn fuel charge (16.5 lbs.) added at 0730

2nd warm up / pre-burn fuel charge (14.6 lbs.) added at 0850

3rd warm up / pre-burn fuel charge (11.5 lbs.) added at 0956

4th warm up / pre-burn fuel charge (2.9 lbs.) added at 1030

5th warm up / pre-burn fuel charge (_____ lbs.) added at _____

TEST DATA SHEET #10

Unit : F500 Run : 3 Date : 05-17 -02

Room Temperature : 70 °F Correction Factor : 0

Uncorrected Values are corrected for room temperature : Yes _____ No

Time Test Fuel moisture reading taken : 0930

Calibration Checks : X Y 12.0 12.1 22.0 22.1

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	12.5	13.3	11.5	12.2	11.5	12.2	12.567
2									
3									
4	2"x4"x8'	P	18.0	19.2	19.0	20.3	18.5	19.8	19.767
5	2"x4"x8'	P	19.0	20.3	19.0	20.3	19.0	20.3	20.300
6	2"x4"x8'	P	19.0	20.3	19.0	20.3	18.5	19.8	20.133
7	2"x4"x8'	P	20.0	21.4	19.0	20.3	19.0	20.3	20.667
8	2"x4"x8'	P							80.867
9									
10									
11	2x4x17	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200
12	"	T	20.5	22.0	21.0	22.5	20.5	22.0	22.167
13	"	T	23.5	25.2	23.5	25.2	23.5	25.2	25.200
14	4x4x17	T	18.5	19.8	19.0	20.3	19.0	20.3	20.133
15	"	T	20.0	21.4	20.0	21.4	20.0	21.4	21.400
16									108.100
17									
18									
19									
20	Spacers	T	18.0	19.2	18.0	19.2	18.5	19.8	19.400

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	12.567 %	20.217 %	21.620 %
Wet Moisture % :	11.164 %	16.817 %	17.777 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

WEIGHT: 4.0
UNIT: F500

GAS DATA SHEET # 12

RUN: 3 DATE: 05-17-02 PAGE: 1 of 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL.WB	STACK	STATIC	SO ₂ PPM
0	20.5	16.5	-	261	6.5	546	13.7	.090	.91					299	-047	350
5	19.7	15.7	.8	413	10.3	410	10.2	.041	.42					371	-056	300
10	19.0	15.0	.7	429	10.7	379	9.5	.046	.47					395	-060	350
15	18.0	14.0	1.0	493	12.3	339	8.5	.039	.40					442	-065	350
20	17.1	13.1	.9	518	12.9	323	8.1	.031	.32					460	-066	350
25	15.9	11.9	1.2	584	14.5	273	6.8	.034	.35					485	-066	350
30	14.8	10.8	1.1	603	15.0	256	6.4	.029	.30					506	-068	350
35	13.7	9.7	1.1	581	14.5	271	6.8	.022	.23					503	-067	350
40	12.8	8.8	.9	572	14.2	280	7.0	.022	.23					499	-067	350
45	12.1	8.1	.7	602	15.0	254	6.3	.019	.20					503	-067	350
50	11.3	7.3	.8	607	15.1	234	5.8	.047	.48					514	-069	350
55	10.4	6.4	.9	584	14.5	257	6.4	.013	.14					502	-068	350
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	5479	-766	*****
60	9.6	5.6	.8	527	13.1	304	7.6	.011	.12					479	-066	350
65	8.9	4.9	.7	450	11.2	364	9.1	.018	.19					452	-064	350
70	8.6	4.6	.3	417	10.4	383	9.6	.027	.28					429	-062	350
75	8.2	4.2	.4	406	10.1	393	9.8	.025	.26					409	-061	350
80	7.8	3.8	.4	400	9.9	399	10.0	.027	.28					398	-060	350
85	7.3	3.3	.5	412	10.2	394	9.8	.019	.20					394	-059	350
90	6.9	2.9	.4	429	10.7	366	9.1	.030	.31					399	-061	350
95	6.5	2.5	.4	360	9.0	443	11.1	.043	.44					379	-058	350
100	6.3	2.3	.2	284	7.1	491	12.3	.065	.66					350	-055	375
105	6.1	2.1	.2	281	7.0	498	12.5	.065	.66					328	-053	375
110	5.9	1.9	.2	282	7.0	498	12.5	.073	.74					313	-051	375
115	5.8	1.8	.1	272	6.8	513	12.8	.077	.78					304	-050	375
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	4634	-700	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	10113	-1460	*****

HEIGHT: 4.0

UNIT: F500

GAS DATA SHEET # 12

RUN: 3 DATE: 05-17-02 PAGE: 2 of 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL WB	STACK	STATIC	SO ₂ PPM	
120	5.6	1.6	.2	.272	6.8	.510	12.8	.090	.91							293	.048	375	
125	5.4	1.4	.2	.272	6.8	.511	12.8	.088	.89							286	.047	375	
130	5.3	1.3	.1	.277	6.9	.508	12.7	.091	.92							283	.046	375	
135	5.2	1.2	.1	.273	6.8	.509	12.7	.092	.93							279	.046	375	
140	5.1	1.1	.1	.276	6.9	.516	12.9	.099	1.00							276	.046	375	
145	4.9	.9	.2	.264	6.6	.520	13.0	.099	1.00							274	.045	375	
150	4.7	.7	.2	.256	6.4	.526	13.2	.113	1.14							272	.043	400	
155	4.6	.6	.1	.258	6.4	.536	13.4	.115	1.16							267	.042	400	
160	4.6	.6	.0	.241	6.0	.542	13.6	.118	1.19							264	.042	400	
165	4.4	.4	.2	.229	5.7	.557	13.9	.126	1.27							261	.041	400	
170	4.4	.4	.0	.236	5.9	.552	13.8	.128	1.29							258	.041	400	
175	4.3	.3	.1	.237	5.9	.549	13.7	.128	1.29							257	.040	400	
TOTAL	*****	****	****	****	****	****	****	****	****	****	****	****	****	****	****	3270	.527	*****	
180	4.3	.3	.0	.237	5.9	.550	13.8	.134	1.35							255	.041	400	
185	4.1	.1	.2	.229	5.7	.553	13.8	.142	1.43							254	.040	400	
190	4.1	.1	.0	.225	5.6	.564	14.1	.129	1.30							249	.038	400	
195	4.0	.0	.1	.218	5.4	.570	14.3	.130	1.31							247	.038	400	
200																			
205																1005	-157		
210																			
215																			
220																			
225																			
230																			
235																			>.40
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	14388	-2.150	*****	
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	360	-0.054	*****	

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 05-17-2002 Analyte : CO₂ (15-1)
 Unit : F500 Run # : 3
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO₂ Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC12767 Conc. : 12.49 % CO₂ Cyl. Press. : 1420 PSI
 Certified by : AIR LIQUIDE Date : 02-15-02
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 407069
 Range : 0 - 25.0 % CO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 25.0 % CO₂
 EPA Control Limits = ± 2.5% of 25.0 % CO₂ = ± 0.625 % CO₂
 Method 28 A = ± .2 % of 25.0 % CO₂ = ± .05 % CO₂

PRE RUN Audit : by : D. Wadsworth Time : 1045 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.2	.002	.028	+ .028	+ .112
SPAN	50.0	.500	12.49	50.2	.502	12.491	+ .001	+ .006

POST RUN Audit : by : D. Wadsworth Time : 1520 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	.003	+ .003	+ .013
SPAN	50.0	.500	12.49	50.2	.502	12.491	+ .001	+ .006

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05-17-2002

Analyte : O₂ (15-2)

Unit : F500

Run # : 3

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂

Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 12.50 % O₂

Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : TELEDYNE Model : 320 A

SN : 37400

Range : 0 - 25.0 % O₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % O₂

EPA Control Limits = ± 2.5% of 25.0 % O₂ = ± 0.625 % O₂

Method 28 A = ± .2 % of 25.0 % O₂ = ± .05 % O₂

PRE RUN Audit : by : J. Washington Time : 1045 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	-0.040	-0.040	-1.58
SPAN	12.50	.500	12.50	12.50	.501	12.538	+0.038	+1.54

POST RUN Audit : by : J. Washington Time : 1520 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.003	.011	+0.011	+0.43
SPAN	12.50	.500	12.50	12.50	.500	12.513	+0.013	+0.53

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date : 05-17-2002

Analyte : CO (15-3)

Unit : F500

Run # : 3

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO

Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 4.80 % CO

Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 408005

Range : 0 - 10.0 % CO

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 10.0 % CO

EPA Control Limits = ± 2.5% of 10.0 % CO = ± 0.25 % CO

Method 28 A = ± .2 % of 10.0 % CO = ± .02 % CO

PRE RUN Audit : by : D. Wadlington Time : 1045 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.014	+ .014	+ .141
SPAN	48.0	.480	4.80	48.1	.481	4.803	+ .003	+ .034

POST RUN Audit : by : D. Wadlington Time : 1520 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.004	+ .004	+ .041
SPAN	48.0	.480	4.80	48.1	.481	4.803	+ .003	+ .034

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05-17-2002 Analyte : SO₂ (15-4)
 Unit : F500 Run # : 3
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC62184 Conc. : 1290 ppm SO₂ Cyl. Press. : 1350 PSI
 Certified by : AIR LIQUIDE Date : 01-29-01
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 403019
 Range : 0 - 2500 ppm SO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = ± 2.5% of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : D. Wadsworth Time : 1110 Temp : 76 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	8.385	+8.385	+1.335
SPAN	51.6	.516	1290	51.6	.516	1292.236	+2.236	+0.089

POST RUN Audit : by : D. Wadsworth Time : 1520 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	3.399	+3.399	+1.136
SPAN	51.6	.516	1290	51.5	.515	1289.743	-2.257	-0.100

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : F500 RUN : 3 DATE : 05-17-02

Thermocouple Check:

T/C # 1	<u> </u>	°F	T/C # 13	<u>64.8</u>	°F
T/C # 2	<u> </u>	°F	T/C # 14	<u>62.3</u>	°F
T/C # 3	<u>64.2</u>	°F	T/C # 15	<u>65.4</u>	°F
T/C # 4	<u>61.1</u>	°F	T/C # 16	<u>60.2</u>	°F
T/C # 5	<u>59.0</u>	°F	T/C # 17	<u>59.8</u>	°F
T/C # 6	<u>60.1</u>	°F	T/C # 18	<u>68.3</u>	°F
T/C # 7	<u>60.7</u>	°F	T/C # 19	<u>62.2</u>	°F
T/C # 8	<u>60.1</u>	°F	T/C # 20	<u>41.2</u>	°F
T/C # 9	<u>60.3</u>	°F	T/C # 21	<u> </u>	°F
T/C # 10	<u>61.4</u>	°F	T/C # 22	<u> </u>	°F
T/C # 11	<u>57.6</u>	°F	T/C # 23	<u>62.7</u>	°F
T/C # 12	<u>71.2</u>	°F	T/C # 24	<u> </u>	°F

Thermocouple Readout:

Pretest zero and span check and calibration

ZERO : 2.0 °F Adj. to 0.0 °F
 SPAN : 2001.0 °F Adj. to 2000.0 °F

post test zero and span

% difference

ZERO 2.1 °F Adj. to .105 %
 SPAN 2004.9 °F Adj. to .245 %

Thermocouple Readout Pretest Linearity Check:

0 = <u>0.0</u> °F	200 = <u>201.6</u> °F	400 = <u>399.0</u> °F
600 = <u>601.3</u> °F	800 = <u>801.3</u> °F	1000 = <u>1000.6</u> °F
1200 = <u>1198.2</u> °F	1400 = <u>1399.2</u> °F	1600 = <u>1599.7</u> °F
1800 = <u>1800.1</u> °F	2000 = <u>2000.0</u> °F	


Sample Train Leak Check
 C-gas Train Leak Check
 SO₂ Train Leak Check
 Static Gauge Zero Check

Pre ✓
 Pre ✓
 Pre ✓
 Pre X

Post ✓
 Post ✓
 Post ✓
 Post ✓

Scale Check Pre : 15.7 - 5.7
 Post : 13.8 - 3.8

Stack Cleaned Prior to Test Run : YES NO X



COMPUTER INPUT DATA SHEET #1

Client: JOTUL U.S.A., INC.

Address: 400 RIVERSIDE ST., P.O. BOX 1157
PORTLAND, MAINE 04104

Phone: (207) 797-5912 Fax: (207) 772-0523

Run No.: 2 Date of Test: 05-16-2002 Burn Rate: 2.877

Model No.: F500 min min-1.25 ~~fan~~

Stove Type: Cat Non Cat Pellet 1.25-1.9 max ~~insert~~

Dry Gas Meter Y Factor: 1.000 • Post Leak Rate: .014 cfm Time: 135 min.
(0.000) (Data Sheet #2) (.000) (Data Sheet #2) (000) (Data Sheet #2)

Dry Gas Meter Volume: 35.765 cf
(00.000) (Data Sheet #2)

Stack Flow: 11.485 dscfm Δ H: .106 in. H₂O
(00.000) (Data Sheet #2) (0.000) (Data Sheet #2)

Maximum Vac.: 2.0 • Barometric Pressure: 30.05 in. Hg
(0.0) (Data Sheet #2) (00.00) (Data Sheet #2)

H₂O Captured: 71.6 g
(00.0) (Data Sheet #3)

Front Half Catch % Of Total: 37.6 % Total Particulate Catch: .1403 g
(00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)

Flue Gas Moisture: 8.9338 %
(00.000) (Data Sheet #7)

Particulate Emission: .0630 gr/dscf
(0.0000) (Data Sheet #7)

Relative Humidity: 25.5 % RH Ambient Moisture: 1.15 % H₂O
(00.0) (Data Sheet #8) (0.00) (Data Sheet #8)

Pretest Fuel Wt.: 48.4 lbs. Coal Bed Wt.: 4.1 lbs. Test Fuel Wt.: 17.2 lbs.
(00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)

Heat Output (EPA Default): 34,690.8 BTU/hr
(00,000.0) (Data Sheet #8)

Kindling Fuel % Moisture (wet): 11.583 % Pretest Fuel % Moisture (wet): 17.460 %
(00.000) (Data Sheet #10) (00.000) (Data Sheet #10)

Test Fuel % Moisture (dry): 20.527 % Test Fuel % Moisture (wet): 17.031 %
(00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])

Fuel Higher Heating Value (dry): — BTU/lb.
(0000) (Data Sheet #11)

Stack Static Pressure: -.061 in. H₂O
(+/- .000) (Data Sheet #12)

Average Ambient Temperature: 79 °F Stove Temperature Change: -41.0 °F
(00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul U.S.A., Inc.

TEST No. : 2

MODEL: F500

DATE: 16-May-02

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
=====	=====	=====	=====	=====	=====	=====
0	558.000	0.150	90	0.62	7.50	250
5	559.500	0.090	90	0.61	14.70	325
10	560.696	0.090	90	0.27	15.50	325
15	561.892	0.090	90	0.34	16.90	325
20	563.088	0.090	90	0.44	17.50	325
25	564.285	0.100	90	0.31	16.20	300
30	565.580	0.090	90	0.44	14.90	325
35	566.776	0.100	90	0.42	15.30	300
40	568.072	0.120	91	0.25	14.20	275
45	569.491	0.120	92	0.13	12.70	275
50	570.915	0.120	92	0.37	8.10	275
55	572.338	0.090	92	1.00	6.90	325
60	573.543	0.090	93	1.24	6.60	325
65	574.754	0.090	93	1.17	6.90	325
70	575.965	0.120	93	0.80	7.60	275
75	577.396	0.120	93	0.46	7.90	275
80	578.827	0.120	93	0.23	8.90	275
85	580.257	0.120	93	0.24	9.10	275
90	581.688	0.150	93	0.56	7.80	250
95	583.262	0.100	93	0.64	7.60	300
100	584.573	0.100	93	1.00	6.80	300
105	585.885	0.100	93	1.10	6.50	300
110	587.197	0.100	93	1.22	6.40	300
115	588.508	0.100	93	0.84	6.70	300
120	589.820	0.100	93	0.96	6.40	300
125	591.132	0.100	94	1.06	6.10	300
130	592.448	0.100	94	1.13	6.10	300
135	593.765	0.100	94	1.16	6.00	300
140						

TABLE 2---RAW DATA

CLIENT :	Jotul U.S.A., Inc.	TEST No.	2
MODEL:	F500	DATE:	16-May-02

METER CAL.		Wt. WOOD	
FACTOR (Y) -----	1	BURNED (LB) -----	17.2 Lbs
BAROMETRIC		WET, FUEL	
PRESS. (Pb) -----	30.05 in Hg	MOISTURE % -----	17.031 %
LEAK RATE		Wt. PART.	
POST (Lp) -----	0.014 cfm	COLLECTED -----	0.1403 g
WATER		METER	
VOL. (V1c) -----	71.6 ML	VOLUME Vm -----	35.765 mcf
TEST		HC MOLE	
TIME (MIN) -----	135 min	FRACTION -----	0.0132

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul U.S.A., Inc.

TEST No. 2

MODEL: F500

DATE: 16-May-02

AVG DELTA		AVG PRCNT		
H	----- 0.11 in H2O	CO	----- 0.68	%
AVG METER		AVG PRCNT		
TEMP. Tm	----- 92 deg F	CO2	----- 9.78	%
AVG PPM		AVG BAL		
SO2	----- 297 PPM	CO2/CO	----- 14.40	%

TABLE 4 ----- CALCULATIONS

CLIENT : Jotul U.S.A., Inc.

TEST No. 2

MODEL: F500

DATE: 16-May-02

STD SAMPLE		STACK GAS		
VOL. Vm(std) -----	34.37 dscf	FLOW Qsd -----	879.919	dscf/Hr
				&
			14.67	dscf/min
VOL. WATER		PARTICULATE		
VAPOR Vw(std) -----	3.370 scf	CONCTR. Cs -----	0.0041	g/dscf
PRCNT		PARTC.EMISS.		
MSTR Bws -----	8.93 %	RATE E -----	3.59	g/Hr
BURN		MOLES OF GAS		
RATE BR -----	2.88 Kg/Hr	PER Lb WOOD Nt --	0.36	Lb-mole/Lb
CO EMISSION		PART.EMISS.		
RATE -----	200.06 g/Hr	RATE -----	1.25	g/Kgdry
	&			fuel
	69.54 g/Kgdry			
	fuel			

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul U.S.A., Inc.

TEST No. : 2

MODEL: F500

DATE: 16-May-02

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	361.8	96	100
10	374.9	100	
15	374.9	100	
20	374.9	100	
25	375.2	100	
30	374.7	100	
35	374.9	100	
40	374.7	100	
45	375.4	100	
50	376.4	100	
55	376.1	100	
60	376.0	100	
65	377.6	100	
70	377.6	100	
75	377.5	100	
80	377.5	100	
85	377.3	100	
90	377.5	100	
95	377.5	100	
100	377.3	100	
105	377.6	100	
110	377.6	100	
115	377.3	100	
120	377.6	100	
125	377.3	100	
130	378.1	101	
135	378.3	101	
140			
145			

METER BOX DATA SHEET PAGE # 2

Page: 1 of 2

UNIT: F500 RUN: 2 DATE: 05-16-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .009 cfm _____ " Hg @ _____ cfm
15 " Hg @ .014 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.14</u>			SAMPLING RATIO: <u>45</u> : 1				BP: <u>30.08</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
0	1120	558.000	—	13.640	.15	90	250	90	2.0	
5	25	559.500	—	10.493	.09	90	325	90	2.0	
10	30	560.696	560.696	10.493	.09	90	325	90	2.0	
15	35	561.892	561.892	10.493	.09	90	325	90	2.0	
20	40	563.088	563.088	10.493	.09	90	325	90	2.0	
25	45	564.285	564.285	11.367	.16	90	300	90	2.0	
30	50	565.580	565.580	10.493	.09	90	325	90	2.0	
35	55	566.774	566.776	11.367	.10	90	300	90	2.0	
40	1200	568.072	568.072	12.378	.12	91	275	91	2.0	
45	05	569.491	569.491	12.355	.12	92	275	92	2.0	
50	10	570.915	570.915	12.355	.12	92	275	92	2.0	
55	15	572.338	572.338	10.455	.09	92	325	92	2.0	
ROTO PRESS: <u>.14</u>			TOTALS:		136.382	1.25	1087	BP: <u>30.04</u>		
60	1220	573.543	573.543	10.422	.09	93	325	93	2.0	
65	25	574.754	574.754	10.422	.09	93	325	93	2.0	
70	30	575.965	575.965	12.317	.12	93	275	93	2.0	
75	35	577.396	577.396	12.317	.12	93	275	93	2.0	
80	40	578.827	578.827	12.317	.12	93	275	93	2.0	
85	45	580.257	580.257	12.317	.12	93	275	93	2.0	
90	50	581.688	581.688	13.548	.15	93	250	93	2.0	
95	55	583.262	583.262	11.290	.10	93	300	93	2.0	
100	1300	584.573	584.573	11.290	.10	93	300	93	2.0	
105	05	585.885	585.885	11.290	.10	93	300	93	2.0	
110	10	587.197	587.197	11.290	.10	93	300	93	2.0	
115	15	588.508	588.508	11.290	.10	93	300	93	2.0	
			TOTALS:		140.110	1.310	1116	MAX VACC =		
TOTAL Cu Ft.			TOTALS:		276.492	2.56	2203	AVG. BP:		

METER BOX DATA SHEET PAGE # 2

Page: 2 of 2

UNIT: F500 RUN: 2 DATE: 05-16-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .009 cfm _____ " Hg @ _____ cfm

15 " Hg @ .1014 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>14</u>		SAMPLING RATIO: <u>45</u>				: 1		BP: <u>30.04</u>	
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
120	1320	589,820	589,820	11,290	.10	93	300	93	2.0
125	25	591,132	591,132	11,270	.10	94	300	94	2.0
130	30	592,448	592,448	11,270	.10	94	300	94	2.0
135	35	593,763	593,765	11,270	.10	94	300	94	2.0
140									
145				45,100	.40	375			
150									
155									
160									
165									
170									
175									
ROTO PRESS:			TOTALS:			BP.:			
180									
185									
190									
195									
200									
205									
210									
215									
220									
225						2578			
230								28	
235				321,592	2.96	92			
			TOTALS:			MAX VACC =		2.0	
TOTAL Cu Ft.		<u>35,765</u>	TOTALS:		<u>11,485</u>	<u>.106</u>	<u>552</u>	AVG. BP: <u>30.05</u>	

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT: F500 RUN: 2 DATE: 05-16-02

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	672.9	603.6	485.8	894.5
INITIAL WT	613.7	601.0	484.3	886.2
NET WT GRAMS	59.2	2.6	1.5	8.3

TOTAL CATCH: 71.6 GRAMS H₂O

FRONT HALF

FILTER #	118F	
FINAL WT g	.7042	.
INITIAL WT g	.6718	.
NET WT g	.0324	.

BEAKER #	51
DESC.	ACETONE
FINAL WT g	104.8993
INITIAL WT g	104.8784
NET WT g	.0209
VOL. DESC. ml	125

BACK HALF

FILTER #	118B	
FINAL WT g	.4387	.
INITIAL WT g	.4294	.
NET WT g	.0093	.

BEAKER #	52	53	54	55	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	107.5540	105.7488	107.3230	93.5070	
INITIAL WT g	107.5027	105.7410	107.3139	93.4941	
NET WT g	.0513	.0078	.0091	.0129	.0220
VOL. DESC ml	150	75	125	145	(290)

FILTER TARE WEIGHTS DATA SHEET #4-1

Into Dessicator : _____ Date : 01/29/02 Time : 1125 By : DKW
 Manufacturer S & S Grade : #25 Glass Front Size : 11 cm Lot No. : ZB921
 Back Size : 8.2 cm Lot No. : ZB911

DATE: <u>02-07</u>			DATE: <u>02-10</u>			DATE: _____	
FILTER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME	BY: _____
111F	.6782	0934	<u>.6780</u>	1939	JOTUL C450		R-2
112F	.6755	0935	<u>.6751</u>	1940	" "		R-3
113F	.6721	0935	<u>.6719</u>	1941	" "		R-4
114F	.6843	0936	<u>.6844</u>	1942	" "		R-5
115F	.6699	0937	<u>.6700</u>	1943	" "		R-6
116F	.6696	0938	<u>.6694</u>	1943	" "		R-7
117F	.6796	0939	<u>.6793</u>	1944	JOTUL F500		R-1
118F	.6715	0940	<u>.6718</u>	1945	" "		R-2
119F	.6743	0941	<u>.6746</u>	1946	" "		R-3
120F	.6844	0942	<u>.6843</u>	1947	" "		R-4

111B	.4462	0943	<u>.4464</u>	1948	JOTUL C450		R-2
112B	.4448	0944	<u>.4451</u>	1949	" "		R-3
113B	.4466	0945	<u>.4464</u>	1949	" "		R-4
114B	.4305	0946	<u>.4307</u>	1950	" "		R-5
115B	.4234	0947	<u>.4236</u>	1951	" "		R-6
116B	.4444	0948	<u>.4445</u>	1952	" "		R-7
117B	.4431	0949	<u>.4430</u>	1953	JOTUL F500		R-1
118B	.4293	0950	<u>.4294</u>	1954	" "		R-2
119B	.4441	0951	<u>.4439</u>	1955	" "		R-3
120B	.4427	0952	<u>.4425</u>	1955	" "		R-4

Checked by: C Washington Date: 2-10-02 Time: 2000

BALANCE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	WB	DB	% RH
02-07	0910	DKW		74	47
02-10	1905	DKW		74	45

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: F500

RUN: 2 DATE: 05-16-02

Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
S1	05-17	1125	BW	104.8996	05-18	1915	BW	104.8993	05-19	1510	BW				
S2	05-18	1930	BW	107.5556	05-20	0901	BW	107.5537	05-21	0935	BW	107.5540	05-22	1159	BW
S3	05-17	1125	BW	105.7485	05-18	1916	BW	105.7488	05-19	1511	BW				
S4	05-17	1125	BW	107.3226	05-18	1917	BW	107.3230	05-19	1512	BW				
S5	05-17	1125	BW	93.5067	05-18	1918	BW	93.5070	05-19	1513	BW				

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
118F	5-16	1400	CP	.7043	05-17	1604	BW	.7042	05-18	1919	BW				
118B	5-16	1400	CP	.4385	05-17	1605	BW	.4387	05-18	1920	BW				

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	05-17	1600	BW	75	48
2	05-18	1905	BW	77	49
3	05-19	1500	BW	77	48
4	05-20	0855	BW	77	47
5	05-21	0930	BW	78	49

Weighing Session	Date	Time	By	DB	%RH
6	05-22	1155	BW	78	48
7					
8					
9					
10					

Dates: From 11-20-2001
Through 02-16-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius
Model: A1205
SN: 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	Wet Bulb	%RH
99.9998	10.0002	1.0003	.1000	DKW	11-20	0945	78		48
100.0000	10.0000	1.0001	.0999	DKW	11-21	1000	75		49
99.9998	9.9998	1.0000	.1001	DKW	11-22	1050	75		49
100.0003	9.9999	1.0000	.0999	DKW	11-26	1150	74		47
100.0001	9.9997	1.0000	.1000	DKW	11-27	1155	74		48
100.0001	10.0000	.9997	.0999	DKW	11-28	1220	72		48
99.9999	10.0000	1.0000	.1000	DKW	11-28	1930	73		48
99.9998	10.0000	.9999	.0999	DKW	11-29	1015	75		46
99.9998	10.0000	.9997	.0998	DKW	11-29	1925	73		46
100.0000	10.0001	.9998	.0999	DKW	11-30	1355	74		45
99.9999	9.9999	1.0000	.1000	DKW	12-01	1210	77		45
100.0003	10.0000	.9997	.1000	DKW	01-08	2045	78		47
100.0001	10.0000	.9998	.1000	DKW	01-09	1600	78		48
99.9999	9.9999	.9999	.1000	DKW	01-12	1900	74		46
99.9998	9.9999	.9997	.1000	DKW	01-13	1730	72		43
100.0000	10.0001	1.0000	.1001	DKW	01-14	1355	78		45
99.9998	9.9999	.9999	.1000	DKW	01-26	1745	72		47
99.9998	10.0000	1.0000	.0999	DKW	01-28	1705	74		44
100.0003	10.0000	1.0000	.0998	DKW	01-29	1130	70		47
99.9998	9.9997	1.0000	.1000	DKW	01-29	2300	71		44
100.0002	10.0000	1.0000	.1000	DKW	01-30	2200	75		45
99.9999	9.9999	.9999	.1000	DKW	01-31	2205	74		47
100.0001	9.9999	1.0000	.1000	DKW	02-02	0700	75		45
100.0002	9.9999	1.0001	.1000	DKW	02-04	1045	73		47
100.0000	10.0000	.9998	.0997	DKW	02-06	0905	73		47
100.0001	10.0000	1.0000	.1000	DKW	02-07	0910	74		47
100.0002	10.0001	1.0000	.0999	DKW	02-07	1235	77		48
99.9999	10.0000	.9999	.0998	DKW	02-08	1110	72		49
99.9998	9.9999	1.0000	.0999	DKW	02-09	1045	70		49
99.9997	10.0000	.9999	.0999	DKW	02-10	0920	74		48
99.9997	10.0001	.9999	.0999	DKW	02-10	1905	76		45
99.9999	9.9999	1.0000	.0997	DKW	02-11	1935	73		43
99.9998	9.9997	1.0000	.0999	DKW	02-13	1740	75		41
99.9997	10.0000	.9999	.1000	DKW	02-14	1015	74		38
99.9998	9.9999	1.0000	.1000	DKW	02-14	2010	74		43
100.0000	10.0000	1.0000	.1000	DKW	02-15	1150	74		41
99.9998	9.9999	.9999	.1000	DKW	02-16	1045	78		41

♡

Dates: From 02-16-2002
Through 05-17-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius
Model: A1205
SN : 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Wet Bulb	Dry Bulb	% RH
100.0000	9.9999	1.0000	.0999	BW	02-16	1845		77	46
100.0000	9.9999	.9999	.0998	BW	02-17	1555		77	47
100.0001	9.9999	.9999	.0997	BW	02-18	0940		77	47
100.0000	10.0000	.9999	.1000	BW	02-19	1025		78	46
100.0000	9.9999	1.0000	.0999	BW	02-20	0915		75	42
100.0003	10.0000	1.0000	.0999	BW	03-14	1020		78	45
99.9999	9.9998	.9998	.0998	BW	03-15	1725		77	45
99.9999	10.0000	1.0002	.0999	BW	03-16	1820		77	38
100.0001	9.9999	1.0001	.1000	BW	03-16	2130		78	43
99.9999	9.9999	.9998	.0998	BW	03-17	1550		77	43
99.9999	10.0000	1.0001	.0999	BW	03-17	2045		77	39
99.9998	10.0000	1.0000	.1000	BW	03-18	1100		77	39
100.0000	9.9999	.9999	.0999	BW	03-19	1800		76	42
100.0001	10.0000	1.0001	.1000	BW	03-20	1835		77	45
99.9999	10.0001	.9999	.0999	BW	03-21	2235		78	45
99.9998	9.9999	1.0000	.1000	BW	03-24	2205		78	42
99.9998	10.0000	1.0000	.1001	BW	03-25	1000		78	41
99.9997	10.0000	1.0001	.1000	BW	04-04	1300		78	49
99.9998	10.0000	1.0000	.0999	BW	04-05	1210		78	49
99.9997	10.0000	.9999	.0998	BW	04-05	2230		78	49
99.9999	10.0001	1.0000	.0998	BW	04-08	1135		78	47
99.9997	10.0000	1.0000	.0999	BW	04-08	1910		78	48
99.9997	9.9998	.9999	.1000	BW	04-09	2150		77	48
99.9999	10.0000	1.0000	.0999	BW	04-10	2205		78	48
100.0000	10.0001	.9999	.0999	BW	04-11	0940		76	49
99.9997	9.9998	1.0000	.0999	BW	04-11	1705		78	48
99.9999	9.9999	.9999	.0998	BW	04-11	2230		78	48
99.9999	10.0001	.9999	.0999	BW	04-12	0950		78	47
100.0000	9.9998	1.0000	.0999	BW	04-12	1810		78	48
100.0000	9.9999	.9999	.0998	BW	04-12	2205		78	47
100.0000	9.9999	.9999	.0999	BW	04-13	1720		78	48
99.9998	10.0000	1.0000	.0998	BW	04-13	2325		78	46
99.9999	10.0001	1.0001	.1000	BW	04-14	1740		78	44
99.9998	10.0000	1.0001	.0999	BW	04-16	1925		75	44
99.9997	9.9999	1.0000	.1000	BW	04-19	1350		78	41
100.0000	10.0001	.9998	.0999	BW	04-20	1210		75	41
99.9998	9.9998	1.0001	.0997	BW	05-16	1430		76	48
99.9999	9.9999	1.0000	.0999	BW	05-17	1600		75	48



BLANK PROCESSING DATA SHEET # 5

UNIT: F500 RUN: 2 DATE: 05-16-02

BLANKS DONE: 02-20-2002

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	McKESSON WATER PRODUCTS CO. CERTIFIED DISTILLED
FINAL WEIGHT	108.9015	106.3081	106.9664
TARE WEIGHT	108.9007	106.3064	106.9660
NET WEIGHT	.0008 ✓	.0017 ✓	.0004 ✓

TARE BEAKERS INTO DESC: TIME: 1205 DATE: 02-15-2002

DATE: 02-16 BY: ML DATE: 02-17 BY: ML DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9002	1849	108.9007	1611 ✓		
B	106.3068	1850	106.3064	1612 ✓		
C	106.9661	1851	106.9660	1613 ✓		

FINAL BEAKERS INTO DESC: TIME: 1125 DATE: 02-18-2002

DATE: 02-19 BY: ML DATE: 02-20 BY: ML DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9016	1027	108.9015	0917 ✓		
B	106.3084	1028	106.3081	0918 ✓		
C	106.9664	1029	106.9664	0919 ✓		

TARE QC

DATE	TIME	BY	WB	DB	%
02-16	1845	ML	}	77	46
02-17	1555	ML		77	47

FINAL QC

DATE	TIME	BY	WB	DB	%
02-19	1025	ML	}	78	46
02-20	0915	ML		75	42

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: F500 RUN: 2 DATE: 05-16-02

BLANK CALCULATIONS

Acetone : $\frac{.0008 \text{ g}}{200 \text{ ml}} = .000004 \text{ g/ml}$
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = .000023 \text{ g/ml}$
 Distilled Water : $\frac{.0004 \text{ g}}{200 \text{ ml}} = .000002 \text{ g/ml}$

FRONT HALF CATCH

FILTERS : $\frac{.0324 \text{ g}}{\text{Total Catch}} - \frac{1}{\text{\# of Filters}} \left(\frac{.0000 \text{ g}}{\text{Blank Value / Filter}} \right) = .0324 \text{ g}$

BEAKERS : $\frac{.0209 \text{ g}}{\text{Total Catch}} - \frac{125 \text{ ml Acetone}}{\text{ml Acetone}} \left(\frac{.000004 \text{ g}}{\text{Blank Value / ml Acetone}} \right) = .0204 \text{ g}$

TOTAL FRONT HALF CATCH : .0528 g

BACK HALF CATCH

FILTERS : $\frac{.0093 \text{ g}}{\text{Total Catch}} - \frac{1}{\text{\# of Filters}} \left(\frac{.0000 \text{ g}}{\text{Blank Value / Filter}} \right) = .0093 \text{ g}$

BEAKERS :
 Acetone : $\frac{.0513 \text{ g}}{\text{Total Catch}} - \frac{150 \text{ ml Acetone}}{\text{ml Acetone}} \left(\frac{.000004 \text{ g}}{\text{Blank Value / ml Acetone}} \right) = .0507 \text{ g}$

Extract : $\frac{.0078 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Dichloromethane}}{\text{ml Dichloromethane}} \left(\frac{.000023 \text{ g}}{\text{Blank Value / Dichloromethane}} \right) = .0061 \text{ g}$

Water : $\frac{.0220 \text{ g}}{\text{Total Catch}} - \frac{290 \text{ ml Water}}{\text{ml Water}} \left(\frac{.000002 \text{ g}}{\text{Blank Value / Water}} \right) = .0214 \text{ g}$

TOTAL BACK HALF CATCH : .0875 g

TOTAL CATCH : .1403 g

% FRONT HALF : 37.6 %

CALCULATIONS DATA SHEET # 7

UNIT: F500 RUN: 2 DATE: 05-16-02

$$1) Vm (std) = \frac{(35.765 Vm) (17.64) (1,000 mcf) \left(30.05'' Hg + \frac{.106'' H_2O}{13.6} \right)}{(552 TmA)} = \frac{34,3538}{000.0000} \text{ dscf}$$

$$2) Vw (std) = (.04707) (71.4 \text{ ml H}_2\text{O}) = \frac{3.3702}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(33702 \text{ scf})}{(33702 \text{ scf} + 343538 \text{ dscf})} = \frac{.0893}{.0000} \text{ Bws} \times 100 = \frac{8.9338}{00.0000} \% H_2O$$

$$4) Cs = \frac{(.1403 \text{ g.})}{(34.3538 \text{ dscf})} (15.43) = \frac{.0630}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(.1403 \text{ g.})}{(34.3538 \text{ dscf})} (11.485 \text{ dscfm}) (60) = \frac{2.8143}{00.0000} \text{ g / hr}$$

Vm =	total cubic feet pulled on meter box during test	(000.000 Vm)
mcf =	meter correction factor (Y factor) of meter box used for test	(0.000 mcf)
" Hg =	average barometric pressure during test	(00.00 " Hg)
" H ₂ O =	average delta H for test	(.000 " H ₂ O)
TmA =	average meter temperature for test in degrees Absolute	(000 TmA)
ml H ₂ O =	total water caught during test	(000.0 ml H ₂ O)
g. =	total particulate catch for test	(00.0000 g.)
dscfm =	average stack flow during test	(00.000 dscf)

TEST DATA SHEET # 8

UNIT: F500 RUN: 2 DATE: 05-16-02

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb

Pre: WB: 62 DB: 85 = 26 % RH 1.0 % H₂O

Post: WB: 64 DB: 88 = 25 % RH 1.3 % H₂O

Average: 25.5 % RH 1.15 % H₂O

Empty Stove Weight (lbs): _____ w/ stack & oil seal: Wet: — Dry: 0.0

Kindling Weight (lbs): Paper: .2 Wood: 5.2

Preburn Fuel Weight: 14.3 + 14.0 + 14.9 Total: 43.2

Kindling & Preburn Fuel Weight (wood only) (lbs): Total: 48.4

Coal Bed Wt Range (lbs): 4.3 - 3.5 Scale: 4.3 - 3.5

Upper: .25 x fuel weight: Always round DOWN to nearest tenth
 Lower: .20 x fuel weight: Always round UP to nearest tenth Actual Coal Bed Weight: 4.1

Maximum Coal Bed Removal (lbs): $((\frac{4.3}{\text{Upper}} + \frac{3.5}{\text{Lower}}) + 2) \cdot .25 = \frac{.9}{\text{round down to nearest tenth}}$

Test Fuel (.75" x 1.5" x 5" spacers) = 16 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	3	7.0	40.7
4" x 4"	17	2	10.2	59.3

Test Fuel Weight: 17.2 lbs

Estimated Dry Burn Rate:

$$\frac{17.2 - (17.2 \times .17031)}{2.2046} \times \frac{60}{135} = \underline{2.877} \text{ kg/hr}$$

$$\text{Estimated BTU's/hr: } 19,140 \times \frac{63}{100} \times \frac{\text{TIME}}{\text{DBR}} = \underline{34,690.8} \text{ BTU's/hr}$$

EPA Default Efficiencies: Non-cat: 63 Cat: 72 Pellet: 78

WOOD STOVE OPERATING DATA PAGE #9

Unit : F500 Run : 2 Date : 05-16-02

FIRE STARTED: 0730

WARM UP AND PREBURN:

PRIMARY AIR : Set wide open for all warm-up / preburn fuel charges. Then set to wide open at start of preburn.

SECONDARY AIR : N/A CAT BYPASS : N/A

CHARCOAL BED PREPARATION :

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 25 sec.

TEST:

DOOR wide open during loading 0 min. 40 sec.

PRIMARY AIR : Opened full for first 5 min., then set to run setting of wide open

SECONDARY AIR : N/A CAT BYPASS : N/A

FAN:

ON OFF during warm-up

ON OFF first 30 minutes of test

ON / OFF during preburn

ON / OFF balance of test run

Fan speed set at High

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER : N/A BRAND : N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 12 or 16 inches.

1st warm up / pre-burn fuel charge (14.3 lbs.) added at 0740

2nd warm up / pre-burn fuel charge (14.0 lbs.) added at 0845

3rd warm up / pre-burn fuel charge (14.9 lbs.) added at 0955

4th warm up / pre-burn fuel charge (____ lbs.) added at _____

5th warm up / pre-burn fuel charge (____ lbs.) added at _____

TEST DATA SHEET #10

Unit : F500 Run : 2 Date : 05-16-02

Room Temperature : 72 °F Correction Factor : ∅

Uncorrected Values are corrected for room temperature : Yes _____ No ✓

Time Test Fuel moisture reading taken : 1000

Calibration Checks : X _____ ✓ Y ✓ 12.0 12.1 22.0 22.1

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	12.5	13.3	13.0	13.8	11.5	12.2	13.100
2									
3									
4	2"x4"x8'	P	18.3	19.8	19.0	20.3	19.0	20.3	20.133
5	2"x4"x8'	P	19.0	20.3	19.0	20.3	19.0	20.3	20.300
6	2"x4"x8'	P	23.5	25.2	23.5	25.2	23.5	25.2	25.200
7	2"x4"x8'	P	19.5	20.9	19.0	20.3	18.5	19.8	20.333
8	2"x4"x8'	P	18.5	19.8	18.5	19.8	18.5	19.8	19.800
9									105.766
10									
11	2x4x17	T	17.5	18.7	18.0	19.2	17.5	18.7	18.867
12	"	T	18.0	19.2	18.0	19.2	19.0	20.3	19.567
13	"	T	23.5	25.2	23.0	24.7	23.5	25.2	25.033
14	4x4x17	T	18.0	19.2	18.5	19.8	18.0	19.2	19.400
15	"	T	18.0	19.2	19.0	20.3	18.5	19.8	19.767
16									102.634
17									
18									
19									
20	Spacers	T	19.5	20.9	20.0	21.4	20.0	21.4	21.233

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	13.100 %	21.153 %	20.527 %
Wet Moisture % :	11.583 %	17.460 %	17.031 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

GAS DATA SHEET # 14

WEIGHT: 1.1
UNIT: F500

RUN: 2 DATE: 05-16-02 PAGE: 2 of 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL.WB	STACK	STATIC	SO ₂ PPM
0	21.3	17.2	-	.303	7.5	.497	12.4	.061	.62					346	.054	250
5	19.2	15.1	2.1	.589	14.7	.265	6.6	.060	.61					708	.075	325
10	17.5	13.4	1.7	.622	15.5	.229	5.7	.026	.27					640	.074	325
15	16.2	12.1	1.3	.677	16.9	.180	4.5	.033	.34					659	.076	325
20	14.9	10.8	1.3	.704	17.5	.149	3.7	.043	.44					676	.076	325
25	13.3	9.2	1.6	.651	16.2	.203	5.0	.030	.31					643	.075	300
30	12.1	8.0	1.2	.599	14.9	.233	5.8	.043	.44					621	.073	325
35	11.1	7.0	1.0	.614	15.3	.222	5.5	.041	.42					601	.073	300
40	10.0	5.9	1.1	.570	14.2	.264	6.6	.024	.25					574	.071	275
45	9.2	5.1	.8	.510	12.7	.318	7.9	.012	.13					532	.068	275
50	8.7	4.6	.5	.325	8.1	.486	12.2	.036	.37					466	.065	275
55	8.3	4.2	.4	.279	6.9	.522	13.1	.099	1.00					415	.061	325
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	6881	.841	*****
60	7.8	3.7	.5	.267	6.6	.529	13.2	.123	1.24					384	.058	325
65	7.5	3.4	.3	.277	6.9	.519	13.0	.116	1.17					371	.057	325
70	7.2	3.1	.3	.307	7.6	.492	12.3	.079	.80					375	.056	275
75	6.8	2.7	.4	.318	7.9	.479	12.0	.045	.46					387	.058	275
80	6.3	2.2	.5	.356	8.9	.442	11.1	.022	.23					402	.059	275
85	5.9	1.8	.4	.365	9.1	.426	10.7	.023	.24					405	.059	275
90	5.6	1.5	.3	.314	7.8	.473	11.8	.055	.56					378	.057	250
95	5.5	1.4	.1	.307	7.6	.482	12.1	.063	.64					367	.056	300
100	5.3	1.2	.2	.272	6.8	.522	13.1	.099	1.00					348	.054	300
105	5.1	1.0	.2	.263	6.5	.532	13.3	.109	1.10					337	.052	300
110	5.0	.9	.1	.259	6.4	.532	13.3	.121	1.22					329	.051	300
115	4.8	.7	.2	.268	6.7	.529	13.2	.083	0.84					327	.051	300
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	4410	.668	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	11291	1.509	*****

WEIGHT: 4.1

UNIT: F500

GAS DATA SHEET # 12

RUN: 2 DATE: 05-16-02 PAGE: 2 of 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL.WB	STACK	STATIC	SO ₂ PPM
120	4.6	.5	.2	259	6.4	540	13.5	095	9.6					320	7050	300
125	4.4	.3	.2	247	6.1	551	13.8	105	1.06					313	7050	300
130	4.3	.2	.1	246	6.1	554	13.9	112	1.13					308	7049	300
135	4.1	.1	.2	240	6.0	560	14.0	115	1.16					305	7048	300
140																
145																
150																
155																
160																
165																
170																
175																
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	1246	7197	*****
180																
185																
190																
195																
200																
205																
210																
215																
220																
225																
230																
235																±28
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	12537	-1706	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	448	-061	*****

TIME	SCALE	DROP	STACK	TOP	LF SIDE	BACK	RT SIDE	BOTTOM	FIREBOX	SEC/CAT	AMBIENT	STATIC	COMMENTS
0	18.2	-	324	434	209	352	287	334	837	725	82	-051	PREBURN START: # 13,9 UP
5	17.3	.9	450	471	206	350	281	335	795	1301	83	-067	COAL BED SCALE RANGE: 4.3 → 3.5
10	15.6	1.7	596	618	204	335	271	328	755	1433	84	-075	PRIMARY AIR: wide open
15	13.7	1.9	653	708	212	323	255	308	742	1462	82	-078	SECONDARY AIR: N/A
20	12.1	1.6	678	733	206	312	249	302	751	1516	84	-079	FAN: High
25	10.4	1.7	665	756	206	312	246	297	767	1497	86	-077	PUMPS ON AT: 1050
30	8.6	1.8	636	761	217	317	256	284	819	1519	86	-075	CHECK WB/DB: N/A
35	7.5	1.1	600	733	212	320	262	278	861	1417	80	-075	
40	6.6	1.9	551	713	213	322	272	281	904	1308	81	-071	
45	6.1	.5	487	662	211	334	282	280	954	1214	81	-067	
50	5.6	.5	445	600	216	346	295	286	991	1120	81	-064	
55	5.3	.3	432	569	216	354	296	289	1017	1089	80	-062	
60	5.0	.3	402	533	219	360	300	294	1027	1059	80	-061	
65	4.8	.2	375	492	219	364	300	297	997	1056	80	-058	
70	4.6	.2	365	473	222	362	299	298	974	1034	79	-056	
75	4.5	.1	351	451	215	358	296	301	947	1013	79	-056	
80	4.3	.2	340	425	214	350	290	301	927	991	78	-055	
85	4.1	.2	346	406	216	348	286	301	881	949	78	-054	311.4 AT

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 05-16-2002 Analyte : CO₂ (15-1)
 Unit : F500 Run # : 2
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO₂ Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC12767 Conc. : 12.49 % CO₂ Cyl. Press. : 1420 PSI
 Certified by : AIR LIQUIDE Date : 02-15-02
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 407069
 Range : 0 - 25.0 % CO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 25.0 % CO₂
 EPA Control Limits = ± 2.5% of 25.0 % CO₂ = ± 0.625 % CO₂
 Method 28 A = ± .2 % of 25.0 % CO₂ = ± .05 % CO₂

PRE RUN Audit : by : D. Wadlington Time : 1045 Temp : 81 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.2	.002	.028	+ .028	+ .112
SPAN	50.0	.500	12.49	50.2	.502	12.491	+ .001	+ .006

POST RUN Audit : by : D. Wadlington Time : 1350 Temp : 79 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	.003	+ .003	+ .013
SPAN	50.0	.500	12.49	50.1	.501	12.466	- .024	- .094

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05-16-2002

Analyte : O₂ (15-2)

Unit : F500

Run # : 2

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂

Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 12.50 % O₂

Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : TELEDYNE Model : 320 A

SN : 37400

Range : 0 - 25.0 % O₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % O₂

EPA Control Limits = $\pm 2.5\%$ of 25.0 % O₂ = $\pm 0.625 % O_2$

Method 28 A = $\pm .2\%$ of 25.0 % O₂ = $\pm .05 % O_2$

PRE RUN Audit : by : D. Wadsworth Time : 1045 Temp : 81 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.003	.011	+ .011	+ .043
SPAN	12.50	.500	12.50	12.49	.499	12.488	- .012	- .047

POST RUN Audit : by : D. Wadsworth Time : 1350 Temp : 79 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.002	- .014	- .014	- .057
SPAN	12.50	.500	12.50	12.49	.499	12.488	- .012	- .047

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date : 05-16-2002

Analyte : CO (15-3)

Unit : F500

Run # : 2

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO

Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 4.80 % CO

Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 408005

Range : 0 - 10.0 % CO

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 10.0 % CO

EPA Control Limits = ± 2.5% of 10.0 % CO = ± 0.25 % CO

Method 28 A = ± .2 % of 10.0 % CO = ± .02 % CO

PRE RUN Audit : by : *D. Whelan* Time : 1045 Temp : 81 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.014	+ .014	+ .141
SPAN	48.0	.480	4.80	48.1	.481	4.803	+ .003	+ .034

POST RUN Audit : by : *D. Whelan* Time : 1350 Temp : 79 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.004	+ .004	+ .041
SPAN	48.0	.480	4.80	48.1	.481	4.803	+ .003	+ .034

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05-16-2002 Analyte : SO₂ (15-4)
 Unit : F500 Run # : 2
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC62184 Conc. : 1290 ppm SO₂ Cyl. Press. : 1350 PSI
 Certified by : AIR LIQUIDE Date : 01-29-01
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 403019
 Range : 0 - 2500 ppm SO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = ± 2.5% of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : D. Wadsworth Time : 1025 Temp : 86 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.2	.002	10.878	+10.878	+ .435
SPAN	51.6	.516	1290	51.5	.515	1289.743	-0.257	- .010

POST RUN Audit : by : D. Wadsworth Time : 1345 Temp : 79 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	5.892	+5.892	+ .236
SPAN	51.6	.516	1290	51.6	.516	1292.236	+2.236	+ .089

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : F500 RUN : 2 DATE : 05-16-02

Thermocouple Check:

T/C # 1	<u> </u>	°F	T/C # 13	<u>64.5</u>	°F
T/C # 2	<u> </u>	°F	T/C # 14	<u>61.7</u>	°F
T/C # 3	<u>64.4</u>	°F	T/C # 15	<u>67.0</u>	°F
T/C # 4	<u>57.9</u>	°F	T/C # 16	<u>12.3</u>	°F
T/C # 5	<u>56.0</u>	°F	T/C # 17	<u>11.3</u>	°F
T/C # 6	<u>57.2</u>	°F	T/C # 18	<u>67.9</u>	°F
T/C # 7	<u>56.6</u>	°F	T/C # 19	<u>59.5</u>	°F
T/C # 8	<u>57.2</u>	°F	T/C # 20	<u>5.6</u>	°F
T/C # 9	<u>57.6</u>	°F	T/C # 21	<u> </u>	°F
T/C # 10	<u>57.8</u>	°F	T/C # 22	<u> </u>	°F
T/C # 11	<u>54.8</u>	°F	T/C # 23	<u>58.2</u>	°F
T/C # 12	<u>73.6</u>	°F	T/C # 24	<u> </u>	°F

Thermocouple Readout:

Pretest zero and span check and calibration

ZERO : 1.7 °F Adj. to 0.0 °F

SPAN : 1996.0 °F Adj. to 2000.0 °F

post test zero and span

ZERO 2.6 °F Adj. to .130 ^{0/0} _{°F}

SPAN 2005.0 °F Adj. to .250 ^{0/0} _{°F}

Thermocouple Readout Pretest Linearity Check:

0	= <u>0.0</u> °F	200	= <u>202.6</u> °F	400	= <u>399.9</u> °F
600	= <u>602.0</u> °F	800	= <u>802.0</u> °F	1000	= <u>1001.0</u> °F
1200	= <u>1198.6</u> °F	1400	= <u>1399.4</u> °F	1600	= <u>1599.8</u> °F
1800	= <u>1800.0</u> °F	2000	= <u>2000.0</u> °F		

Sample Train Leak Check

Pre

Post

C-gas Train Leak Check

Pre

Post

SO₂ Train Leak Check

Pre

Post

Static Gauge Zero Check


Pre

Post

Scale Check Pre : 18.1 - 8.1 .

Post : 13.9 - 3.9 .

Stack Cleaned Prior to Test Run : YES NO



COMPUTER INPUT DATA SHEET #1

Client: JOTUL U.S.A., INC.

Address: 400 RIVERSIDE ST., P.O. BOX 1157
PORTLAND, MAINE 04104

Phone: (207) 797-5912 Fax: (207) 772-0523

Run No.: 5 Date of Test: 05-21-2002 Burn Rate: 1:210

Model No.: F500 min min-1.25 fan

Stove Type: Cat Non Cat Pellet 1.25-1.9 max insert

Dry Gas Meter Y Factor: 1,000 Post Leak Rate: .017 cfm Time: 310 min.
(0.000) (Data Sheet #2) (.000) (Data Sheet #2) (000) (Data Sheet #2)

Dry Gas Meter Volume: 99.891 cf
(00.000) (Data Sheet #2)

Stack Flow: 7.034 dscfm Δ H: .154 in. H₂O
(00.000) (Data Sheet #2) (0.000) (Data Sheet #2)

Maximum Vac.: 3.0 Barometric Pressure: 30.04 in. Hg
(0.0) (Data Sheet #2) (00.00) (Data Sheet #2)

H₂O Captured: 169.7 g
(00.0) (Data Sheet #3)

Front Half Catch % Of Total: 28.7 % Total Particulate Catch: .9613 g
(00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)

Flue Gas Moisture: 7.6095 %
(00.000) (Data Sheet #7)

Particulate Emission: .1529 gr/dscf
(0.0000) (Data Sheet #7)

Relative Humidity: 43.5 % RH Ambient Moisture: 1.25 % H₂O
(00.0) (Data Sheet #8) (0.00) (Data Sheet #8)

Pretest Fuel Wt.: 51.3 lbs. Coal Bed Wt.: 4.0 lbs. Test Fuel Wt.: 16.6 lbs.
(00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)

Heat Output (EPA Default): 14,588.4 BTU/hr
(00,000.0) (Data Sheet #8)

Kindling Fuel % Moisture (wet): 10.608 % Pretest Fuel % Moisture (wet): 16.823 %
(00.000) (Data Sheet #10) (00.000) (Data Sheet #10)

Test Fuel % Moisture (dry): 20.460 % Test Fuel % Moisture (wet): 16.985 %
(00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])

Fuel Higher Heating Value (dry): — BTU/lb.
(0000) (Data Sheet #11)

Stack Static Pressure: -.044 in. H₂O
(+/- .000) (Data Sheet #12)

Average Ambient Temperature: 76 °F Stove Temperature Change: -45.8 °F
(00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul U.S.A., Inc.

TEST No. : 5

MODEL: F500

DATE: 21-May-02

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
0	757.000	0.150	77	1.16	5.30	500
5	758.500	0.360	78	0.46	8.10	325
10	760.842	0.110	79	0.96	3.80	575
15	762.173	0.120	79	1.03	4.40	550
20	763.563	0.120	79	1.06	5.50	550
25	764.954	0.120	79	1.21	7.60	550
30	766.345	0.100	79	1.57	6.50	625
35	767.569	0.190	79	0.58	9.00	450
40	769.268	0.190	79	0.35	9.60	450
45	770.967	0.230	82	0.29	12.30	400
50	772.900	0.230	82	0.22	12.60	400
55	774.833	0.230	84	0.18	13.10	400
60	776.779	0.230	84	0.22	15.20	400
65	778.728	0.230	85	0.31	15.20	400
70	780.683	0.200	86	0.10	13.90	425
75	782.530	0.230	86	0.10	12.90	400
80	784.493	0.200	87	0.17	12.30	425
85	786.347	0.200	88	0.09	13.30	425
90	788.208	0.180	88	0.29	11.20	450
95	789.966	0.160	88	0.62	10.60	475
100	791.631	0.160	87	0.77	9.70	475
105	793.290	0.140	87	0.66	10.50	500
110	794.867	0.140	86	0.52	11.30	500
115	796.438	0.160	86	0.38	12.00	475
120	798.091	0.180	86	0.41	10.40	450
125	799.836	0.160	87	1.11	8.10	475
130	801.495	0.140	87	1.21	7.90	500
135	803.072	0.130	87	1.29	7.30	525
140	804.573	0.130	88	1.21	7.30	525
145	806.080	0.130	88	1.42	7.10	525
150	807.587	0.140	88	1.25	6.80	500
155	809.169	0.130	88	1.15	6.90	525
160	810.676	0.140	88	1.30	6.70	500
165	812.259	0.140	88	1.55	6.50	500
170	813.841	0.140	88	1.55	6.40	500
175	815.423	0.140	88	1.62	6.40	500
180	817.005	0.140	88	1.70	6.30	500
185	818.589	0.140	88	1.65	6.20	500
190	820.172	0.140	88	1.59	6.20	500
195	821.755	0.140	88	1.36	6.60	500
200	823.339	0.140	88	1.12	6.60	500
205	824.922	0.140	88	1.34	6.30	500
210	826.505	0.140	88	1.56	5.80	500
215	828.089	0.140	88	1.52	5.80	500

220	829.672	0.140	88	2.29	4.80	500
225	831.255	0.130	88	2.26	4.80	525
230	832.763	0.130	88	2.02	4.90	525
235	834.271	0.130	88	1.97	5.10	525
240	835.779	0.130	88	2.28	4.70	525
245	837.287	0.130	88	2.30	4.70	525
250	838.795	0.130	88	2.29	4.70	525
255	840.303	0.130	88	2.24	4.70	525
260	841.811	0.130	88	2.24	4.70	525
265	843.319	0.130	88	2.24	4.70	525
270	844.827	0.130	88	2.01	4.60	525
275	846.335	0.130	88	1.64	5.00	525
280	847.843	0.130	88	1.79	4.80	525
285	849.351	0.130	88	1.90	4.70	525
290	850.859	0.130	88	1.99	4.60	525
295	852.367	0.130	88	2.25	4.50	525
300	853.875	0.130	88	2.20	4.40	525
305	855.383	0.130	88	2.20	4.30	525
310	856.891	0.130	88	2.11	4.30	525
315						

TABLE 2---RAW DATA

CLIENT : Jotul U.S.A., Inc.

TEST No. 5

MODEL: F500

DATE: 21-May-02

METER CAL. FACTOR (Y) -----	1	Wt. WOOD BURNED(LB) -----	16.6	Lbs
--------------------------------	---	------------------------------	------	-----

BAROMETRIC PRESS.(Pb) -----	30.04 in Hg	WET,FUEL MOISTURE % -----	16.985	%
--------------------------------	-------------	------------------------------	--------	---

LEAK RATE POST (Lp) -----	0.017 cfm	Wt. PART. COLLECTED -----	0.9613	g
------------------------------	-----------	------------------------------	--------	---

WATER VOL. (V1c) -----	169.7 MI	METER VOLUME Vm -----	99.891	mcf
---------------------------	----------	--------------------------	--------	-----

TEST TIME (MIN) -----	310 min	HC MOLE FRACTION -----	0.0132	
--------------------------	---------	---------------------------	--------	--

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul U.S.A., Inc.

TEST No. 5

MODEL: F500

DATE: 21-May-02

AVG DELTA		AVG PRCNT		
H	----- 0.15 in H2O	CO	----- 1.28	%
AVG METER		AVG PRCNT		
TEMP. Tm	----- 86 deg F	CO2	----- 7.50	%
AVG PPM		AVG BAL		
SO2	----- 494 PPM	CO2/CO	----- 5.87	%

TABLE 4 ---- CALCULATIONS

CLIENT : Jotul U.S.A., Inc.

TEST No. 5

MODEL: F500

DATE: 21-May-02

STD SAMPLE			STACK GAS			
VOL. Vm(std) d) -----	97.03 dscf		FLOW Qsd -----	431.682	dscf/Hr	
				7.19	& dscf/min	
VOL. WATER			PARTICULATE			
VAPOR Vw(s td) -----	7.988 scf		CONCTR. C s -----	0.0099	g/dscf	
PRCNT			PARTC.EMISS.			
MSTR Bws -----	7.61 %		RATE E -----	4.28	g/Hr	
BURN			MOLES OF GAS			
RATE BR -----	1.21 Kg/Hr		PER Lb WOOD Nt ----	0.42	Lb-mole/Lb	
CO EMISSION			PART.EMISS.			
RATE -----	184.56 g/Hr		RATE -----	3.54	g/Kgdry	
	&				fuel	
	152.53 g/Kgdry					
	fuel					

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul U.S.A., Inc.

TEST No. : 5

MODEL: F500

DATE: 21-May-02

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	740.1	97	100
10	750.1	98	
15	753.0	99	
20	752.2	99	
25	752.8	99	
30	752.8	99	
35	752.7	99	
40	752.4	99	
45	750.3	98	
50	756.8	99	
55	755.4	99	
60	759.1	100	
65	759.6	100	
70	760.5	100	
75	762.6	100	
80	762.2	100	
85	763.4	100	
90	765.6	100	
95	765.7	100	
100	766.2	100	
105	764.1	100	
110	765.3	100	
115	763.0	100	
120	762.8	100	
125	762.2	100	
130	764.1	100	
135	764.6	100	
140	763.4	100	
145	765.7	100	
150	765.7	100	
155	765.6	100	
160	765.7	100	
165	766.1	100	
170	765.6	100	
175	765.6	100	
180	765.6	100	
185	766.5	100	
190	766.1	100	
195	766.1	100	
200	766.5	100	
205	766.1	100	
210	766.1	100	
215	766.5	100	
220	766.1	100	

METER BOX DATA SHEET PAGE # 2

Page: 1 of 3

UNIT: F500

RUN: 5

DATE: 05-21-02

Meter Box: 5H

Y Factor: 1.000

Leak checks: 15 " Hg @ .010 cfm

" Hg @ _____ cfm

15 " Hg @ .017 cfm

" Hg @ _____ cfm

Inject SO₂ @ 100 cc/min.

Nozzle: Probe @ 3/8" od

Initial Volume: 1,500

ROTO: PRESS: <u>.14</u>			SAMPLING RATIO: <u>23</u> : 1				BP: <u>30.07</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
0	1250	757.000	—	6.983	.15	77	500	77	2.0
5	55	758.500	—	10.723	.36	78	325	78	3.0
10	1300	766.842	766.842	6.050	.11	79	575	79	2.0
15	05	762.173	762.173	6.325	.12	79	550	79	2.0
20	10	763.563	763.563	6.325	.12	79	550	79	2.0
25	15	764.954	764.954	6.325	.12	79	550	79	2.0
30	20	766.345	766.345	5.566	.10	79	625	79	2.0
35	25	767.569	767.569	7.730	.19	79	450	79	2.0
40	30	769.268	769.268	7.730	.19	79	450	79	2.0
45	35	770.967	770.967	8.648	.23	82	400	82	2.0
50	40	772.900	772.900	8.648	.23	82	400	82	2.0
55	45	774.833	774.833	8.616	.23	84	400	84	2.0
ROTO PRESS: <u>.14</u>			TOTALS: 89.669		2.15	956	BP: 30.05		
60	1350	776.779	776.779	8.611	.23	84	400	84	2.0
65	55	778.728	778.728	8.595	.23	85	400	85	2.0
70	1400	780.683	780.683	8.074	.20	86	425	86	2.0
75	05	782.530	782.530	8.579	.23	86	400	86	2.0
80	10	784.493	784.493	8.060	.20	87	425	87	2.0
85	15	786.347	786.347	8.045	.20	88	425	88	2.0
90	20	788.208	788.208	7.598	.18	88	450	88	2.0
95	25	789.966	789.966	7.198	.16	88	475	88	2.0
100	30	791.631	791.631	7.211	.16	87	475	87	2.0
105	35	793.290	793.290	6.851	.14	87	500	87	2.0
110	40	794.867	794.867	6.863	.14	86	500	86	2.0
115	45	796.438	796.438	7.224	.16	86	475	86	
			TOTALS:		92.909	2.23	1038	MAX VACC =	
TOTAL Cu Ft. <u>/</u>			TOTALS:		182.578	4.38	1994	AVG. BP: <u>/</u>	

225	766.1	100
230	766.2	100
235	766.2	100
240	766.2	100
245	766.2	100
250	766.2	100
255	766.2	100
260	766.2	100
265	766.2	100
270	766.2	100
275	766.2	100
280	766.2	100
285	766.2	100
290	766.2	100
295	766.2	100
300	766.2	100
305	766.2	100
310	766.2	100
315		
320		

METER BOX DATA SHEET PAGE # 2

Page: 2 of 3

UNIT: F500

RUN: 5

DATE: 05-21-02

Meter Box: 5H

Y Factor: 1.000

Leak checks: 15 " Hg @ .010 cfm _____ " Hg @ _____ cfm

15 " Hg @ .107 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min.

Nozzle: Probe @ 3/8" od

Initial Volume: 1.500

ROTO: PRESS: <u>.14</u>		SAMPLING RATIO: <u>23</u> : 1					BP: <u>30.05</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
120	1450	798.091	798.091	7.626	.18	86	450	86	2.0
125	55	799.836	799.836	7.211	.16	87	475	87	2.0
130	1500	801.495	801.495	6.851	.14	87	500	87	2.0
135	05	803.072	803.072	6.524	.13	87	525	87	2.0
140	10	804.573	804.573	6.513	.13	88	525	88	2.0
145	15	806.080	806.080	6.513	.13	88	525	88	2.0
150	20	807.587	807.587	6.838	.14	88	500	88	2.0
155	25	809.169	809.169	6.513	.13	88	525	88	2.0
160	30	810.676	810.676	6.838	.14	88	500	88	2.0
165	35	812.259	812.259	6.838	.14	88	500	88	2.0
170	40	813.841	813.841	6.838	.14	88	500	88	2.0
175	45	815.423	815.423	6.838	.14	88	500	88	2.0
ROTO PRESS: <u>.14</u>		TOTALS:		81.941	1.70	1051	BP: <u>30.03</u>		
180	1550	817.005	817.005	6.834	.14	88	500	88	2.0
185	55	818.589	818.589	6.834	.14	88	500	88	2.0
190	1600	820.172	820.172	6.834	.14	88	500	88	2.0
195	05	821.755	821.755	6.834	.14	88	500	88	2.0
200	10	823.339	823.339	6.834	.14	88	500	88	2.0
205	15	824.922	824.922	6.834	.14	88	500	88	2.0
210	20	826.505	826.505	6.834	.14	88	500	88	2.0
215	25	828.089	828.089	6.834	.14	88	500	88	2.0
220	30	829.672	829.672	6.834	.14	88	500	88	2.0
225	35	831.255	831.255	6.508	.13	88	525	88	2.0
230	40	832.763	832.763	6.508	.13	88	525	88	2.0
235	45	834.271	834.271	6.508	.13	88	525	88	2.0
		TOTALS:		81.030	1.65	1056	MAX VACC =		
TOTAL Cu Ft.		TOTALS:		162.971	3.35	2107	AVG. BP:		

METER BOX DATA SHEET PAGE # 2

Page: 3 of 3

UNIT: F500 RUN: 5 DATE: 05-21-02

Meter Box: 5H Y Factor: 1.000

Leak checks: 15 " Hg @ .010 cfm _____ " Hg @ _____ cfm

15 " Hg @ .017 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.14</u>		SAMPLING RATIO: <u>23</u> : 1					BP: <u>30.03</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
240	1650	835.779	835.779	6.508	.13	88	525	88	2.0	
245	55	837.287	837.287	6.508	.13	88	525	88	2.0	
250	1700	838.795	838.795	6.508	.13	88	525	88	2.0	
255	05	840.303	840.303	6.508	.13	88	525	88	2.0	
260	10	841.811	841.811	6.508	.13	88	525	88	2.0	
265	15	843.319	843.319	6.508	.13	88	525	88	2.0	
270	20	844.827	844.827	6.508	.13	88	525	88	2.0	
275	25	846.335	846.335	6.508	.13	88	525	88	2.0	
280	30	847.843	847.843	6.508	.13	88	525	88	2.0	
285	35	849.351	849.351	6.508	.13	88	525	88	2.0	
290	40	850.859	850.859	6.508	.13	88	525	88	2.0	
295	45	852.367	852.367	6.508	.13	88	525	88	2.0	
ROTO PRESS: <u>.14</u>		TOTALS:			<u>78.096</u>	<u>1.56</u>	<u>1054</u>	BP: <u>30.03</u>		
300	1750	853.875	853.875	6.508	.13	88	525	88	2.0	
305	55	855.383	855.383	6.508	.13	88	525	88	2.0	
310	1800	856.891	856.891	6.508	.13	88	525	88	2.0	
315	05									
320	10			19.524	.39	264				
325	15			97.620	(1.95)	(1320)				
330	20									
335	25									
340	30									
345	35									
350	40									
355	45					5421	163			
TOTALS:				443.169	9.68	86	MAX VACC =		3.0	
TOTAL Cu Ft.		99.891	TOTALS:		7.034	(546)	AVG. BP: 30.04			

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT: F500 RUN: 5 DATE: 05-21-02

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	760.0	597.7	486.3	936.1
INITIAL WT	617.8	587.7	483.6	921.3
NET WT GRAMS	142.2	10.0	2.7	14.8

TOTAL CATCH: 169.7 GRAMS H₂O

FRONT HALF

FILTER #	121F	
FINAL WT g	.9090	.
INITIAL WT g	.6962	.
NET WT g	.2128	.

BEAKER #	71
DESC.	ACETONE
FINAL WT g	104.2205
INITIAL WT g	104.1555
NET WT g	.0650
VOL. DESC. ml	90

BACK HALF

FILTER #	121B	
FINAL WT g	.5153	.
INITIAL WT g	.4110	.
NET WT g	.1043	.

BEAKER #	72	73	74	75	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	104.1402	104.4410	107.6038	96.5748	
INITIAL WT g	103.8327	104.3600	107.5129	96.4715	
NET WT g	.3075	.0810	.0909	.1033	.1942
VOL. DESC ml	130	75	200	175	(375)

FILTER TARE WEIGHTS DATA SHEET #4-1

Into Dessicator : _____ Date : 04-24-2002 Time : 1850 By : DKW
 Manufacturer S & S Grade : # 25 Glass Front Size : 11 cm Lot No. : ZB921
 Back Size : 8.2 cm Lot No. : ZB911

FILTER #	DATE: <u>05-17</u>	BY: <u>DKW</u>	DATE: <u>05-19</u>	BY: <u>DKW</u>	DATE: _____	BY: _____
	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME
121F	.6963	1623	.6962	1537	JOTUL F500	R-5
122F	.7031	1624	.7032	1538		
123F	.6989	1625	.6991	1539		
124F	.7095	1626	.7093	1540		
125F	.7076	1627	.7077	1541		
126F	.7022	1628	.7026	1542		
127F	.7056	1629	.7056	1543		
128F	.6936	1630	.6937	1544		
129F	.6894	1632	.6896	1545		
130F	.6957	1633	.6955	1546		

121B	.4110	1634	.4110	1547	JOTUL F500	R-5
122B	.4403	1635	.4403	1548		
123B	.4468	1636	.4467	1549		
124B	.4444	1637	.4443	1550		
125B	.4482	1638	.4483	1551		
126B	.4427	1639	.4430	1552		
127B	.4433	1640	.4435	1553		
128B	.4292	1641	.4293	1554		
129B	.4259	1642	.4258	1555		
130B	.4274	1643	.4274	1556		

Checked by: C. W. [Signature] Date: 5-20-02 Time: 1445

BALANCE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	WB	DB	% RH
05-17	1600	DKW	/	75	48
05-19	1500	DKW	/	77	48

BEAKER TARE WEIGHTS DATA SHEET #4-2

Into Dessicator: Date : 04-24-2002 Time : 1820 By : DKW

BEAKER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME
	DATE: <u>05-17</u> BY: <u>DKW</u>		DATE: <u>05-19</u> BY: <u>DKW</u>		DATE: _____ BY: _____	
66	96.5130	1606	96.5125	1518	} TOTAL F500 R-4	
67	106.2279	1607	106.2276	1519		
68	94.1608	1608	94.1606	1520		
69	108.9974	1609	108.9969	1521		
70	107.4847	1611	107.4845	1523		
71	104.1557	1612	104.1555	1524	} TOTAL F500 R-5	
72	103.8325	1613	103.8327	1525		
73	104.3597	1614	104.3600	1527		
74	107.5126	1615	107.5129	1528		
75	96.4716	1616	96.4715	1529		
76	103.8088	1617	103.8088	1530	} TOTAL F500 R-5	
77	107.3923	1618	107.3924	1532		
78	94.5006	1620	94.5004	1533		
79	97.6258	1621	97.6257	1534		
80	109.1322	1622	109.1320	1535		

BALANCE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	WB	DB	% RH	
05-17	1600	DKW	}	75	48	Checked by <u>C. Washington</u>
05-19	1500	DKW		77	48	Date : <u>5-20-02</u>
						Time : <u>1430</u>

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: **F500** RUN: **5** DATE: **05-22-02** Page: **1** of **1**

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
71	05-22	1240	RL	104.2203	05-23	2109	RL	104.2205	05-28	1229	RL
72	05-22	1240	RL	104.1400	05-23	2110	RL	104.1402	05-28	1230	RL
73	05-22	1845	RL	104.4534	05-23	2111	RL	104.4412	05-28	1231	RL
74	05-22	1240	RL	107.6049	05-23	2112	RL	107.6039	05-28	1232	RL
75	05-22	1240	RL	96.5752	05-23	2113	RL	96.5748	05-28	1233	RL

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
121F	5-21	1830	CP	9104	05-22	1209	RL	9091	05-22	1929	RL
121B	5-21	1830	CP	5157	05-22	1210	RL	5153	05-23	1931	RL

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	05-22	1155	RL	78	48
2	05-22	1920	RL	78	49
3	05-23	2105	RL	77	48
4	05-28	1225	RL	78	49
5	05-28	1625	RL	78	47

Weighing Session	Date	Time	By	DB	%RH
6					
7					
8					
9					
10					

Dates: From 02-16-2002
Through 05-17-2002

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale: Sartorius
Model: A1205
SN : 37010004

100g weight	10 g weight	1.0 g weight	100 mg weight	Tech	Date	Time	Wet Bulb	Dry Bulb	% RH
100.0000	9.9999	1.0000	.0999	JKW	02-16	1845		77	46
100.0000	9.9999	.9999	.0998	JKW	02-17	1555		77	47
100.0001	9.9999	.9999	.0997	JKW	02-18	0940		77	47
100.0000	10.0000	.9999	.1000	JKW	02-19	1025		78	46
100.0000	9.9999	1.0000	.0999	JKW	02-20	0915		75	42
100.0003	10.0000	1.0000	.0999	JKW	03-14	1020		78	45
99.9999	9.9998	.9998	.0998	JKW	03-15	1725		77	45
99.9999	10.0000	1.0002	.0999	JKW	03-16	1820		77	38
100.0001	9.9999	1.0001	.1000	JKW	03-16	2130		78	43
99.9999	9.9999	.9998	.0998	JKW	03-17	1550		77	43
99.9999	10.0000	1.0001	.0999	JKW	03-17	2045		77	39
99.9998	10.0000	1.0000	.1000	JKW	03-18	1100		77	39
100.0000	9.9999	.9999	.0999	JKW	03-19	1800		76	42
100.0001	10.0000	1.0001	.1000	JKW	03-20	1835		77	45
99.9999	10.0001	.9999	.0999	JKW	03-21	2235		78	45
99.9998	9.9999	1.0000	.1000	JKW	03-24	2205		78	42
99.9998	10.0000	1.0000	.1001	JKW	03-25	1000		78	41
99.9997	10.0000	1.0001	.1000	JKW	04-04	1300		78	49
99.9998	10.0000	1.0000	.0999	JKW	04-05	1210		78	49
99.9997	10.0000	.9999	.0998	JKW	04-05	2230		78	49
99.9999	10.0001	1.0000	.0998	JKW	04-08	1135		78	47
99.9997	10.0000	1.0000	.0999	JKW	04-08	1910		78	48
99.9997	9.9998	.9999	.1000	JKW	04-09	2150		77	48
99.9999	10.0000	1.0000	.0999	JKW	04-10	2205		78	48
100.0000	10.0001	.9999	.0999	JKW	04-11	0940		76	49
99.9997	9.9998	1.0000	.0999	JKW	04-11	1705		78	48
99.9999	9.9999	.9999	.0998	JKW	04-11	2230		78	48
99.9999	10.0001	.9999	.0999	JKW	04-12	0950		78	47
100.0000	9.9998	1.0000	.0999	JKW	04-12	1810		78	48
100.0000	9.9999	.9999	.0998	JKW	04-12	2205		78	47
100.0000	9.9999	.9999	.0999	JKW	04-13	1720		78	48
99.9998	10.0000	1.0000	.0998	JKW	04-13	2325		78	46
99.9999	10.0001	1.0001	.1000	JKW	04-14	1740		78	44
99.9998	10.0000	1.0001	.0999	JKW	04-16	1925		75	44
99.9997	9.9999	1.0000	.1000	JKW	04-19	1350		78	41
100.0000	10.0001	.9998	.0999	JKW	04-20	1210		75	41
99.9998	9.9998	1.0001	.0997	JKW	05-16	1430		76	48
99.9999	9.9999	1.0000	.0999	JKW	05-17	1600		75	48

88

BLANK PROCESSING DATA SHEET # 5

UNIT: FS00 RUN: 5 DATE: 05-21-2002

BLANKS DONE: 02-20-2002

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	McKESSON WATER PRODUCTS CO. CERTIFIED DISTILLED
FINAL WEIGHT	108.9015	106.3081	106.9664
TARE WEIGHT	108.9007	106.3064	106.9660
NET WEIGHT	.0008 ✓	.0017 ✓	.0004 ✓

TARE BEAKERS INTO DESC: TIME: 1205 DATE: 02-15-2002

DATE: 02-16 BY: DL DATE: 02-17 BY: DL DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9002	1849	108.9007	1611 ✓		
B	106.3068	1850	106.3064	1612 ✓		
C	106.9661	1851	106.9660	1613 ✓		

FINAL BEAKERS INTO DESC: TIME: 1125 DATE: 02-18-2002

DATE: 02-19 BY: DL DATE: 02-20 BY: M DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9016	1027	108.9015	0917 ✓		
B	106.3084	1028	106.3081	0918 ✓		
C	106.9664	1029	106.9664	0919 ✓		

TARE QC

DATE	TIME	BY	WB	DB	%
02-16	1845	DL	}	77	46
02-17	1555	DL		77	47

FINAL QC

DATE	TIME	BY	WB	DB	%
02-19	1025	DL	}	78	46
02-20	0915	DL		75	42

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: FS00 RUN: 5 DATE: 05-21-02

BLANK CALCULATIONS

Acetone : $\frac{.0008 \text{ g}}{200 \text{ ml}} = .000004 \text{ g/ml}$
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = .000023 \text{ g/ml}$
 Distilled Water : $\frac{.0004 \text{ g}}{200 \text{ ml}} = .000002 \text{ g/ml}$

FRONT HALF CATCH

FILTERS : $\frac{.2128 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ (# of Filters)}}{.0000 \text{ g}} \text{ (Blank Value / Filter)} = .2128 \text{ g}$

BEAKERS : $\frac{.0650 \text{ g}}{\text{Total Catch}} - \frac{90 \text{ ml Acetone}}{.000004 \text{ g}} \text{ (Blank Value / ml Acetone)} = .0646 \text{ g}$

TOTAL FRONT HALF CATCH : .2774 g

BACK HALF CATCH

FILTERS : $\frac{.1043 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ (# of Filters)}}{.0000 \text{ g}} \text{ (Blank Value / Filter)} = .1043 \text{ g}$

BEAKERS :
 Acetone : $\frac{.3075 \text{ g}}{\text{Total Catch}} - \frac{150 \text{ ml Acetone}}{.000004 \text{ g}} \text{ (Blank Value / ml Acetone)} = .3069 \text{ g}$

Extract : $\frac{.0810 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Dichloromethane}}{.000023 \text{ g}} \text{ (Blank Value / Dichloromethane)} = .0793 \text{ g}$

Water : $\frac{.1942 \text{ g}}{\text{Total Catch}} - \frac{375 \text{ ml Water}}{.000002 \text{ g}} \text{ (Blank Value / Water)} = .1934 \text{ g}$

TOTAL BACK HALF CATCH : .6839 g

TOTAL CATCH : .9613 g

% FRONT HALF : 28.7 %

CALCULATIONS DATA SHEET # 7

UNIT: F500 RUN: 5 DATE: 05-21-02

$$1) Vm(\text{std}) = \frac{(99.891 \text{ Vm})(17.64)(1,000 \text{ mcf}) \left(30.04'' \text{ Hg} + \frac{.154'' \text{ H}_2\text{O}}{13.6} \right)}{(546 \text{ TmA})} = \frac{96,9831}{000.0000} \text{ dscf}$$

$$2) Vw(\text{std}) = (.04707)(169.7 \text{ ml H}_2\text{O}) = \frac{7.9878}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(7.9878 \text{ scf})}{(7.9878 \text{ scf} + 96,9831 \text{ dscf})} = \frac{.0761}{.0000} \text{ Bws} \times 100 = \frac{7.6095}{00.0000} \% \text{ H}_2\text{O}$$

$$4) Cs = \frac{(.9613 \text{ g.})}{(96,9831 \text{ dscf})} (15.43) = \frac{.1529}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(.9613 \text{ g.})}{(96,9831 \text{ dscf})} (7.034 \text{ dscfm})(60) = \frac{4.1833}{00.0000} \text{ g / hr}$$

<p>Vm = total cubic feet pulled on meter box during test mcf = meter correction factor (Y factor) of meter box used for test " Hg = average barometric pressure during test " H₂O = average delta H for test TmA = average meter temperature for test in degrees Absolute ml H₂O = total water caught during test g. = total particulate catch for test dscfm = average stack flow during test</p>	<p>(000,000 Vm) (0,000 mcf) (00.00" Hg) (.000" H₂O) (000 TmA) (000.0 ml H₂O) (00,000 g.) (00,000 dscf)</p>
<p>(p. 2) (p. 2) (p. 2) (p. 2) (p. 2) (p. 3) (p. 6) (p. 2)</p>	<p>(p. 2) (p. 2) (p. 2) (p. 2) (p. 3) (p. 6) (p. 2)</p>

TEST DATA SHEET # 8

UNIT: F500 RUN: 5 DATE: 05-21-02

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb

Pre: WB: 60 DB: 71 = 52 % RH 1.4 % H₂O

Post: WB: 60 DB: 77 = 35 % RH 1.1 % H₂O

Average: 43.5 % RH 1.25 % H₂O

Empty Stove Weight (lbs): _____ w/ stack & oil seal : Wet: _____ Dry: 0.0

Kindling Weight (lbs): Paper: 1.2 Wood: 2.8

Preburn Fuel Weight: 17.5 + 14.2 + 13.5 + 3.3 Total: 48.5

Kindling & Preburn Fuel Weight (wood only) (lbs): Total: 51.3

Coal Bed Wt Range (lbs): 4.1 - 3.4 Scale: 4.1 - 3.4

Upper: .25 x fuel weight: Always round DOWN to nearest tenth
 Lower: .20 x fuel weight: Always round UP to nearest tenth Actual Coal Bed Weight: 4.0

Maximum Coal Bed Removal (lbs): $(\frac{4.1}{\text{Upper}} + \frac{3.4}{\text{Lower}}) \div 2 \times .25 = \underline{.9}$ round down to nearest tenth

Test Fuel (.75" x 1.5" x 5" spacers) = 16 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	3	6.3	38.0
4" x 4"	17	2	10.3	62.0

Test Fuel Weight: 16.6 lbs

Estimated Dry Burn Rate:

$$\frac{16.6 - (16.6 \times .16985)}{2.2046} \times \frac{60}{310} = \underline{1.210} \text{ kg/hr}$$

Estimated BTU's/hr: $19,140 \times \frac{63}{100} \times \frac{1.210}{\text{DBR}} = \underline{14,588.4}$ BTU's/hr

EPA Default Efficiencies: Non-cat: 63 Cat: 72 Pellet: 78

WOOD STOVE OPERATING DATA PAGE #9

Unit: F500 Run: 5 Date: 05-21-02

FIRE STARTED: 0820

WARM UP AND PREBURN:

PRIMARY AIR: Set wide open for all warm-up / preburn fuel charges. Then set to 1/8" at start of preburn.

SECONDARY AIR: N/A CAT BYPASS: N/A

CHARCOAL BED PREPARATION:

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 25 sec.

TEST:

DOOR wide open during loading 0 min. 40 sec.

PRIMARY AIR: Opened full for first 5 min., then set to run setting of 1/3".

SECONDARY AIR: N/A CAT BYPASS: N/A

FAN:

ON / ~~OFF~~ during warm-up

ON / ~~OFF~~ during preburn

ON / ~~OFF~~ first ALL minutes of test

ON / ~~OFF~~ balance of test run

Fan speed set at OFF

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER: N/A BRAND: N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 12 or 16 inches.

1st warm up / pre-burn fuel charge (17.5 lbs.) added at 0735

2nd warm up / pre-burn fuel charge (14.2 lbs.) added at 0900

3rd warm up / pre-burn fuel charge (13.5 lbs.) added at 1015

4th warm up / pre-burn fuel charge (3.3 lbs.) added at 1140

5th warm up / pre-burn fuel charge (____ lbs.) added at _____

TEST DATA SHEET #10

Unit : F500 Run : 5 Date : 05-21-02

Room Temperature : 70 °F Correction Factor : ϕ

Uncorrected Values are corrected for room temperature : Yes _____ No X

Time Test Fuel moisture reading taken : 1045

Calibration Checks : X ✓ Y ✓ 12.0 12.1 22.0 22.1

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	11.5	12.2	11.0	11.7	11.0	11.7	11.867
2									
3									
4	2"x4"x8'	P	18.0	19.2	18.0	19.2	18.0	19.2	19.200
5	2"x4"x8'	P	19.5	20.9	18.0	19.2	18.0	19.2	19.767
6	2"x4"x8'	P	20.0	21.4	19.5	20.9	20.5	22.0	21.433
7	2"x4"x8'	P	19.5	20.9	19.0	20.3	19.0	20.3	20.500
8	2"x4"x8'	P							80.900
9									
10									
11									
12	2x4x17	T	17.5	18.7	17.5	18.7	18.0	19.2	18.867
13	"	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200
14	"	T	23.5	25.2	23.0	24.7	23.5	25.2	25.033
15	4x4x17	T	18.5	19.8	18.0	19.2	18.0	19.2	19.400
16	"	T	18.5	19.8	18.5	19.8	18.5	19.8	19.800
17									102.300
18									
19									
20	Spacers	T	17.5	18.7	18.0	19.2	18.5	19.8	19.233

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	11.867 %	20.225 %	20.460 %
Wet Moisture % :	10.608 %	16.823 %	16.985 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet; 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

GAS DATA SHEET # 12

WEIGHT: 4.0

UNIT: F500

RUN: 5 DATE: 05-21-02 PAGE: 1 of 3

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL.WB	STACK	STATIC	SO ₂ PPM
0	20.6	16.6	-	.213	5.3	.578	14.5	.115	1.16					231	-.040	500
5	20.0	16.0	.6	.324	8.1	.468	11.7	.045	.46					342	-.056	325
10	19.6	15.6	.4	.152	3.8	.651	16.3	.095	.96					241	-.045	575
15	19.2	15.2	.4	.177	4.4	.632	15.8	.102	1.03					223	-.043	550
20	18.8	14.8	.4	.221	5.5	.593	14.9	.105	1.06					218	-.042	550
25	18.2	14.2	.6	.305	7.6	.491	12.3	.120	1.21					250	-.049	550
30	17.7	13.7	.5	.261	6.5	.537	13.4	.156	1.57					246	-.047	625
35	17.1	13.1	.6	.360	9.0	.443	11.1	.057	.58					287	-.054	450
40	16.1	12.1	1.0	.386	9.6	.440	11.0	.034	.35					307	-.056	450
45	15.7	11.7	.4	.496	12.3	.346	8.6	.028	.29					332	-.058	400
50	15.0	11.0	.7	.506	12.6	.335	8.4	.021	.22					346	-.058	400
55	14.4	10.4	.6	.527	13.1	.319	8.0	.017	.18					358	-.059	400
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	3381	-.607	*****
60	13.6	9.6	.9	.609	15.2	.240	6.0	.021	.22					385	-.059	400
65	12.7	8.7	.9	.612	15.2	.245	6.1	.030	.31					401	-.061	400
70	12.1	8.1	.6	.557	13.9	.291	7.3	.009	.10					391	-.060	425
75	11.5	7.5	.6	.519	12.9	.322	8.0	.009	.10					387	-.060	400
80	10.9	6.9	.6	.494	12.3	.347	8.7	.016	.17					367	-.059	425
85	10.4	6.4	.5	.533	13.3	.315	7.9	.008	.09					367	-.058	425
90	9.9	5.9	.5	.449	11.2	.371	9.3	.028	.29					356	-.068	450
95	9.5	5.5	.4	.427	10.6	.384	9.6	.061	.62					343	-.067	475
100	9.2	5.2	.3	.390	9.7	.401	10.0	.074	.77					327	-.061	475
105	8.8	4.8	.4	.423	10.5	.376	9.4	.065	.66					329	-.059	500
110	8.4	4.4	.4	.453	11.3	.358	8.9	.051	.52					320	-.056	500
115	8.0	4.0	.4	.484	12.0	.341	8.5	.037	.38					327	-.054	475
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	4306	-.722	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	7687	-1.329	*****

WEIGHT: 7.0

GAS DATA SHEET # 14


UNIT: F500

RUN: 5

DATE: 05-21-02 PAGE: 2

of 3

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL WB	STACK	STATIC	SO ₂ PPM
120	7.5	3.5	.5	.418	10.4	.386	9.6	.040	.41					320	-0.050	450
125	7.3	3.3	.2	.325	8.1	.446	11.2	.110	1.11					302	-0.055	475
130	7.1	3.1	.2	.316	7.9	.446	11.2	.120	1.21					284	-0.050	500
135	6.9	2.9	.2	.295	7.3	.476	11.9	.128	1.29					256	-0.046	525
140	6.8	2.8	.1	.295	7.3	.479	12.0	.120	1.21					257	-0.044	525
145	6.6	2.6	.2	.286	7.1	.484	12.1	.141	1.42					249	-0.043	525
150	6.5	2.5	.1	.274	6.8	.499	12.5	.124	1.25					242	-0.041	500
155	6.4	2.4	.1	.276	6.9	.497	12.4	.114	1.15					237	-0.041	525
160	6.3	2.3	.1	.270	6.7	.502	12.6	.129	1.30					232	-0.040	500
165	6.2	2.2	.1	.260	6.5	.510	12.8	.154	1.55					228	-0.040	500
170	6.1	2.1	.1	.259	6.4	.512	12.8	.154	1.55					225	-0.040	500
175	6.0	2.0	.1	.259	6.4	.510	12.8	.161	1.62					220	-0.039	500
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	3052	-529	*****
180	5.9	1.9	.1	.255	6.3	.513	12.8	.169	1.70					218	-0.039	500
185	5.8	1.8	.1	.244	6.2	.525	13.1	.164	1.65					214	-0.039	500
190	5.7	1.7	.1	.244	6.2	.526	13.2	.158	1.59					212	-0.038	500
195	5.6	1.6	.1	.265	6.6	.515	12.9	.135	1.36					211	-0.038	500
200	5.5	1.5	.1	.266	6.6	.519	13.0	.111	1.12					212	-0.038	500
205	5.4	1.4	.1	.253	6.3	.527	13.2	.133	1.34					212	-0.038	500
210	5.3	1.3	.1	.232	5.8	.547	13.7	.155	1.56					206	-0.037	500
215	5.2	1.2	.1	.233	5.8	.547	13.7	.151	1.52					204	-0.037	500
220	5.1	1.1	.1	.193	4.8	.571	14.3	.229	2.29					199	-0.036	500
225	5.1	1.1	.1	.192	4.8	.570	14.3	.226	2.26					196	-0.034	525
230	5.0	1.0	.1	.199	4.9	.570	14.3	.201	2.02					194	-0.033	525
235	4.9	.9	.1	.204	5.1	.567	14.2	.196	1.97					193	-0.033	525
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	2471	-440	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	5523	-969	*****



WEIGHT: 4.0
 UNIT: F500

GAS DATA SHEET # 12

RUN: 5 DATE: 05-21-02 PAGE: 3 of 3

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	WB	DB	% H ₂ O	CAL.WB	STACK	STATIC	SO ₂ PPM
240	4.9	.9	0	.191	4.7	.574	14.4	.228	2.28					191	-032	525
245	4.8	.8	.1	.190	4.7	.574	14.4	.230	2.30					189	-032	525
250	4.7	.7	.1	.189	4.7	.573	14.3	.229	2.29					187	-031	525
255	4.7	.7	0	.188	4.7	.578	14.5	.224	2.24					187	-031	525
260	4.6	.6	.1	.188	4.7	.578	14.5	.224	2.24					186	-031	525
265	4.5	.5	.1	.188	4.7	.578	14.5	.224	2.24					185	-031	525
270	4.5	.5	0	.186	4.6	.583	14.6	.201	2.01					183	-031	525
275	4.4	.4	.1	.201	5.0	.582	14.6	.163	1.64					183	-030	525
280	4.3	.3	.1	.192	4.8	.585	14.7	.178	1.79					182	-030	525
285	4.3	.3	0	.191	4.7	.582	14.6	.189	1.90					181	-030	525
290	4.2	.2	.1	.187	4.6	.583	14.6	.198	1.99					181	-030	525
295	4.2	.2	0	.180	4.5	.584	14.6	.225	2.25					180	-030	525
TOTAL	*****	****	****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	2215	-369	*****
300	4.1	.1	.1	.177	4.4	.587	14.7	.220	2.20					179	-030	525
305	4.1	.1	0	.175	4.3	.588	14.7	.220	2.20					178	-030	525
310	4.0	0	.1	.172	4.3	.592	14.8	.211	2.11					177	-030	525
315																
320														534	-090	
325																
330																
335																
340																
345																
350																
355																463
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	1599	-2757	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	253	-044	*****

TEMPERATURE DATA SHEET # 14

UNIT: F500

RUN: 5

DATE: 05-21-02

PAGE 1

of 3

TIME	TOP	LT SIDE	BACK	RT SIDE	BOTTOM	FIREBOX	SEC/CAT	AMBIENT	FURNACE	SAMPLE	SAMP IMP	C-GAS	GAS IMP	SO, IMP
0	1250	302	271	302	260	649	596	70	1286	238	65	239	36	2730
5	371	223	263	293	265	557	832	69	1290	240	44	243	36	37
10	326	218	256	285	274	524	596	68	1291	239	45	245	34	36
15	303	211	246	274	274	506	567	67	1290	239	45	245	36	37
20	289	204	238	263	269	493	663	67	1292	238	46	246	36	37
25	313	201	232	257	264	483	779	67	1298	239	46	247	36	37
30	325	196	227	248	260	479	1048	67	1308	238	46	245	35	37
35	378	193	223	239	250	498	1254	67	1313	239	46	246	35	36
40	415	194	225	234	247	514	1261	70	1315	241	45	247	35	34
45	457	200	224	231	242	530	1279	72	1318	243	46	250	34	35
50	506	200	234	229	234	569	1340	74	1328	242	46	250	36	35
55	524	203	236	230	232	561	1346	74	1327	243	46	248	36	36
TOTAL	4509	2473	2875	3085	3071	6363	11561	832	*****	*****	*****	*****	*****	*****
60	1350	204	235	231	231	553	1348	75	1327	245	47	246	36	37
65	565	218	245	233	226	614	1334	76	1328	242	47	244	37	36
70	564	215	248	236	226	635	1280	77	1331	246	47	244	36	35
75	555	216	258	242	223	659	1248	78	1336	246	47	247	35	34
80	507	227	264	247	221	668	1243	78	1338	242	48	247	34	35
85	554	232	269	252	227	690	1256	78	1338	242	48	248	35	36
90	542	236	272	257	222	696	1199	78	1341	243	49	250	36	36
95	435	241	273	259	224	709	1174	77	1343	243	49	251	36	35
100	507	257	274	266	227	712	1151	75	1344	243	50	253	35	34
105	508	251	278	271	228	725	1199	76	1345	242	49	252	36	36
110	509	248	281	274	229	738	1240	75	1346	241	50	252	37	36
115	511	245	284	279	230	751	1280	75	1348	240	50	253	36	38
TOTAL	6302	2796	3181	3047	2714	8149	14955	918	*****	*****	*****	*****	*****	*****
TOTAL	10811	5263	6056	6132	5785	14512	26516	1750	*****	*****	*****	*****	*****	*****

TEMPERATURE DATA SHEET # 14

UNIT: F500

RUN: 5

DATE: 05-21-02

PAGE

of

3

TIME	TOP	LT SIDE	BACK	RT SIDE	BOTTOM	FIREBOX	SEC/CAT	AMBIENT	FURNACE	SAMPLE	SAMP IMP	C-GAS	GAS IMP	SO ₂ IMP
0	302	230	271	302	260	649	596	70	1286	238	65	239	36	2730
5	371	223	263	293	265	557	832	69	1290	240	44	243	36	35
10	326	218	256	285	274	524	596	68	1291	239	45	245	34	36
15	303	211	246	274	274	506	567	67	1290	239	45	245	36	37
20	289	204	238	263	269	493	663	67	1292	238	46	246	36	37
25	313	201	232	257	264	483	779	67	1298	239	46	247	36	37
30	325	196	227	248	260	479	1048	67	1308	238	46	245	35	37
35	378	193	223	239	250	498	1254	67	1313	239	46	246	35	36
40	415	194	225	234	247	514	1261	70	1315	241	45	247	36	34
45	457	200	224	231	242	530	1279	72	1318	243	46	250	34	55
50	506	200	234	229	234	569	1340	74	1328	242	46	250	36	35
55	524	203	236	230	232	561	1346	74	1327	243	46	248	36	36
TOTAL	4509	2473	2875	3085	3071	6363	11561	832	*****	*****	*****	*****	*****	*****
60	545	204	235	231	231	553	1348	75	1327	245	47	246	36	37
65	565	218	245	233	226	614	1334	76	1328	242	47	244	37	36
70	564	215	248	236	226	635	1280	77	1331	246	47	244	36	35
75	555	216	258	242	223	659	1248	78	1336	246	47	247	35	34
80	507	227	264	247	221	668	1243	78	1338	242	48	247	34	35
85	554	232	269	252	227	690	1256	78	1338	242	48	248	35	36
90	542	236	272	257	222	696	1199	78	1341	243	49	250	36	36
95	435	241	273	259	224	709	1174	77	1343	243	49	251	36	35
100	507	257	274	266	227	712	1154	75	1344	243	50	253	35	34
105	508	251	278	271	228	725	1199	76	1345	242	49	252	36	36
110	509	248	281	274	229	738	1240	75	1346	241	50	252	37	36
115	511	245	284	279	230	751	1280	75	1348	240	50	253	36	38
TOTAL	6302	2796	3181	3047	2714	8149	14955	918	*****	*****	*****	*****	*****	*****
TOTAL	10811	5263	6056	6132	5785	14512	26516	1750	*****	*****	*****	*****	*****	*****

UNIT: F500

RUN: 5

DATE: 05-21-02 PAGE 2 of 3

TIME	TOP	LT SIDE	BACK	RT SIDE	BOTTOM	FIREBOX	SEC/CAT	AMBIENT	FURNACE	SAMPLE	SAMP IMP	C-GAS	GAS IMP	SO ₂ IMP
120 140	493	252	285	286	232	755	1059	75	1348	239	50	253	34	35
125 55	469	254	287	289	232	762	1004	76	1350	238	51	253	35	36
130 150	447	256	290	292	232	770	944	76	1352	238	50	253	35	36
135 05	425	253	290	297	232	776	913	78	1355	239	51	256	36	38
140 10	406	253	293	300	233	777	895	79	1355	239	51	254	36	37
145 15	389	253	292	303	236	777	860	79	1355	239	51	252	36	37
150 20	372	252	293	304	239	773	808	79	1350	239	52	252	36	37
155 25	359	252	292	305	241	769	798	79	1343	238	52	251	36	37
160 30	348	250	290	305	242	763	776	80	1336	238	52	251	35	36
165 35	338	246	289	303	245	757	760	78	1330	237	52	249	35	36
170 40	331	245	288	302	245	754	746	78	1327	237	53	247	35	36
175 45	321	244	284	300	247	746	731	78	1321	236	53	245	35	36
TOTAL	4698	3010	3473	3586	2856	9179	10294	935	*****	*****	*****	*****	*****	*****
180 50	317	242	283	299	248	742	719	78	1321	235	53	245	35	36
185 55	309	240	280	296	249	725	690	78	1319	235	52	244	35	36
190 60	304	239	277	295	251	716	705	78	1317	234	53	243	36	36
195 05	301	236	274	292	252	705	721	77	1316	234	53	243	35	36
200 10	300	235	273	289	252	701	748	77	1313	233	53	243	35	36
205 15	296	233	270	288	251	693	741	77	1311	233	53	242	37	36
210 20	292	230	269	288	251	685	685	77	1310	232	53	242	37	36
215 25	288	229	268	286	252	680	691	77	1308	232	53	241	36	37
220 30	281	227	265	284	252	665	615	76	1307	231	54	242	36	35
225 35	276	228	264	283	252	651	600	78	1307	233	54	246	35	34
230 40	271	226	261	282	251	640	595	78	1312	234	54	247	35	35
235 45	266	225	258	279	248	633	591	78	1316	234	55	249	35	35
TOTAL	3501	2790	3242	3461	3009	8236	8101	929	*****	*****	*****	*****	*****	*****
TOTAL	8199	5800	6715	7047	5865	17415	18999	1864	*****	*****	*****	*****	*****	*****

273.0

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 05-21-2002

Analyte : CO₂ (15-1)

Unit : F500

Run # : 5

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO₂

Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 12.49 % CO₂

Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 407069

Range : 0 - 25.0 % CO₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % CO₂

EPA Control Limits = ± 2.5% of 25.0 % CO₂ = ± 0.625 % CO₂

Method 28 A = ± .2 % of 25.0 % CO₂ = ± .05 % CO₂

PRE RUN Audit : by : D. Wadsworth Time : 1115 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	.003	+ .003	+ .013
SPAN	50.0	.500	12.49	50.2	.502	12.491	+ .001	+ .006

POST RUN Audit : by : D. Wadsworth Time : 1820 Temp : 74 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	.003	+ .003	+ .013
SPAN	50.0	.500	12.49	50.0	.500	12.442	- .048	- .194

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05-21-2002 Analyte : O₂ (15-2)
 Unit : F500 Run # : 5
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂ Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC12767 Conc. : 12.50 % O₂ Cyl. Press. : 1420 PSI
 Certified by : AIR LIQUIDE Date : 02-15-02
 Analyzer : Make : TELEDYNE Model : 320 A SN : 37400
 Range : 0 - 25.0 % O₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 25.0 % O₂
 EPA Control Limits = ± 2.5% of 25.0 % O₂ = ± 0.625 % O₂
 Method 28 A = ± .2 % of 25.0 % O₂ = ± .05 % O₂

PRE RUN Audit : by : A. Wadlington Time : 1115 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.003	.011	+ .011	+ .043
SPAN	12.50	.500	12.50	12.49	.499	12.488	- .012	- .047

POST RUN Audit : by : A. Wadlington Time : 1820 Temp : 74 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.004	.036	+ .036	+ .144
SPAN	12.50	.500	12.50	12.49	.499	12.488	- .012	- .047

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date : 05-21-2002

Analyte : CO (15-3)

Unit : F500

Run # : 5

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO

Cyl. Press. : 2000 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC12767 Conc. : 4.80 % CO

Cyl. Press. : 1420 PSI

Certified by : AIR LIQUIDE

Date : 02-15-02

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 408005

Range : 0 - 10.0 % CO

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 10.0 % CO

EPA Control Limits = ± 2.5% of 10.0 % CO = ± 0.25 % CO

Method 28 A = ± .2 % of 10.0 % CO = ± .02 % CO

PRE RUN Audit : by : A. Wadsworth Time : 1115 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.014	+0.014	+0.141
SPAN	48.0	.480	4.80	48.0	.480	4.793	-0.007	-0.066

POST RUN Audit : by : A. Wadsworth Time : 1820 Temp : 74 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.004	+0.004	+0.041
SPAN	48.0	.480	4.80	48.1	.481	4.803	+0.003	+0.034

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05-21-2002 Analyte : SO₂ (15-4)
 Unit : F500 Run # : 5
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 2000 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC62184 Conc. : 1290 ppm SO₂ Cyl. Press. : 1350 PSI
 Certified by : AIR LIQUIDE Date : 01-29-01
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 403019
 Range : 0 - 2500 ppm SO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = ± 2.5% of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : D. Washington Time : 1105 Temp : 82 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	8.385	+8.385	+335
SPAN	51.6	.516	1290	51.7	.517	1294.729	+4.729	+189

POST RUN Audit : by : D. Washington Time : 1815 Temp : 75 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.2	.002	10.878	+10.878	+435
SPAN	51.6	.516	1290	51.5	.515	1289.743	-.257	-.010

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : F500 RUN : 5 DATE : 05-21-02

Thermocouple Check:

T/C # 1	<u>—</u>	°F	T/C # 13	<u>72.0</u>	°F
T/C # 2	<u>—</u>	°F	T/C # 14	<u>68.8</u>	°F
T/C # 3	<u>71.0</u>	°F	T/C # 15	<u>72.4</u>	°F
T/C # 4	<u>67.6</u>	°F	T/C # 16	<u>61.0</u>	°F
T/C # 5	<u>65.2</u>	°F	T/C # 17	<u>60.4</u>	°F
T/C # 6	<u>66.7</u>	°F	T/C # 18	<u>74.6</u>	°F
T/C # 7	<u>67.8</u>	°F	T/C # 19	<u>67.9</u>	°F
T/C # 8	<u>66.8</u>	°F	T/C # 20	<u>45.6</u>	°F
T/C # 9	<u>67.3</u>	°F	T/C # 21	<u>—</u>	°F
T/C # 10	<u>68.3</u>	°F	T/C # 22	<u>—</u>	°F
T/C # 11	<u>63.0</u>	°F	T/C # 23	<u>67.0</u>	°F
T/C # 12	<u>79.4</u>	°F	T/C # 24	<u>—</u>	°F

Thermocouple Readout:

Pretest zero and span check and calibration

ZERO : .4 °F Adj. to 0.0 °F

SPAN : 1998.0 °F Adj. to 2000.0 °F

post test zero and span

% difference

ZERO 1.2 °F Adj. to .060 %

SPAN 2004.2 °F Adj. to .210 %

Thermocouple Readout Pretest Linearity Check:

0	= <u>0.0</u> °F	200	= <u>202.4</u> °F	400	= <u>399.6</u> °F
600	= <u>601.9</u> °F	800	= <u>801.9</u> °F	1000	= <u>1000.9</u> °F
1200	= <u>1198.3</u> °F	1400	= <u>1399.2</u> °F	1600	= <u>1599.8</u> °F
1800	= <u>1800.1</u> °F	2000	= <u>2000.0</u> °F		

Sample Train Leak Check

Pre X

Post X

C-gas Train Leak Check

Pre ✓

Post ✓

SO₂ Train Leak Check

Pre ✓

Post ✓

Static Gauge Zero Check

Pre X

Post ✓

Scale Check Pre :

17.2 - 7.2


Post :

13.8 - 3.8

Stack Cleaned Prior to Test Run : YES

NO

X



INSPECTION CERTIFICATE

**Phillips
Morris
Scale
Company**

934 Elliott Avenue W.
Seattle, WA 98119
Ph#(206)284-6090
Fax#(206)282-6612

CUSTOMER: LOKKE TESTING
 ADDRESS: 13235 Prairie Circle E
Sumner, WA 98390
 TECHNICIAN: P. McCellan
 AUTHORIZATION SIGNATURE: _____

DATE OF INSPECTION: 5-2-02
 NEXT INSPECTION DUE: 11-2-02
 CERTIFICATION TYPE
 STANDARD
 ISO 9000
 MIL STD-45662

EQUIPMENT TESTED

INDICATOR	BASE	OPTIONS INSTALLED
MAKE <u>weightronix</u>	_____	PRINTER _____
MODEL <u>wr-110</u>	_____	SCORE BOARD _____
SR# <u>16409</u>	_____	COMPUTER _____
CLASS <u>III</u>	_____	OTHER _____
CAP. <u>1000 lbs</u>	_____	
PRE-TEST	POST-TEST	MANUFACTURER TOLERANCE
<u>1000.2</u>	<u>500.0</u>	_____
_____	<u>999.9</u>	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
CORNER TEST	P <input checked="" type="checkbox"/> F <input checked="" type="checkbox"/>	
SHIFT TEST	P <input checked="" type="checkbox"/> F <input checked="" type="checkbox"/>	
STATIC TEST	2 MIN. _____ 5 MIN. <input checked="" type="checkbox"/>	
WEIGHT KIT# _____	NIST# _____	
SERIAL NUMBERS OF WEIGHTS USED (OR COPY OF CERTIFICATE)		
<u>T15-20</u>	_____	_____
<u>T15-28</u>	_____	_____
_____	_____	_____
_____	_____	_____

QUALITY CONTROL SERVICES Inc.

2340 S.E. 11Th. Avenue Portland, Oregon 97214
(503) 236-2712 / FAX:(503) 235-2535

Customer and Contact
Lee Testing Labs
 235 Prairie Circle E
 Sumner, WA. 98390
 Ship Wadington

Report Number: EESPC37010004020508

CERTIFICATE OF CALIBRATION AND TEST RECORD

INSTRUMENT INFORMATION

Item	Make	Model	Serial Number	Customer ID	Location	SOP Used
Balance	Sartorius	A120S	37010004	N/A	Lab	QC012
Units	Readability	Range Calibrated	Tolerance Used	Cal. Date	Last Cal.	Cal. Due
Grams	0.0001	0-100	Factory	05/06/2002	10/31/2001	11/2002

Functional Checks

CORNERLOAD:	LINEARITY:	REPEATABILITY:	ENVIRONMENTAL CONDITIONS:
Test Wt: Tol: 100 0.0003	Test Wt: Tol: 50x2 0.0004	Test Wt: Tol: 100 0.0001	<input type="checkbox"/> Good <input checked="" type="checkbox"/> Fair <input type="checkbox"/> Poor
AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	
AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	

CALIBRATION DATA

Standard	As Found Instrument	As Left Instrument
100	100.0004	100.0000
70	70.0003	70.0000
50	50.0002	50.0000
20	20.0001	20.0000
10	10.0000	10.0000
5	5.0000	5.0000

CALIBRATION STANDARDS

Item	Make	Model	Serial Number	Units	Cal. Date	Cal. Due	Traceable ID#
Weight Set	R.L./Troemner	1MG-25KG	A45	Grams	12/13/2001	12/2002	2261-1201

Comments / Info Concerning This Calibration:

Permanent Information Concerning This Instrument:

Technician: D. Deleasa

Signature: 

CALIBRATIONS ARE PERFORMED UNDER AMBIENT CONDITIONS USING MANUFACTURER'S OR CUSTOMERS SPECIFICATIONS FOR THE PASS/FAIL RESULTS. RESULTS MAY BE INFLUENCED BY THE AGE OF THE INSTRUMENT AND ENVIRONMENTAL CONDITIONS. CALIBRATION DATA SHOULD BE REVIEWED TO INSURE THAT THE INSTRUMENT IS PERFORMING TO ITS INTENDED ACCURACY. CALIBRATIONS CONFORM TO ISO/IEC GUIDE 25-1990(17025) AND ANSI / NCSL Z540-1-1994 SPECIFICATIONS.

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF QUALITY CONTROL SERVICES, INC.

Form Number: BA62

Customer Code: EESPC

Rev. Date: 03/19/2002

QUALITY CONTROL SERVICES Inc.

2340 S.E. 11Th. Avenue Portland, Oregon 97214-5306

(503) 236-2712 / FAX:(503) 235-2535

CERTIFICATE OF CALIBRATION

Customer and Contact

Lokee Testing Labs
13235 Prairie Circle East
Sumner, WA. 98390
Chip Wadington

Report Number: EESPC37010004011031

INSTRUMENT INFORMATION

Item	Make	Model	Serial Number	Customer ID	Location	SOP Used
Balance	Sartorius	A120S	37010004	N/A	Lab	QC012
Units	Readability	Range Calibrated	Tolerance Used	Cal. Date	Last Cal.	Cal. Due
Grams	0.0001	0-100	Factory	10/31/2001	04/30/2001	04/2002

Functional Checks

Cornerload Linearity 0 - 1/2 - Full Capacity Reproduceability

CALIBRATION DATA

As Found Instrument	Standard	As Left Instrument
100.0002	100	100.0000
50.0001	50	50.0000
20.0000	20	20.0000
10.0000	10	10.0000
5.0000	5	5.0000
1.0000	1	1.0000

CALIBRATION STANDARDS

Item	Make	Model	Serial Number	Units	Cal. Date	Cal. Due	Traceable ID#
Weight Set	R.L./Troemner	5MG-25KG	A45	Grams	12/11/2000	12/2001	A45-2000

Comments / Info Concerning This Calibration:

Permanent Information Concerning This Instrument:

100 CUSTOMER REQUESTED SPECIFIC 6 POINT CHECK.100,50,20,10,5,1

Technician: D. Deleasa

Signature: D. Deleasa

CALIBRATIONS ARE PERFORMED UNDER AMBIENT CONDITIONS USING MANUFACTURER'S OR CUSTOMERS SPECIFICATIONS FOR THE PASS/FAIL RESULTS. RESULTS MAY BE INFLUENCED BY THE AGE OF THE INSTRUMENT AND ENVIRONMENTAL CONDITIONS. CALIBRATION DATA SHOULD BE REVIEWED TO INSURE THAT THE INSTRUMENT IS PERFORMING TO ITS INTENDED ACCURACY. CALIBRATIONS CONFORM TO ISO/IEC GUIDE 25-1990(17025) AND ANSI / NCSL Z540-1-1994 SPECIFICATIONS.

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF QUALITY CONTROL SERVICES, INC.

Thermocouple Calibration Record Semi-Annual

Thermocouples Check against

Reference Thermometer

serial number 9123454

Ice Water Bath

32.0

Boiling Water

211.9

Room Temperature

68.2

Barometric Pressure

30.02

DATE: 5-13-02

TC	Location	Ice Bath Temp	Boiling Water Temp
1	Wet Bulb	32.2	211.9
2	Dry Bulb	32.2	211.8
3	Stack	32.0	211.8
4	Stove Top	32.2	211.7
5	Left Side	32.1	211.9
6	Back	32.2	211.8
7	Right Side	32.0	212.0
8	Bottom	32.0	211.8
9	Firebox	32.1	211.9
10	Secondary/Cat	32.1	212.0
11	Ambient	32.2	211.7
12	Tube Furnace	32.0	212.0
13	Sample Box	32.1	211.8
14	Impinger Out	32.2	211.8
15	C. Gas Box	32.2	212.0
16	C. Gas Out	32.0	211.6
17	SO2 Out	32.0	211.9
18	Upper Ambient	32.1	212.0
19			
20			
21			
22			
23	Calibrator	32.0	211.9
24	Oven	32.0	211.5

Thermocouple Readout Semi-Annual Calibration Data Sheet

Date: 5-13-02
 Ambient Temperature: 68.6
 Technician: Ch W.

Thermocouple Number: T/C Readout
 Barometric Pressure: 30.02
 Reference: Mercury in glass
FISHER #9123454
 Other: OMEGA CL-300

Reference Point No. ^a	Source ^b	Reference Thermometer Temperature °F	Thermocouple Potentiometer Temperature °F	Difference (%) ^c
32	Ice Water	32.0	32.0	ϕ
212	Boiling Water	212.0	211.9	.047
250	Omega	250.0	250.0	ϕ
300	Omega	300.0	299.8	.067
400	Omega	400.0	400.3	-.075
500	Omega	500.0	500.1	-.020
600	Omega	600.0	599.8	.033
700	Omega	700.0	700.8	-.114
800	Omega	800.0	799.8	-.025
900	Omega	900.0	900.0	ϕ
1000	Omega	1000.0	1000.1	-.010
1200	Omega	1200.0	1198.7	.108
1400	Omega	1400.0	1399.6	.029
1600	Omega	1600.0	1599.2	.050
1800	Omega	1800.0	1799.8	.011
2000	Omega	2000.0	2000.0	ϕ

^a Every 50°F for each reference point

^b Type of Calibration System Used

^c
$$\frac{(\text{reference temperature}) - (\text{thermocouple temperature})}{\text{reference temperature}} * 100$$

TRACEABILITY DOCUMENTATION Semi-Annual

SO₂ INJECTION ROTAMETER, DRY GAS METER AND SLING PSYCHROMETER
THERMOMETERS IN LAB. CHECKED AGAINST FISHER SN 9123454 (NIST).

DATE: 5-13-02

SO₂ INJECTION ROTAMETER
9123454

FISHER SN

NIST Traceable

Actual	°C = °F	°F
0.0	32.0	32.0
18.8	65.9	65.9
39.4	102.9	103.0
58.6	136.7	136.4

DRY GAS METER THERMOCOUPLES

Actual	°C = °F	SH in	SH out	KK
0	32.0	32.0	32.0	32.0
18.8	66.0	66.1	66.1	66.2
39.4	102.9	102.7	103.0	102.8
58.2	136.7	136.6	136.6	136.8

SLING PSYCHROMETER

Actual	°C = °F	Wet Bulb	Dry Bulb
0	32.0	32.0	32.0
18.8	66.0	66.0	66.2
28.10	83.5	83.3	83.5
39.2	102.6	102.4	102.4

Conversions =

$$^{\circ}\text{F} = (^{\circ}\text{C} \times 1.8) + 32$$

$$^{\circ}\text{C} = (^{\circ}\text{F} - 32) / 1.8$$

VANEOMETER CALIBRATION

LoKee Testing Lab uses a Dwyer Model #480 Vaneometer to measure test chamber air velocity. The manufacturer's specifications for accuracy are $\pm 5.0\%$ to 100 FPM and $\pm 10\%$ from FPM to top of scale. LoKee Testing Lab insures that the instrument is level and clean prior to taking each reading. According to EPA personnel (Westlin, RTP) no further calibration of the instrument is necessary.

DRAFT GAUGE CALIBRATION

LoKee Testing Lab uses a Dwyer model 115-AV 0-0.25" inclined water manometer (readability resolution ± 0.001 " of water) to measure the static pressure in the stack. Once leveled and zeroed as per the manufacturer's written operating instructions, the Dwyer manometer is a primary standard and requires no additional calibration.

The manometer is leveled and zeroed at the start of each test run, checked as necessary during the run to verify the settings have not changed and again at the end of each test run. The results of each check are recorded on Data Sheet #16 in each test run.

BAROMETER CALIBRATION

LoKee Testing Lab uses a Princo Model 469 NOVA Mercury Barometer to measure barometric pressure. When installed and maintained as per the manufacturer's written operating instruction, the Princo Model 469 Mercury Barometer is a primary standard and needs no further calibration.

MOISTURE METER CALIBRATION

The Delmhorst Model RC-1C, SN 16152 Moisture Meter is calibrated each time the meter is used by adjusting the zero and span calibration. The potentiometers of each calibration point (X = zero, Y = span) are adjusted until the meter is calibrated correctly. The meter is then checked against a calibration block (Delmhorst Model MCS-1, moisture content standard at 12.0% and 22.0%) in its normal operating range of 11-25%.

LoKee Testing Lab also has a second moisture meter, Delmhorst Model G-30, SN 2477 to use as a backup.

POST TEST METER BOX AUDIT DATA SHEET

UNIT: F500 DATE: 6-23-02

TEST DATA

RUN #	1	2	3	4	5	6	7	8	9	10
AVG. Δ H	.142	.106	.137	.169	.154	Σ	Σ	Σ	Σ	Σ
MAX VAC	2.0	2.0	2.0	3.0	3.0	Σ	Σ	Σ	Σ	Σ

Avg. Test Series Δ H: .142 in H₂O Test Series Max Vac: 3.0 in Hg

Audit Dry Gas Meter: KZ Correction (Y) Factor: 1.006 (mcf)

Test Dry Gas Meter: H Correction (Y) Factor: 1.000 (mcf)

AUDIT DATA

	Audit #1	Audit #2	Audit #3
BP	<u>30.02</u>	<u>30.02</u>	<u>30.02</u>
VAC	<u>3.0</u>	<u>3.0</u>	<u>3.0</u>

AUDIT METER :

VOL. (Vw)	Final	Initial	Vol.	Audit #1	Audit #2	Audit #3
				<u>200.000</u>	<u>204.983</u>	<u>209.975</u>
				<u>195.000</u>	<u>200.000</u>	<u>204.983</u>
				<u>5.000</u>	<u>4.983</u>	<u>4.992</u>

TEMP (°F) (Tw)	Initial	Mid	Final	Avg.	Audit #1	Audit #2	Audit #3
	<u>88</u>	<u>89</u>	<u>90</u>	<u>89</u>	<u>88</u>	<u>90</u>	<u>92</u>
					<u>89</u>	<u>91</u>	<u>93</u>
					<u>90</u>	<u>92</u>	<u>94</u>
(°F / °A)					<u>89</u> (549)	<u>91</u> (551)	<u>93</u> (553)

Δ H	Initial	Mid	Final	Avg.	Audit #1	Audit #2	Audit #3
	<u>.142</u>	<u>.142</u>	<u>.142</u>	<u>.142</u>	<u>.142</u>	<u>.142</u>	<u>.142</u>
					<u>.142</u>	<u>.142</u>	<u>.142</u>
					<u>.142</u>	<u>.142</u>	<u>.142</u>
					<u>.142</u>	<u>.142</u>	<u>.142</u>

DRY GAS METER :

VOL. (Vd)	Final	Initial	Vol.	Audit #1	Audit #2	Audit #3
	<u>877.500</u>	<u>872.500</u>	<u>5.000</u>	<u>877.500</u>	<u>882.500</u>	<u>887.500</u>
				<u>872.500</u>	<u>877.500</u>	<u>882.500</u>
				<u>5.000</u>	<u>5.000</u>	<u>5.000</u>

TEMP (°F) (Tm)	Initial	Mid	Final	Avg.	Audit #1	Audit #2	Audit #3
	<u>83</u>	<u>85</u>	<u>86</u>	<u>85</u>	<u>83</u>	<u>86</u>	<u>90</u>
					<u>85</u>	<u>88</u>	<u>92</u>
					<u>86</u>	<u>90</u>	<u>94</u>
(°F / °A)					<u>85</u> (545)	<u>88</u> (548)	<u>92</u> (552)

$$Y = \frac{(V_w)(mcf)(BP)(T_m)}{(V_d) \left(BP + \frac{DH}{13.6} \right) (T_w)}$$

$$Y \text{ Factor } \% \text{ Diff.} = \frac{\text{Act} - \text{Exp}}{\text{Exp}} \times 100$$

NOTE : mcf = meter correction (Y) factor for Dry Gas Meter used as a transfer standard

RUN 1

$$Y = \frac{(5.000)(1.006)(30.02)(545)}{(5.000) \left(30.02 + \frac{.142}{13.6} \right) (549)} = \frac{82295.33}{82433.56} = .998$$

$$\Delta \% = \frac{(.998 - .994)}{.994} \times 100 = .426 \%$$

RUN 2

$$Y = \frac{(4.983)(1.006)(30.02)(548)}{(5.000) \left(30.02 + \frac{.142}{13.6} \right) (551)} = \frac{82466.98}{82733.87} = .997$$

$$\Delta \% = \frac{(.997 - .994)}{.994} \times 100 = .319 \%$$

RUN 3

$$Y = \frac{(4.992)(1.006)(30.02)(552)}{(5.000) \left(30.02 + \frac{.142}{13.6} \right) (553)} = \frac{83218.97}{83034.17} = 1.002$$

$$\Delta \% = \frac{(1.002 - .994)}{.994} \times 100 = 2.766 \%$$

NOTE : The Y factor % difference must be < ± 5.0 % to be acceptable

INTERPOLATED Y FACTOR

$$\frac{.1}{(A)} \text{ inch H}_2\text{O } \Delta H = \frac{.992}{(C)}$$

Calculated calibration Y factor from calibrations

$$\frac{.2}{(B)} \text{ inch H}_2\text{O } \Delta H = \frac{.996}{(D)}$$

Calculated calibration Y factor from calibrations

$$\frac{.2}{(B)} - \frac{.1}{(A)} = \frac{.1}{(D)} \times 100 = \frac{10}{(E)}$$

$$\frac{.996}{(D)} - \frac{.992}{(C)} = \frac{.004}{(E)} \times \frac{10}{(F)} = \frac{.0004}{(F)}$$

$$\frac{.142}{\text{Avg } \Delta H} - \frac{.1}{(A)} = \frac{.042}{(G)} \times 100 = \frac{4.2}{(G)}$$

$$\left[\frac{.0004}{(F)} \times \frac{4.2}{(G)} \right] + \frac{.992}{(C)} = \frac{.994}{\text{Interpolated Y factor}}$$

Volume Metering System Leak Check : 0.000 inch H₂O in one minute

DRY GAS METER CALIBRATION

DATE: 5-13-02 DRY GAS METER: H BOX: 5

BAROMETRIC PRESSURE, Pb		30.23 in. Hg.					
Orifice Manometer Setting, ΔH, in. H ₂ O		.1	.2	.3	.5	.75	1.0
Gas Volume Wet Test Meter Vw ft ³	Final	153.054	158.121	163.195	168.268	174.357	179.438
	Initial	148.000	153.054	158.121	163.195	168.268	174.357
	Vw ft ³	5.054	5.067	5.074	5.073	6.089	5.081
Gas Volume Dry Test Meter Vd ft ³	Final	417.000	422.000	427.000	432.000	438.000	443.000
	Initial	412.000	417.000	422.000	427.000	432.000	438.000
	Vd ft ³	5.000	5.000	5.000	5.000	6.000	5.000
Wet Test Meter Temperature tw	Initial	80	78	78	78	78	78
	Middle	79	78	78	78	78	77
	Final	78	78	78	78	78	77
	Average	79 (539)	78 (538)	(538)	(538)	(538)	(537)
Dry Test Meter Temperature tm	Initial	66	66	66	67	69	71
	Middle	66	66	67	68	70	71
	Final	66	66	67	69	71	71
	Average	66 (526)	66 (526)	(527)	(528)	(530)	(531)
$Y = \frac{(Kz) (Vw) (Pb) (tm)}{Vd \left[Pb + \frac{\Delta H}{13.6} \right] (tw)}$		80845.73 81481.67	81053.69 81358.26	81319.97 81378.04	81458.22 81417.60	98142.64 97760.46	82050.24 81364.98
		.992	.996	.999	1.000	1.004	1.008

Average Y = 1.000

METER BOX CALIBRATION

Avg MKF 1.0055
1.006

Date : 07/11/01
 Calibrated By : J.C.
 Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 28.1 in. Hg
 Vacuum = 0.0 in. Hg

Orifice Manometer
 Setting, Delta H
 in. H2O

	0.10	0.10	0.10	0.10	0.10	0.10
--	------	------	------	------	------	------

Gas Volume Wet Test Meter
 Vw, cu. ft.

	5.000	5.000	5.000	5.000	5.000	5.000
--	-------	-------	-------	-------	-------	-------

Gas Volume Dry Gas Meter

	M Final 1058.033	1063.070	1068.101	1073.139	1078.188	1083.200
	M Initial 1053.000	1058.033	1063.070	1068.101	1073.139	1078.139
Vd, cu. ft.	5.033	5.037	5.031	5.038	5.049	5.061

Wet Test Meter

tw Deg F	84	84	84	84	84	84
tw Deg A	544	544	544	544	544	544

Dry Gas Meter

Outlet, tmo	1)	86	86	87	88	90	91
	2)	86	87	87	89	90	92
	3)	86	87	88	89	90	92

Dry Gas Meter

Inlet, tmi	1)	91	91	92	92	94	95
	2)	91	92	92	93	94	96
	3)	91	92	92	93	95	96

Mean tm, Deg F

	89	89	90	91	92	94
Mean tm, Deg A	549	549	550	551	552	554

Results :

	Y =	1.002	1.002	1.004	1.004	1.005	1.005
--	-----	-------	-------	-------	-------	-------	-------

Averages :

	Y =	1.004
--	-----	-------

METER BOX CALIBRATION

Date : 01/11/01
Calibrated By : J.C.
Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 28.1 in. Hg
Vacuum = 0.0 in. Hg

Orifice Manometer
Setting, Delta H
in. H2O

0.20	0.20	0.20	0.20	0.20	0.20
------	------	------	------	------	------

Gas Volume Wet Test Meter
Vw, cu. ft.

5.000	5.000	5.000	5.000	5.000	5.000
-------	-------	-------	-------	-------	-------

Gas Volume Dry Gas Meter

	1088.255	1093.310	1098.375	1103.444	1108.513	1113.590
M Final						
M Initial	1083.200	1088.255	1093.310	1098.375	1103.444	1108.513
Vd, cu. ft.	5.055	5.055	5.065	5.069	5.069	5.077

Wet Test Meter
tw Deg F
tw Deg A

84	84	84	84	84	84
544	544	544	544	544	544

Dry Gas Meter
Outlet, tmo

	88	89	89	91	92	93
1)						
2)	88	89	90	91	92	93
3)	89	89	90	91	93	94

Dry Gas Meter
Inlet, tmi

	94	95	96	97	99	99
1)						
2)	94	95	96	98	99	100
3)	95	95	97	98	99	100

Mean tm, Deg F
Mean tm, Deg A

91	92	93	94	96	97
551	552	553	554	556	557

Results :

	1.001	1.003	1.003	1.005	1.007	1.007
Y =						

Averages :

	1.004
Y =	

METER BOX CALIBRATION

Date : 07/11/01
 Calibrated By : J.C.
 Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 28.1 in. Hg
 Vacuum = 0.0 in. Hg

Orifice Manometer
 Setting, Delta H
 in. H2O

0.30 0.30 0.30 0.30 0.30 0.30

Gas Volume Wet Test Meter
 Vw, cu. ft.

5.000 5.000 5.000 5.000 5.000 5.000

Gas Volume Dry Gas Meter
 M Final
 M Initial
 Vd, cu. ft.

	118.654	123.730	128.811	133.900	138.989	144.090
	113.590	118.654	123.730	128.811	133.900	138.989
	5.064	5.076	5.081	5.089	5.089	5.101

Wet Test Meter
 tw Deg F
 tw Deg A

	84	84	85	85	85	85
	544	544	545	545	545	545

Dry Gas Meter
 Outlet, tmo
 1)
 2)
 3)

	92	93	94	95	95	96
	92	94	94	95	95	96
	93	94	94	95	95	96

Dry Gas Meter
 Inlet, tmi
 1)
 2)
 3)

	95	97	99	100	102	103
	95	97	100	101	102	103
	96	98	100	102	103	104

Mean tm, Deg F
Mean tm, Deg A

	94	96	97	98	99	100
	554	556	557	558	559	560

Results :

	Y =	1.005	1.005	1.005	1.005	1.006	1.006
--	-----	-------	-------	-------	-------	-------	-------

Averages :

	Y =	1.005
--	-----	-------

METER BOX CALIBRATION

Date : 07/11/01
Calibrated By : J.C.
Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 28.11 in. Hg
Vacuum = 0.0 in. Hg

Orifice Manometer
Setting, Delta H
in. H2O

	0.50	0.50	0.50	0.50	0.50	0.50
--	------	------	------	------	------	------

Gas Volume Wet Test Meter
Vw, cu. ft.

	5.000	5.000	5.000	5.000	5.000	5.000
--	-------	-------	-------	-------	-------	-------

Gas Volume Dry Gas Meter

	149.140	154.207	159.295	164.392	169.499	174.610
M Final						
M Initial	144.090	149.140	154.207	159.295	164.392	169.499
Vd, cu. ft.	5.050	5.067	5.088	5.097	5.107	5.111

Wet Test Meter
tw Deg F
tw Deg A

	85	85	85	85	85	85
tw Deg F	545	545	545	545	545	545
tw Deg A						

Dry Gas Meter
Outlet, tmo

	94	95	96	96	97	97
1)	94	95	96	96	97	97
2)	94	95	96	96	97	97
3)	95	95	96	96	97	97

Dry Gas Meter
Inlet tmi

	91	96	100	102	103	105
1)	91	96	100	102	103	105
2)	93	98	101	103	104	106
3)	96	100	103	104	105	106

Mean tm, Deg F
Mean tm, Deg A

	94	97	99	100	101	101
Mean tm, Deg F	554	557	559	560	561	561
Mean tm, Deg A						

Results :

	1.005	1.006	1.006	1.006	1.006	1.006
Y =						

Averages :

	1.006
Y =	



Scott Specialty Gases

500 WEAVER PARK RD, LONGMONT, CO 80501

Phone: 303-442-4700

Fax: 303-772-7673

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

ENERGY & ENV MEASUREMENT

C/O ED WADINGTON
3730 N. PELLEGRINO DR.
TUCSON, AZ 85749

Assay Laboratory

SCOTT SPECIALTY GASES
500 WEAVER PARK RD
LONGMONT, CO 80501

Project No.: 08-34135-003

P.O. No.: VERBAL

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #G1; September, 1993.

Cylinder Number: ALM049127
Cylinder Pressure***: 1860 PSIG

Certification Date: 4/21/97

Exp. Date: 4/21/2000

COMPONENT

SULFUR DIOXIDE °
NITROGEN

CERTIFIED CONCENTRATION
1,770 PPM
BALANCE

ANALYTICAL ACCURACY**
+/- 1% NIST TRACEABLE

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST standards.

* This Protocol has been certified using corrected NIST SO2 standard values, per EPA guidance dated 7/24/96 and will not correlate with uncorrected Protocols.

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM-R-1696	7/03/98	ALM057797	3131. PPM	SULFUR DIOXIDE

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#
FTIR System/8220/AAB9400251

LAST DATE CALIBRATED
03/20/97

ANALYTICAL PRINCIPLE
Scott Enhanced FTIR

ANALYZER READINGS

First Triad Analysis

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)
Second Triad Analysis Calibration Curve

SULFUR DIOXIDE °

Date: 04/14/97 Response Unit: PPM

Z1=0.7210	R1=3127.7	T1=1767.1
R2=3131.7	Z2=4.6770	T2=1768.1
Z3=4.6770	T3=1768.1	R3=3133.7

Avg. Concentration: 1768. PPM

Date: 04/21/97 Response Unit: PPM

Z1=0.4020	R1=3125.8	T1=1770.2
R2=3132.3	Z2=6.8640	T2=1769.3
Z3=4.9410	T3=1770.9	R3=3134.8

Avg. Concentration: 1770. PPM

Concentration = A + Bx + Cx² + Dx³ + Ex⁴

r = 0.999980 1898

Constants: A = 0.00000

B = 1.00000 C = 0.00000

D = 0.00000 E = 0.00000

Special Notes:

ANALYST:

Devon VonFeldt
DEVON VONFELDT

SO2 concentration analysis
05/14/02

Vm(std) 1.500

mcf 1

Hg 30.08

DH 0.12

temp 69

ml BA ++ 621

Normality 0.0101

529

dscf= 1.500

ppm = 1778

Run1 1773

Run 2 1761

Run3 1778

avg. 1771

Tank I.D. # ALMO49127

Certificate of Analysis

ANALYTICAL CONTROL LABORATORY ANALYSIS

ACETONE - OPTIMA

Catalog No.: A-929

January 13, 1997

Lot No.: 972630

This is to certify that this lot was tested and found to comply with the specifications for this product. The following are the actual analytical results obtained:

TESTS

Aldehyde
Assay
Color
Density (g/mL) at 25°C
Description
Fluorescence Background
(as Quinine Sulfate)
Identification
Isopropyl Alcohol
Methanol
Optical Absorbance at 350nm
 at 340nm
 at 330nm
Pesticide Residue Analysis
(as Heptachlor Epoxide)
Refractive Index at 25°C
Residue after Evaporation
Solubility in Water
Substances Reducing Permanganate
Titratable Acid
Titratable Base
Water (H₂O)

ACTUAL ANALYSIS

0.0005%
99.6%
5 APHA
0.7851
Clear, Colorless Liquid
Not More Than 1 PPB

Pass Test
0.01%
0.03%
0.001
0.05
0.69
Not More Than 10 ng/L

1.3560
0.3 PPM
Pass Test
Pass Test
0.0003 Meq/g.
0.0001 Meq/g.
0.4%

Approved By: _____

Robert Dowd
Robert Dowd
Q.C. Laboratory Manager



Fisher
Scientific

Chemical Division
1 Reagent Lane
Fair Lawn, N.J. 07410
(201) 796-7100

METER BOX CALIBRATION

Date : 07/11/01
Calibrated By : J.C.
Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 28.11 in. Hg
Vacuum = 0.0 in. Hg

Orifice Manometer
Setting, Delta H
in. H2O

	0.75	0.75	0.75	0.75	0.75	0.75
--	------	------	------	------	------	------

Gas Volume Wet Test Meter
Vw, cu. ft.

	5.000	5.000	5.000	5.000	5.000	5.000
--	-------	-------	-------	-------	-------	-------

Gas Volume Dry Gas Meter

	179.682	184.756	189.839	200.016	205.109	210.211
M Final						
M Initial	174.610	179.682	184.756	194.927	200.016	205.109
Vd, cu. ft.	5.072	5.074	5.083	5.089	5.093	5.102

Wet Test Meter
tw Deg F
tw Deg A

	85	85	85	85	85	85
tw Deg F						
tw Deg A	545	545	545	545	545	545

Dry Gas Meter
Outlet, tmo

	95	96	96	97	97	98
1)						
2)	95	96	96	97	97	98
3)	95	96	97	97	97	98

Dry Gas Meter
Inlet, tmi

	99	100	101	102	103	104
1)						
2)	99	101	102	103	104	105
3)	100	101	102	103	104	105

Mean tm, Deg F
Mean tm, Deg A

	97	98	99	100	100	101
Mean tm, Deg F						
Mean tm, Deg A	557	558	559	560	560	561

Results :

	1.006	1.007	1.007	1.007	1.007	1.007
Y =						

Averages :

	1.007
Y =	

METER BOX CALIBRATION

Date : 07/11/01
Calibrated By : J.C.
Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 28.11 in. Hg
Vacuum = 0.0 in. Hg

Orifice Manometer

Setting, Delta H
in. H2O

	1.00	1.00	1.00	1.00	1.00	1.00
--	------	------	------	------	------	------

Gas Volume Wet Test Meter

Vw, cu. ft.

	5.000	5.000	5.000	5.000	5.000	5.000
--	-------	-------	-------	-------	-------	-------

Gas Volume Dry Gas Meter

M Final	215.294	220.386	225.481	230.580	235.682	240.785
M Initial	210.211	215.294	220.386	225.481	230.580	235.682
Vd, cu. ft.	5.083	5.092	5.095	5.099	5.102	5.103

Wet Test Meter

tw Deg F	85	85	85	85	85	85
tw Deg A	545	545	545	545	545	545

Dry Gas Meter

Outlet, tmo						
	1)	97	97	98	98	98
	2)	97	98	98	98	98
	3)	97	98	98	98	98

Dry Gas Meter

Inlet, tmi						
	1)	100	102	103	104	105
	2)	100	103	104	105	105
	3)	102	103	104	105	106

Mean tm, Deg F

	99	100	101	101	102	102
Mean tm, Deg A	559	560	561	561	562	562

Results :

Y =	1.006	1.007	1.007	1.007	1.007	1.008

Averages :

Y =	1.007
------------	-------

WET TEST METER CALIBRATION LOG

Wet Test Meter Serial Number AA455 Date 8-20-01

Range of Wet Test Meter Flow Rate 0 - 0.25

Volume of Test Flask Vs 37.850 Hs

Satisfactory Leak Check? Yes

Ambient Temperature of Equilibrate Liquid in Wet Test Meter and Reservoir 82°F

TEST #	MANOMETER READING, a mm H ₂ O	FINAL VOLUME (Vf), l	INITIAL VOLUME (Vi), l	TOTAL VOLUME (Vm), b l	FLASK VOLUME (Vs), l	PERCENT ERROR, c %
1	∅	3.0	Reset to ∅	3.0	3.007	- .233
2	∅	3.0	Reset to ∅	3.0	3.010	- .332
3	∅	3.0	Reset to ∅	3.0	3.011	- .365

a - Must be less than 10 mm H₂O (0.4' H₂O)

Calculations:

b - $V_m - V_f - V_i$

c - % error = $\frac{100(V_m - V_s)}{V_s} = \text{Avg } - .308 (\pm 1\%)$

SO₂ ROTAMETER CALIBRATION

Last Cal. : 10-12-01 By: Clp W Date: 5-13-02 By: Clp W

Manufacturer : SKC-WEST
SKC ACCUFLOW Digital Flow Calibrator: Model 712

SN : 311325

Barometric Pressure : 30.04 " Hg Temperature : 66.8


RUN #	50 CC/MINUTE	100 CC/MINUTE	150 CC/MINUTE
	DIGITAL VOLUME	DIGITAL VOLUME	DIGITAL VOLUME
1	56.1	128.9	185.6
2	56.0	128.7	185.5
3	55.9	128.7	185.7
4	56.0	128.9	185.8
5	56.0	129.0	185.9
6	56.2	128.8	185.7
7	55.9	129.0	185.6
8	56.0	128.9	185.7
9	56.2	129.0	185.6
10	56.1	128.9	185.8
AVERAGE	56.0 cc/min	128.9 cc/min	185.7 cc/min

SETTING	cc/min
0	0.0
50	56.0
100	128.9
150	185.7

Rotometer setting for 100 cc/minute based on regression with this data.

100 CC / MINUTE = 80.8

SO2 Rotameter
05/13/02



Regression Output:

Constant	-1.85
Std Err of Y Est	5.2254186435
R Squared	0.9972557251
No. of Observations	4
Degrees of Freedom	2
X Coefficient(s)	1.26
Std Err of Coef.	0.0467375652

ORSAT ANALYSIS DATA SHEET

DATE: 5-14-02

Gas	1	2	3	AVE	CONC	TANK ID
CO ₂	0	0	0	∅	N ₂	042TAC-2-A
O ₂	0	0	0	∅	N ₂	
CO	0	0	0	∅	N ₂	
CO ₂	12.5	12.4	12.5	12.47	12.49	CC12767
O ₂	12.5	12.5	12.5	12.50	12.50	
CO	4.8	4.8	4.8	4.80	4.80	
CO ₂	21.2	21.2	21.2	21.2	21.23	CC55904
O ₂	21.1	21.1	21.1	21.1	21.10	
CO	8.6	8.6	8.6	8.6	8.60	
CO ₂	6.2	6.2	6.2	6.2	6.25	AAL21084
O ₂	6.3	6.2	6.2	6.33	6.24	
CO	2.0	2.0	2.0	2.0	2.01	
CO ₂						
O ₂						
CO						

**CO₂ ANALYZER
MULTIPOINT CALIBRATION REPORT FORM**

JOTUL
F500
MAY 2002

Date: 05-15-02
 Analyzer: Make: HORIBA Model: PIR 2000 SN: 407069
 Calibration by: D. Wadlington
 Cal Gas Flow: 1.5 SCFH Measured by: Rotameter
 BP: 30.23 Instrument ID: PRINCO
 Temp: 76 Instrument ID: TR

Cylinders:

1. # 042TAC 2-A Concentration: 00.00 % CO₂ Cyl. Press.: 2000 PSI
 Certified by: AIR LIQUIDE Date: 02-20-02
2. # CC 12767 Concentration: 12.49 % CO₂ Cyl. Press.: 1420 PSI
 Certified by: AIR LIQUIDE Date: 02-15-02
3. # CC 55904 Concentration: 21.23 % CO₂ Cyl. Press.: 910 PSI
 Certified by: AIR LIQUIDE Date: 02-14-00
4. # AAL 21084 Concentration: 6.25 % CO₂ Cyl. Press.: 550 PSI
 Certified by: SCOTT SPECIALTY GASES Date: 05-15-97

Analyzer: **Calibrated Range:** 0-25.0 % **Output:** 0-1.0 V.
Flow: 1.5 SCFH **Measured by:** Rotameter

Calibration Results

Point #	CYL. #	% CO ₂	EXPECTED		ACTUAL		ADJ.	
			METER	DVM	METER	DVM	METER	DVM
1	1	0.00	00.0	.000	00.0	.002	00.0	.000
2	2	12.49	50.0	.500	52.0	.520	50.0	.500
3	3	21.23	84.9	.849	85.3	.853		
4	4	6.25	25.0	.250	25.4	.254		
5	1	0.00	00.0	.000	00.0	.000		

.5 = 12.442

CO₂ Linear Regression Results:


$Y = MX + B$

Slope (M) = .0008847

Y Intercept (B) = .0401166

Correlation Coefficient(r) = .9999868

$r^2 =$.9999737





EPA Span Value = $\pm 2.0\%$ of $25\% \text{ CO}_2 = \pm .5\%$

Cal Volts = Cal Volt Conc - Std Conc = \pm Conc Diff = $\pm \Delta\%$

HIGH VOLTS .853 = 21.308 - 21.23 = .078 = .312

LOW VOLTS .254 = 6.345 - 6.25 = .095 = .380



**O₂ ANALYZER
MULTIPOINT CALIBRATION REPORT FORM**

Date: 05-15-02
 Analyzer: Make: TELEDYNE Model: 320A SN: 37400
 Calibration by: D. Wadlington
 Cal Gas Flow: 1.5 SCFH Measured by: Rotameter
 BP: 30.23 Instrument ID: PRINCO
 Temp: 76 Instrument ID: TR

Cylinders:

1. # 042TAC 2-A Concentration: 00.00 % O₂ Cyl. Press.: 2000 PSI
 Certified by: AIR LIQUIDE Date: 02-20-02
2. # CC12767 Concentration: 12.50 % O₂ Cyl. Press.: 1420 PSI
 Certified by: AIR LIQUIDE Date: 02-15-02
3. # CC55904 Concentration: 21.10 % O₂ Cyl. Press.: 910 PSI
 Certified by: AIR LIQUIDE Date: 02-14-00
4. # AAL21084 Concentration: 6.24 % O₂ Cyl. Press.: 550 PSI
 Certified by: SCOTT SPECIALTY GASES Date: 05-15-97

Analyzer: **Calibrated Range:** 0-25.0 % **Output:** 0-1.0 V.
Flow: 1.5 SCFH **Measured by:** Rotameter

Calibration Results

Point #	CYL. #	% O ₂	EXPECTED		ACTUAL		ADJ.	
			METER	DVM	METER	DVM	METER	DVM
1	1	0.00	00.0	.000	00.0	.001	00.0	.000
2	2	12.50	12.50	.500	12.90	.515	12.5	.500
3	3	21.10	21.10	.844	21.10	.840		
4	4	6.24	6.24	.250	6.40	.254		
5	1	0.00	00.0	.000	00.0	.000		

.5 = 12.513

O₂ Linear Regression Results:


$Y = MX + B$

Slope (M) = .0025912

Y Intercept (B) = .0397499

Correlation Coefficient (r) = .9999739

$r^2 =$.9999478





EPA Span Value = $\pm 2.0\%$ of $25\% \text{ O}_2 = \pm .5\%$

Cal Volts = Cal Volt Conc - Std Conc = \pm Conc Diff = $\pm \Delta\%$

HIGH VOLTS .840 = 21.00 - 21.10 = -.100 = -.400

LOW VOLTS .254 = 6.35 - 6.24 = .110 = .440



**CO ANALYZER
MULTIPOINT CALIBRATION REPORT FORM**

Date: 05-15-02
 Analyzer: Make: HORIBA Model: PIR 2000 SN: 408005
 Calibration by: A. Wadlington
 Cal Gas Flow: 1.5 SCFH Measured by: Rotameter
 BP: 30.23 Instrument ID: PRINCO
 Temp: 76 Instrument ID: TR

Cylinders:

1. # 042TAC 2-A Concentration: 00.00 % CO Cyl. Press.: 2000 PSI
 Certified by: AIR LIQUIDE Date: 02-20-02
2. # CC12767 Concentration: 4.80 % CO Cyl. Press.: 1420 PSI
 Certified by: AIR LIQUIDE Date: 02-15-02
3. # CC55904 Concentration: 8.60 % CO Cyl. Press.: 910 PSI
 Certified by: AIR LIQUIDE Date: 02-14-00
4. # AAL 21084 Concentration: 2.01 % CO Cyl. Press.: 550 PSI
 Certified by: SCOTT SPECIALTY GASES Date: 05-15-97

Analyzer: **Calibrated Range:** 0-10.0 % **Output:** 0-1.0 V.
Flow: 1.5 SCFH **Measured by:** Rotameter

Calibration Results

Point #	CYL. #	% CO	EXPECTED		ACTUAL		ADJ.	
			METER	DVM	METER	DVM	METER	DVM
1	1	0.00	00.0	.000	00.1	.001	00.0	.000
2	2	4.80	48.0	.480	48.0	.480	48.0	.480
3	3	8.60	86.0	.860	86.3	.863		
4	4	2.01	20.1	.201	19.9	.199		
5	1	0.00	00.0	.000	00.0	.000		

.5 = 4.993

CO Linear Regression Results:


$Y = MX + B$

Slope (M) = -0.0014073

Y Intercept (B) = 0.1004302

Correlation Coefficient (r) = 0.9999940

$r^2 = 0.9999880$





EPA Span Value = $\pm 2.0\%$ of 10% CO = $\pm .2\%$

Cal Volts = Cal Volt Conc - Std Conc = \pm Conc Diff = $\pm \Delta\%$

HIGH VOLTS 0.863 = 8.63 - 8.60 = 0.030 = 0.300

LOW VOLTS 0.199 = 1.99 - 2.01 = -0.020 = -0.200



**SO₂ ANALYZER
MULTIPOINT CALIBRATION REPORT FORM**

Date: 05-15-02
 Analyzer: Make: HORIBA Model: PIR 2000 SN: 403019
 Calibration by: A. Wadlington
 Cal Gas Flow: 1.5 SCFH Measured by: Rotameter
 BP: 30.23 Instrument ID: PRINCO
 Temp: 76 Instrument ID: TR

Cylinders:

1. # 042TAC 2-A Concentration: 00.00 % SO₂ Cyl. Press.: 2000 PSI
 Certified by: AIR LIQUIDE Date: 02-20-02
2. # CC62184 Concentration: 1290 % SO₂ Cyl. Press.: 1350 PSI
 Certified by: AIR LIQUIDE Date: 01-29-01
3. # ALMO 49127 Concentration: 1770 % SO₂ Cyl. Press.: 940 PSI
 Certified by: SCOTT SPECIALTY GASES Date: 05-15-97
4. # ALMO 52285 Concentration: 506 % SO₂ Cyl. Press.: 850 PSI
 Certified by: SCOTT SPECIALTY GASES Date: 05-15-97

Analyzer: **Calibrated Range:** 0-2500 PPM **Output:** 0-1.0 V.
Flow: 1.5 SCFH **Measured by:** Rotameter

Calibration Results

Point #	CYL. #	PPM SO ₂	EXPECTED		ACTUAL		ADJ.	
			METER	DVM	METER	DVM	METER	DVM
1	1	0.00	00.0	.000	00.2	.002	00.0	.000
2	2	1290	51.6	.516	51.9	.519	51.6	.516
3	3	1770	70.8	.708	70.8	.708		
4	4	506	20.2	.202	19.7	.197		
5	1	0.00	00.0	.000	00.0	.000		

.5 = 1252.349

SO₂ Linear Regression Results:


$Y = MX + B$

Slope (M) = -0.0023403

Y Intercept (B) = .0004011

Correlation Coefficient (r) = .9999676

$r^2 =$.9999351





EPA Span Value = $\pm 2.0\%$ of 2500 PPM SO₂ = ± 50 PPM

Cal Volts = Cal Volt Conc - Std Conc = \pm Conc Diff = $\pm \Delta\%$

HIGH VOLTS .708 = 1770.0 - 1770.0 = 0 = 0

LOW VOLTS .197 = 492.5 - 506 = -13.50 = -5.40





Scott Specialty Gases

Shipped
From:

500 WEAVER PARK RD
LONGMONT CO 80501
Phone: 303-442-4700

Fax: 303-772-7673

CERTIFICATE OF ANALYSIS

ENERGY & ENV MEASUREMENT

C/O ED WADINGTON
3730 N. PELLEGRINO DR.
TUCSON AZ 85749

PROJECT #: 08-34135-005
PO#: VERBAL
ITEM #: 08024520 4AL
DATE: 4/24/97

CYLINDER #: AAL210B4
FILL PRESSURE: 2015 PSIA
BLEND TYPE : CERTIFIED MASTER GAS

ANALYTICAL ACCURACY: +/-2%
PRODUCT EXPIRATION: 4/24/2000

COMPONENT
CARBON DIOXIDE
CARBON MONOXIDE
OXYGEN
NITROGEN

REQUESTED GAS
CONC MOLES
6.25 %
2. %
6.25 %
BALANCE

ANALYSIS
(MOLES)
6.25 %
2.01 %
6.24 %
BALANCE

GA 590

2015 PSIA

ANALYST:

Diana Beehler
DIANA BEEHLER



Scott Specialty Gases

500 WEAVER PARK RD, LONGMONT, CO 80501

Phone: 303-442-4700

Fax: 303-772-7673

CERTIFICATE OF ANALYSIS: Interference-Free™ Multi-Component EPA Protocol Gas

Customer
ENERGY & ENV MEASUREMENT

C/O ED WADINGTON
3730 N. PELLEGRINO DR.
TUCSON, AZ 85749

Assay Laboratory

SCOTT SPECIALTY GASES
500 WEAVER PARK RD
LONGMONT, CO 80501

Project No.: 08-34136-001
P.O. No.: VERBAL

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards)
Procedure #G1; September, 1993.

Cylinder Number: ALM052285
Cylinder Pressure***: 1996 PSIG

Certification Date: 4/21/97

Exp. Date: 4/21/2000

COMPONENT
SULFUR DIOXIDE *
NITROGEN

CERTIFIED CONCENTRATION
506 PPM
BALANCE

ANALYTICAL ACCURACY
+/- 1% NIST Traceable

Do not use when cylinder pressure is below 160 psig.

Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST standards.

This Protocol has been certified using corrected NIST 802 standard values, per EPA guidance dated 7/24/86 and will not correlate with Uncorrected Protocols.

REFERENCE STANDARD

TYPE/BRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1881	9/27/98	ALM059505	488.5 PPM	802/N2

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#
FTIR System/8220/AAB9400251

LAST DATE CALIBRATED
03/20/97

ANALYTICAL PRINCIPLE
Scott Enhanced FTIR

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)
First Triad Analysis Second Triad Analysis Calibration Curve

SULFUR DIOXIDE *

Date: 04/14/97	Response Unit: PPM		
Z1 = 0.3847	R1 = 487.72	T1 = 505.77	
R2 = 488.75	Z2 = 1.8201	T2 = 505.89	
Z3 = 1.8425	T3 = 505.78	R3 = 488.85	
Avg. Concentration:	505.8	PPM	

Date: 04/21/97	Response Unit: PPM		
Z1 = 0.3241	R1 = 488.29	T1 = 505.43	
R2 = 488.83	Z2 = 1.6098	T2 = 505.78	
Z3 = 0.8340	T3 = 505.74	R3 = 488.88	
Avg. Concentration:	505.8	PPM	

Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴	
r = 0.999999	
Constants:	A = 0.500000
B = 1.000000	C = 0.000000
D = 0.000000	E = 0.000000

ANALYST:

Devon VonFeldt
Devon VonFeldt

SO2 concentration analysis
05/14/02

Vm(std) 1.500

mcf 1

Hg 30.08

DH 0.12

temp 68

ml BA ++ 190

Normality 0.0101

528

dscf= 1.600

ppm = 510

71 Run1 504

72 Run 2 502

72 Run3 510

Tank I.D. # ALMO52285

avg. 505



AIR LIQUIDE

8832 DICE ROAD, SANTA FE SPRINGS, CALIFORNIA 90670 (562) 945-1383

CERTIFICATE of ANALYSIS

EPA Protocol Gases


Cyl. Number: CC 184	Cyl. Pressure: 2000PSIG	Lot Number: SFS34489	COMPONENT Name: Sulfur Dioxide Nitrogen	REQUESTED Concentration: 1250 ppm Balance	ASSAY Concentration: 1290 ± 20 ppm Balance
Date: 01/11	Expiration Date: 01/29/04	Document Number: 7638112			
Customer: AIR LIQUIDE TACOMA, WA	P.O. Number: LÖKKEE	Item Number:			

This is valid only to 150 psig EPA Method 8000 Section No. 2.2, Procedure G-1	REFERENCE STANDARD EMPLOYED FOR ANALYSIS <table border="1"> <thead> <tr> <th>Concentration</th> <th>Component</th> <th>Balance</th> <th>Cyl. No.</th> <th>Batch</th> <th>Exp. Date</th> <th>Sample No.</th> <th>Type</th> </tr> </thead> <tbody> <tr> <td>1540 ± 10 ppm</td> <td>Sulfur Dioxide</td> <td>Nitrogen</td> <td>CC 62136</td> <td>L99-029</td> <td>12/02/01</td> <td>GL</td> <td>GMIS</td> </tr> </tbody> </table>	Concentration	Component	Balance	Cyl. No.	Batch	Exp. Date	Sample No.	Type	1540 ± 10 ppm	Sulfur Dioxide	Nitrogen	CC 62136	L99-029	12/02/01	GL	GMIS
Concentration	Component	Balance	Cyl. No.	Batch	Exp. Date	Sample No.	Type										
1540 ± 10 ppm	Sulfur Dioxide	Nitrogen	CC 62136	L99-029	12/02/01	GL	GMIS										
Analyzed by: Thuan Tran John Oliveri	Sulfur Dioxide																
GAS ANALYZER EMPLOYED Manufacturer: Horiba Model Number: CMA-331A Serial Number: 58874503 Last Calibrated: 01/12/01 Analytical Principle: NDIR																	



ANALYSIS SUMMARY

	01/22/01 Sulfur Dioxide			01/29/01 Sulfur Dioxide			Units
	Triad 1	Triad 2	Triad 3	Triad 4	Triad 5	Triad 6	
Zero	0	0	0	0	0	0	Vdc
Reference	153	153	153	153	153	153	Vdc
Candidate	127	128	128	128	128	128	Vdc
Result	1278	1288	1288	1288	1288	1288	ppm
Evaluation	VALID	VALID	VALID	VALID	VALID	VALID	
MEAN ANALYTICAL RESULT:							1285 ppm

Analyst: <i>Thuan Tran</i>	Approved by: <i>[Signature]</i>
-------------------------------	------------------------------------



FIREBOX VOLUME CALCULATIONS AND FUEL LOAD CALCULATIONS FOR THE JOTUL F500 WOODSTOVE



$$\begin{aligned}
 A &= 24.75 \times 16.0 \times 12.5 = 4950.000 \\
 - B &= .5(10.25 \times 24.75 \times 1.0) = 126.844 \\
 - C &= 3 \times 2.50 \times 12.5 = 93.750 \\
 - D &= 3 \times 3.50 \times 12.5 = 131.250 \\
 - E &= .5(2 \times 1.625 \times 11.5) = 18.688 \\
 - F &= .5(1.25 \times 1.625 \times 11.5) = 11.680 \\
 - G &= .5(3 \times 3.625 \times 18.75) = 101.953
 \end{aligned}$$

$$\begin{aligned}
 &4465.835 \text{ in.}^3 \\
 &2.584 \text{ ft}^3
 \end{aligned}$$

Fuel Load Range =		
LOW	IDEAL	HIGH
16.3	18.091	19.8

Faint, illegible text on the left side of the page, possibly bleed-through from the reverse side.




Large blank white area on the right side of the page.

Jøtul F 500

Jøtul F 500

Installation and Operating Instructions for USA/Canada



Monterings- og bruksanvisningen må oppbevares under hele produktets levetid. These instructions must be kept for future references. Wir empfehlen Ihnen, die Montage- und Bedienungsanleitung für spätere Zwecke sorgfältig aufzubewahren. Ce document doit être conservé pendant toute la vie de l'appareil.

USA/CANADA

Installation and Operating Instructions for the USA

Installation et fonctionnement pour Canada

Safety notice: If this solid fuel room heater is not properly installed, a house fire may result. For your safety, follow the installation directions. Contact local building or fire officials about restrictions and installation inspection requirements in your area. Kindly save these instructions for future reference.

Avis de sécurité: Une installation non appropriée de ce poêle de chauffage risque de provoquer un incendie. Assurez votre sécurité en respectant les directives d'installation suivantes. Consultez les autorités locales du bâtiment ou de la prévention des incendies au sujet des restrictions et exigences relatives aux inspections d'installations dans votre région.

Tested and listed by ITS, Intertek Testing Services, Middleton, Wisconsin.

Tested to U.S. Standards: ANSI/UL 1482 and ANSI/UL 737, Canadian Standards: CAN/ULC-S627-M93

Standards:

The Jøtul F 500 woodstove has been tested and listed to;
U.S. Standards: ANSI/UL 1482 & ANSI/UL 737.
Canadian Standards: CAN/ULC-S627-M93

Tests performed by:
ITS Intertek Testing Services, Middleton, WI

Manufactured by:
Jøtul A.S, P.O. Box 1411, N-1602 Fredrikstad, Norway

Distributed by:
Jøtul North America, P.O. Box 1157, 400 Riverside Street,
Portland, ME 04104

This heater meets the U.S. Environment Protection Agency's Emissions limits for wood heaters manufactured and sold after July 1, 1990.

Under specific test conditions, this heater has shown heat output at rates ranging from 11,900 to 34,600 BTU's per hour.

The Jøtul F 500 woodstove is only listed to burn wood. Do not burn any other fuels.

When installing, operating and maintaining your Jøtul F 500 woodstove, follow the guidelines presented in these instructions, and make them available to anyone using or servicing the stove.

A number of areas require a building permit to install a solid fuel burning appliance.

In the U.S., the National Fire Protection Association's Code, NFPA 211, *Standards for Chimneys, Fireplaces, Vents and Solid Fuel Burning Appliances*, or similar regulations, may apply to the installation of a solid fuel burning appliance in your area.

In Canada, the guideline is established by the CSA Standard, CAN/CSA-B365-M93, *Installation Code for Solid-Fuel-Burning Appliances and Equipment*.

Always consult your local building inspector or authority having jurisdiction to determine what regulations apply in your area.

Jøtul North America Inc.
400 Riverside Street
Portland, Maine
USA

Table of contents:

Safety Notices 3

Installation
 Assembly before Installation 4
 Chimney connector 4

Chimneys
 Masonry Chimney 5
 Prefabricated Chimneys 5
 Chimney Height 5
 Wall pass-throughs 5

Connecting to the Chimney
 Masonry Chimney Thimbles 6
 Hearthmount Into a Masonry Fireplace 6
 Prefabricated Chimneys 6

Clearances to Combustibles
 Floor Protection 7
 Clearances to Walls and Ceilings 7
 Using Shields to Reduce Clearances 7

Alcove Installations
Mobile Home Installations
Operation
 Controls on The Jøtul F 500 8
 Breaking in Your New Stove 8
 Starting and Maintaining a Fire 9
 Adding Fuel 9
 The Formation of Creosote 9

Maintenance
 Ash Removal 10
 Glass Care 10

General Maintenance

Accessories
 Firescreen 11
 Outside Air Kit 11
 Floor Bracket Kit 12
 Rear Heatshield 12
 Bottom Heatshield 12
 Stove-top Thermometer 12

Figures -Drawings 13-15
Clearances 16-17
Exploded view 18
Appendix A (alternate floor protection)..... 20

Safety notices:

- Be sure to read this entire manual before you install or use your new Jøtul F 500 woodstove.
- If this room heater is not properly installed, a house fire may result. To reduce the risk of fire, follow the installation instructions. Failure to follow these instructions may result in property damage, bodily injury, or even death.
- Jøtul recommends that you have your new Jøtul F 500 installed by a professional installer of solid fuel burning appliances.
- Extremely hot while in operation! Keep children, clothing and furniture away. Contact may cause skin burns.
- Avoid creating a low pressure condition in the room where the stove is operating. Operating an exhaust fan or a clothes dryer could create a low pressure area, causing poisonous gases to come out of the stove into the room.
- You can prevent low pressure conditions by providing adequate combustion air within 24" (610mm) but not closer than 12" (305mm) from the stove. Or, simply install the optional outside air manifold system, which allows the direct connection of air from outside the house to the stove.
- Do not use chemicals or fluids to start the fire. Some fuels will, during combustion, separate carbon monoxide and generate it in the burn chamber. Carbon monoxide is toxic, so please follow the guidelines in this manual for proper operation of your Jøtul F 500.
- If you for some reason experience smoke "roll-out" from the stove, it may activate smoke detectors if installed in the house.

USA/CANADA

Installation:

If this solid fuel room heater is not properly installed a house fire may result. For your safety, follow the installation directions. Contact the local building or fire officials about restrictions and installation inspection requirements in your area.

Reminder:

Your local officials have final authority in determining if a proposed installation is acceptable. Any requirement, that is requested by the local authority having jurisdiction, that is not specifically addressed in this manual, defaults to NFPA 211, and local codes in the U.S. or in Canada, CAN/CSA-B365-M and local codes.

Assembly before Installation

The Jøtul F 500 is shipped with the flue collar, gasketing and hardware inside the stove.

- To install the flue collar in the top or rear exit position remove the tape from the gasketing and adhere to the groove on the back of the stove around the flue opening.
- Place the flue collar on the stove in the top or rear exit position and secure with the nut, bolt and washer.
- The nut and washer are placed on the inside of the stove.

Chimney Connector

The chimney connector is a single walled pipe used to connect the stove to the chimney. For use with the Jøtul F 500, the chimney connector must be 6" (152mm) in diameter, with a minimum thickness of 24 gauge black steel.

- Aluminum and Galvanized steel pipe is not acceptable for use with the Jøtul F 500. These materials cannot withstand the extreme temperatures of a wood fire and can give off toxic fumes when heated.
- **Do not use the connector pipe as a chimney.**
- Each chimney connector or stove pipe section must be installed to the stove flue collar and to each other with the male (crimped) end toward the stove. See figure 2, page 13.
- This prevents any amount of condensed or liquid creosote from running down the outside of the pipe or the stove top.
- All joints, including the flue collar connection must be secured with three sheet metal screws.
- For the best performance the chimney connector should be as short and direct as possible, with no more than two 90° elbows.
- **The maximum horizontal run is 36" (915mm) and a recommended total length of stove pipe should not exceed 10 feet.**
- Always slope horizontal runs upward 1/4" (6,35mm) per foot toward the chimney.
- No part of the chimney connector may pass through an attic or roof space, closet or other concealed space, or

through a floor or ceiling.

- All sections of the chimney connectors must be accessible for cleaning.
- Where passage through a wall or partition of combustible construction is desired, the installation must conform with NFPA 211 or CAN/CSA-B365, and is also addressed in this manual.
- **Do not connect this unit to a chimney flue servicing another appliance.**

Chimneys:

There are two types of chimneys suitable for the Jøtul F 500:

1. A code-approved masonry chimney with a flue liner.
2. A prefabricated chimney complying with the requirements for Type HT (2100°F) chimneys per UL 103 or ULC S629.

The chimney size should not be less than the cross-sectional area of the flue collar, and not more than three times greater than the cross-sectional area of the flue collar.

When selecting a chimney type and the location for the chimney in the house, keep this in mind: it is the chimney that makes the stove work, not the stove that makes the chimney work. This is because a chimney actually creates a suction, called "draft", which pulls air through the stove.

Several factors affect draft: chimney height, cross-sectional area (size), and temperature of the chimney, as well as the proximity of surrounding trees or buildings.

As a result, a short masonry chimney on the exterior of a house will give the poorest performance. This is because it can be very difficult to warm the chimney thereby creating inadequate draft. In extremely cold northern areas it may be necessary to reline the chimney or extend its height to help establish draft.

Conversely, a tall masonry chimney inside the house is easier to keep warm and will perform the best.

The following guidelines give the necessary chimney requirements based on the national code (ANSI-NFPA 211 for the US. And CSA CAN-B365 for Canada). However, many local codes differ from the national code to take into account climate, altitude, or other factors.

Notice:

It is important that you check with your local building officials to find out what codes apply in your area before installing your new Jøtul F 500.

Remember: Your local inspector(s) have the final authority in approving your installation. It is always best to consult with them prior to the installation.

Masonry Chimneys

When installing the Jøtul F500 into a masonry chimney you must conform to all of the following guidelines:

- The masonry chimney must have a fireclay liner or equivalent, with a minimum thickness of 5/8" (16mm) and must be installed with refractory mortar. There must be at least 1/4" (6,35mm) air space between the flue liner and chimney wall.
- The fireclay flue liner must have a nominal size of 8" X 8", and should not be larger than 8" X 12". If a round fireclay liner is to be used it must have a minimum inside diameter of 6" (157mm) and not larger than 8" (208mm) in diameter.
- If a chimney with larger dimensions is to be used, it should be relined with an appropriate liner that is code approved.
- The masonry wall of the chimney, if brick or modular block, must be a minimum of 4" (106mm) nominal thickness. A mountain or rubble stone wall must be at least 12" (310mm) thick.
- A newly-built chimney must conform to local codes and in their absence must recognize national regulations. When using an existing chimney, it must be inspected by a licensed professional chimney sweep, fire official, or code officer, to ensure that the chimney is in proper working order.
- No other appliance can be vented into the same flue.
- An airtight clean-out door should be located at the base of the chimney.

Prefabricated Chimneys

If a prefabricated metal chimney is to be used it must be a chimney type that is tested and listed for use with solid fuel burning appliances.

That means a chimney that is tested to the following:

High Temperature (HT) Chimney Standard UL 103 for the U.S. and High Temperature Standard ULC S-629 for Canada.

The manufacturer's installation instructions must be followed precisely. Always maintain the proper clearance to combustibles as established by the pipe manufacturer. This clearance is usually a minimum of 2" (56mm), although it may vary by manufacturer or for certain chimney components.

Chimney Height

Whether a masonry chimney or prefabricated metal chimney is used it must be the required height above the roof line.

The requirement is:

The chimney must be at least 3 feet higher than the highest point where it passes through the roof and at least 2 feet higher than the highest part of the roof or structure that is within 10 feet of the chimney, measured horizontally. See figure 3, page 13.

Chimneys shorter than 14 feet may not provide adequate draft. This could result in smoke spilling into the room from the stove when loading the stove, or when the door is open. In addition, inadequate draft can cause back puffing, which is a build up of gases inside the firebox.

Other times, chimney height can create excessive draft which can cause high stove temperatures and short burn times. Excessive drafts can be corrected by installing a butterfly damper. If you suspect you have a draft problem, consult your dealer.

Wall Pass-throughs

When your installation unavoidably requires the chimney connector to pass through a combustible wall to reach the chimney, always consult your local building officials, and be sure any materials to be used have been tested and listed for wall pass-throughs.

In the U.S.

The National Fire Protection Association's publication, NFPA 211, Standard for Chimneys, Fireplaces, Vents and Solid Fuel Burning Appliances permits four methods for passing through a combustible wall. Before proceeding with any method be sure to consult with your local building officials to discuss any local code requirements.

Common Method:

- When passing through a combustible wall to a masonry chimney this method requires the removal of all combustible materials from at least 12" (310mm) around the chimney connectors proposed location. With a 6" (157mm) round liner the minimum area required would be 31" x 31" (792x792mm) square.
- The space is then filled with at least 12" (310mm) of brick around a fireclay liner. Remember, the liner must be ASTM C35 or equivalent, with a minimum wall thickness of 5/8" (16mm).
- It is important to remember to locate the pass-through at least 18" (457mm) from the ceiling for proper clearance to combustibles.
- It will be necessary to cut wall studs, install headers, and construct a sill frame to maintain the proper dimensions and to support the weight of the brick.
- The bricks must be solid brick with a minimum of 3 1/4" (83mm) thick (4" (106mm) nominal).
- Refractory mortar must be used at the junction of the chimney and the pass-through liner. The pass-through liner must not penetrate the chimney liner beyond the inner surface of the chimney liner. Use extreme care when constructing the hole in the chimney liner, the tiles can shatter easily. See figure 4, page 13.

In Canada

In Canada the standard has been established by the Canadian Standard Association. The installation must conform to CAN/CSA-B365, Installation Code for Solid Fuel Burning Appliances and Equipment. Before proceeding be sure to consult your local building inspector.

USA/CANADA

Common Method:

This method requires the removal of all combustible materials from at least 18" (457mm) around the chimney connector's proposed location. With a 6" (157mm) round liner the minimum area required would be 43" x 43" square (1092x1092mm).

It is important to remember to locate the pass-through at least 18" (457mm) from the ceiling to maintain the proper clearance to combustibles.

The space that is cleared of combustible materials must then remain empty. Sheet metal panels can then be used to cover the area. However, when using a panel on both sides of the wall each cover must be installed on noncombustible spacers at least 1" (25,4mm) from the wall. If one panel of sheet metal is to be used it may be installed flush to the wall.

See section 5.3.1 and 5.3.2 of CAN/CSA - B365-M91.

Consult your local building inspector, authorized Jøtul Dealer, NFPA 211 in the U.S. or CAN/CSA-B635 in Canada for other approved wall pass-through methods.

Connecting to the chimney:

Masonry Chimney Thimbles

When installing a Jøtul F 500 into a masonry chimney through a "thimble" (the opening through the chimney wall to the flue), the thimble must be lined with ceramic tile or metal and be securely cemented in place.

The chimney connector/stove pipe must slide completely inside the thimble to the inner surface or the flue liner. It may be necessary to make use of a thimble sleeve (a pipe with a slightly smaller diameter than standard stove pipe). This special pipe can be easily installed into a thimble. See figure 5, page 14.

Make sure the connector pipe or thimble sleeve does not protrude into the flue liner, thereby restricting the area the smoke has to flow through. This bottle-neck will have a negative affect on the chimney system.

The chimney connector should be sealed at the thimble with refractory cement and the stove pipe leading to the stove should have a minimum of three screws.

Do not connect this stove to a chimney flue servicing another appliance of any kind.

Hearthmount Into a Masonry Fireplace

The Jøtul F 500 may be installed into a masonry fireplace provided the height of the opening is a minimum of 31" (787mm).

When installing the Jøtul F 500 into a masonry fireplace, code requires that the fireplace damper plate be removed or securely fixed in the open position. A connector pipe must then extend from the stove's flue exit through the damper area of the fireplace and into the chimney tile liner. See figure 6, page 14.

The inside area of the flue liner must not be less than the area of the stove's flue exit, and cannot be more than three times greater than the cross sectional area of the stove's flue exit.

If the chimney liner is too large to accommodate the stove, an approved relining system must be installed to resize the flue.

A new sheet metal damper block-off plate must be installed around the connector pipe at the damper frame and sealed with the proper sealant (usually High-Temp Silicone).

Fireplace installation must also observe the proper clearances to surrounding trim and mantels (addressed in clearance section of this manual). In addition, fireplace installations must also adhere to the floor protection guidelines specified in the following section.

Prefabricated Chimneys

When installing the Jøtul F 500 to a prefabricated metal chimney always follow the pipe manufacture's instructions and be sure to use the components that are required. This usually includes some type of "smoke pipe adapter" that is secured to the bottom section of the metal chimney and allows the chimney pipe to be secured to it with three sheet metal screws. See figure 7, page 14.

Clearances to Combustibles:

Floor Protection

Floor protection under the stove must be constructed of a non-combustible material for protection from radiant heat, sparks, and embers.

Individual sections of floor protection must be mortared together to prevent sparks from falling through to combustible materials. Any carpeting must be removed from under the floor protection.

In the U.S. and Canada

The Jøtul F 500 must be installed on a non-combustible surface extending:

A minimum of 18" (457mm) in front of the stove and the left side load door (measured from the legs). And 8" (200mm) on the left side and back of the stove (measured from side and back panels).

This will result in a minimum floor protection of 56"W X 50,5"D. (1422mm X 1283mm) See figure 8, page 14.

In a rear vent installation the floor protection must also extend under the stove pipe a minimum of 2" (50mm) beyond either side of the pipe.

Alternate hearth protection

A hearth pad measuring 46" wide X 50,5" deep (1168mm X 1283mm) can be used only if the left side door is looked to prevent use.

When constructing a new hearth or floor pad, consult appendix a at the back of this manual for alternate materials and methods.

Clearances to Walls and Ceilings

The following clearances have been tested to UL and ULC standards and are the minimum clearances specifically established for the Jøtul F 500.

The following diagrams give the required clearances you must maintain when installing the Jøtul F 500 near combustible surfaces. See pages 16-17.

A combustible surface is anything that can burn (i.e. sheet rock, wall paper, wood, fabrics etc.). These surfaces are not limited to those that are visible and also include materials that are behind non-combustible materials.

If you are not sure of the combustible nature of a material, consult your local fire officials. Contact your local building officials about restrictions and installation requirements in your area.

Remember: "Fire Resistant" materials are considered combustible; they are difficult to ignite, but will burn. Also "Fire-rated" sheet rock is also considered combustible.

Using Shields to Reduce Clearances

Pipe shields: When using listed pipe shields to reduce the connector clearance to combustibles, it must start 1" (25,4mm) above the lowest exposed point of the connect pipe and extend vertically a minimum of 25" (635mm) above the top surface of the stove.

Double wall pipe: Listed double wall pipe is an acceptable alternative to connector pipe heatshields.

Wall-Mounted Protection: When reducing clearances through the use of wall mounted protection:

In the U.S. refer to NFPA 211, Standard for Chimneys, Fireplaces, Vents and Solid Fuel Burning Appliances, for acceptable materials, proper sizing and construction guidelines.

In Canada, refer to CAN/CSA-B365, Installation Code for Solid-Fuel Burning Appliances and Equipment, also for acceptable materials, proper sizing and construction guidelines.

Stove Mounted Heatshield: A stove rear heatshield has been specifically designed for the Jøtul F 500. Rear heatshield part # 154329.

No other heat shield may be used.

See pages 16-17 for complete clearance requirements and diagrams.

Notice

Accessories for wood stoves for clearance reduction have been developed by many manufacturers. If not following the methods of the installation codes, be sure that any accessory you choose has been tested by an independent laboratory and carries the laboratory's testing mark. Make sure to follow all of the manufacturer's instructions.

Always contact your local building inspector or fire officials about restriction and requirements in your area. Reminder, it is the local officials who have final authority in the installations approval.

USA/CANADA

Alcove Installation:

The Jøtul F 500 can be installed in an alcove situation provided: See figures 9 and 10, page 14.

1. The stove must be installed with listed double walled pipe.
2. In a protected alcove installation both side walls and rear wall must be protected per NFPA 211 or CAN/CSA-B365. The wall protection must be elevated 1" (24,5mm) from the floor and at least 1" (24,5mm) off the combustible wall to allow for an air-flow.
3. The height of the wall protection including the bottom air space must be 48" (1219mm).
4. The bottom heatshield is required in all alcove installations.
5. If a listed (UL/UCL) hearth board is not used the hearth that is constructed must have a minimum r value of 1.6 (see appendix a, page 19).
6. Minimum ceiling height in an unprotected installation, off the top of the stove is 48" (1219mm). The minimum ceiling height off the top of the stove in a *protected* ceiling installation is 15" (380mm).

Use of the left side load door is prohibited in alcove installations.

Mobile Home Installations:

The Jøtul F 500 has been approved for use in mobile homes in the U.S. and Canada, provided:

1. The stove is secured to the floor or the mobile home. Floor mounting kit #750304.
2. The stove is provided outside air for combustion. Outside Air kit #154333 (see page 11 for more details)
3. The stove must be grounded to the mobile home frame per NFPA 70.

As always, consult with your local building inspector or fire officials about restrictions and requirements in your area prior to installing the stove.

WARNING:

Do not install in a bedroom/sleeping room. The structural integrity of the mobile home's floor, wall, ceiling/roof must be maintained.

Operation:

Before building a fire in your new Jøtul F 500, please read the following section carefully and completely.

This stove is designed to burn natural wood **only**. Wood that has been air-dried for a period of 6 to 14 months will provide the cleanest most efficient heat.

Do not burn:

- | | |
|-------------|------------------------------|
| * Coal | * Treated or painted wood |
| * Garbage | * Chemical Chimney cleaners |
| * Cardboard | * Colored paper |
| * Solvents | * Any synthetic fuel or logs |

The burning of any of these materials can result in the release of toxic fumes. Never use gasoline, gasoline-type lantern fuel, kerosene, charcoal lighter fluid, or similar liquids to start or "freshen-up" the fire. Always keep such liquids away from the heater at all times.

Important

Never build or allow the fire to rest directly on the glass. The logs should always be spaced at least one inch from the glass to allow for proper air flow within the stove.

Controls on The Jøtul F 500

A single air control lever controls the burn time and heat output of the stove. This primary air control lever is located on the front of the stove directly above the ashlip. The primary air lever controls the amount of air that enters the stove for combustion.

When first starting or reviving the fire: The primary control lever should be at the far right position, which allows the maximum amount of air into the stove.

The more air entering the stove, the hotter the fire, the shorter the burn time. Moving the lever to the left reduces the air-flow into the stove which prolongs the fire at a lower heat output. See figure 11, page 15.

Breaking in Your New Stove

Your new Jøtul F 500 is constructed of cast iron and stove furnace cement. This type of construction requires the stove to be "broken-in" gradually so that heat expansion does not occur too quickly and cause damage.

Complete the following steps for the proper break-in procedure for the Jøtul F 500:

To monitor the stove's temperature, Jøtul recommends the use of a magnetic stove-top thermometer, *placed directly on the corner of the stove's top plate.*

1. Light a small fire, newspaper and kindling only, only allow the stove to reach a maximum surface temperature of 200°. Burn for approximately 1 hour.
2. Allow stove to cool to room temperature.
3. Light a second fire, allowing the stove to reach a maximum temperature of 300° for 1 hour.
4. Cool the stove to room temperature.
5. Light a third fire and gradually allow the stove to reach a surface temperature of 400°
6. Cool stove to room temperature. This completes the "break-in" procedure.

Never allow the stove to exceed a 400° surface temperature during any "break-in fire" with the exception of the last "break-in" fire.

Note: It is normal for a new painted stove to emit an odor and even smoke during its first several fires. This is caused by the seasoning of the high temperature paint and will diminish with each fire and will eventually disappear. Opening a window or door to provide additional ventilation will reduce the odor as this process takes its course.

Starting and Maintaining a Fire

Burn only solid wood directly on the bottom grate of the stove, do not elevate the fire in any way.

- The ash pan door on the stove must always be securely closed when the stove is in operation.
- Burning the stove with the ash pan door open will overfire the stove and cause interior damage.
- With the primary air control lever in the full open position, start with several sheets of crumbled newspaper placed directly on the grate. On top of the newspaper, place several pieces of small dry kindling (approx. 1" (24,5mm) in diameter) with two to three larger logs (approx. 3" (76mm) to 5" (127mm) in diameter) on top.
- Light the fire and close the door, slowly building the fire by adding larger and larger logs. Be sure to follow the break-in procedure before creating a fire that will damage the stove.
- Once the stove has reached a surface temperature range of between 400° and 600°, adjust the primary air control lever as necessary to generate the heat output and burn time desired.
- Jøtul recommends the use of a magnetic stove top thermometer to monitor the surface temperature of the stove. The optimum surface temperature range for the most efficient burn is between 400° to 600°. See figure 12, page 15, for the optimum locations of a stove-top thermometer.

Adding Fuel

When reloading the stove while it is still hot and a bed of hot embers still exist, follow this reloading procedure:

- Always wear gloves when tending to the stove.
- Push the air control lever to the full open position (far right).
- Wait a few seconds before opening the door.
- Use a stove tool or poker to distribute the hot embers equally around the firebox.
- Load the fuel, usually with smaller logs first.
- Close the door, be sure to latch the door tightly.
- Wait 5–10 minutes before adjusting the primary air to the desired heat output setting. (If you have at least a 2" (50mm) thick ember bed when reloading, it may be possible to close the door and immediately adjust the air control setting).

The Formation of Creosote

When wood is burned slowly and at low temperatures, it produces tar and other organic vapors, which combine with moisture to form creosote. The slow moving smoke carries the creosote vapors, which condense in the cooler chimney flues, and this creosote then sticks to the chimney walls.

The creosote that accumulates in the chimney is highly flammable and is the fuel of chimney fires. To prevent chimney fires it is important to have the chimney and chimney connector pipe inspected and/or cleaned semi-annually. A qualified chimney sweep or other authorized service person can provide this service.

It is also important to remember that chimney size, temperature and height all affect draft which in turn affects the formation of creosote. Be sure to follow the installation and operation guidelines established in this manual.

USA/CANADA

Maintenance:

For your protection always wear safety gloves when handling the ash pan.

Ash removal

Ash removal will be required periodically depending on how frequently the stove is used. Conveniently, the Jøtul F 500 is equipped with an ash pan assembly for easy ash removal, without the need for opening the front door.

The ash pan door is located under the front ashlip of the stove. To open the ash door insert the pin on the end of your specially designed ash tool into the hole on the ash door latch. Rotate the door counterclockwise to unlatch the door and clockwise to latch the door.

Remove the ash pan. When the stove is in operation always close the ash door before leaving to dispose of the ashes.

The ashes should be placed in a metal container equipped with a tight sealing lid. The container should be placed on a noncombustible floor or on the ground, well away from all combustible materials, pending final disposal. If the ashes are disposed of by burial in soil or otherwise locally dispersed, they should be retained in the closed container until all cinders have thoroughly cooled.

WARNING. Do not, at any time, operate this stove with the ash pan door open. This condition will lead to overfiring and will damage the stove. This damage is not covered under warranty. Only empty the ash drawer before refueling, when the fire is low or out. The ash door should be open only long enough to empty the ash drawer and then securely closed. Inspect the gasket on the ash pan door regularly and replace as necessary.

Glass Care

Cleaning:

On occasion it will be necessary to clean the carbon deposits and fly ash off of the glass. If the carbon and fly ash are allowed to remain on the glass for an extended period of time it could eventually cause the glass to become etched and cloudy. Any creosote, which might deposit on the glass, should burn off during the next hot fire.

The proper cleaning procedure is as follows:

1. Glass needs to be completely cool.
2. Only use a cleaner that is specifically designed for this purpose. The use of abrasives will damage the glass and ultimately leave the glass frosted.
3. Rinse and dry glass completely before burning your stove.

Never operate the stove with a cracked or broken glass panel.

Glass removal:

Always operate the doors slowly and cautiously to avoid cracking or breaking the glass. Never use the door to push wood into the firebox. If the glass becomes cracked or broken follow this procedure for replacement:

1. Remove the door from the stove and place on a flat surface.
2. Carefully remove all of the glass clips from the inside of the door.
3. Gently remove all pieces of the glass panel and gasketing.
4. Remove all remaining debris from the glass area using a wire brush.
5. Apply a small bead of gasket/stove cement and the new gasket. Do not overlap the ends of the gasket rope.
6. Center the new glass panel over the gasket and reinstall the glass clips. See figure 13, page 15.

Important: The side of the glass treated with an infrared coating (marked on the perimeter) should always be facing outward. It is extremely important to tighten the glass clips slowly and in a repeating pattern, like tightening the lugs on an automobile wheel.

It may be necessary to retighten the glass clips after the stove has burned and the gasketing has been seated.

Important:

Replace glass only with a ceramic glass panel specifically designed for the Jøtul F 500. Do not use substitutes. Replacement glass panels can be ordered through your Jøtul dealer.

General maintenance

Like your car, regular maintenance prolongs the life of your stove. The following procedures do not take long and are generally inexpensive, but when done consistently, increase the life of your stove and in turn, increase your years of enjoyment.

At least once a year you should perform the following maintenance procedures:

1. Thoroughly clean the stove. Enamel surfaces should be cleaned with soap and water.
2. Empty stove of all soot and ashes. Only use a vacuum for this job if the vacuum is specifically designed for ashes.
3. Inspect the stove: Using a strong light inspect the stove inside and out for cracks or leaks. Replace all cracked parts and repair any cement leaks with furnace cement.

Gaskets

Check doors and window gaskets for tightness. To check the seal of the front door, close and latch the door on a dollar bill and slowly try to pull the dollar bill free. If it can be easily removed then the seal is too loose. Check several spots around the door, and repeat the procedure on the ash pan door as well.

- If gaskets need to be replaced, scrape out the old gasket and cement and clean the area with a wire brush.
- Apply a small bead of cement and push in the new gasket.
- After closing and latching the doors wipe clean any excessive cement that has come from beneath the gasketing.

Gaskets for:

Description	Size	Length
Top Cover	ld360	3/8" / Ø8,7mm x 3,4' / 1050mm
Top Plate	ld375	3/8" / Ø9,5mm x 7' / 2100mm
Smoke Outlet	ld250	3/16" / Ø6,4mm x 3' / 930mm
Ash Housing	ld250	3/16" / Ø6,4mm x 4,2' / 1300mm
Ash pan door,	ld250	1/4" / Ø6,4 mm x 4,6' / 1100 mm
Front door,	ld375	3/8" / Ø9,5 mm x 6' / 1800 mm
Left side door,	ld375	3/8" / Ø9,5 mm x 4,2' / 1300 mm
Glass,	ld250	3/8" / Ø8,7 mm x 5' / 1500 mm

The Jøtul F 500 is designed to burn cleanly and efficiently when used according to the guidelines expressed in these operating instructions. However, to maintain the proper performance, a yearly chimney inspection and cleaning is necessary. Failure to keep the chimney system free of creosote and build up could result in a serious chimney fire.

Accessories:

Many accessories have been manufactured for use with the Jøtul F 500. Only use accessories that are specifically designed for the Jøtul F 500.

Firescreen

The Jøtul F 500 has been approved for use as an open fireplace, with front door open. This feature is especially nice when the ambience of a fire is desired. Some care should be taken when operating the stove as a fireplace.

- Always have the firescreen in place, attached to the stove front.
- Never over load the stove: For the best appearance burn in the traditional three log configuration.
- Reminder, when burning the stove with the screen in place, you are sacrificing efficiency for aesthetics, and you will be consuming wood at a much faster rate.

Warning: Operate your Jøtul F 500 with the front door fully open and the firescreen in place, or fully closed. Partially opened doors may result in overfiring. Also, if doors are left partly open, gas and flame may be drawn out of the stove opening, creating risks from both fire and smoke.

Outside Air Kit

In certain installations it may be necessary to provide outside air to your Jøtul F 500 wood stove. Guidelines to determine the need for additional combustion air may not be adequate for every situation. If in doubt, it is advisable to provide additional air.

The outside air kit includes an adapter to mount onto the stove that will accept the fresh air pipe. Installation will require some additional materials:

- A. The appropriate length of metallic pipe for a conduit of the outside air (4" (100mm) diameter).
- B. A rain/weather resistant cap for the outside of the house.
- C. A rodent screen - that is no larger than 1/4" (6,4mm) mesh.

Outside air may be required if:

1. The Jøtul F 500 does not "draw" steadily, smoke rollout occurs, fuel burns poorly, or back-drafts occur whether or not there is combustion present.
2. Existing fuel-fired equipment in the house, such as fireplaces or other heating appliances, smell, do not operate properly, suffer smoke roll - out when opened, or back-draft whether or not there is combustion present.
3. Opening a window slightly on a calm (windless) day alleviates any of the above symptoms.
4. The house is equipped with a well-sealed vapor barrier and tight fitting windows and/or has any powered devices that exhaust house air.
5. There is excessive condensation on the windows in the winter.
6. A ventilation system is installed in the house.

If these or other indications suggest that infiltration air is inadequate, additional combustion air should be provided from the outdoors. Outside combustion air can be provided to the appliance by the following means:

Direct connection: The Jøtul F 500 has been tested and listed for use with an outside air kit. This outside air kit is connected directly to the stove. Be sure to follow the instructions provided with the kit.

Indirect method: Outside air is ducted to a point no closer than (12") 300mm from the appliance, to avoid affecting the performance of the appliance.

USA/CANADA

A mechanical ventilation system: If the house has a ventilation system (air change or heat recovery):

A. The ventilation system may be able to provide sufficient combustion make-up air for the solid fuel fired appliance.

B. The homeowner should be informed that the ventilation system might need to be rebalanced by a ventilation technician after installation of the appliance.

Floor Bracket Kit

Use of the floor bracket kit is required in all mobile home installations to secure the stove to the floor. Complete installation instructions and diagrams are supplied with each floor bracket kit.

Rear Heatshield

A stove rear heatshield has been specifically designed for the Jøtul F 500 to reduce clearances off the rear of the stove to combustible materials. Use of the heatshield does not affect the clearance off the sides of the appliance.

See pages 16-17 for specific clearance requirements. Complete installation instructions are supplied with the heatshield. No other type of heatshield may be used on the rear of the Jøtul F 500.

Bottom Heatshield

A bottom heatshield has been specifically designed for the Jøtul F 500. It is required in all alcove installations. Use of the bottom heatshield does not affect the floor protection requirements described on page 9 of this manual. No other type of heatshield may be used on the bottom of the Jøtul F 500.

Stove-top Thermometer

Jøtul recommends the use of a magnetic stove-top thermometer to monitor the surface temperature of the stove. The optimum surface temperature range for the most efficient, clean burn is between 400° and 600°.

Fig.1a




Fig.2




Fig.1b




Fig.3




Fig.1c




Fig.4




Fig. 5




Fig. 8




Fig. 6




Fig. 9




Fig. 7




Fig. 10




Fig.11




Fig.12






Fig.13




Jøtul F 500 Woodstove Clearances

Unprotected Surface Parallel to the Wall



Protected Surface Parallel to the Wall


PER NFPA 211 or CAN/CSA-B365



Important:
Connector heatshields and double wall pipe must be a listed product.
Always follow the manufacturer's instructions.


● = SINGLE WALL PIPE WITH CONNECTOR SHIELDS ● = DOUBLE WALL PIPE

Unprotected Surface Corner Installation



Protected Surface Corner Installation

PER NFPA 211 or CAN/CSA-B365



Jøtul F 500 Woodstove Clearances

Stove clearances	Unprotected surface Parallel installation			Protected surface NFPA 211 Parallel installation		
	Side	Rear	Corner*	Side	Rear	Corner*
Stove- no heatshields Single wall pipe	14" A 355mm	18" B 460mm	13" C 330mm	6" D 150mm	12" E 300mm	9" F 230mm
Stove with rear heatshield Single wall pipe	14" G 355mm	10" H 255mm	9" I 230mm	6" J 150mm	10" K 255mm	9" L 230mm
Stove with rear heatshield With connector shield	14" M 355mm	6" N 150mm	9" O 230mm	6" P 150mm	6" Q 150mm	6" R 150mm
Stove with rear heatshield With double wall pipe	14" S 355mm	6" T 150mm	9" U 230mm	6" V 150mm	6" W 150mm	6" X 150mm

Connector clearances (pipe)	Unprotected surface Vertical installation		Protected surface NFPA 211 Vertical installation	
Single wall pipe	18" 460mm		12" 300mm	
Single wall pipe with connector shields	6" 150mm		6" 150mm	
Double wall pipe	6" 150mm		6" 150mm	

Connector clearances (pipe)	Unprotected surface Horizontal installation		Protected surface NFPA 211 Horizontal installation	
Single wall connector	18"	460mm	12"	300mm
Double wall pipe	6"	150mm	6"	150mm
Mantel and trim clearances	Stove to 1" thick or less, side trim		12"	300mm
	Stove to 1" thick or less, top trim		16"	410mm
	Stove to mantel- maximum mantel depth 12"		30"	765mm

* Attention: Stove and pipe clearances must both be taken into Consideration. The greater clearance dictates the stove's position.

* Use of the right side load door is prohibited in alcove and Corner installations.



JOTUL NORTH AMERICA

JOTUL U.S.A., INC.

P.O. Box 1157

Portland, Maine 04104

Tel: (207) 797-5912

Fax: (207) 772-0523

Email: jotul@ime.net

May 1, 2002

Chip Wadington
Lokee Testing Labs
13235 Prairie Circle East
Sumner, WA 98390-7250

Dear Mr. Wadington

The following information is being provided to assist you in obtaining test results in the applicable burn rate categories for the Jotul F500.

By removing the inspection cover you will expose the air slider valve which controls primary air. The measurement of the size of the open air passage created by the air slider correlates to the following burn rates.


<u>Opening</u>	<u>Burn rate</u>
< .125"	Low
.125" - .188"	Medium low
.188" - .375"	Medium high
Full open	High

The fan should be activated at 30 minutes after the start of the test run.

Sincerely,

Roger W. Purinton

Project Engineer, Jotul North America



EXAMPLE CALIBRATION/DATA FLOW

All individual test run raw data sheets are organized in a manner that would allow a data reviewer to follow the data as it is being calculated in a step by step fashion. In many cases, the equations used to calculate a specific required data are given on the raw data sheets themselves.

For example, the particulate emission rate in g/dscf is calculated on Data Sheet #7. However, the data used to derive this data begins on Data Sheet #2 (Meterbox Data Sheet) where the meter volume (cubic feet), average meter temperature (°F), average ΔH (in. H₂O), and average Barometric pressure (in. Hg) are recorded and averaged. Each of the averages for these parameters are used in equation 1 on P. 7 where the volume (MCF) is converted to dscf.

The moisture catch total (g. H₂O) on the Particulate Catch/Moisture Data sheet (p. 3) is transferred to P. 7 and the percent stack moisture is calculated in equations 2 and 3.

The gross and net gravimetric (g) particulate catches are determined and calculated on PP. 3-6. Pages 4-1, 4-2 and 4-3 show the initial (tare) constant weights for filters (p. 4-1) and beakers (p. 4-2) and the final constant weights (p. 4-3) for those filters and beakers used for each run. Final and tare weight data is transferred to P. 3 and the gross gravimetric (g) catch for each filter and beaker is calculated. On P. 5 the gravimetric catch for each blank is calculated. The gross gravimetric catch for each filter and beaker is transferred to P. 6 and the net gravimetric catch (g) is calculated, as well as front half and back half catch totals. The net gravimetric catch (g) is transferred to P. 7 and the grain loading/dscf is calculated in equation 4.

Some data sheet specific information is listed below on a page by page basis.

P. 8 The % ambient moisture is determined by interpolating from psychrometric charts which are contained in the State of Oregon Department of Environmental Quality's "Standard Method for Measuring the Emissions and Efficiencies of Woodstoves".

 The % relative humidity is determined from the wet bulb/dry bulb temperature readings using the tables found in Section 3.1.2.4 of the State of Montana Air Quality Bureau's Quality Assurance Manual.

P. 10 The uncorrected moisture meter readings are corrected for pin insulation and may or may not be corrected for ambient (wood) temperatures. All corrections are based upon the correction equations or tables supplied by the moisture meter manufacturer. (These are standard, known corrections.)

P. 11 The moisture meter readings are corrected as discussed above.

P. 12 The gas concentrations shown for each gas monitored (CO₂, O₂, CO and SO₂) are determined by converting the analyzer's voltage output recorded on P. 12 to the concentration shown using the analyzer's current calibration curve. The SO₂ concentration is determined using the manufacturer's calibration curve and the current calibration curve.

The cal. W/B (calculated wet bulb) temperature is obtained by first determining the % moisture in the extracted flue gas stream using the temperature data from thermocouples 1 (Wet Bulb) and 2 (Dry Bulb). Then based upon the stack temperature (thermocouple 3) and the % moisture in the extracted gas stream, a calculated wet bulb temperature is determined. All data is derived from the psychrometric tables found in the State of Oregon's "Standard Method for Measuring the Emissions and Efficiencies of Woodstoves".

The following pages contain the equations used to generate the data on Tables 3-5 on the computer printouts:

Dry Gas Volume (standard):

$$V_{m(\text{std})} = \frac{V_m * 17.65 * \text{mcf} * \left(P_{\text{bar}} + \frac{\Delta H}{13.6} \right)}{T_m}$$

Volume of Water:

$$V_{w(\text{std})} = (0.04707)(ml \text{ H}_2\text{O})$$

Moisture Content:

$$B_{ws} = \left(\frac{V_w}{V_w + V_{m(\text{std})}} \right) * 100$$

Dry Burn Rate:

$$Br = \left(\frac{Wwt - (Wwt * \% \text{ H}_2\text{O})}{2.2046} \right) * \frac{60}{\theta}$$

Carbon Balance (N_t):

$$N_t = \frac{K_3 N_c}{(Y_{CO_2} + Y_{CO} + Y_{HC})}$$

Stack Flow Rate (Q_{sd}):

$$Q_{sd} = K_4 N_t B_r$$

Particulate Concentration (C_s):

$$C_s = \frac{M_n}{V_{m(std)}}$$

Particulate Emission Rate (E):

$$E = C_s Q_{sd}$$

Proportional Rate Variation (Pr):

$$Pr = \left(\frac{\theta S_i * V_{mi(std)}}{10 \sum_{i=1}^n [S_i * V_{mi(std)}]} \right) * 100$$


Where:

- B_r = dry wood burn rate, kg/hr.
- B_{ws} = Water vapor in the gas stream, proportion by volume.
- c_s = Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, g/dscm (g/dscf).
- E = Particulate Emission Rate, g/hr.
- ΔH = Average pressure differential across the orifice meter (see Figure 5-2), mm H₂O (in. H₂O).
- K_3 = 1.0 lb/lb (English)
1000 g/kg (metric)
- K_4 = 0.02406 dsm³/g-mole(metric)
384.8 dscf/lb-mole (English)

m_n =	Total amount of particulate matter collected, mg.
m_{cf} =	Dry gas meter correction factor.
N_c =	Gram atoms of carbon/gram of dry fuel (lb/lb), equal to 0.0425.
N_t =	Total dry moles of exhaust gas/Kg of dry wood burned.
P_r =	Percent of proportional sampling rate.
P_{bar} =	Barometric pressure at the sampling site, mm Hg (in. Hg).
Q_{sd} =	Total gas flow rate, dscf/hr.
S_i =	Concentration measured at the SO_2 analyzer for the "i th " 5 minute interval, ppm.
S_1 =	Concentration measured at the SO_2 analyzer for the first 5 minute interval, ppm
T_m =	Absolute average DGM temperature (see Figure 5-2), °K (°R).
T_{std} =	Standard absolute temperature, 293°K (528°R).
V_m =	Volume of gas sample as measured by dry gas meter, dcm (dcf).
$V_m(std)$ =	Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscm (dscf).
$V_w(std)$ =	Volume of water vapor in the gas sample, corrected to standard conditions, scm (scf).
W_{wt} =	Wet wood weight.
Y =	Dry gas meter calibration factor.
Y_{CO} =	Measured mole fraction of CO (dry).
Y_{CO_2} =	Measured mole fraction of CO_2 (dry).
Y_{HC} =	Assumed mole fraction of HC (dry); =0.0088 for catalytic woodheaters =0.0132 for noncatalytic woodheaters =0.0080 for pellet fired woodheaters
θ =	Total sampling time, min.
13.6 =	Specific gravity of mercury.
60 =	Sec/min.
100 =	Conversion to percent.

M5H PARTICULATE SAMPLING TRAIN

1. Probe
3/8" seamless SS-20" long. Outlet end of probe is attached to a SS outlet fitting with a Sweglock SS union. The probe is unheated except for the portion that is in the stack and the heated filter box. The probe is sealed to the stack with a washer.
2. Filter Holder
A 3" or 4" standard M5 filter holder. A SS filter support with gasket.
3. Filters
3" or 4" fiber glass (#25 glass) manufactured by Schleicher and Schuell.
4. Front Half Filter Heater
A box containing a fan for air circulation and a cone heater. The temperature in the box is monitored with a type K thermocouple and adjusted with a voltage regulator to maintain a temperature below 248 °F.
5. Desiccant
Indicating silica gel, 6-20 mesh. The silica gel is changed as needed.
6. Filter (Back Half) Holder
Same as front half 3" or 4" filter.
7. Impinger Gas
Type K thermocouple threaded into the exit "arm" of the impinger. Ice is added to the cooler whenever necessary to maintain an exit gas temperature less than 68 °F.
8. Meterbox
RAC Stack Sampler modified by EEMC
Ranges: 0-1.0" inclined water manometer
0-10.0" vertical water manometer
Accuracy: Dry gas Meter 0-999.999 cu ft $\pm 1.0\%$
Temperatures are monitored using two type K thermocouples.



SAMPLING PROCEDURES AND INSTALLATION DESCRIPTION

This section is broken into two major parts. The first contains a brief description of the sampling and procedures used by LoKee Testing Laboratory when performing a test using EPA Methods 28, 28A and 5H. The second section contains a complete listing of all equipment in each of the major sampling trains and a diagram of each major train.

LoKee Testing Laboratory uses EPA M5H for the particulate sampling procedure and collects the required data so that efficiency of a unit can be calculated using the Oregon Method.

TEST FACILITY AND WOOD HEATER EQUIPMENT LIST

1. Flue Pipe

The diameter of the 24 gauge black steel flue pipe used for each stove varies with the size of the stove's flue collar, e.g., 6" flue pipe is used with a 6" flue collar. The joint at the flue collar is sealed with mortar. The pipe is attached to the stove at the flue collar with three sheet metal screws. All sampling ports are sized for the sampling probes and sealed using washers.

2. Insulated Flue Pipe

The diameter of the insulated flue pipe matches the diameter of the flue collar on the stove. The 6", 7" and 8" pipe meet the requirements of UL 103 HT. The SO₂ injection loop port is sealed with high temperature silicone sealant.

3. Liquid Seal

The liquid (oil) seal used by LoKee varies in size with the flue pipe. The seals are made of 12 gauge steel. The liquid sealant is mineral oil. The cooler consists of 3/8" copper tubing which is coiled in the bottom of the lower half of the seal. Ambient air is pumped through this line when necessary to cool the seal.

4. Supports

The lower half of the seal and the 24 gauge steel black flue pipe is supported by the stove. The upper half of the seal and the insulated flue pipe are hung from wooden supports.

5. Platform Scale

Platform (30" X 30" deck)

Manufacturer: Weightronics

Model: platform: DS-014/SN 4479 readout: W1-110/SN 016409

Type: Electronic

Range: 0-1000 lb.

Capacity: 1000 lb.
 Resolution: ± 0.1 lb.
 Accuracy: $\pm 0.1\%$

6. Fuel Balance Scale

LoKee uses the platform scale listed above to weigh the fuel charges.

7. Fuel Storage Area

LoKee stores the fuel in a humidity and temperature regulated room.

8. Moisture Meter

LoKee has two moisture meters which it uses to determine wood moisture levels.

The primary meter is:

Manufacturer: Delmhorst Instrument Co.
 Model: RC-1C/SN 16152 with 26-E probe and #496 insulated pins.
 Type: Electrical Resistance
 Resolution: $\pm 0.1\%$ moisture
 Ranges: 6-11%, 11-25%, 25-80%
 Accuracy:

Moisture	Content Accuracy
6-12%	$\pm 0.5\%$
12-20%	$\pm 1.0\%$
20%-saturation point	$\pm 2.0\%$

Type of Calibration: The RC-1C is equipped with two potentiometers (Zero and Span) which are checked and adjusted on a daily basis. The unit is also checked with a calibration block.

Electrode and Pin Type: 26-E probe and #496 insulated pins

The backup moisture meter:

Manufacturer: Delmhorst Instrument Co.
 Model: G-30SN/2477 with 26-E probe and #496 insulated pins
 Type: Electrical Resistance
 Resolution: $\pm 0.1\%$ moisture
 Accuracy:

Moisture	Content Accuracy
6-12%	$\pm 0.5\%$
12-20%	$\pm 1.0\%$
20%-saturation point	$\pm 2.0\%$

Type of Calibration: Calibration is accomplished with an internal calibration point and a potentiometer. The calibration can also be checked against a calibration block.

Description of Operation: The pins are pounded into the wood to be sampled. The meter reading is recorded on Data Sheet #10 (Wood Moisture) or Data Sheet #11 (Density Determination). This is the uncorrected reading which is then corrected for pin insulation and, as needed, temperature using the correction tables for each parameter supplied by the manufacturer.

9. Temperature Monitors

The temperatures are monitored with Type K thermocouples. Each thermocouple's calibration is checked prior to use.

The thermocouple readout is an Omega Model 410B-K/SN 05/4475, with a range of -58 °F to 1999 °F (type K) and an accuracy of ± 0.9 °C, which can be read at ± 0.1 °F. EEMC reads and rounds to 1.0 °F. The single channel readout is interfaced with a manually operated selector switch that allows 24 channels to be monitored with the same readout. The thermocouples are attached to the test unit with sheet metal screws. The thermocouples monitoring internal stove temperature are sealed at the point of entry with sealant.

10. Draft Gauge

Manufacturer:	Dwyer
Model:	
Type:	Inclined Water Manometer
Range:	0-0.25" water
Resolution:	0.001" water
Accuracy:	± 0.001 " water (readability)

11. Anemometer

Manufacturer:	Dwyer
Model:	480 Vaneometer/SN S 222 D
Range:	0-400 FPM
Accuracy:	$\pm 5\%$ of full scale from 0-1 FPM

12. Humidity Gauge

Manufacturer:	Bacharach
Model:	SAC
Type:	Sling Psychrometer
Range:	Wet Bulb: 30-110 °F
Dry Bulb:	30-110 °F
Resolution:	± 1 °F
Accuracy:	± 1 °F

13. Barometer

Manufacturer:	Princo Instruments, Inc.
Model:	NOVA 469

Type:	Mercury Barometer
Range:	20-32" Hg
Resolution:	0.01" Hg
Accuracy:	±0.01" when calibrated and installed as per the manufacturer's written operating instructions.

Equation 6.3.1a of the "Standard Methods for Measuring the Emissions and Efficiencies of Residential Wood Stoves" and equation #1 are programmed into a Hewlett Packard 15C calculator which first calculates stack gas flow rate and then the ΔH . The stack gas flow rate and ΔH are both recorded on Data sheet #2. The ΔH is used to set the flow rate through the dry gas meter at 5 minute intervals during the test.

In order to successfully maintain the correct sampling ratio, the following data is recorded on Data Sheet #2 (Meter Box Data Sheet): temperature ($^{\circ}F$) at the SO_2 injection rotameter (Tr), pressure (inches H_2O) at the SO_2 injection rotameter (Pr), SO_2 injection rate (cc/min), barometric pressure (BP) (inches Hg), stack gas SO_2 concentration (ppm SO_2), sampling ratio (Sr), and the average dry gas meter temperature ($^{\circ}F$). This data is entered into the HP15C, which is used to first calculate a stack gas flow rate (dscf) and then a ΔH for every sampling interval. The flow rate through the dry gas meter is adjusted and maintained by maintaining the appropriate ΔH .

CEM MONITORS

1. Calibration Gases
LoKee uses vendor certified ($\pm 2.0\%$) calibration gases for each CEM. The concentrations purchased coincide with ranges specified in M5H. Upon receipt of the cylinder, the concentrations are verified with Method 3 (ORSAT) analysis.
2. Flow Regulators
LoKee uses a variety of standard gas flow regulators to meter the flow of calibration gases from the cylinders.
3. Point of Injection
Calibration gases are injected directly into the end of the probe. The line carrying the calibration gases from the cylinders is connected to the probe with a short piece of rubber tubing.
4. Sample Gas Conditioning System
The combustion gas is conditioned with a train that is a duplicate of a M5H train. It contains the following components:

SS probe

Glass 4" M5H filter and holder in a heated box

4 1000 ml glass impingers
Glass 4" MSH filter and holder
Indicating silica gel
Type K thermocouple to monitor exit gas temperature
Thomas pump

5. Filters

The filters used are the same as EPA M5H filters.

6. Manifold and Exhaust

The gas stream is delivered to each analyzer through a manifold and flowmeter with the excess gases being routed to an exhaust.

7. CO Analyzer

Horiba PIR 2000/SN 408005
Nondispersive infrared (NDIR)

The gas stream flow is controlled by a SS flowmeter downstream of the analyzer. The calibrated range used is 0-10.0% by volume. The resolution is 0.01% CO. The manufacturer's specification given for linearity is $\pm 1.0\%$.

8. CO₂ Analyzer

Horiba PIR 2000/SN 407069

The CO₂ analyzer is also a NDIR and is operated in exactly the same manner as the CO analyzer. The range of the CO₂ analyzer is 0-25.0% CO₂.

COMBUSTION GAS ANALYZER TRAIN OPERATING INSTRUCTIONS

A. Pretest Preparation, Checks and Audit Procedures

1. Clean the probe with acetone and a brush. Seal the end of the probe for a leak check.
2. Remove the filter holder from the sample box and change the filter.
3. Empty water from all the impingers in the train. Clean all impingers and fill the first 2 with 100 ml of water.
4. Remove the second filter holder from the train and change the filter.
5. Visually check the indicating silica gel in the fourth impinger. If it is visibly impacted by water, replace the silica gel with dry silica gel.
6. Turn on the pump and perform a leak check on the entire train. This is done by placing the exhaust line in water. A successful leak check is accomplished when no bubbles are detected.
7. Slowly release the plug from the probe to prevent any back flushing.
8. Turn off the pump.

9. Turn on the heat in the sample box. Adjust Variac voltage controller so that temperature in the sample box does not exceed 248 °F.
10. Open the bypass valve on the pump.
11. Connect the probe to the zero/span gas delivery line.
12. Turn on the zero gas and adjust the flow rate to 1.5 SCFH.
13. Wait until the zero gas has completely flushed the train and a stable reading is obtained.
14. Record the zero gas readings of the DVM on Data Sheets #15.
15. Turn off the zero gas at the cylinder.
16. Disconnect the zero/span gas delivery line from the zero gas cylinder.
17. Connect the zero/span gas delivery line to the span gas source for each analyzer.
18. Turn on the span gas and adjust the flow rate to 1.5 SCFH. Wait until a stable reading is obtained on each analyzer. Repeat until all three analyzers are spanned properly.
19. Record the span gas readings of the DVM. Record the analyzer's output and all other pertinent information Data Sheets #15.
20. Turn off the span gas at the cylinder.
21. Disconnect the probe from the zero/span gas delivery line.
22. Insert the probe in the stack.
23. Close the bypass valve on the pumps.
24. Approximately 15-20 minutes before the actual start of the test, turn on the pump and adjust the flow through each analyzer until the flow rate is 1.5 SCFH.

B. Operation During Testing

1. Monitor the flow rate to the analyzers periodically to maintain a flow rate of 1.5 SCFH. Make any necessary adjustments.
2. Record data as follows:
 - a. At the start of each 5 minute data cycle, record the scale weight, wet bulb/dry bulb, stack gas temperature and static pressure on Data Sheet #12 (Gas Data).
 - b. Record the combustion gas (CO₂, O₂ and CO) analyzer data and the SO₂ analyzer data on Data Sheet #12.
 - c. Record the remainder of the temperature data.

C. Post Test Checks and Audit Procedures

1. Remove the probe from the stack. (Be careful when handling the probe as it can be quite hot.)
2. Seal the end of the probe.
3. Perform a leak check on the entire train.
4. Slowly release the plug from the end of the probe to prevent any back flushing.
5. Turn off the pump.

6. Open the bypass valve on the pump.
7. Connect the probe to the zero/span gas delivery line.
8. Turn on the zero gas and adjust the flow rate through each analyzer to 1.5 SCFH.
9. Wait until the zero gas has completely flushed the train and a stable reading is obtained from each analyzer.
10. Record the zero gas reading. Record each analyzer's output and all other pertinent information on Data Sheets #15.
11. Turn off the zero gas at the cylinder.
12. Disconnect the zero/span gas delivery line from the zero gas cylinder.
13. Connect the zero/span gas delivery line to the span gas source for each analyzer.
14. Turn on the span gas and adjust until the flow rate through each analyzer to 1.5 SCFH. Wait until the span gas has completely flushed the train and a stable reading is obtained on each analyzer.
15. Record the span gas reading. Record each analyzer's output and all other pertinent information on Data Sheets #15.
16. Turn off the span gas at the cylinder.
17. Disconnect the probe from the zero/span gas delivery line.

D. Determination of the Combustion Gas Train's Response Time

1. The response time of the combustion gas analyzer train is to be determined using the following procedures. It is best to determine the combustion gas analyzer train response time during the "charcoal phase" of a test burn so that CO levels are relatively stable.
 - a. Leak check the combustion gas (CEM) analyzer train.
 - b. Zero the CO analyzer using ambient air.
 - c. Calibrate the CO analyzer.
 - d. Insert the probe for the combustion gas analyzer train in the stack.
 - e. Sample flue gas until a stable reading is obtained.
 - f. Remove the probe from the stack, note the exact CO concentration as measured on the DVM and start a stop watch at the exact time of removal.
 - g. Observe the stop watch and DVM. Record the length of time to initial response, i.e., when the CO levels begin to decline.
 - h. Continue observing the stop watch and DVM. Record the time when the analyzer's output equals zero (0.000 v).
 - i. Repeat steps d-h 2 or 3 times to verify results.

E. Calibration and Audit Procedures for the Combustion Gas Analyzers

1. Calibrate by presenting zero and span gases to each analyzer at the probe and through the entire sampling train. (See Sections 6.7.2 and 6.9 [M5H].) Record the responses on the appropriate calibration forms.
2. Immediately prior to and after each test run, present the zero and span gases to the analyzers through the entire sampling train as is discussed in section C. Record each analyzer's response on Data Sheets #15.
3. Calculate the \pm concentration difference and the actual percent difference as follows using the zero and span gas values obtained in #2 above. All calculations are to be based upon the actual gas concentrations involved.

$$\pm \text{ Concentration Difference} = \text{Actual Conc (\%)} - \text{Std Conc (\%)}$$

$$\text{Zero \% Difference} = \frac{\text{Act Conc (\% or ppm)} - \text{Std Conc (\% or ppm)}}{\text{Full Scale Value (\% or ppm)}} * 100$$

$$\text{Span Act \% Difference} = \frac{\text{Act Response (\% or ppm)} - \text{Exp Response (\% or ppm)}}{\text{Full Scale Value (\% or ppm)}} * 100$$

Then refer to Section 4.2 and 4.3 (M5H) to determine whether the audits are acceptable or not.

TRACER GAS (SO₂) EQUIPMENT

1. SO₂ Injection Probe

A circular SS loop about 4" in diameter is positioned in the center of the stack. The loop extends outside the stack and is connected to the line leading from the SO₂ injection rotameter with Sweglock fittings. The loop is inserted in the stack at 9.5 \pm 0.5 ft above the top of the scale.

2. Rotameter

A rotameter that has been calibrated with a bubble tube. The rotameter is all glass, stainless steel and Teflon. The rotameter has a flow control mechanism which is set to the calibrated flow.

3. Temperature

The temperature at the injection rotameter is measured with a type K thermocouple.

4. Injection Gas

Pure SO₂, 99.999% pure, released from the cylinder through a SS regulator and shut off valve.

5. Calibration Gases
LoKee uses vendor certified calibration gases with traceability established in accordance with EPA Protocol #1 as specified in Section 3.3.1 and verified using EPA Method 6.
6. Sample Probe
3/8" SS tubing inserted at 13.5 ±0.5 feet above the platform scale. No obstructions are in the stack between the injection and sample probes.
7. Combustor
Lindberg tube furnace, Model 55035/SN 800125, range 0-2000 °F. The temperature in the tube furnace is monitored with a type K thermocouple and controlled with a Variac voltage regulator. Power adjustments are made as necessary to maintain temperature at 1425 °F ±25 °F.
8. Sample Condenser
The sample condenser consists of 3 modified M5 impingers immersed in a freezer.
A filter assembly
The exit gas temperature is monitored with a type K thermocouple.
9. Filter
A standard EPA M5H 3" or 4" filter.
10. SO₂ Analyzer
Horiba, PIR 2000/SN 403019
Nondispersive infrared (NDIR)
The analyzer is operated as per the manufacturer's instructions at a flow rate of 1.5 SCFH. The calibration range is 0-2500 ppm SO₂ at a resolution of ±25.0 ppm. The manufacturer's specification for linearity is ±1.0%. The voltage response is displayed on a DVM which is converted to ppm using the manufacturer's calibration curves.
11. Flow Control
Flow through the tracer gas sampling train is controlled by a SS flowmeter.

TRACER GAS TRAIN OPERATING INSTRUCTIONS

- A. Pretest Preparation and Checks and Audit Procedures
 1. Clean the probe with a brush. After cleaning, seal the end of the probe.
Note: Do Not Use Acetone Or Other Organic Solvents To Clean The Probe Immediately Prior To Running A Test Or Conducting A Leak Check.
 2. Turn on the tube furnace in order to insure that the unit is at the correct operating temperature (1425 °F) at the start of the test.
 3. Remove all water and clean the impingers.
 4. Change the filter.

5. Turn on the pump.
6. Perform a leak check on the entire tracer gas train. This is done by placing the SO₂ exhaust line in water. A successful leak check is accomplished when no bubbles are detected.
7. Slowly remove the plug from the end of the probe to prevent any back flushing.
8. Turn off the pump.
9. Bypass the pump.
10. Connect the probe to the zero/span delivery gas line.
11. Connect the zero/span gas delivery line to the zero gas cylinder and turn on the zero gas and adjust the flow until the flow rate through the SO₂ analyzer is 1.5 SCFH.
12. Wait until the zero gas has completely flushed the train.
13. Record the zero gas reading. Record the SO₂ analyzer's DVM output on Data Sheets #15.
14. Turn off zero gas at the cylinder.
15. Disconnect the zero/span gas delivery line from the zero gas cylinder.
16. Connect the zero/span gas delivery line to the span gas cylinder.
17. Turn on the span gas and adjust the flow until the flow rate through the SO₂ analyzer is 1.5 SCFH. Wait until the span gas has completely flushed the train and a stable reading is obtained on the analyzer.
18. Record the span gas reading. Record the analyzer's output and all other pertinent information on Data Sheets #15.
19. Turn off the span gas at the cylinder.
20. Disconnect the zero/span gas delivery line from the probe.
21. Insert the probe in the stack.
22. Close the bypass on the pump.
23. Approximately 15 to 20 minutes before the actual start of the test, turn on the SO₂ injection train and the pump for the tracer gas train.

B. Operation

1. Turn on the tube furnace to insure furnace is at approximately 1425 °F when the test begins.
2. Approximately 15-20 minutes before the actual start of the test, turn on the cylinder of pure SO₂.
3. Using the rotameter's current calibration, adjust the SO₂ flow rate to the calibrated level.
4. Turn on the pump in the tracer gas train. Adjust the flow rate through the SO₂ analyzer so that it remains at 1.5 SCFH.

5. Monitor the SO₂ concentrations in the stack and stack gas flow rates in order to establish a sampling ratio for the test and a correct ΔH at the start of the test.
6. At the start of the test and every 5 minutes thereafter, record the SO₂ analyzer output in volts and the stack gas SO₂ concentration in order to calculate the stack gas flow rate and determine the correct ΔH for the meter box.
Also monitor and record the temperature at the Rotameter (Tr), pressure at the Rotameter (Pr), barometric pressure (BP) SO₂ injection rate (cc/min) and static pressure on Data Sheets #2 and #12.

C. Post Test Checks and Audit (Zero/Span) Procedures

1. Remove the probe from the stack. (Be careful when removing the probe from the stack as it can be quite hot.)
2. Plug the end of the probe.
3. Perform a leak check.
4. Slowly remove the plug from the end of the probe to prevent any back flushing.
5. Turn off the pump.
6. Bypass the pump.
7. Connect the probe to the zero/span gas delivery line.
8. Connect the zero/span gas delivery line to the zero gas cylinder. Turn on and adjust until the flow rate through the SO₂ analyzer is 1.5 SCFH.
9. Wait until the zero gas has completely flushed the train.
10. Record the zero gas reading. Record the SO₂ analyzer's DVM output on Data Sheet #15.
11. Turn off zero gas at the cylinder.
12. Disconnect the zero/span gas delivery line from the zero gas cylinder.
13. Connect the zero/span gas delivery line to the span gas cylinder.
14. Turn on the span gas and adjust the flow until the flow rate through the SO₂ analyzer is 1.5 SCFH. Wait until the span gas has completely flushed the train and a stable reading is obtained.
15. Record the span gas reading. Record the analyzer's output and all other pertinent information on Data Sheet #15.
16. Turn off the span gas at the cylinder.
17. Disconnect the zero/span gas delivery line from the probe.

D. Determination of Tracer Gas Train's Response Time

1. Zero and calibrate the SO₂ analyzer.
2. Prepare and leak check the tracer gas train as per A above.
3. Insert the probe in the stack which contains flue gas and SO₂ concentrations in the ranges normally encountered during wood stove testing.

4. Sample flue gas with SO₂ concentrations until a stable reading is obtained. It is best to determine the tracer gas train's response time during the "charcoal phase" of a test burn so that the SO₂ concentrations are as stable as possible.
5. Remove the probe from the stack, noting the exact SO₂ concentration as measured by the DVM and starting a stop watch at the exact time of removal.
6. Observe the stop watch and DVM. Record the length of time to the initial response, i.e., when the SO₂ levels begin to decline.
7. Continue observing the stop watch and DVM. Record the time when the SO₂ analyzer's output equals zero (0.000 v.).
8. Repeat steps 3-7 two or three times to verify results.

E. Calibration and Audit Procedures for the Tracer Gas (SO₂) Analyzer

1. Calibrate by presenting zero and span gases to the analyzer at the probe and through the entire sampling train. Record the responses on the appropriate calibration form.
2. Immediately prior to and after each test run, present the zero and span gases to the analyzer through the entire sampling train as is discussed in Sections A and C. Record the analyzer's response on Data Sheet #15.
3. Calculate the ± concentration differences and actual percent difference as follows using values obtained in #2 above as the expected response. All calculations are to be based upon the actual gas concentration involved.

$$\pm \text{Concentration Difference} = \text{Actual Conc (\%)} - \text{Std Conc (\%)}$$

$$\text{Zero \% Difference} = \frac{\text{Act Conc (\% or ppm)} - \text{Std Conc (\% or ppm)}}{\text{Full Scale Value (\% or ppm)}} * 100$$

$$\text{Span Act \% Difference} = \frac{\text{Act Response (\% or ppm)} - \text{Exp Response (\% or ppm)}}{\text{Full Scale Value (\% or ppm)}} * 100$$

Then refer to Section 4.2 and 4.3 (M5H) to determine whether the audits are acceptable or not.

TEMPERATURE SENSING OPERATING INSTRUCTIONS

- A. Operate the thermocouple readout selector switch and record the temperature for each thermocouple. All the temperature in the test facility should be approximately the same. Repair as necessary.

- B. Check the operation and output of the thermocouple readout using the Omega NBS Traceable Thermocouple Simulator. The simulator is hooked up to thermocouple readout #23. Check the readout over its full range at 200 °F intervals. Record the data on Data Sheet #16.
- C. One hour before the actual test start record stove temperatures (thermocouple readout #'s 4, 5, 6, 7 and 8), firebox (readout #9), post catalytic combustor or secondary burn chamber (readout #10), and room temperature (readout #11). Record the temperatures every 5 minutes until the start of the test on Data Sheet #13 (Preburn).
- D. During the test record the temperatures every 5 minutes for each of the thermocouples on Data Sheets #12 and 14.

FUEL PREPARATION

- A. No more than 4 hours prior to use, obtain 3 moisture readings from each piece of wood. Record all moisture readings on Data Sheet #10.
- B. Obtain kindling by finely splitting pieces that otherwise cannot be used as test fuel. Weigh the kindling and record the weight on Data Sheet #8.
- C. Obtain the pretest fuel by using 2 x 4's. The length of the pretest fuel can be no less than 1/3 the length of the test fuel. Weigh the pretest fuel prior to its being loaded in the stove. Record weights on Data Sheets #8 and #9.
- D. Obtain the test fuel by cutting dimensional lumber (either 2 x 4's or 4 x 4's) so that the length is 5/6's the length of the longest usable dimension of the firebox. Use the mix of 2 x 4's and 4 x 4's specified in Section 4.3 M28. The test fuel shall be essentially free of knots, sap seams or rotten areas.
- E. The spacers shall measure 1 x 5 x 1" (nominally). The spacers shall be free of knots, sap seams or rotten areas. Nail the spacers to the 2 x 4's and 4 x 4's as described in the regulations.
- F. Take a photograph of the assembled fuel charge at a 90° angle from the photograph that will be taken when the fuel charge is loaded in the stove.

WOOD DENSITY DETERMINATION

- A. When cutting the test fuel, cut a representative piece of 2 x 4 or 4 x 4 that is approximately 3 to 5-inches in length.
- B. Take a moisture reading from the top, bottom and side of the piece. Record readings on Data Sheet #11. Determine the % moisture on a wet and dry basis.
- C. Weight the piece on a balance.
- D. Take measurements of width, depth and length at the four corners with a micrometer. Determine the volume of the piece. (Length x width x depth = Volume in cubic centimeters)
- E. Dry the piece in an oven at 95-100 °C for a minimum of 24 hours.
- F. Reweigh the piece on the balance.

- G. Calculate % moisture on a dried basis.

$$\% \text{ moisture (dry basis)} = 1 - \frac{\text{dried weight}}{\text{wet weight}} * 100$$

- H. Calculate the density.

$$\text{Density (g/cc)} = \frac{\text{dried weight (g)}}{\text{volume (cc)}}$$

BTU'S/LB DETERMINATION

- A. When cutting the test fuel (only the test fuel, not the kindling, pretest fuel or spacers), collect a sawdust sample. Place in a clearly marked plastic bag.
- B. Forward sample to a commercial laboratory for BTU contents analysis.

STOVE PREPARATION

- A. Clean the stove.
- B. Weigh the stove, record the weight on Data Sheet #8.
- C. Add approximately 0.3 lb. of wadded newspaper to the stove. Record weight of newspaper on Data Sheet #8. Add 4-8 lb. of kindling to the stove, and record the weight of the kindling on Data Sheet #8.
- D. Light the paper and kindling, leaving the stove's air draft control(s) wide open and the door cracked until well ignited.
- E. Close door.
- F. When between 50% - 75% of the weight of the kindling has been burned add the first pretest fuel charge.
- G. Continue to add pretest fuel until the stove has thoroughly warmed up. As necessary, rake the coal bed prior to adding additional pretest fuel charges.
- H. Remove all material from the firebox after two or more hours of burning on high. Obtain the dry empty stove weight and record on Data Sheet #8.
- I. Set the stove's air draft control(s) at the desired setting a minimum of 1 hour before the test run is to begin.
- J. As necessary set the heat exchange blower(s) at the specified setting a minimum of one hour before the test is to begin.

- K. Record the stove surface temperatures, firebox and post catalytic or secondary burn temperatures and scale weigh for a minimum of one hour before the test run begins. As necessary add fuel, rake the coal bed, level the coal bed and/or remove coals during the first 45 minutes of the hour immediately preceding the start of the test. Record all information concerning raking, fuel additions, etc. on Data Sheet #13.
- L. If necessary, sometime during the last 15 minutes before the start of the test, open the door and brake up all large pieces and then rake and level the pretest fuel in the stove. At this time, level the coal bed as necessary to accommodate loading the fuel charge into the stove. Close the door. Total time door can be open during the last 15 minutes is 1 minute. No further manipulation of the stove is allowed during the 15 minutes immediately preceding the start of the test.
- M. When the weight of the coal bed equals 20-25% of the weight of the test fuel charge, load the test fuel. Take a photograph of the fuel load in the stove immediately after loading the fuel. Leave the door open as per the manufacturer's instruction, but no longer than 5 minutes.
- N. Document all stove operating data from ignition through loading and test start up on Data Sheet #9.







