
LOKEE TESTING
Laboratory

United States
Environmental Protection Agency
Wood Heater Certification Test Report

JOTUL U.S.A., INC.
F600

Volume 1 of 1

13235 PRAIRIE CIRCLE EAST, SUMNER, WASHINGTON 98390
TELEPHONE: 360-897-9685

United States
Environmental Protection Agency
Wood Heater Certification Test Report

Jotul U.S.A., Inc.
400 Riverside Street
P. O. Box 1157
Portland, ME 04104

F600

Volume 1

Report By:

Chip Wadington
Deborah Wadington

CONFIDENTIAL

RELEASED ONLY BY
AUTHORIZED PERSONNEL

May 15, 2003

TABLE OF CONTENTS

<u>Page(s)</u>		<u>Section(s)</u>
Introduction		
	Title Page	i
	Table of Contents	ii
	Test Report (Data) Page Number Index	iii-iv
	Individual Test Run Page Number Index	v
	Test Series Information and Discussion	vi
	Stove Storage Information	vii
	Stack Measurements and Sampling Port Locations	viii
	Stove / Catalysts Aging Data	ix
	Scheduling Information	varies
Summary and Discussion of Results		
	Emission Test Summary	Data Summary 1
	Emission Graph	1
	Data Summary	2, 3
Individual Test Runs (Raw Data)		
	See Introduction, Individual Test	<0.80 kg/hr varies
	Run Page Index for a complete,	0.8 - 1.25 kg/hr varies
	sequential list of data and data	1.25 - 1.90 kg/hr varies
	sequence in the individual test runs	>1.90 kg/hr varies
		Fan Confirmation (if necessary) varies
		Insert Confirmation (if necessary) varies
Calibration Data		
	See Test Report (data) Page Number	Cal Data varies
	Index, Item 14, for a complete, sequential	
	listing of the data in this section.	
Stove Q C		
	Stove Q C	Stove Q C varies
	Firebox Volume Dimensions	
	Manufacturer's Drawings	
Manual		
	Manufacturer's Written Test	Manual varies
	Instructions (if provided)	
	Manufacturer's Operation Manual	
Appendices		
	A: - Example Calculations	Appendix A varies
	B: - Installation Description and Operating Instructions	Appendix B varies
Efficiencies		
	A. Data Summary	Efficiencies varies
	B. Individual Run Data	
Photos		
	Photos of wood loads in and out	Photograph Pages varies
	of the test unit.	

2. Post Certification Test	Cal Data	Pages 16 & 17
3. Transfer Standard Calibration	Cal Data	Pages 18-23
4. Wet Test Meter Calibration	Cal Data	Page 24
I. Tracer Gas Rotameter	Cal Data	Pages 25-26
J. Combustion Gas (CO ₂ , O ₂ , CO) Train Response Check	Cal Data	Page 27
K. Tracer Gas (SO ₂) Train Response Check	Cal Data	Page 27
L. CO Analyzer		
1. Calibration	Cal Data	Pages 28 & 29
2. Zero/Span Control Chart	Cal Data	Page 30
3. Pre and Post Test Zero/Span	Individual Test Runs	Data Sheet # 15-3
M. CO ₂ Analyzer		
1. Calibration	Cal Data	Pages 31 & 32
2. Zero/Span Control Chart	Cal Data	Page 33
3. Pre and Post Test Zero/Span	Individual Test Runs	Data Sheet # 15-1
N. O ₂ Analyzer (Optional)		
1. Calibration	Cal Data	Pages 34 & 35
2. Zero/Span Control Chart	Cal Data	Page 36
3. Pre and Post Test Zero/Span	Individual Test Runs	Data Sheet # 15-2
O. SO ₂ Analyzer		
1. Calibration	Cal Data	Pages 37 & 38
2. Zero/Span Control Chart	Cal Data	Page 39
3. Pre and Post Test Zero/Span	Individual Test Runs	Data Sheet # 15-4
P. Calibration Gas Certificates of Analysis		
1. Pre and Post Test Zero/Span Audits	Individual Test Runs	Data Sheets #15-1 - 15-4
2. Method 3 Verification of Analysis (CO ₂ , O ₂ , CO, N ₂)	Cal Data	Varies
3. Method 6 Verification of Analysis (SO ₂ , N ₂)	Cal Data	Varies
15. Quality Checks		
A. Leak Checks		
1. Particulate Sampling Train	Individual Test Runs	Data Sheet #2
2. SO ₂ Injection System	Individual Test Runs	Data Sheet #16
3. Combustion Gas (CO ₂ , O ₂ , CO) (CEM) Train	Individual Test Runs	Data Sheet #16
4. Tracer Gas (SO ₂) Train	Individual Test Runs	Data Sheet #16
B. Proportional Checks	Individual Test Runs	Table 5-Computer Printout
16. Sample Calculations		
A. Weighted Average Emission Rate	Data Summary	Weighted Average Calc Sheet
B. Dry Burn Rate	Individual Test Runs	Data Sheet # 8
C. [Vm] - [Vm (std)]	Individual Test Runs	Data Sheet # 7 (Particulate Calc Sheet)
D. Total Gas Flow Rate (Qsd)	Individual Test Runs	Table 4-Computer Printout
E. Proportionality Rate (PR)	Individual Test Runs	Table 5-Computer Printout
F. Particulate Emission Rate	Individual Test Runs	Table 4-Computer Printout
17. Raw Test Data	Individual Test Runs	Data Sheets # 1-16
18. Analytical Data		
A. Filter and Beaker Tares	Individual Test Runs	Data Sheets # 4-1, 4-2
B. Solvent Blanks	Individual Test Runs	Data Sheet # 5
C. Particulate Catches		
1. Gross	Individual Test Runs	Data Sheet # 3
2. Blanks	Individual Test Runs	Data Sheets # 5 & 6
3. Net	Individual Test Runs	Data Sheet # 6
4. Gr/dscf	Individual Test Runs	Data Sheet # 7
D. Constant Weight Weighing	Individual Test Runs	Data Sheet # 4-3

TEST SERIES INFORMATION

Unit name and model number: F600

Type of unit: Wood Heater

Manufacturer: Jotul U.S.A., Inc.
Address: 400 Riverside Steet
Portland, ME 04104

Contact: Roger Purington
Phone Number: 207-797-5912
Fax Number: 207-772-0523

Observers: None

Date Rcv'd: 03/24/2003 Aged: 04/21-22/2003 Tested: 04/29-05/07/2003

Tested by: LoKee Testing Lab using EPA Methods 28, 28A and 5H where applicable.

Test Location: 13235 Prairie Circle East
Sumner, WA 98390-7250
Test Site Elevation: 500 feet above sea level


LoKee's Field Team

Team Members: Chip Wadington
Deborah Wadington

The following pages contain (1) test unit storage information, (2) a diagram showing the height and location of the stack components and sampling ports, and (3) copies of the certification test notices and cancellations sent to the EPA.

Model: F800

Date: 04/29/03



AGING DATA SHEET

UNIT : F 600

DATE: 4-21-03

Hr #	DATE	TIME	TEMP	
			Fbox 1	Sec 2
1	4-21	1300	1005	1316
2	"	1400	510	583
3	"	1500	348	965
4	"	1600	552	948
5	"	1700	669	906
6	"	1800	614	964
7	"	1900	510	579
8	"	2000	455	544
9	4-22	1505	888	1058
10	"	1605	541	612
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

Hr #	DATE	TIME	TEMP	
			1	2
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				
47				
48				
49				
50				

COMMENTS:

4-21-03 / Stone lit 0930

4-22-03 / Stone lit 1000

April 29, 2003

Mr. John Dupree
Federal Programs Section
U.S. EPA
Stationary Source Compliance Division
Mail Code 2223A Room #7124
1200 Pennsylvania Avenue NW
Washington, DC 20460


Mr. Dupree:

This is a request to waive the 30 notification for testing in order run certification tests on the:

Jotul :
Model F 600

If you have any questions please feel free to call.

Sincerely,



Chip Wadington
Owner

April 29, 2003

Mr. John Dupree
Federal Programs Section
U.S. EPA
Stationary Source Compliance Division
Mail Code 2223A Room #7138
1200 Pennsylvania Avenue NW
Washington, DC 20460


Mr. Dupree:

On April 29, 2003 at 10:47 am PST, Irvin Keefer waived the 30 day intent to certify notice at the request of LoKee Testing Laboratory in order to run certification tests on the:

Jotul North America :
Model -F600

If you have any questions please feel free to call.

Sincerely,



Chip Wadington
Owner

May 8, 2003


Irvin Keefer
Office of Compliance, Manufacturing,
Energy, and Transportation Division (2223-A)
USEPA
401 M Street, S.W.
Washington, D.C. 20460

Mr. Keefer

Here is a document for your records stating that all the test runs were not run on consecutive workdays during the testing of the Jotul F600. This is due to a crack in the back half filter housing that occurred when ice was loaded into the impinger bucket shortly before test run #2 started. This took place after the system leak check earlier in the day. The break was caught during the 5 minute to 10-minute period of the test when the test meter system showed no vacuum during a large sample pull. The test was immediately aborted. There was no sample to collect.

If you have any questions please feel free to call.

Thankyou



Chip Wadington

May 8, 2003


Irvin Keefer
Office of Compliance, Manufacturing,
Energy, and Transportation Division (2223-A)
USEPA
401 M Street, S.W.
Washington, D.C. 20460

Mr. Keefer

Here is a document for your records stating that all the test runs were not run on consecutive workdays during the testing of the Jotul F600. This is due to a crack in the back half filter housing that occurred when ice was loaded into the impinger bucket shortly before test run #2 started. This took place after the system leak check earlier in the day. The break was caught during the 5 minute to 10-minute period of the test when the test meter system showed no vacuum during a large sample pull. The test was immediately aborted. There was no sample to collect.

If you have any questions please feel free to call.

Thankyou



Chip Wadington

May 8, 2003


Irvin Keefer
Office of Compliance, Manufacturing,
Energy, and Transportation Division (2223-A)
USEPA
401 M Street, S.W.
Washington, D.C. 20460

Mr. Keefer

Here is a document for your records stating that all the test runs were not run on consecutive workdays during the testing of the Jotul F600. This is due to a crack in the back half filter housing that occurred when ice was loaded into the impinger bucket shortly before test run #2 started. This took place after the system leak check earlier in the day. The break was caught during the 5 minute to 10-minute period of the test when the test meter system showed no vacuum during a large sample pull. The test was immediately aborted. There was no sample to collect.

If you have any questions please feel free to call.

Thankyou



Chip Wadington

Wood Heater Emission Test Summary

Laboratory/Wood Heater Information


Stove Manufacturer: JOTUL U.S.A., INC
 Model Identification: F600
 -Stove Type-
 1=cat, 2=noncat, 3=pellet: 2

Laboratory Name: LoKee Testing Laboratory
 Laboratory Contact: CHIP WADINGTON
 Telephone number: 360-897-9685

Test Dates: APR 29 THRU MAY 07, 2003

-Test Methods Used-
 Method 28/Other: 28
 Sampling Method: 5H

Run no.	Burn Rate (kg/hr)	Emission Rate (g/hr)	Heat Output (Btu/hr)	Wtd Avg (g/hr)
				4.08
3	0.96	4.80	11576	
4	1.22	4.49	14711	
1	1.86	2.81	22428	
5	2.70	3.30	32557	
6	1.11	4.84	13385	



DATA SUMMARY

Unit : Jotul U.S.A., Inc. - F600

	RUN #	3	4	1	5	6 FAN
Particulate Emissions:						
Concentration:	grains/dscf:	.2022	.1511	.0689	.0609	.1636
Emissions Rate	grams/hr:	4.80	4.49	2.81	3.30	4.84
Emissions Factor	grams/kg:	4.97	3.68	1.51	1.22	4.35
Front Half Catch	% of total	44.0	32.8	40.2	52.1	32.3
Total Mass Captured	total catch:	1.7193	1.1582	.2972	.1357	1.3857
Heat Output (EPA Default):	BTU/hr	11,623.7	14,698.8	22,462.0	32,510.2	13,436.3
Fuel Burn Rates:						
Average kg/hr (dry)	Kg/hr	0.96	1.22	1.86	2.70	1.11
Fuel Moisture Content:						
Kindling (wet basis)	%	13.917	14.286	16.504	15.636	15.110
Pretest Fuel (wet basis)	%	19.159	18.452	17.369	18.055	17.548
Test Fuel (wet basis)	%	18.189	17.759	17.789	18.846	18.345
Air to Fuel Ratio		N/A	N/A	N/A	N/A	N/A
Average Stack Gas						
Avg CO ₂	%	6.63	6.97	8.32	9.61	5.96
Avg O ₂	%	N/A	N/A	N/A	N/A	N/A
Avg CO	%	1.55	1.30	1.02	0.68	1.50
Avg Moisture	%	6.40	6.46	7.78	8.62	9.35
Avg Stack Gas Emissions:						
CO	g/Kg	196.40	163.66	115.58	70.85	205.91
	g/hr	189.33	199.50	215.33	191.00	229.39

[Faint, illegible handwriting on lined paper]



COMPUTER INPUT DATA SHEET #1

Client: JOTUL USA, INC.
Address: 400 RIVERSIDE ST. / P.O. BOX 1157
PORTLAND, ME 04104
Phone: 800-797-5912 Fax: 207-797-6072
Run No.: 3 Date of Test: 05/01/03 Burn Rate: 964 ✓
Model No.: F600 min min-1.25 fan
Stove Type: Cat Non Cat Pellet 1.25-1.9 max insert
Dry Gas Meter Y Factor: 990 ✓ Post Leak Rate: 0.006 cfm Time: 425 min. ✓
(0.000) (Data Sheet #2) (0.000) (Data Sheet #2) (000) (Data Sheet #2)
Dry Gas Meter Volume: 137.024 cf ✓
(00.000) (Data Sheet #2)
Stack Flow: 6.433 dscfm Δ H: 1.63 in. H₂O ✓
(00.000) (Data Sheet #2) (0.000) (Data Sheet #2)
Maximum Vac.: 5.0 Barometric Pressure: 30.03 in. Hg ✓
(0.0) (Data Sheet #2) (00.00) (Data Sheet #2)
H₂O Captured: 190.6 g ✓
(00.0) (Data Sheet #3)
Front Half Catch % Of Total: 44.0 % Total Particulate Catch: 1.7193 g ✓
(00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)
Flue Gas Moisture: 6.4012 % ✓
(00.000) (Data Sheet #7)
Particulate Emission: 2022 gr/dscf ✓
(0.0000) (Data Sheet #7)
Relative Humidity: 34.0 % RH Ambient Moisture: 1.30 % H₂O ✓
(00.0) (Data Sheet #8) (0.00) (Data Sheet #8)
Preburn Fuel Wt.: 46.1 lbs. Coal Bed Wt.: 4.3 lbs. Test Fuel Wt.: 18.4 lbs. ✓
(00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)
Heat Output (EPA Default): 11,623.7 BTU/hr ✓
(00,000.0) (Data Sheet #8)
Kindling Fuel % Moisture (wet): 13.917 % Pretest Fuel % Moisture (wet): 19.159 % ✓
(00.000) (Data Sheet #10) (00.000) (Data Sheet #10)
Test Fuel % Moisture (dry): 22.233 % Test Fuel % Moisture (wet): 18.189 % ✓
(00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])
Fuel Higher Heating Value (dry): - BTU/lb. ✓
(0000) (Data Sheet #11)
Stack Static Pressure: -0.027 in. H₂O ✓
(+/- .000) (Data Sheet #12)
Average Ambient Temperature: 81 °F Stove Temperature Change: -81.0 °F ✓
(00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul

TEST No. : 3

MODEL: F600

DATE: 01-May-03

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
=====	=====	=====	=====	=====	=====	=====
0	542.800	0.150	87	1.55	6.10	550
5	544.300	0.600	87	0.47	5.90	275
10	547.387	0.150	87	0.70	2.70	550
15	548.934	0.140	87	0.75	3.10	575
20	550.414	0.130	87	0.88	3.60	600
25	551.833	0.110	87	1.02	4.00	650
30	553.142	0.120	87	0.95	5.00	625
35	554.504	0.110	87	1.25	6.10	650
40	555.813	0.100	87	1.46	4.80	675
45	557.074	0.100	87	1.50	5.30	675
50	558.335	0.100	87	1.67	5.50	675
55	559.596	0.140	87	1.15	6.80	575
60	561.075	0.120	87	1.94	4.80	625
65	562.437	0.150	87	1.12	8.10	550
70	563.984	0.200	87	0.86	9.00	475
75	565.775	0.200	87	0.83	8.60	475
80	567.566	0.220	87	0.72	9.80	450
85	569.456	0.220	87	0.74	9.30	450
90	571.347	0.250	87	0.44	10.70	425
95	573.348	0.250	87	0.50	11.60	425
100	575.349	0.280	87	0.44	11.90	400
105	577.475	0.280	87	0.51	11.60	400
110	579.601	0.280	87	0.46	11.30	400
115	581.726	0.250	87	0.31	10.10	425
120	583.728	0.250	87	0.39	9.50	425
125	585.729	0.250	87	0.42	9.30	425
130	587.730	0.250	87	0.37	9.40	425
135	589.731	0.250	87	0.31	10.60	425
140	591.732	0.250	87	0.37	9.80	425
145	593.733	0.250	87	0.26	9.70	425
150	595.734	0.250	87	0.26	10.40	425
155	597.735	0.250	87	0.27	10.60	425
160	599.737	0.250	88	0.21	9.70	425
165	601.745	0.250	88	0.19	9.40	425
170	603.753	0.250	88	0.81	8.50	425
175	605.762	0.180	88	0.93	7.70	500
180	607.470	0.180	88	1.23	6.80	500
185	609.180	0.140	89	1.81	6.10	575
190	610.667	0.150	89	1.76	6.20	550
195	612.222	0.160	89	1.70	6.40	525
200	613.851	0.150	89	1.96	6.20	550
205	615.405	0.160	89	2.06	6.10	525
210	617.034	0.160	89	2.23	6.00	525
215	618.663	0.160	89	2.20	6.00	525

220	620.292	0.150	89	2.15	6.10	550
225	621.847	0.150	89	2.27	5.80	550
230	623.401	0.150	89	2.29	5.80	550
235	624.956	0.150	89	2.44	5.80	550
240	626.511	0.150	89	2.46	5.80	550
245	628.067	0.150	89	2.19	5.90	550
250	629.623	0.140	89	2.36	5.80	575
255	631.111	0.130	90	1.93	6.00	575
260	632.610	0.120	90	2.04	5.80	600
265	634.047	0.120	90	2.14	5.80	600
270	635.484	0.120	90	1.94	5.90	600
275	636.921	0.120	90	1.96	5.90	600
280	638.358	0.120	90	2.03	5.80	600
285	639.794	0.120	90	2.04	5.90	600
290	641.231	0.120	90	1.89	6.00	600
295	642.668	0.120	90	1.92	6.00	600
300	644.105	0.120	90	1.88	5.90	600
305	645.542	0.130	90	1.82	5.90	575
310	647.041	0.130	90	1.43	6.00	575
315	648.540	0.120	90	1.60	5.90	600
320	649.977	0.120	90	1.65	5.80	600
325	651.414	0.120	90	1.77	5.70	600
330	652.851	0.130	90	1.79	5.70	575
335	654.350	0.120	90	1.86	5.70	600
340	655.787	0.120	90	1.81	5.70	600
345	657.224	0.120	90	1.79	5.60	600
350	658.660	0.120	90	1.89	5.50	600
355	660.097	0.120	90	2.04	5.40	600
360	661.534	0.120	90	2.52	5.00	600
365	662.971	0.120	90	2.54	4.90	600
370	664.408	0.120	90	2.51	4.90	600
375	665.845	0.120	88	2.50	4.80	600
380	667.271	0.120	88	2.51	4.80	600
385	668.697	0.120	88	2.50	4.80	600
390	670.124	0.120	88	2.31	5.20	600
395	671.550	0.120	88	2.41	4.90	600
400	672.977	0.110	88	2.38	5.00	625
405	674.346	0.110	88	2.39	4.90	625
410	675.715	0.110	88	2.77	4.60	625
415	677.085	0.110	88	2.75	4.50	625
420	678.454	0.110	88	2.77	4.30	625
425	679.824	0.110	88	2.71	4.30	625
430						

TABLE 2---RAW DATA

CLIENT : Jotul

TEST No. 3

MODEL: F600

DATE: 01-May-03

METER CAL. FACTOR (Y) -----	0.99	Wt. WOOD BURNED (LB) -----	18.4	Lbs
BAROMETRIC PRESS. (Pb) -----	30.03 in Hg	WET, FUEL MOISTURE % -----	18.189	%
LEAK RATE POST (Lp) -----	0.006 cfm	Wt. PART. COLLECTED -----	1.7193	g
WATER VOL. (V1c) -----	190.6 Ml	METER VOLUME Vm -----	137.024	mcf
TEST TIME (MIN) -----	425 min	HC MOLE FRACTION -----	0.0132	

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul

TEST No. 3

MODEL: F600

DATE: 01-May-03

AVG DELTA		AVG PRCNT		
H	----- 0.16 in H2O	CO	----- 1.55	%
AVG METER		AVG PRCNT		
TEMP. Tm	----- 88 deg F	CO2	----- 6.63	%
AVG PPM		AVG BAL		
SO2	----- 546 PPM	CO2/CO	----- 4.29	%

TABLE 4 ----- CALCULATIONS

CLIENT : Jotul

TEST No. 3

MODEL: F600

DATE: 01-May-03

STD SAMPLE		STACK GAS	
VOL. Vm(std) -----	131.17 dscf	FLOW Qsd -----	365.819 dscf/Hr & 6.10 dscf/min
VOL. WATER		PARTICULATE	
VAPOR Vw(std) ----	8.972 scf	CONCTR. Cs -----	0.0131 g/dscf
PRCNT		PARTC.EMISS.	
MSTR Bws -----	6.40 %	RATE E -----	4.80 g/Hr
BURN		MOLES OF GAS	
RATE BR -----	0.96 Kg/Hr	PER Lb WOOD Nt --	0.45 Lb-mole/Lb
CO EMISSION		PART.EMISS.	
RATE -----	189.33 g/Hr & 196.40 g/Kgdry fuel	RATE -----	4.97 g/Kgdry fuel

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul

TEST No. : 3

MODEL: F600

DATE: 01-May-03

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	791.7	97	100
10	815.6	100	
15	816.5	100	
20	816.6	100	
25	817.0	100	
30	816.4	100	
35	816.8	100	
40	816.4	100	
45	816.7	100	
50	816.7	100	
55	816.7	100	
60	816.1	100	
65	816.8	100	
70	816.5	100	
75	816.5	100	
80	816.5	100	
85	816.3	100	
90	816.7	100	
95	816.3	100	
100	816.3	100	
105	816.3	100	
110	816.3	100	
115	816.0	100	
120	816.7	100	
125	816.3	100	
130	816.3	100	
135	816.3	100	
140	816.3	100	
145	816.3	100	
150	816.3	100	
155	816.3	100	
160	816.0	100	
165	817.7	100	
170	817.7	100	
175	818.1	100	
180	818.1	100	
185	818.3	100	
190	817.5	100	
195	817.7	100	
200	817.7	100	
205	817.2	100	
210	817.7	100	
215	817.7	100	
220	817.7	100	

225	817.7	100
230	817.2	100
235	817.7	100
240	817.7	100
245	818.3	100
250	818.3	100
255	817.3	100
260	822.6	100
265	822.8	101
270	822.8	101
275	822.8	101
280	822.8	101
285	822.3	100
290	822.8	101
295	822.8	101
300	822.8	101
305	822.8	101
310	822.6	100
315	822.6	100
320	822.8	101
325	822.8	101
330	822.8	101
335	822.6	100
340	822.8	101
345	822.8	101
350	822.3	100
355	822.8	101
360	822.8	101
365	822.8	101
370	822.8	101
375	824.3	101
380	819.5	100
385	819.5	100
390	820.1	100
395	819.5	100
400	820.1	100
405	819.5	100
410	819.5	100
415	820.1	100
420	819.5	100
425	820.1	100
430		
435		

METER BOX DATA SHEET PAGE # 2

Page: 1 of 4

UNIT: E600 RUN: 3 DATE: 5-1-03

Meter Box: SH Y Factor: .990

Leak checks: 15 " Hg @ .1007 cfm _____ " Hg @ _____ cfm

15 " Hg @ .1004 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO PRESS: <u>.16</u>			SAMPLING RATIO: <u>20.5</u> : 1				BP: <u>30.06</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
0	1235	542.800	—	6.230	.15	87	550	87	1.0	
5	40	544.300	—	12.461	.60	87	275	87	5.0	
10	45	547.387	547.387	6.230	.15	87	550	87	1.0	
15	50	548.934	548.934	5.959	.14	87	575	87	1.0	
20	55	550.414	550.414	6.711	.13	87	600	87	1.0	
25	1300	551.833	551.833	5.272	.11	87	650	87	1.0	
30	05	553.142	553.142	5.483	.12	87	625	87	1.0	
35	10	554.504	554.504	5.272	.11	87	650	87	1.0	
40	15	555.813	555.813	5.077	.10	87	675	87	1.0	
45	20	557.074	557.074	5.077	.10	87	675	87	1.0	
50	25	558.335	558.335	5.077	.10	87	675	87	1.0	
55	30	559.596	559.596	5.959	.14	87	575	87	1.0	
ROTO PRESS: <u>.16</u>			TOTALS: <u>73.808</u>		<u>1.95</u>	<u>1044</u>	BP: <u>30.06</u>			
60	1335	561.075	561.075	5.483	.12	87	625	87	1.0	
65	40	562.437	562.437	6.230	.15	87	550	87	1.0	
70	45	563.984	563.984	7.214	.20	87	475	87	1.0	
75	50	565.775	565.775	7.214	.20	87	475	87	1.0	
80	55	567.566	567.566	7.615	.22	87	450	87	1.0	
85	1400	569.456	569.456	7.615	.22	87	450	87	2.0	
90	05	571.347	571.347	8.063	.25	87	425	87	2.0	
95	10	573.348	573.348	8.063	.25	87	425	87	2.0	
100	15	575.349	575.349	8.567	.28	87	400	87	2.0	
105	20	577.475	577.475	8.567	.28	87	400	87	2.0	
110	25	579.601	579.601	8.567	.28	87	400	87	2.0	
115	30	581.726	581.726	8.063	.25	87	425	87	2.2	
			TOTALS: <u>91.261</u>		<u>2.70</u>	<u>1044</u>	MAX VACC =			
TOTAL Cu Ft.			TOTALS: <u>165.069</u>		<u>4.65</u>	<u>2088</u>	AVG. BP:			

METER BOX DATA SHEET PAGE # 2

Page: 2 of 4

UNIT: F600 RUN: 3 DATE: 5-1-03

Meter Box: SH Y Factor: .990

Leak checks: 15 " Hg @ .007 cfm _____ " Hg @ _____ cfm

15 " Hg @ .006 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.16</u>			SAMPLING RATIO: <u>20.5</u> : 1				BP: <u>30.06</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
120	1435	583.728	583.728	8.063	.25	87	425	87	2.0
125	40	585.729	585.729	8.063	.25	87	425	87	2.0
130	45	587.730	587.730	8.063	.25	87	425	87	2.0
135	50	589.731	589.731	8.063	.25	87	425	87	2.0
140	55	591.732	591.732	8.063	.25	87	425	87	2.0
145	1500	593.733	593.733	8.063	.25	87	425	87	2.0
150	05	595.734	595.734	8.063	.25	87	425	87	2.0
155	10	597.735	597.735	8.063	.25	87	425	87	2.0
160	15	599.737	599.737	8.048	.25	88	425	88	2.0
165	20	601.745	601.745	8.048	.25	88	425	88	2.0
170	25	603.753	603.753	8.048	.25	88	425	88	2.0
175	30	605.762	605.762	6.841	.18	88	500	88	2.0
ROTO PRESS: <u>.16</u>			TOTALS: 95.489		2.93	1048	BP.: 30.02		
180	1535	607.470	607.470	6.832	.18	88	500	88	2.0
185	40	609.180	609.180	5.941	.14	89	575	89	2.0
190	45	610.667	610.667	6.211	.15	89	550	89	2.0
195	50	612.222	612.222	6.506	.16	89	525	89	2.0
200	55	613.851	613.851	6.211	.15	89	550	89	2.0
205	1600	615.405	615.405	6.506	.16	89	525	89	2.0
210	05	617.034	617.034	6.506	.16	89	525	89	2.0
215	10	618.663	618.663	6.506	.16	89	525	89	2.0
220	15	620.292	620.292	6.211	.15	89	550	89	2.0
225	20	621.847	621.847	6.211	.15	89	550	89	2.0
230	25	623.401	623.401	6.211	.15	89	550	89	2.0
235	30	624.956	624.956	6.211	.15	89	550	89	2.0
				TOTALS:	76.063	1.86	1067	MAX VACC =	
TOTAL Cu Ft.				TOTALS:	171.552	4.79	2115	AVG. BP:	

METER BOX DATA SHEET PAGE # 2

Page: 3 of 4

UNIT: FL00 RUN: 3 DATE: 5-1-03

Meter Box: SH Y Factor: .990

Leak checks: 15 " Hg @ .007 cfm _____ " Hg @ _____ cfm
15 " Hg @ .006 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1,500

ROTO: PRESS: <u>116</u>			SAMPLING RATIO: <u>20.5</u> : 1				BP: <u>30.06</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
240	1635	626.511	626.511	6.207	.15	89	550	89	2.0	
245	40	628.067	628.067	6.207	.15	89	550	89	2.0	
250	45	629.623	629.623	5.937	.14	89	575	89	2.0	
255	50	631.111	631.111	5.915	.13	90	575	90	2.0	
260	55	632.610	632.610	5.669	.12	90	600	90	2.0	
265	1700	634.047	634.047	5.669	.12	90	600	90	2.0	
270	05	635.484	635.484	5.669	.12	90	600	90	2.0	
275	10	636.921	636.921	5.669	.12	90	600	90	2.0	
280	15	638.358	638.358	5.669	.12	90	600	90	2.0	
285	20	639.794	639.794	5.669	.12	90	600	90	2.0	
290	25	641.231	641.231	5.669	.12	90	600	90	2.0	
295	30	642.668	642.668	5.669	.12	90	600	90	2.0	
ROTO PRESS: <u>116</u>			TOTALS: <u>69.618</u>			<u>1.53</u>	<u>1077</u>	BP: <u>30.00</u>		
300	1735	644.105	644.105	5.669	.12	90	600	90	2.0	
305	40	645.542	645.542	5.915	.13	90	575	90	2.0	
310	45	647.041	647.041	5.915	.13	90	575	90	2.0	
315	50	648.540	648.540	5.669	.12	90	600	90	2.0	
320	55	649.977	649.977	5.669	.12	90	600	90	2.0	
325	1800	651.414	651.414	5.669	.12	90	600	90	2.0	
330	05	652.851	652.851	5.915	.13	90	575	90	2.0	
335	10	654.350	654.350	5.669	.12	90	600	90	2.0	
340	15	655.787	655.787	5.669	.12	90	600	90	2.0	
345	20	657.224	657.224	5.669	.12	90	600	90	2.0	
350	25	658.666	658.666	5.669	.12	90	600	90	2.0	
355	30	660.097	660.097	5.669	.12	90	600	90	2.0	
			TOTALS: <u>68.766</u>			<u>1.47</u>	<u>1080</u>	MAX VACC =		
TOTAL Cu Ft.			TOTALS: <u>138.384</u>			<u>3.00</u>	<u>2157</u>	AVG. BP:		

METER BOX DATA SHEET PAGE # 2

Page: 4 of 4

UNIT: Fluor RUN: 3

DATE: 5-1-03

Meter Box: 5H Y Factor: .990

Leak checks: 15 " Hg @ .007 cfm _____ " Hg @ _____ cfm

15 " Hg @ .006 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO PRESS: <u>.16</u>		SAMPLING RATIO: <u>20.5</u> : 1				BP: <u>30.00</u>				
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
360	1835	661.534	661.534	5.669	.12	90	600	90	2.0	
365	40	662.971	662.971	5.669	.12	90	600	90	2.0	
370	45	664.408	664.408	5.669	.12	90	600	90	2.0	
375	50	665.845	665.845	5.689	.12	88	600	88	2.0	
380	55	667.271	667.271	5.689	.12	88	600	88	2.0	
385	1900	668.697	668.697	5.689	.12	88	600	88	2.0	
390	05	670.124	670.124	5.689	.12	88	600	88	2.0	
395	10	671.550	671.550	5.689	.12	88	600	88	2.0	
400	15	672.977	672.977	5.462	.11	88	625	88	2.0	
405	20	674.346	674.346	5.462	.11	88	625	88	2.0	
410	25	675.715	675.715	5.462	.11	88	625	88	2.0	
415	30	677.085	677.085	5.462	.11	88	625	88	2.0	
ROTO PRESS: <u>.16</u>		TOTALS: <u>67.300</u>			<u>1.40</u>	<u>1062</u>	BP: <u>30.00</u>			
420	1935	678.454	678.454	5.462	.11	88	625	88	2.0	
425	40	679.824	679.824	5.462	.11	88	625	88	2.0	
430										
435				10.924	.22	176				
440										
445										
450										
455						7598				
460										
465										
470				553.229	11.06	88				
475										
		TOTALS:						MAX VACC =	<u>5.0</u>	
TOTAL Cu Ft. <u>137.024</u>		TOTALS:			<u>6.433</u>	<u>1163</u>	<u>548</u>	AVG. BP:	<u>30.03</u>	

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT: FL600 RUN: 3 DATE: 5-1-03

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	763.9	607.4	486.8	891.8
INITIAL WT	619.0	599.4	483.7	857.2
NET WT GRAMS	144.9	8.0	3.1	34.6

TOTAL CATCH: 190.6 GRAMS H₂O

FRONT HALF

FILTER #	149F	
FINAL WT g	1.2874	✓
INITIAL WT g	.6939	✓
NET WT g	.5935	✓

BEAKER #	6
DESC.	ACETONE
FINAL WT g	91.3707
INITIAL WT g	91.2076
NET WT g	.1631
VOL. DESC. ml	110

BACK HALF

FILTER #	149B	
FINAL WT g	.6255	✓
INITIAL WT g	.4288	✓
NET WT g	.1967	✓

BEAKER #	7	8	9	10	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	97.5830	108.7097	108.2322	105.8478	
INITIAL WT g	97.1382	108.6357	108.0960	105.7306	
NET WT g	.4448	.0740	.1362	.1172	.2534
VOL. DESC ml	175	75	200	185	(385)

BEAKER TARE WEIGHTS DATA SHEET #4-2

Into Dessicator: Date: 08-19-2002 Time: 1205 By: DM

BEAKER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME
1	104.9172	1043	104.9174	0704		
2	106.2542	1044	106.2538	0705	Total Flood R-1	
3	107.7782	1046	107.7777	0706		
4	108.7744	1047	108.7740	0708		
5	97.4390	1048	97.4366	0709		
6	91.2080	1050	91.2076	0710		
7	97.1385	1051	97.1382	0711	Total Flood R-3	
8	108.6356	1052	108.6357	0713		
9	108.0961	1053	108.0960	0714		
10	105.7310	1055	105.7306	0715		
11	104.7892	1056	104.7887	0717	Total Flood R-4	
12	98.2303	1057	98.2304	0718		
13	104.1788	1059	104.1784	0719		
14	97.9822	1100	97.9819	0721		
15	104.7644	1101	104.7642	0722		
16	95.7427	1102	95.7429	0723	Total Flood R-5	
17	104.5948	1104	104.5944	0724		
18	108.8626	1105	108.8623	0725		
19	106.5473	1106	106.5468	0726		
20	108.5936	1108	108.5932	0728		

SCALE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	DB	% RH	
08-22	1040	DM	78	49	Checked by: <u>Chp Wadby</u>
08-23	0700	DM	78	49	
					Date: <u>8-23-02</u>
					Time: <u>0910</u>

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: F600

RUN: 3

DATE: 5-1-03

Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
6	05/02	1140	DK	91.3705	05/06	2146	DK	91.3707	05/09	0724	DK				
7	05/05	1030	DK	97.5827	05/06	2147	DK	97.5830	05/09	0725	DK				
8	05/05	1030	DK	108.7184	05/06	2148	DK	108.7152	05/09	0726	DK	108.7127	05/16	1443	DK
9	05/02	1140	DK	108.7099	05/11	2144	DK	108.7097	05/12	0949	DK				
10	05/02	1140	DK	108.2316	05/10	2149	DK	108.2323	05/09	0728	DK	108.2322	05/16	1444	DK
								105.8477	05/06	2150	DK	105.8478	05/09	0729	DK

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
149F	5-1	2000	CP	1.2879	05/02	1134	DK	1.2870	05/06	2151	DK	1.2874	05/09	0730	DK
149B	5-1	2000	CP	.6462	05/03	1135	DK	.6349	05/06	2152	DK	.6300	05/09	0732	DK
				.6275	05/10	1445	DK	.6253	05/11	1215	DK	.6255	05/12	0944	DK

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	05/02	1130	DK	77	49
2	05/06	2135	DK	77	46
3	05/09	0715	DK	77	45
4	05/10	1435	DK	78	47
5	05/11	1210	DK	77	46

Weighing Session	Date	Time	By	DB	%RH
6	05/12	0940	DK	76	45
7					
8					
9					
10					

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET


Dates: From 05-18-2002 Through 10-27-2002	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9999	10.0000	.9999	.0999	AKW	05-18	1905	77	49
99.9997	9.9998	.9999	.0998	AKW	05-19	1500	77	48
99.9999	10.0000	.9998	.0999	AKW	05-20	0855	77	47
99.9998	9.9998	1.0000	.0999	AKW	05-21	0930	78	49
99.9998	9.9999	1.0000	.1000	AKW	05-22	1155	78	48
99.9999	9.9999	1.0000	.1001	AKW	05-22	1920	78	49
99.9999	10.0001	1.0001	.0998	AKW	05-23	2105	77	48
99.9998	9.9998	.9998	.0999	AKW	05-28	1225	78	49
99.9998	9.9997	1.0001	.0999	AKW	05-28	1625	78	47
99.9997	10.0001	1.0002	.1000	AKW	06-27	1950	78	49
99.9998	10.0001	1.0002	.1001	AKW	06-29	1830	78	49
99.9997	9.9999	1.0000	.0998	AKW	07-01	0845	77	49
100.0000	9.9999	1.0002	.1000	AKW	07-01	2220	78	47
99.9998	10.0000	.9999	.0999	AKW	08-14	1130	78	49
100.0001	9.9999	1.0000	.1000	AKW	08-16	1045	78	49
100.0000	9.9998	1.0000	.0998	AKW	08-22	1040	78	49
99.9997	9.9999	.9999	.0997	AKW	08-23	0700	78	49
99.9998	10.0000	1.0000	.0998	AKW	08-29	0915	78	49
100.0000	10.0000	1.0002	.1001	AKW	08-29	2225	78	49
99.9998	9.9999	1.0001	.0998	AKW	09-03	1120	78	49
99.9997	9.9998	.9999	.0998	AKW	09-03	2230	78	49
100.0000	10.0001	.9999	.0999	AKW	09-05	1915	78	49
99.9999	9.9999	1.0000	.0999	AKW	09-06	1815	78	48
99.9997	9.9999	1.0000	.0998	AKW	09-07	1355	78	47
100.0000	10.0002	.9998	.0997	Chp	9-10	1110	77	42
99.9997	10.0002	1.0000	.0100	Chp	9-11	1500	74	47
99.9999	9.9999	1.0000	.0997	Chp	9-13	2020	76	38
100.0003	10.0002	1.0002	.0998	Chp	9-14	1300	76	41
100.0000	10.0001	1.0000	.0999	Chp	9-16	1930	74	44
100.0000	9.9999	.9998	.0999	Chp	9-17	1710	77	42
100.0000	10.0001	1.0000	.1000	Chp	9-19	1000	74	47
100.0001	10.0000	.9998	.0999	Chp	9-20	1115	74	44
99.9998	9.9999	1.0001	.0999	AKW	10-18	2155	77	44
99.9997	9.9999	1.0000	.1000	AKW	10-22	2255	77	46
100.0001	10.0002	1.0000	.0999	AKW	10-23	2815	77	42
99.9997	9.9998	.9999	.1000	AKW	10-25	1350	77	43
99.9998	9.9999	1.0000	.1000	AKW	10-26	1735	77	41
99.9998	9.9998	.9999	.1000	AKW	10-27	1130	77	36
99.9998	9.9999	.9999	.0999	AKW	10-27	1435	77	38

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates: From 12-05-2002 Through 02-23-2003	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9997	9.9998	1.0000	.0997	AKW	12-05	1825	77	47
99.9998	10.0000	.9999	.1000	AKW	12-06	1125	77	45
99.9997	10.0001	1.0000	.1000	AKW	12-07	1310	76	41
99.9997	10.0001	1.0000	.0999	AKW	12-08	1430	77	44
99.9998	9.9999	1.0001	.0999	AKW	12-09	1125	78	44
99.9998	10.0000	.9999	.0998	AKW	12-10	1220	78	43
99.9997	10.0000	.9998	.0998	AKW	12-11	1650	77	45
99.9997	10.0001	.9999	.0999	AKW	12-12	1445	77	47
99.9998	10.0000	.9999	.1000	AKW	12-14	1530	78	47
99.9997	10.0000	1.0000	.0999	AKW	01-10	2300	78	48
99.9998	9.9999	1.0001	.1000	AKW	01-14	1115	77	48
99.9999	10.0000	.9999	.1000	AKW	01-15	1705	77	48
99.9999	10.0001	.9999	.0998	AKW	01-16	1830	78	46
99.9997	10.0000	1.0000	.0999	AKW	01-17	1215	77	41
99.9997	9.9999	1.0000	.0999	AKW	01-17	2035	76	42
99.9996	10.0000	.9999	.0999	AKW	01-18	1730	77	43
99.9999	9.9999	.9998	.0999	AKW	01-19	1210	76	42
99.9998	10.0000	1.0000	.0999	AKW	01-20	2105	76	44
99.9999	10.0000	.9999	.0998	AKW	01-21	0935	75	44
99.9998	10.0000	.9999	.0999	AKW	01-22	1125	77	46
100.0000	9.9998	.9999	.1000	AKW	01-23	1430	77	48
99.9999	10.0001	1.0001	.1000	AKW	01-24	1200	76	48
99.9998	9.9999	.9999	.0999	AKW	01-25	1140	76	47
99.9997	10.0000	1.0000	.0999	AKW	01-25	1850	78	48
99.9998	9.9998	1.0000	.1000	AKW	01-27	1415	75	47
99.9999	9.9999	1.0000	.1000	AKW	01-30	1920	77	48
99.9998	10.0000	.9998	.0999	AKW	01-31	2205	78	47
99.9999	9.9998	.9998	.1000	AKW	02-01	1855	77	47
99.9997	9.9998	.9999	.1001	AKW	02-02	1420	76	46
99.9997	10.0001	.9998	.0999	AKW	02-18	1155	77	49
99.9999	9.9999	.9999	.0999	AKW	02-19	1925	77	48
99.9997	10.0000	1.0000	.0999	AKW	02-22	2010	78	45
99.9997	10.0000	.9999	.1000	AKW	02-23	1130	78	44
								

BLANK PROCESSING DATA SHEET # 5

UNIT: F600 RUN: 3 DATE: 05/01/03

DATE BLANKS DONE: 02-23-03

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	DWNA, INC. SPARKLETES DISTILLED
FINAL WEIGHT	108.9007	106.3074	106.9660
TARE WEIGHT	108.8995	106.3057	106.9646
NET WEIGHT	.0012 ✓	.0017 ✓	.0014 ✓

TARE BEAKERS INTO DESC : TIME : 1430 DATE : 02-12-03

DATE : 02-18 BY : BL DATE : 02-19 BY : BL DATE : BY :

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.8996	1158	108.8995	1928	✓	
B	106.3060	1159	106.3057	1930	✓	
C	106.9649	1200	106.9646	1931	✓	

FINAL BEAKERS INTO DESC : TIME : 1600 DATE : 02-20-03

DATE : 02-22 BY : BL DATE : 02-23 BY : BL DATE : BY :

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9010	2013	108.9007	1132	✓	
B	106.3078	2015	106.3074	1133	✓	
C	106.9661	2016	106.9660	1134	✓	

TARE QC

DATE	TIME	BY	WB	DB	%
02-18	1155	BL	}	77	49
02-19	1925	BL		77	48

FINAL QC

DATE	TIME	BY	WB	DB	%
02-22	2010	BL	}	78	45
02-23	1130	BL		78	44

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: F600 RUN: 3 DATE: 05/01/03

BLANK CALCULATIONS

Acetone : $\frac{.0012 \text{ g}}{200 \text{ ml}} = \frac{.000006 \text{ g}}{\text{ml}}$ ✓
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = \frac{.000023 \text{ g}}{\text{ml}}$ ✓
 Distilled Water : $\frac{.0014 \text{ g}}{200 \text{ ml}} = \frac{.000007 \text{ g}}{\text{ml}}$ ✓

FRONT HALF CATCH

FILTERS : $\frac{.5935 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ # of Filters}}{.0000 \text{ g}} = \frac{.5935 \text{ g}}{\text{Blank Value / Filter}}$ ✓
 BEAKERS : $\frac{.1631 \text{ g}}{\text{Total Catch}} - \frac{110 \text{ ml Acetone}}{.000006 \text{ g}} = \frac{.1624 \text{ g}}{\text{Blank Value / ml Acetone}}$ ✓
 TOTAL FRONT HALF CATCH : .7559 g ✓

BACK HALF CATCH

FILTERS : $\frac{.1967 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ # of Filters}}{.0000 \text{ g}} = \frac{.1967 \text{ g}}{\text{Blank Value / Filter}}$ ✓
 BEAKERS :
 Acetone : $\frac{.4448 \text{ g}}{\text{Total Catch}} - \frac{175 \text{ ml Acetone}}{.000006 \text{ g}} = \frac{.4437 \text{ g}}{\text{Blank Value / ml Acetone}}$ ✓
 Extract : $\frac{.0740 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Dichloromethane}}{.000023 \text{ g}} = \frac{.0723 \text{ g}}{\text{Blank Value / Dichloromethane}}$ ✓
 Water : $\frac{.2534 \text{ g}}{\text{Total Catch}} - \frac{385 \text{ ml Water}}{.000007 \text{ g}} = \frac{.2507 \text{ g}}{\text{Blank Value / Water}}$ ✓
 TOTAL BACK HALF CATCH : .9634 g ✓

TOTAL CATCH : 1.7193 g ✓

% FRONT HALF : $\frac{.7559}{1.7193} = \frac{44.0}{(00.0)}$ % ✓

CALCULATIONS DATA SHEET # 7

UNIT: Jotul F600 RUN: 3 DATE: 05/01/05

$$1) Vm (std) = \frac{(137.024 Vm) (17.64) (990 mcf) (30.03 \text{ " Hg} + \frac{163 \text{ " H}_2\text{O}}{13.6})}{(548 \text{ TmA})} = \frac{131.1833}{000.0000} \text{ dscf}$$

$$2) Vw (std) = (.04707) (190.6 \text{ ml H}_2\text{O}) = \frac{8.9715}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(8.9715 \text{ scf})}{(8.9715 \text{ scf} + 131.1833 \text{ dscf})} = \frac{.0640}{.0000} \text{ Bws} \times 100 = \frac{6.4012}{00.0000} \% \text{ H}_2\text{O}$$

$$4) Cs = \frac{(1.7193 \text{ g.})}{(131.1833 \text{ dscf})} (15.43) = \frac{.2022}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(1.7193 \text{ g.})}{(131.1833 \text{ dscf})} (6.433 \text{ dscfm}) (60) = \frac{5.0587}{00.0000} \text{ g / hr}$$

- Vm = total cubic feet pulled on meter box during test
- mcf = meter correction factor (Y factor) of meter box used for test
- " Hg = average barometric pressure during test
- " H₂O = average delta H for test
- TmA = average meter temperature for test in degrees Absolute
- ml H₂O = total water caught during test
- g. = total particulate catch for test
- dscfm = average stack flow during test

- (000.000 Vm)
- (0.000 mcf)
- (00.00 " Hg)
- (.000 " H₂O)
- (000 TmA)
- (000.0 ml H₂O)
- (00.0000 g.)
- (00.000 dscf)
- (p. 2)
- (p. 2)
- (p. 2)
- (p. 2)
- (p. 2)
- (p. 3)
- (p. 6)
- (p. 2)

TEST DATA SHEET # 8

UNIT: F 600 RUN: 3 DATE: 5-1-03

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb
 Pre: WB: 65 DB: 84 = 34 % RH 1.4 % H₂O
 Post: WB: 62 DB: 80 = 34 % RH 1.2 % H₂O
 Average: 34.0 % RH 1.30 % H₂O

Empty Stove Weight (lbs): _____ w/ stack & oil seal : Wet : _____ Dry : 0.0

Kindling Weight (lbs) : Paper : .2 Wood : 4.0
 Preburn Fuel Weight : 16.5 + 12.7 + 12.9 Total : 42.1
 Kindling & Preburn Fuel Weight (wood only) (lbs) : Total : 46.1

Coal Bed Wt Range (lbs) : 4.6 - 3.7 Scale : 4.6 - 3.7
 Upper : .25 x fuel weight : Always round DOWN to nearest tenth
 Lower : .20 x fuel weight : Always round UP to nearest tenth Actual Coal Bed Weight : 4.3

Maximum Coal Bed Removal (lbs) : $((\frac{4.6}{\text{Upper}} + \frac{3.7}{\text{Lower}}) \div 2) \cdot .25 = \underline{1.0}$
round down to nearest tenth

Test Fuel (.75" x 1.5" x 5" spacers) = 20 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	4	9.3	50.5
4" x 4"	17	2	9.1	49.5

Test Fuel Weight : 18.4 lbs

Estimated Dry Burn Rate:
 $\frac{18.4 - (18.4 \times .18189)}{2.2046} \times \frac{60}{425} = \underline{.964}$ kg/hr

Estimated BTU's/hr : $19,140 \times \frac{63}{100} \times \frac{.964}{\text{DBR}} = \underline{11,623.7}$ BTU's/hr

EPA Default Efficiencies : Non-cat : 63 Cat : 72 Pellet : 78

WOOD STOVE OPERATING DATA PAGE #9

Unit: F600 Run: 3 Date: 5-1-03

FIRE STARTED: 0700

WARM UP AND PREBURN:

PRIMARY AIR: Set wide open for all warm-up / preburn fuel charges. Then set to 5/32" at start of preburn.

SECONDARY AIR: N/A CAT BYPASS: N/A

CHARCOAL BED PREPARATION:

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 30 sec.

TEST:

DOOR wide open during loading 0 min. 45 sec.

PRIMARY AIR: Opened full for first 5 min., then set to run setting of 5/32".

SECONDARY AIR: N/A CAT BYPASS: N/A

FAN:

ON / OFF during warm-up

ON / OFF during preburn

ON / OFF first 30 minutes of test

ON / OFF balance of test run

Fan speed set at High

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER: N/A BRAND: N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 16 or - inches.

1st warm up / pre-burn fuel charge (16.5 lbs.) added at 16.5 0720

2nd warm up / pre-burn fuel charge (12.7 lbs.) added at 12.7 0840

3rd warm up / pre-burn fuel charge (12.9 lbs.) added at 12.9 1005

4th warm up / pre-burn fuel charge (____ lbs.) added at _____

5th warm up / pre-burn fuel charge (____ lbs.) added at _____

TEST DATA SHEET #10

Unit : F600 Run : 3 Date : 5-1-03

Room Temperature : 68 °F Correction Factor : ϕ

Uncorrected Values are corrected for room temperature : Yes _____ No ✓

Time Test Fuel moisture reading taken : 1120 ✓

Calibration Checks : X ✓ Y ✓ 12.0 ✓ 12.1 ✓ 22.0 ✓ 22.1 ✓

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	15.5	16.5	15.0	16.0	15.0	16.0	16.167
2									
3									
4	2"x4"x8'	P	20.5	22.0	21.0	22.5	21.0	22.5	22.333
5	2"x4"x8'	P	23.0	24.7	23.0	24.7	21.5	23.1	24.167
6	2"x4"x8'	P	22.0	23.7	22.0	23.7	22.0	23.7	23.700
7	2"x4"x8'	P	21.5	23.1	21.5	23.1	21.5	23.1	23.100
8	2"x4"x8'	P	23.5	25.2	23.5	25.2	23.5	25.2	25.200
9									118.500
10									
11	2x4x17	T	17.5	18.7	18.5	19.8	17.5	18.7	19.067
12	"	T	20.5	22.0	20.5	22.0	20.0	21.4	21.800
13	"	T	21.0	22.5	21.0	22.5	21.0	22.5	22.500
14	"	T	23.0	24.7	23.0	24.7	23.5	25.2	24.867
15	4x4x17	T	22.5	24.1	22.5	24.1	22.5	24.1	24.100
16	"	T	20.0	21.4	19.5	20.9	19.3	20.9	21.067
17									133.401
18									
19									
20	Spacers	T	18.5	19.8	18.0	19.2	18.5	19.8	19.600

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	16.167 %	23.700 %	22.233 %
Wet Moisture % :	13.917 %	19.159 %	18.189 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

GAS DATA SHEET #12

WEIGHT: 4.3

DATE: 5-1-03

UNIT: F600

RUN: 3

PAGE: 1 OF 3

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO ₂ PPM
0 1235	22.7	18.4	-	.246	6.1	.525	13.1	.154	1.55	7024	550
5 40	22.3	18.0	.4	.236	5.9	.578	14.5	.1046	.47	7032	275
10 45	22.1	17.8	.2	.109	2.7	.696	17.4	.1069	.70	7026	550
15 50	21.9	17.6	.2	.125	3.1	.678	16.9	.074	.75	7025	575
20 55	21.7	17.4	.2	.145	3.6	.653	16.3	.087	.88	7025	600
25 130	21.4	17.1	.3	.163	4.0	.629	15.7	.101	1.02	7025	650
30 05	21.2	16.9	.2	.202	5.0	.593	14.8	.094	.95	7025	625
35 10	20.8	16.5	.4	.245	6.1	.538	13.5	.124	1.25	7026	650
40 15	20.3	16.0	.5	.194	4.8	.581	14.5	.145	1.46	7026	675
45 20	20.1	15.8	.2	.213	5.3	.560	14.0	.149	1.50	7026	675
50 25	19.7	15.4	.4	.222	5.5	.544	13.6	.166	1.67	7026	675
55 30	19.2	14.9	.5	.274	6.8	.513	12.8	.114	1.15	7029	575
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-315	*****
60 135	18.9	14.6	.3	.194	4.8	.562	14.0	.193	1.94	7026	625
65 40	18.5	14.2	.4	.324	8.1	.464	11.6	.111	1.12	7029	550
70 45	17.9	13.6	.6	.360	9.0	.439	11.0	.085	.86	7035	475
75 50	17.4	13.1	.5	.345	8.6	.455	11.4	.082	.83	7036	475
80 55	16.8	12.5	.6	.394	9.8	.410	10.3	.071	.72	7038	450
85 140	16.2	11.9	.6	.374	9.3	.429	10.7	.073	.74	7040	450
90 05	15.6	11.3	.6	.431	10.7	.384	9.6	.043	.44	7041	425
95 10	15.0	10.7	.6	.464	11.6	.349	8.7	.049	.50	7042	425
100 15	14.4	10.1	.6	.477	11.9	.338	8.5	.043	.44	7043	400
105 20	13.8	9.5	.6	.466	11.6	.347	8.7	.050	.51	7043	400
110 25	13.1	8.8	.7	.455	11.3	.360	9.0	.045	.46	7043	400
115 30	12.6	8.3	.5	.404	10.1	.417	10.4	.030	.31	7042	425
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-458	*****
120 145	12.1	7.8	.5	.380	9.5	.437	10.9	.038	.39	7041	425
125 40	11.7	7.4	.4	.374	9.3	.442	11.1	.041	.42	7041	425
130 45	11.3	7.0	.4	.378	9.4	.440	11.0	.036	.37	7040	425
135 50	10.9	6.6	.4	.425	10.6	.396	9.9	.030	.31	7040	425
140 55	10.5	6.2	.4	.395	9.8	.423	10.6	.036	.37	7040	425
145 150	10.1	5.8	.4	.389	9.7	.434	10.8	.025	.26	7040	425
150 05	9.7	5.4	.4	.416	10.4	.407	10.2	.025	.26	7040	425
155 10	9.3	5.0	.4	.425	10.6	.397	9.9	.026	.27	7040	425
160 15	9.0	4.7	.3	.390	9.7	.435	10.9	.020	.21	7040	425
165 20	8.7	4.4	.3	.377	9.4	.448	11.2	.018	.19	7039	425
170 25	8.5	4.2	.2	.341	8.5	.460	11.5	.080	.81	7036	425
175 30	8.3	4.0	.2	.310	7.7	.486	12.1	.092	.93	7035	500
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-472	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-1245	*****

GAS DATA SHEET #12

WEIGHT: 4.3

DATE: 05-01-03

UNIT: FL00

RUN: 3

PAGE: 2 OF 3

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO ₂ PPM	
180	1535	8.1	3.8	.2	.275	6.8	.509	12.7	1.22	1.23	7033	500
185	40	7.9	3.6	.2	.247	6.1	.514	12.8	1.80	1.81	7031	575
190	45	7.8	3.5	.1	.251	6.2	.512	12.8	1.75	1.76	7030	550
195	50	7.7	3.4	.1	.257	6.4	.508	12.7	1.69	1.70	7029	525
200	55	7.6	3.3	.1	.249	6.2	.506	12.6	1.95	1.96	7028	550
205	1600	7.5	3.2	.1	.245	6.1	.506	12.6	2.05	2.06	7026	525
210	05	7.4	3.1	.1	.243	6.0	.501	12.5	2.22	2.23	7026	525
215	10	7.3	3.0	.1	.242	6.0	.503	12.6	2.19	2.20	7025	525
220	15	7.2	2.9	.1	.246	6.1	.501	12.5	2.14	2.15	7025	550
225	20	7.1	2.8	.1	.235	5.8	.507	12.7	2.26	2.27	7024	550
230	25	7.0	2.7	.1	.235	5.8	.506	12.7	2.28	2.29	7024	550
235	30	6.9	2.6	.1	.235	5.8	.500	12.5	2.43	2.44	7023	550
SUBTOTAL		*****	*****	*****	*****	*****	*****	*****	*****	*****	-224	*****
240	1635	6.9	2.6	⊖	.235	5.8	.500	12.5	2.45	2.46	7023	550
245	40	6.8	2.5	.1	.239	5.9	.506	12.7	2.18	2.19	7022	550
250	45	6.7	2.4	.1	.234	5.8	.505	12.6	2.35	2.36	7022	575
255	50	6.6	2.3	.1	.241	6.0	.515	12.9	1.92	1.93	7021	575
260	55	6.5	2.2	.1	.235	5.8	.516	12.9	2.03	2.04	7021	600
265	1700	6.5	2.2	⊖	.232	5.8	.515	12.9	2.13	2.14	7021	600
270	05	6.4	2.1	.1	.237	5.9	.518	13.0	1.93	1.94	7021	600
275	10	6.3	2.0	.1	.236	5.9	.519	13.0	1.95	1.96	7021	600
280	15	6.3	2.0	⊖	.235	5.8	.517	12.9	2.02	2.03	7021	600
285	20	6.2	1.9	.1	.236	5.9	.515	12.9	2.03	2.04	7021	600
290	25	6.1	1.8	.1	.242	6.0	.515	12.9	1.88	1.89	7021	600
295	30	6.0	1.7	.1	.241	6.0	.515	12.9	1.91	1.92	7021	600
SUBTOTAL		*****	*****	*****	*****	*****	*****	*****	*****	*****	-256	*****
300	1735	5.9	1.6	.1	.239	5.9	.519	13.0	1.87	1.88	7021	600
305	40	5.9	1.6	⊖	.239	5.9	.521	13.0	1.81	1.82	7021	575
310	45	5.8	1.5	.1	.243	6.0	.533	13.3	1.42	1.43	7020	575
315	50	5.7	1.4	.1	.238	5.9	.531	13.3	1.59	1.60	7020	600
320	55	5.6	1.3	.1	.233	5.8	.534	13.4	1.64	1.65	7020	600
325	1800	5.6	1.3	⊖	.231	5.7	.531	13.3	1.76	1.77	7020	600
330	05	5.5	1.2	.1	.229	5.7	.532	13.3	1.78	1.79	7020	575
335	10	5.4	1.1	.1	.229	5.7	.530	13.2	1.85	1.86	7020	600
340	15	5.4	1.1	⊖	.228	5.7	.533	13.3	1.80	1.81	7020	600
345	20	5.3	1.0	.1	.225	5.6	.536	13.4	1.78	1.79	7020	600
350	25	5.3	1.0	⊖	.222	5.5	.535	13.4	1.88	1.89	7020	600
355	30	5.2	.9	.1	.216	5.4	.535	13.4	2.03	2.04	7020	600
SUBTOTAL		*****	*****	*****	*****	*****	*****	*****	*****	*****	-242	*****
TOTAL		*****	*****	*****	*****	*****	*****	*****	*****	*****	-822	*****

A

TEMPERATURE DATA SHEET #14

		TEST TIME	425		
STACK AVG	185	TOP AVG	244	LT SIDE AVG	235
BACK AVG	171	RT SIDE AVG	242	BOTTOM AVG	200
FIREBOX AVG	520	SEC/CAT AVG	787	AMBIENT AVG	81 ↗

END 181.0
START 262.0 ↗

-81.0 DELTA T

CIRCLE: LOSS / GAIN

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube Furn	Smpl Box	Smpl Out	C-Gas Box	C-Gas Out	SO2 Out
0	194	240	287	199	296	288	560	723	84	1313	239	64	248	37	39
5	261	234	285	261	284	279	453	1015	84	1323	240	48	246	37	35
10	186	229	272	259	269	268	431	544	81	1329	240	45	247	37	37
15	172	220	258	251	253	262	408	513	81	1333	239	47	247	38	37
20	166	215	247	243	240	254	390	527	80	1335	238	47	247	38	36
25	163	208	237	236	229	249	376	596	80	1337	237	47	248	37	36
30	163	205	228	229	219	242	363	1009	80	1338	236	47	248	37	35
35	170	210	204	164	209	232	357	814	81	1335	236	48	248	39	36
40	174	221	193	152	202	225	352	772	80	1333	236	48	248	37	36
45	170	210	188	146	197	220	348	767	80	1332	235	48	247	36	35
50	168	205	180	141	193	218	347	931	80	1331	235	48	246	37	35
55	177	211	178	138	189	210	351	910	79	1335	234	49	246	37	35
60	169	210	176	136	186	206	355	737	79	1344	234	49	246	36	35
65	180	212	173	133	184	203	368	1154	78	1350	233	49	246	36	36
70	207	238	175	133	185	199	387	1163	78	1354	233	49	246	37	36
75	220	258	180	132	187	194	413	1072	78	1354	234	48	246	38	35
80	233	274	187	133	191	193	436	1178	78	1352	234	48	247	37	35
85	248	290	196	134	196	190	462	1041	78	1350	234	48	248	37	35
90	263	319	205	136	202	186	493	1085	78	1346	236	48	249	38	36
95	274	345	217	140	210	186	522	1156	79	1342	237	49	248	38	36
100	280	367	228	143	221	184	545	1188	78	1340	238	49	249	36	36
105	282	381	238	149	231	183	563	1167	79	1338	238	50	248	36	36
110	281	389	248	156	242	181	583	1154	80	1338	239	50	248	34	37
115	272	391	259	162	252	178	592	1072	80	1338	239	51	248	34	36
120	264	387	263	165	259	180	594	1029	80	1341	239	52	248	34	36
125	257	378	268	169	266	178	595	1031	80	1343	239	53	247	34	35
130	252	373	270	171	271	179	598	1010	81	1340	238	53	245	35	36
135	254	374	271	174	274	179	602	1049	81	1337	239	54	246	36	37
140	254	379	273	176	276	181	610	1034	81	1334	238	54	248	35	37
145	253	375	276	177	280	181	618	1011	82	1331	238	55	247	35	37
150	253	374	281	179	284	181	634	1053	81	1328	237	55	246	35	37
155	256	377	288	180	290	183	650	1068	82	1329	237	56	245	35	37
160	252	371	294	182	293	181	664	1087	82	1331	237	56	243	35	37
165	247	364	300	184	298	182	671	1073	82	1332	236	57	243	35	37
170	227	345	303	186	300	186	667	921	82	1338	236	57	243	35	37
175	221	335	304	187	301	186	669	1087	82	1339	236	57	242	35	36

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube	Furn	Smpl Box	Smpl Out	C-Gas Box	C-Gas Out	SO2 Out
180	211	320	302	189	300	186	665	998	82	1341		236	58	242	35	36
185	201	304	303	187	299	189	658	909	82	1344		235	58	241	35	36
190	195	288	300	184	297	192	655	854	82	1346		235	58	239	34	36
195	190	276	297	183	293	190	651	841	82	1348		235	59	240	34	35
200	182	266	293	183	290	194	641	810	82	1349		235	59	239	34	35
205	177	256	290	182	287	195	631	784	83	1350		234	60	238	34	35
210	174	249	284	182	283	198	621	766	83	1350		234	60	237	35	34
215	171	241	282	180	278	199	613	750	83	1349		234	60	237	34	34
220	168	234	275	179	275	200	605	738	83	1346		233	60	239	35	34
225	166	229	273	179	271	199	597	713	82	1342		233	60	239	35	33
230	164	224	268	179	268	199	588	702	82	1339		232	60	239	36	34
235	162	220	263	178	263	203	584	689	82	1336		232	60	238	35	34
240	161	217	257	177	260	204	579	681	82	1334		232	60	239	35	35
245	159	212	256	178	258	202	568	673	81	1331		232	59	240	36	34
250	158	210	248	176	255	204	562	669	82	1330		231	59	239	37	37
255	157	209	243	175	252	204	560	659	82	1329		231	59	240	36	37
260	156	205	242	174	249	201	555	653	81	1327		232	59	240	36	37
265	156	203	238	172	248	201	550	650	82	1327		232	60	241	37	37
270	155	202	236	171	246	204	547	648	82	1326		232	60	242	37	36
275	154	199	233	170	244	201	544	646	82	1325		232	60	245	36	36
280	153	197	232	169	242	198	542	641	81	1323		233	60	246	35	37
285	153	197	228	168	241	198	540	639	81	1324		233	60	245	35	37
290	153	195	225	167	239	201	533	651	82	1325		233	60	246	36	37
295	153	194	223	166	238	198	531	657	81	1324		233	60	245	36	35
300	153	194	222	166	237	198	529	651	81	1323		233	61	245	36	35
305	152	191	223	166	237	200	528	653	82	1322		234	61	245	35	36
310	151	190	221	165	235	198	525	650	81	1322		234	62	245	35	36
315	150	190	220	165	234	198	519	643	81	1323		235	60	245	36	36
320	149	189	219	165	233	198	513	633	81	1324		235	60	245	36	36
325	149	188	216	164	232	199	509	636	80	1324		235	60	245	37	36
330	149	187	216	162	225	185	507	632	79	1323		235	60	245	38	37
335	149	186	213	164	229	196	504	631	79	1322		235	61	244	38	37
340	148	185	212	164	228	195	499	621	79	1322		235	62	245	38	38
345	148	185	210	163	228	195	493	619	79	1321		235	62	244	38	38
350	147	184	208	162	228	198	490	615	81	1323		235	62	244	38	38
355	146	182	207	162	227	198	487	613	81	1324		235	62	244	37	38

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube Furn	Smpl Box	Smpl Out	C-Gas Box	C-Gas Out	SO2 Out
360	146	182	205	162	226	195	484	602	80	1324	235	62	243	37	38
365	145	181	204	161	225	193	480	593	80	1324	235	62	243	37	38
370	144	180	201	161	224	194	477	586	80	1325	235	62	243	37	37
375	144	179	201	161	223	194	473	580	79	1325	234	63	242	37	37
380	143	177	199	160	221	194	469	573	79	1326	235	63	243	36	37
385	143	176	197	159	220	194	464	568	80	1326	235	63	243	36	37
390	142	175	195	159	218	192	464	571	80	1326	235	64	243	36	37
395	142	174	194	159	217	188	463	570	79	1326	235	64	242	36	36
400	142	173	193	159	215	191	463	568	80	1327	235	64	243	36	36
405	141	172	191	159	213	188	462	564	79	1327	235	62	242	36	36
410	140	172	190	159	212	189	458	558	80	1328	235	62	243	35	36
415	139	170	190	159	211	186	454	550	79	1328	235	62	243	35	36
420	139	169	189	159	209	186	445	541	79	1328	234	62	244	35	36
425	138	168	187	159	208	183	438	534	79	1328	234	62	243	35	35

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 05/01/03 Analyte : CO₂ (15-1)
 Unit : F600 Run # : 3
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO₂ Cyl. Press. : 900 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC-3131 Conc. : 12.40 % CO₂ Cyl. Press. : 1625 PSI
 Certified by : AIR LIQUIDE Date : 03-13-03
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 407069
 Range : 0 - 25.0 % CO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 25.0 % CO₂
 EPA Control Limits = $\pm 2.5\%$ of 25.0 % CO₂ = $\pm 0.625 % CO_2$
 Method 28 A = $\pm .2\%$ of 25.0 % CO₂ = $\pm .05 % CO_2$

PRE RUN Audit : by : A. Wadley Time : 1045 Temp : 83 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	0.023	0.023	-0.091 ✓
SPAN	49.6	.496	12.40	49.5	.495	12.342	0.058	-0.233 ✓

POST RUN Audit : by : A. Wadley Time : 2000 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	.002	+0.002	+0.009
SPAN	49.6	.496	12.40	49.5	.495	12.342	-0.058	-0.233 ✓

$\pm \text{Conc. Difference} = \text{Act \%} - \text{Exp (Std) \%}$
 $\text{Zero \% Difference} = \frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 $\text{Span \% Difference} = \frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05/01/03

Analyte : O₂ (15-2)

Unit : F600

Run # : 3

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂

Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % O₂

Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE

Date : 03-13-03

Analyzer : Make : TELEDYNE Model : 320 A

SN : 37400

Range : 0 - 25.0 % O₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % O₂
 EPA Control Limits = $\pm 2.5\%$ of 25.0 % O₂ = $\pm 0.625 % O_2$
 Method 28 A = $\pm .2 %$ of 25.0 % O₂ = $\pm .05 % O_2$

PRE RUN Audit : by : A. Wood Time : 1045 Temp : 83 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.025	+ .025	+ .101 ✓
SPAN	12.50	.500	12.50	12.55	.501	12.526	+ .026	+ .105 ✓

POST RUN Audit : by : A. Wood Time : 2000 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.050	.050	+ .201 ✓
SPAN	12.50	.500	12.50	12.55	.501	12.526	+ .026	+ .105 ✓

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date: 05/01/03

Analyte: CO (15-3)

Unit: F600 Run #: 3

Zero Cyl. #: 042TAC 2-A Conc.: 0.00 % CO Cyl. Press.: 900 PSI

Certified by: AIR LIQUIDE Date: 02-20-02

Span Cyl. #: CC-3131 Conc.: 12.40 % CO Cyl. Press.: 1625 PSI

Certified by: AIR LIQUIDE Date: 03-13-03

Analyzer: Make: HORIBA Model: PIR-2000 SN: 408005
 Range: 0 - 10.0 % CO Analyzer Output: 0 - 1.0 v.
 Flow: 1.5 SCFH Measured by: Rotameter

EPA Span Value = 10.0 % CO
 EPA Control Limits = $\pm 2.5\%$ of 10.0 % CO = $\pm 0.25 % CO$
 Method 28 A = $\pm .2 %$ of 10.0 % CO = $\pm .02 % CO$

PRE RUN Audit: by: A. Abdou Time: 1045 Temp: 83 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.011	+ .011	+ .110 ✓
SPAN	50.2	.502	5.02	50.4	.504	5.050	+ .030	+ .297 ✓

POST RUN Audit: by: A. Abdou Time: 2000 Temp: 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.011	+ .011	+ .110 ✓
SPAN	50.2	.502	5.02	50.3	.503	5.040	+ .020	+ .197 ✓

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05/01/03

Analyte : **SO₂ (15-4)**

Unit : FG00

Run # : 3

Zero Cyl. # : 042JAC 2-A Conc.: 0.00 ppm SO₂ Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE Date : 02-20-02

Span Cyl. # : CC62184 Conc. : 1290 ppm SO₂ Cyl. Press. : 1025 PSI

Certified by : AIR LIQUIDE Date : 01-29-01

Analyzer : Make : **HORIBA** Model : **PIR-2000** SN : **403019**
 Range : **0 - 2500 ppm SO₂** Analyzer Output : **0 - 1.0 v.**
 Flow : **1.5 SCFH** Measured by : **Rotameter**

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = ± 2.5% of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : A. Wadsworth Time : 1045 Temp : 83 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.3	.003	14.183	+14.183	+567 ✓
SPAN	51.6	.516	1290	52.0	.520	1300.003	+10.003	+400 ✓

POST RUN Audit : by : A. Wadsworth Time : 2000 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.2	.002	11.696	+11.696	+468 ✓
SPAN	51.6	.516	1290	51.8	.518	1295.028	+5.028	+201 ✓

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : F600 RUN : 3 DATE : 5-1-03

Thermocouple Check:

T/C # 1	<u>—</u>	°F	T/C # 13	<u>75.3</u>	°F
T/C # 2	<u>—</u>	°F	T/C # 14	<u>70.2</u>	°F
T/C # 3	<u>74.3</u>	°F	T/C # 15	<u>76.7</u>	°F
T/C # 4	<u>70.9</u>	°F	T/C # 16	<u>53.4</u>	°F
T/C # 5	<u>69.4</u>	°F	T/C # 17	<u>54.8</u>	°F
T/C # 6	<u>70.5</u>	°F	T/C # 18	<u>77.0</u>	°F
T/C # 7	<u>69.2</u>	°F	T/C # 19	<u>71.0</u>	°F
T/C # 8	<u>69.0</u>	°F	T/C # 20	<u>—</u>	°F
T/C # 9	<u>71.2</u>	°F	T/C # 21	<u>—</u>	°F
T/C # 10	<u>72.1</u>	°F	T/C # 22	<u>—</u>	°F
T/C # 11	<u>65.4</u>	°F	T/C # 23	<u>70.2</u>	°F
T/C # 12	<u>84.1</u>	°F	T/C # 24	<u>—</u>	°F

Thermocouple Readout:

Pretest zero and span check and calibration		post test zero and span	% difference
ZERO <u>1.3</u> °F	Adj. to <u>0.0</u> °F	ZERO <u>.3</u> °F	Difference <u>.015</u> % ✓
SPAN <u>1997.4</u> °F	Adj. to <u>2000.0</u> °F	SPAN <u>2002.6</u> °F	Difference <u>.130</u> % ✓


Thermocouple Readout Pretest Linearity Check:

0 = <u>0.0</u> °F	200 = <u>201.6</u> °F	400 = <u>399.0</u> °F
600 = <u>601.3</u> °F	800 = <u>801.4</u> °F	1000 = <u>1000.6</u> °F
1200 = <u>1198.1</u> °F	1400 = <u>1399.2</u> °F	1600 = <u>1599.7</u> °F
1800 = <u>1800.0</u> °F	2000 = <u>2000.0</u> °F	

Sample Train Leak Check	Pre <u>✓</u>	Post <u>X</u>
C-gas Train Leak Check	Pre <u>✓</u>	Post <u>✓</u>
SO ₂ Train Leak Check	Pre <u>✓</u>	Post <u>✓</u>
Static Gauge Zero Check	Pre <u>X</u>	Post <u>✓</u>

Scale Check Pre : 6.0 - 16.0 ✓
 Post : 3.7 - 13.7 ✓

Stack Cleaned Prior to Test Run : YES _____ NO X



COMPUTER INPUT DATA SHEET #1

Client: JOTUL USA, INC.
 Address: 400 RIVERSIDE ST / P.O. BOX 1157
PORTLAND, ME 04104
 Phone: 800-797-5912 Fax: 207-797-6072
 Run No.: 4 Date of Test: 05-05-03 Burn Rate: 1.219 ✓
 Model No.: F600 min min-1.25 fan
 Stove Type: Cat Non Cat Pellet 1.25-1.9 max insert

Dry Gas Meter Y Factor: .990 ✓ Post Leak Rate: .000 ✓ cfm Time: 325 ✓ min.
 (0.000) (Data Sheet #2) (.000) (Data Sheet #2) (000) (Data Sheet #2)

Dry Gas Meter Volume: 123.211 ✓ cf
 (00.000) (Data Sheet #2)

Stack Flow: 7.929 ✓ dscfm Δ H: .223 ✓ in. H₂O
 (00.000) (Data Sheet #2) (.000) (Data Sheet #2)

Maximum Vac.: 4.0 ✓ Barometric Pressure: 30.11 ✓ in. Hg
 (0.0) (Data Sheet #2) (00.00) (Data Sheet #2)

H₂O Captured: 173.6 ✓ g
 (00.0) (Data Sheet #3)

Front Half Catch % Of Total: 32.8 ✓ % Total Particulate Catch: 1.1582 ✓ g
 (00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)

Flue Gas Moisture: 6.4615 ✓ %
 (00.000) (Data Sheet #7)

Particulate Emission: .1511 ✓ gr/dscf
 (0.0000) (Data Sheet #7)

Relative Humidity: 28.5 ✓ % RH Ambient Moisture: 1.15 ✓ % H₂O
 (00.0) (Data Sheet #8) (0.00) (Data Sheet #8)

Preburn Fuel Wt.: 43.6 ✓ lbs. Coal Bed Wt.: 3.8 ✓ lbs. Test Fuel Wt.: 17.7 ✓ lbs.
 (00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)

Heat Output (EPA Default): 14,698.8 ✓ BTU/hr
 (00,000.0) (Data Sheet #8)

Kindling Fuel % Moisture (wet): 14.286 ✓ % Pretest Fuel % Moisture (wet): 18.452 ✓ %
 (00.000) (Data Sheet #10) (00.000) (Data Sheet #10)

Test Fuel % Moisture (dry): 21.594 ✓ % Test Fuel % Moisture (wet): 17.759 ✓ %
 (00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])

Fuel Higher Heating Value (dry): — ✓ BTU/lb.
 (0000) (Data Sheet #11)

Stack Static Pressure: -.035 ✓ in. H₂O
 (+/- .000) (Data Sheet #12)

Average Ambient Temperature: 73 ✓ °F Stove Temperature Change: 62.6 ✓ °F
 (00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : jotul

TEST No. : 4

MODEL: F600

DATE: 05-May-03

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
0	680.500	0.150	85	1.56	5.80	525
5	682.000	0.460	85	0.63	12.60	300
10	684.689	0.190	85	0.61	3.80	475
15	686.389	0.170	85	0.71	4.90	500
20	688.005	0.150	85	0.85	4.70	525
25	689.544	0.150	85	0.93	4.30	525
30	691.083	0.150	85	0.80	5.20	525
35	692.622	0.150	85	0.87	5.80	525
40	694.161	0.150	85	1.00	5.70	525
45	695.699	0.150	85	0.95	5.90	525
50	697.238	0.190	85	0.85	6.90	475
55	698.939	0.230	85	0.77	8.50	425
60	700.839	0.300	85	0.53	9.80	375
65	702.992	0.260	85	0.62	9.60	400
70	705.011	0.300	86	0.46	10.40	375
75	707.171	0.300	86	0.50	11.40	375
80	709.332	0.300	86	0.40	10.20	375
85	711.493	0.290	87	0.49	11.60	375
90	713.662	0.260	88	0.53	10.90	400
95	715.703	0.260	89	0.60	11.70	400
100	717.751	0.260	89	0.56	11.90	400
105	719.799	0.260	89	0.60	11.90	400
110	721.848	0.260	89	0.43	10.90	400
115	723.896	0.290	89	0.40	11.10	375
120	726.081	0.290	89	0.41	11.60	375
125	728.266	0.260	89	0.44	12.00	400
130	730.314	0.290	89	0.25	10.60	375
135	732.499	0.250	90	0.50	8.70	400
140	734.553	0.250	92	0.62	8.00	400
145	736.626	0.250	92	0.76	7.40	400
150	738.697	0.200	92	1.22	6.40	450
155	740.538	0.200	92	1.33	6.20	450
160	742.379	0.200	92	1.48	6.10	450
165	744.220	0.220	92	1.53	6.20	425
170	746.170	0.230	90	1.89	5.90	425
175	748.105	0.230	90	1.66	6.20	425
180	750.040	0.230	90	1.73	6.10	425
185	751.976	0.230	90	1.84	5.90	425
190	753.911	0.230	90	2.01	5.80	425
195	755.846	0.200	90	1.61	6.30	450
200	757.674	0.200	90	1.46	6.30	450
205	759.502	0.200	90	1.48	6.30	450
210	761.330	0.200	90	1.55	6.30	450
215	763.158	0.200	90	1.58	6.40	450

220	764.986	0.200	90	1.63	6.30	450
225	766.814	0.230	90	1.66	6.20	425
230	768.749	0.230	90	1.85	6.00	425
235	770.685	0.230	90	1.89	5.90	425
240	772.620	0.230	89	1.79	5.70	425
245	774.549	0.230	89	1.94	5.60	425
250	776.477	0.200	89	2.18	5.30	450
255	778.299	0.200	89	2.29	5.00	450
260	780.121	0.200	89	2.12	5.10	450
265	781.943	0.200	89	2.16	5.00	450
270	783.765	0.200	89	2.18	4.90	450
275	785.587	0.200	89	2.05	4.90	450
280	787.409	0.200	89	2.05	4.90	450
285	789.231	0.200	89	1.93	5.30	450
290	791.053	0.200	89	2.05	4.80	450
295	792.875	0.200	89	1.97	4.60	450
300	794.697	0.200	89	2.15	4.30	450
305	796.519	0.200	89	2.11	4.10	450
310	798.341	0.200	89	2.02	4.00	450
315	800.163	0.200	89	1.99	4.00	450
320	801.985	0.180	89	1.96	3.90	475
325	803.711	0.200	89	1.88	3.80	450
330						

TABLE 2---RAW DATA

CLIENT : jotul

TEST No. 4

MODEL: F600

DATE: 05-May-03

METER CAL. FACTOR (Y) -----	0.99	Wt. WOOD BURNED (LB) -----	17.7	Lbs
BAROMETRIC PRESS. (Pb) -----	30.11 in Hg	WET, FUEL MOISTURE % -----	17.759	%
LEAK RATE POST (Lp) -----	0.000 cfm	Wt. PART. COLLECTED -----	1.1582	g
WATER VOL. (V1c) -----	173.6 Ml	METER VOLUME Vm -----	123.211	mcf
TEST TIME (MIN) -----	325 min	HC MOLE FRACTION -----	0.0132	

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :jotul

TEST No. 4

MODEL: F600

DATE: 05-May-03

AVG DELTA		AVG PRCNT		
H	----- 0.22 in H2O	CO	----- 1.30	%
AVG METER		AVG PRCNT		
TEMP. Tm	----- 88 deg F	CO2	----- 6.97	%
AVG PPM		AVG BAL		
SO2	----- 436 PPM	CO2/CO	----- 5.36	%

TABLE 4 ----- CALCULATIONS

CLIENT : jotul

TEST No. 4

MODEL: F600

DATE: 05-May-03

STD SAMPLE		STACK GAS		
VOL. Vm(std)	----- 118.26 dscf	FLOW Qsd	----- 457.992	dscf/Hr
				&
			7.63	dscf/min
VOL. WATER		PARTICULATE		
VAPOR Vw(std)	---- 8.171 scf	CONCTR. Cs	----- 0.0098	g/dscf
PRCNT		PARTC.EMISS.		
MSTR Bws	----- 6.46 %	RATE E	----- 4.49	g/Hr
BURN		MOLES OF GAS		
RATE BR	----- 1.22 Kg/Hr	PER Lb WOOD Nt	-- 0.44	Lb-mole/Lb
CO EMISSION		PART.EMISS.		
RATE	----- 199.50 g/Hr	RATE	----- 3.68	g/Kgdry
	&			fuel
	163.66 g/Kgdry			
	fuel			

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : jotul

TEST No. : 4

MODEL: F600

DATE: 05-May-03

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	760.5	97	100
10	779.6	99	
15	779.9	99	
20	780.3	99	
25	780.3	99	
30	780.3	99	
35	780.3	99	
40	780.3	99	
45	779.8	99	
50	780.3	99	
55	780.4	99	
60	780.0	99	
65	780.0	99	
70	779.4	99	
75	781.1	100	
80	781.5	100	
85	780.7	99	
90	782.2	100	
95	783.6	100	
100	785.6	100	
105	785.6	100	
110	786.0	100	
115	785.6	100	
120	785.8	100	
125	785.8	100	
130	785.6	100	
135	785.1	100	
140	785.0	100	
145	790.8	101	
150	790.1	101	
155	790.0	101	
160	790.0	101	
165	790.0	101	
170	791.8	101	
175	787.1	100	
180	787.1	100	
185	787.5	100	
190	787.1	100	
195	787.1	100	
200	787.3	100	
205	787.3	100	
210	787.3	100	
215	787.3	100	
220	787.3	100	

225	787.3	100
230	787.1	100
235	787.5	100
240	787.8	100
245	786.1	100
250	785.7	100
255	786.1	100
260	786.1	100
265	786.1	100
270	786.1	100
275	786.1	100
280	786.1	100
285	786.1	100
290	786.1	100
295	786.1	100
300	786.1	100
305	786.1	100
310	786.1	100
315	786.1	100
320	786.1	100
325	786.0	100
330		
335		

METER BOX DATA SHEET PAGE # 2

Page: 1 of 3

UNIT: F600 RUN: 4

DATE: 5-5-03

Meter Box: 5H Y Factor: .990 ✓

Leak checks: 16 " Hg @ .003 cfm _____ " Hg @ _____ cfm

15 " Hg @ .000 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1,500

ROTO: PRESS: <u>.16</u>			SAMPLING RATIO: <u>21.5</u> : 1				BP: <u>30.11</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
0	1345	680.500	—	6.562	.15	85	525	85	1.0	
5	50	682.000	—	11.483	.46	85	300	85	4.0	
10	55	684.689	684.689	7.253	.19	85	475	85	2.0	
15	1400	686.389	686.389	6.890	.17	85	500	85	2.0	
20	05	688.005	688.005	6.562	.15	85	525	85	2.0	
25	10	689.544	689.544	6.562	.15	85	525	85	2.0	
30	15	691.083	691.083	6.562	.15	85	525	85	2.0	
35	20	692.622	692.622	6.562	.15	85	525	85	2.0	
40	25	694.161	694.161	6.562	.15	85	525	85	2.0	
45	30	695.699	695.699	6.562	.15	85	525	85	2.0	
50	35	697.238	697.238	7.253	.19	85	475	85	2.0	
55	40	698.939	698.939	8.106	.23	85	425	85	2.0	
ROTO PRESS: <u>.16</u>			TOTALS: 86.919			2.29	1020	BP.: 30.11		
60	1445	700.839	700.839	9.187	.30	85	375	85	2.0	
65	50	702.992	702.992	8.612	.26	85	400	85	2.0	
70	55	705.011	705.011	9.170	.30	86	375	86	2.0	
75	1500	707.171	707.171	9.170	.30	86	375	86	2.0	
80	05	709.332	709.332	9.170	.30	86	375	86	2.0	
85	10	711.493	711.493	9.153	.29	87	375	87	2.0	
90	15	713.662	713.662	8.565	.26	88	400	88	2.0	
95	20	715.703	715.703	8.550	.26	89	400	89	2.0	
100	25	717.751	717.751	8.550	.26	89	400	89	2.0	
105	30	719.799	719.799	8.550	.26	89	400	89	2.0	
110	35	721.848	721.848	8.550	.26	89	400	89	2.0	
115	40	723.896	723.896	9.120	.29	89	375	89	2.0	
			TOTALS: 106.347			3.34	1048	MAX VACC =		
TOTAL Cu Ft.			TOTALS: 143.266			5.63	2068	AVG. BP:		

METER BOX DATA SHEET PAGE # 2

UNIT: F600 RUN: 4 DATE: 5-5-03

Meter Box: 5H Y Factor: .990 ✓

Leak checks: .16 " Hg @ .003 cfm _____ " Hg @ _____ cfm

15 " Hg @ .000 cfm ✓ _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle : Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.16</u>			SAMPLING RATIO: <u>21.5</u> : 1				BP: <u>30.11</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
120	1545	726.081	726.081	9.120	.29	89	375	89	2.0
125	50	728.266	728.266	8.550	.26	89	400	89	2.0
130	55	730.314	730.314	9.120	.29	89	375	89	2.0
135	1600	732.499	732.499	8.534	.25	90	400	90	2.0
140	05	734.553	734.553	8.503	.25	92	400	92	2.0
145	10	736.626	736.626	8.503	.25	92	400	92	2.0
150	15	738.697	738.697	7.558	.20	92	450	92	2.0
155	20	740.538	740.538	7.558	.20	92	450	92	2.0
160	25	742.379	742.379	7.558	.20	92	450	92	2.0
165	30	744.220	744.220	8.003	.22	92	425	92	2.0
170	35	746.170	746.170	8.032	.23	90	425	90	2.0
175	40	748.105	748.105	8.032	.23	90	425	90	2.0
ROTO PRESS: <u>.16</u>			TOTALS: <u>99.071</u>		<u>2.87</u>	<u>1089</u>	BP: <u>30.11</u>		
180	1645	750.040	750.040	8.032	.23	90	425	90	2.0
185	50	751.976	751.976	8.032	.23	90	425	90	2.0
190	55	753.911	753.911	8.032	.23	90	425	90	2.0
195	1700	755.846	755.846	7.586	.20	90	450	90	2.0
200	05	757.674	757.674	7.586	.20	90	450	90	2.0
205	10	759.502	759.502	7.586	.20	90	450	90	2.0
210	15	761.330	761.330	7.586	.20	90	450	90	2.0
215	20	763.158	763.158	7.586	.20	90	450	90	2.0
220	25	764.986	764.986	7.586	.20	90	450	90	2.0
225	30	766.814	766.814	8.032	.23	90	425	90	2.0
230	35	768.749	768.749	8.032	.23	90	425	90	2.0
235	40	770.685	770.685	8.032	.23	90	425	90	2.0
			TOTALS: <u>93.708</u>		<u>2.58</u>	<u>1080</u>	MAX VACC =		
TOTAL Cu Ft.			TOTALS: <u>192.779</u>		<u>5.45</u>	<u>2169</u>	AVG. BP:		

METER BOX DATA SHEET PAGE # 2

Page: 3 of 3

UNIT: F600 RUN: 4 DATE: 5-5-03

Meter Box: SH Y Factor: .990 ✓

Leak checks: 16 " Hg @ .003 cfm _____ " Hg @ _____ cfm

15 " Hg @ .000 cfm ✓ _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.16</u>			SAMPLING RATIO: <u>21.5</u> : 1				BP: <u>30.10</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
240	1745	772.620	772.620	8.044	.23	89	425	89	2.0	
245	50	774.549	774.549	8.044	.23	89	425	89	2.0	
250	55	776.477	776.477	7.597	.20	89	450	89	2.0	
255	1800	778.299	778.299	7.597	.20	89	450	89	2.0	
260	05	780.121	780.121	7.597	.20	89	450	89	2.0	
265	10	781.943	781.943	7.597	.20	89	450	89	2.0	
270	15	783.765	783.765	7.597	.20	89	450	89	2.0	
275	20	785.587	785.587	7.597	.20	89	450	89	2.0	
280	25	787.409	787.409	7.597	.20	89	450	89	2.0	
285	30	789.231	789.231	7.597	.20	89	450	89	2.0	
290	35	791.053	791.053	7.597	.20	89	450	89	2.0	
295	40	792.875	792.875	7.597	.20	89	450	89	2.0	
ROTO PRESS: <u>.16</u>			TOTALS: <u>92.058</u>		<u>2.46</u>	<u>1068</u>	BP: <u>30.10</u>			
300	1845	794.697	794.697	7.597	.20	89	450	89	2.0	
305	50	796.519	796.519	7.597	.20	89	450	89	2.0	
310	55	798.341	798.341	7.597	.20	89	450	89	2.0	
315	1900	800.163	800.163	7.597	.20	89	450	89	2.0	
320	05	801.985	801.985	7.197	.18	89	475	89	2.0	
325	10	803.711	803.711	7.597	.20	89	450	89	2.0	
330										
335				45.182	1.18	534				
340										
345										
350				523.285	14.72	5839				
355							<u>460</u>			
			TOTALS:			<u>88</u>	MAX VACC =		<u>4.0</u>	
TOTAL Cu Ft.		<u>123,211</u>	TOTALS:		<u>7.929</u>	<u>.223</u>	<u>548</u>	AVG. BP: <u>30.11</u>		

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT : FG00 RUN : 4 DATE : 5-5-03

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	759.9	614.2	486.5	894.4
INITIAL WT	612.6	593.8	483.7	891.3
NET WT GRAMS	147.3	20.4	2.8	3.1

TOTAL CATCH : 173.6 GRAMS H₂O

FRONT HALF

FILTER #	150F	
FINAL WT g	.9736	✓
INITIAL WT g	.6943	✓
NET WT g	.2793	✓

BEAKER #	11
DESC.	ACETONE
FINAL WT g	104.8900
INITIAL WT g	104.7887
NET WT g	.1013
VOL. DESC. ml	110

BACK HALF

FILTER #	150B	
FINAL WT g	.5766	✓
INITIAL WT g	.4299	✓
NET WT g	.1467	✓

BEAKER #	12	13	14	15	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	98.5737	104.2654	98.0891	104.8639	
INITIAL WT g	98.2304	104.1784	97.9819	104.7642	
NET WT g	.3433	.0870	.1072	.0997	.2069
VOL. DESC ml	200	75	200	180	(380)

FILTER TARE WEIGHTS DATA SHEET #4-1

Into Dessicator : Date : 01/17/03 Time : 2055 By : BW
 Manufacturer S & S Grade : # 25 Glass Front Size : 11 cm Lot No. : ZB921
 Back Size : 8.2 cm Lot No. : ZB911

DATE: 01/20/03 BY: BW DATE: 01/21/03 BY: BW DATE: _____ BY: _____

FILTER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME
141F	.6987	2108	.6986	0937	HEARTHSTONE MORGAN R-6	
142F	.6899	2109	.6900	0938	" " R-7	
143F	.6957	2110	.6958	0938	NEW BUCK R-1	
144F	.6992	2110	.6995	0940	" " R-2	
145F	.6984	2111	.6985	0941	" " R-3	
146F	.6949	2112	.6950	0942	" " R-4	
147F	.6947	2113	.6946	0943	" " R-5	
148F	.6958	2113	.6960	0943	TOTAL F600 R-1	
149F	.6938	2114	.6939	0944	" " R-3	
150F	.6941	2115	.6943	0945	" " R-4	

141B	.4321	2116	.4322	0946	HEARTHSTONE MORGAN R-6	
142B	.4291	2117	.4293	0947	" " R-7	
143B	.4287	2118	.4288	0947	NEW BUCK R-1	
144B	.4313	2118	.4312	0948	" " R-2	
145B	.4302	2119	.4303	0949	" " R-3	
146B	.4232	2120	.4234	0950	" " R-4	
147B	.4275	2121	.4275	0950	" " R-5	
148B	.4400	2121	.4400	0951	TOTAL F600 R-1	
149B	.4287	2122	.4288	0952	" " R-3	
150B	.4297	2123	.4299	0953	" " R-4	

Checked by: C. W. [Signature] Date: 1-21-03 Time: 1010

SCALE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	DB	% RH
01/20	2105	BW	76	44
01/21	0935	BW	75	44

BEAKER TARE WEIGHTS DATA SHEET #4-2

Into Dessicator: Date: 08-19-2002 Time: 1205 By: DM

BEAKER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME
1	104.9172	1043	1049.174	0704		
2	106.2542	1044	106.2538	0705	} Total Flood R-1	
3	107.7782	1046	107.7777	0706		
4	108.7744	1047	108.7740	0708		
5	97.4390	1048	97.4366	0709		
6	91.2080	1050	91.2076	0710		
7	97.1385	1051	97.1382	0711	} Total Flood R-3	
8	108.6356	1052	108.6357	0713		
9	108.0961	1053	108.0960	0714		
10	105.7310	1055	105.7306	0715		
11	104.7892	1056	104.7887	0717	} Total Flood R-4	
12	98.2303	1057	98.2304	0718		
13	104.1788	1059	104.1784	0719		
14	97.9822	1100	97.9819	0721		
15	104.7644	1101	104.7642	0722		
16	95.7427	1102	95.7429	0723	} Total Flood R-5	
17	104.5948	1104	104.5944	0724		
18	108.8626	1105	108.8623	0725		
19	106.5473	1106	106.5468	0726		
20	108.5936	1108	108.5932	0728		

SCALE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	DB	% RH	
08-22	1040	DM	78	49	Checked by: <u>Chp Wainwright</u>
08-23	0700	DM	78	49	
					Date: <u>8-23-02</u>
					Time: <u>0910</u>

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: F600

RUN: 4

DATE: 5-5-03

Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
11	05/06	0935	RL	104.8904	05/09	0733	RL	104.8900	05/10	1447	RL	98.5737	05/11	1217	RL
12	05/06	0935	RL	98.5756	05/09	0734	RL	98.5740	05/10	1448	RL	104.2658	05/11	1218	RL
13	05/06	2155	RL	104.2753	05/09	0735	RL	104.2708	05/10	1449	RL	98.0891	05/10	1450	RL
14	05/06	0935	RL	104.2654	05/09	0736	RL	104.8639	05/10	1451	RL				
15	05/06	0935	RL	98.0891	05/09	0737	RL								

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
150F 5-5	05/06	1450	CJ	.9739	05/06	2153	RL	.9736	05/09	0738	RL	.5789	05/10	1453	RL
150B 5-5	05/06	1450	CP	.5857	05/06	2154	RL	.5801	05/09	0739	RL	.5766	05/12	0947	RL
				.5770	05/11	1219	RL								

SCALE ROOM ENVIRONMENTAL CONDITIONS


Weighing Session	Date	Time	By	DB	%RH
1	05/06	2135	RL	77	46
2	05/09	0715	RL	77	45
3	05/10	1435	RL	78	47
4	05/11	1210	RL	77	46
5	05/12	0940	RL	76	45

Weighing Session	Date	Time	By	DB	%RH
6					
7					
8					
9					
10					

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates: From 12-05-2002 Through 02-23-2003	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9997	9.9998	1.0000	.0997	AKW	12-05	1825	77	47
99.9998	10.0000	.9999	.1000	AKW	12-06	1125	77	45
99.9997	10.0001	1.0000	.1000	AKW	12-07	1310	76	41
99.9997	10.0001	1.0000	.0999	AKW	12-08	1430	77	44
99.9998	9.9999	1.0001	.0999	AKW	12-09	1125	78	44
99.9998	10.0000	.9999	.0998	AKW	12-10	1220	78	43
99.9997	10.0000	.9998	.0998	AKW	12-11	1650	77	45
99.9997	10.0001	.9999	.0999	AKW	12-12	1445	77	47
99.9998	10.0000	.9999	.1000	AKW	12-14	1530	78	47
99.9997	10.0000	1.0000	.0999	AKW	01-10	2300	78	48
99.9998	9.9999	1.0001	.1000	AKW	01-14	1115	77	48
99.9999	10.0000	.9999	.1000	AKW	01-15	1705	77	48
99.9999	10.0001	.9999	.0998	AKW	01-16	1830	78	46
99.9997	10.0000	1.0000	.0999	AKW	01-17	1215	77	41
99.9997	9.9999	1.0000	.0999	AKW	01-17	2035	76	42
99.9996	10.0000	.9999	.0999	AKW	01-18	1730	77	43
99.9999	9.9999	.9998	.0999	AKW	01-19	1210	76	42
99.9998	10.0000	1.0000	.0999	AKW	01-20	2105	76	44
99.9999	10.0000	.9999	.0998	AKW	01-21	0935	75	44
99.9998	10.0000	.9999	.0999	AKW	01-22	1125	77	46
100.0000	9.9998	.9999	.1000	AKW	01-23	1430	77	48
99.9999	10.0001	1.0001	.1000	AKW	01-24	1200	76	48
99.9998	9.9999	.9999	.0999	AKW	01-25	1140	76	47
99.9997	10.0000	1.0000	.0999	AKW	01-25	1850	78	48
99.9998	9.9998	1.0000	.1000	AKW	01-27	1415	75	47
99.9999	9.9999	1.0000	.1000	AKW	01-30	1920	77	48
99.9998	10.0000	.9998	.0999	AKW	01-31	2205	78	47
99.9999	9.9998	.9998	.1000	AKW	02-01	1855	77	47
99.9997	9.9998	.9999	.1001	AKW	02-02	1420	76	46
99.9997	10.0001	.9998	.0999	AKW	02-18	1155	77	49
99.9999	9.9999	.9999	.0999	AKW	02-19	1925	77	48
99.9997	10.0000	1.0000	.0999	AKW	02-22	2010	78	45
99.9997	10.0000	.9999	.1000	AKW	02-23	1130	78	44
								

BLANK PROCESSING DATA SHEET # 5

UNIT: F600 RUN: 4 DATE: 05/05/03

DATE BLANKS DONE: 02-23-03

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	DWNA, INC. SPARKLETES DISTILLED
FINAL WEIGHT	108.9007	106.3074	106.9660
TARE WEIGHT	108.8995	106.3057	106.9646
NET WEIGHT	.0012 ✓	.0017 ✓	.0014 ✓

TARE BEAKERS INTO DESC : TIME : 1430 DATE : 02-12-03

DATE : 02-18 BY: BR DATE : 02-19 BY: BR DATE : _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.8996	1158	108.8995	1928	✓	
B	106.3060	1159	106.3057	1930	✓	
C	106.9649	1200	106.9646	1931	✓	

FINAL BEAKERS INTO DESC : TIME : 1600 DATE : 02-20-03

DATE : 02-22 BY: BR DATE : 02-23 BY: BR DATE : _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9010	2013	108.9007	1132	✓	
B	106.3078	2015	106.3074	1133	✓	
C	106.9661	2016	106.9660	1134	✓	

TARE QC

DATE	TIME	BY	WB	DB	%
02-18	1155	BR	}	77	49
02-19	1925	BR		77	48

FINAL QC

DATE	TIME	BY	WB	DB	%
02-22	2010	BR	}	78	45
02-23	1130	BR		78	44

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: F600 RUN: 4 DATE: 05/05/03

BLANK CALCULATIONS

Acetone : $\frac{.0012 \text{ g}}{200 \text{ ml}} = \frac{.000006 \text{ g}}{\text{ml}}$ ✓
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = \frac{.000023 \text{ g}}{\text{ml}}$ ✓
 Distilled Water : $\frac{.0014 \text{ g}}{200 \text{ ml}} = \frac{.000007 \text{ g}}{\text{ml}}$ ✓

FRONT HALF CATCH

FILTERS : $\frac{.2793 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ } (.0000 \text{ g})}{\text{\# of Filters Blank Value / Filter}} = \frac{.2793 \text{ g}}{\text{g}}$ ✓
 BEAKERS : $\frac{.1013 \text{ g}}{\text{Total Catch}} - \frac{110 \text{ ml } (.000006 \text{ g})}{\text{ml Acetone Blank Value / ml Acetone}} = \frac{.1006 \text{ g}}{\text{g}}$ ✓
TOTAL FRONT HALF CATCH : .3799 g ✓

BACK HALF CATCH

FILTERS : $\frac{.1467 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ } (.0000 \text{ g})}{\text{\# of Filters Blank Value / Filter}} = \frac{.1467 \text{ g}}{\text{g}}$ ✓
 BEAKERS :
 Acetone : $\frac{.3433 \text{ g}}{\text{Total Catch}} - \frac{200 \text{ ml } (.000006 \text{ g})}{\text{ml Acetone Blank Value / ml Acetone}} = \frac{.3421 \text{ g}}{\text{g}}$ ✓
 Extract : $\frac{.0870 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml } (.000023 \text{ g})}{\text{ml Dichloromethane Blank Value / Dichloromethane}} = \frac{.0853 \text{ g}}{\text{g}}$ ✓
 Water : $\frac{.2069 \text{ g}}{\text{Total Catch}} - \frac{380 \text{ ml } (.000007 \text{ g})}{\text{ml Water Blank Value / Water}} = \frac{.2042 \text{ g}}{\text{g}}$ ✓
TOTAL BACK HALF CATCH : .7783 g ✓

TOTAL CATCH : 1.1582 g ✓

% FRONT HALF : 32.8 % ✓
 (00.0)

CALCULATIONS DATA SHEET # 7

UNIT: JOTUL F600 RUN: 4 DATE: 05/05/05

$$1) Vm (std) = \frac{(123.21 Vm) (17.64) (990 mcf) (30.11" Hg + \frac{223" H_2O}{13.6})}{(548 TmA)} = \frac{118.2905}{000.0000} \text{ dscf}$$

$$2) Vw (std) = (.04707) (173.6 \text{ ml H}_2\text{O}) = \frac{8.1714}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(8.1714 \text{ scf})}{(\text{scf} + 118.2905 \text{ dscf})} = \frac{.0646}{.0000} \text{ Bws} \times 100 = \frac{6.4615}{00.0000} \% \text{ H}_2\text{O}$$

$$4) Cs = \frac{(1.1582 \text{ g.})}{(118.2905 \text{ dscf})} (15.43) = \frac{.1511}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(1.1582 \text{ g.})}{(118.2905 \text{ dscf})} (7.929 \text{ dscfm}) (60) = \frac{4.6580}{00.0000} \text{ g / hr}$$

- Vm = total cubic feet pulled on meter box during test (000.000 Vm)
- mcf = meter correction factor (Y factor) of meter box used for test (0.000 mcf)
- " Hg = average barometric pressure during test (00.00 " Hg)
- " H₂O = average delta H for test (.000 " H₂O)
- TmA = average meter temperature for test in degrees Absolute (000 TmA)
- ml H₂O = total water caught during test (000.0 ml H₂O)
- g. = total particulate catch for test (00.0000 g.)
- dscfm = average stack flow during test (00.000 dscf)

TEST DATA SHEET # 8

UNIT: FL600 RUN: 4 DATE: 5-5-03

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb

Pre : WB : 63 DB : 85 = 27 % RH 1.2 % H₂O

Post : WB : 60 DB : 79 = 30 % RH 1.1 % H₂O

Average : 28.5 % RH 1.15 % H₂O

Empty Stove Weight (lbs) : _____ w/ stack & oil seal : Wet : — Dry : 0.0

Kindling Weight (lbs) : Paper : 1.2 Wood : 1.7

Preburn Fuel Weight : 15.2 + 12.6 + 14.1 Total : 41.9

Kindling & Preburn Fuel Weight (wood only) (lbs) : Total : 43.6

Coal Bed Wt Range (lbs) : 4.4 - 3.6 Scale : 4.4 - 3.6

Upper : .25 x fuel weight : Always round DOWN to nearest tenth

Lower : .20 x fuel weight : Always round UP to nearest tenth Actual Coal Bed Weight : 3.8

Maximum Coal Bed Removal (lbs) : $((\frac{4.4}{\text{Upper}} + \frac{3.6}{\text{Lower}}) \div 2) \cdot .25 = \underline{1.0}$ round down to nearest tenth

Test Fuel (.75" x 1.5" x 5" spacers) = 20 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	4	8.9	50.3
4" x 4"	17	2	8.8	49.7

Test Fuel Weight : 17.7 lbs

Estimated Dry Burn Rate :

$$\frac{17.7 \cdot (17.7 \cdot .17759)}{2.2046} \times \frac{60}{325} = \underline{1.219} \text{ kg/hr}$$

Estimated BTU's/hr : $19,140 \times \frac{63}{100} \times \frac{1.219}{\text{DBR}} = \underline{14,698.8}$ BTU's/hr

EPA Default Efficiencies : Non-cat : 63 Cat : 72 Pellet : 78

WOOD STOVE OPERATING DATA PAGE #9

Unit: FL600 Run: 4 Date: 5-5-03

FIRE STARTED: 0915

WARM UP AND PREBURN:

PRIMARY AIR: Set wide open for all warm-up / preburn fuel charges. Then set to 3/16" at start of preburn.

SECONDARY AIR: N/A CAT BYPASS: N/A

CHARCOAL BED PREPARATION :

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 35 sec.

TEST:

DOOR wide open during loading 0 min. 45 sec.

PRIMARY AIR: Opened full for first 5 min., then set to run setting of 3/16".

SECONDARY AIR: N/A CAT BYPASS: N/A

FAN:

ON / OFF during warm-up

ON / OFF during preburn

ON / OFF first 30 minutes of test

ON / OFF balance of test run

Fan speed set at High

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER: _____ BRAND: _____

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 16 or - inches.

1st warm up / pre-burn fuel charge (15.2 lbs.) added at 0935

2nd warm up / pre-burn fuel charge (12.6 lbs.) added at 1100

3rd warm up / pre-burn fuel charge (14.1 lbs.) added at 1205

4th warm up / pre-burn fuel charge (_____ lbs.) added at _____

5th warm up / pre-burn fuel charge (_____ lbs.) added at _____

TEST DATA SHEET #10

Unit : F600 Run : 4 Date : 5-5-03
 Room Temperature : 72 °F Correction Factor : ∅
 Uncorrected Values are corrected for room temperature : Yes _____ No
 Time Test Fuel moisture reading taken : 1210 ✓
 Calibration Checks : X Y 12.0 12.1 22.0 22.1

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	16.0	17.0	15.5	16.5	15.5	16.5	16.667 ✓
2									
3									
4	2"x4"x8'	P	21.5	23.1	21.5	23.1	22.0	23.7	23.300 ✓
5	2"x4"x8'	P	22.0	23.7	22.0	23.7	22.0	23.7	23.700 ✓
6	2"x4"x8'	P	19.5	20.9	21.0	22.5	21.0	22.5	21.967 ✓
7	2"x4"x8'	P	20.0	21.4	19.0	20.3	19.5	20.9	20.867 ✓
8	2"x4"x8'	P	22.0	23.7	22.0	23.7	21.0	22.5	23.300 ✓
9									113.134 ✓
10									
11	2x4x17	T	17.5	18.7	18.5	19.8	18.5	19.8	19.433 ✓
12	"	T	20.5	22.0	21.0	22.5	21.0	22.5	22.333 ✓
13	"	T	20.0	21.4	20.0	21.4	20.0	21.4	21.400 ✓
14	"	T	23.5	25.2	23.0	24.7	23.5	25.2	25.033 ✓
15	4x4x17	T	19.5	20.9	20.0	21.4	19.5	20.9	21.067 ✓
16	"	T	19.0	20.3	19.0	20.3	19.0	20.3	20.300 ✓
17									129.566 ✓
18									
19									
20	Spacers	T	18.5	19.8	18.0	19.2	18.0	19.2	19.400 ✓

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	16.667 % ✓	22.627 % ✓	21.594 % ✓
Wet Moisture % :	14.286 % ✓	18.452 % ✓	17.759 % ✓

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

GAS DATA SHEET #12

WEIGHT: 3.8

DATE: 05-05-03

UNIT: Flood

RUN: 4

PAGE: 1 OF 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO ₂ PPM	
0	1345	21.5	17.7	-	.232	5.8	.539	13.5	.155	1.56	7028	525
5	50	20.6	16.8	.19	.506	12.6	.302	7.6	.062	.63	7042	300
10	55	20.3	16.5	.3	.153	3.8	.656	16.4	.060	.61	7035	475
15	1400	20.1	16.3	.2	.197	4.9	.608	15.2	.070	.71	7033	500
20	05	19.7	15.9	.4	.190	4.7	.609	15.2	.084	.85	7033	525
25	10	19.4	15.6	.3	.174	4.3	.622	15.5	.092	.93	7031	525
30	15	19.1	15.3	.3	.210	5.2	.591	14.8	.079	.80	7032	525
35	20	18.7	14.9	.4	.233	5.8	.565	14.1	.086	.87	7034	525
40	25	18.3	14.5	.4	.230	5.7	.563	14.1	.099	1.00	7034	525
45	30	18.0	14.2	.3	.236	5.9	.559	14.0	.094	.95	7033	525
50	35	17.5	13.7	.5	.279	6.9	.520	13.0	.084	.85	7036	475
55	40	17.0	13.2	.5	.342	8.5	.460	11.5	.076	.77	7040	425
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	7.411	*****
60	1545	16.4	12.6	.6	.395	9.8	.417	10.4	.052	.53	7042	375
65	50	15.9	12.1	.5	.384	9.6	.424	10.6	.061	.62	7043	400
70	55	15.3	11.5	.6	.419	10.4	.396	9.9	.045	.46	7045	375
75	1600	14.6	10.8	.7	.456	11.4	.357	8.9	.049	.50	7046	375
80	05	13.9	10.1	.7	.410	10.2	.407	10.2	.039	.40	7047	375
85	10	13.2	9.4	.7	.464	11.6	.349	8.7	.048	.49	7047	375
90	15	12.6	8.8	.6	.437	10.9	.375	9.4	.052	.53	7047	400
95	20	12.0	8.2	.6	.470	11.7	.337	8.5	.059	.60	7046	400
100	25	11.4	7.6	.6	.479	11.9	.332	8.3	.055	.56	7046	400
105	30	10.8	7.0	.6	.472	11.9	.330	8.3	.059	.60	7046	400
110	35	10.2	6.4	.6	.439	10.9	.377	9.4	.042	.43	7046	400
115	40	9.7	5.9	.5	.447	11.1	.370	9.3	.039	.40	7046	375
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	7.547	*****
120	1645	9.2	5.4	.5	.464	11.6	.353	8.8	.040	.41	7046	375
125	50	8.7	4.9	.5	.480	12.0	.335	8.4	.043	.44	7046	400
130	55	8.2	4.4	.5	.426	10.6	.397	9.9	.024	.25	7046	375
135	1700	7.9	4.1	.3	.348	8.7	.465	11.6	.049	.50	7044	400
140	05	7.6	3.8	.3	.323	8.0	.485	12.1	.061	.62	7042	400
145	10	7.4	3.6	.2	.299	7.4	.504	12.6	.075	.76	7041	400
150	15	7.3	3.5	.1	.256	6.4	.528	13.2	.121	1.22	7038	450
155	20	7.1	3.3	.2	.251	6.2	.529	13.2	.132	1.33	7037	450
160	25	7.0	3.2	.1	.244	6.1	.530	13.2	.147	1.48	7036	450
165	30	6.9	3.1	.1	.245	6.2	.523	13.1	.152	1.53	7035	425
170	35	6.8	3.0	.1	.239	5.9	.518	13.0	.188	1.89	7035	425
175	40	6.7	2.9	.1	.249	6.2	.518	12.9	.165	1.66	7034	425
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	7.480	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	7.1438	*****

GAS DATA SHEET #12

WEIGHT: 3.8

DATE: 05-05-03

UNIT: F600

RUN: 4

PAGE: 2 OF 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO:PPM
180 1745	6.5	2.7	.2	.245	6.1	.519	13.0	.172	1.73	7033	425
185 50	6.4	2.6	.1	.237	5.9	.522	13.1	.183	1.84	7032	425
190 55	6.3	2.5	.1	.232	5.8	.521	13.0	.200	2.01	7032	425
195 180	6.2	2.4	.1	.253	6.3	.516	12.9	.160	1.61	7031	450
200 05	6.1	2.3	.1	.252	6.3	.523	13.1	.145	1.46	7031	450
205 10	6.0	2.2	.1	.252	6.3	.521	13.0	.148	1.48	7031	450
210 15	5.8	2.0	.2	.254	6.3	.517	12.9	.154	1.55	7030	450
215 20	5.7	1.9	.1	.256	6.4	.514	12.8	.157	1.58	7030	450
220 25	5.6	1.8	.1	.252	6.3	.516	12.9	.162	1.63	7030	450
225 30	5.4	1.6	.2	.248	6.2	.519	13.0	.165	1.66	7030	425
230 35	5.3	1.5	.1	.243	6.0	.516	12.9	.184	1.85	7030	425
235 40	5.3	1.5	⊖	.239	5.9	.518	13.0	.188	1.89	7029	425
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	70369	*****
240 1845	5.2	1.4	.1	.231	5.7	.530	13.3	.178	1.79	7029	425
245 50	5.1	1.3	.1	.225	5.6	.530	13.3	.193	1.94	7029	425
250 55	5.0	1.2	.1	.212	5.3	.534	13.3	.217	2.18	7029	450
255 190	4.9	1.1	.1	.202	5.0	.539	13.4	.228	2.29	7029	450
260 05	4.8	1.0	.1	.205	5.1	.543	13.6	.211	2.12	7028	450
265 10	4.7	.9	.1	.201	5.0	.546	13.6	.215	2.16	7028	450
270 15	4.6	.8	.1	.199	4.9	.547	13.7	.217	2.18	7028	450
275 20	4.5	.7	.1	.199	4.9	.552	13.8	.204	2.05	7027	450
280 25	4.4	.6	.1	.196	4.9	.555	13.9	.204	2.05	7027	450
285 30	4.3	.5	.1	.192	5.3	.544	13.6	.212	1.93	7027	450
290 35	4.2	.4	.1	.192	4.8	.559	14.0	.204	2.05	7027	450
295 40	4.2	.4	⊖	.187	4.6	.567	14.2	.196	1.97	7027	450
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	70335	*****
300 1945	4.1	.3	.1	.174	4.3	.573	14.3	.214	2.15	7026	450
305 50	4.0	.2	.1	.167	4.1	.582	14.5	.210	2.11	7026	450
310 55	4.0	.2	⊖	.161	4.0	.591	14.8	.201	2.02	7026	450
315 200	3.9	.1	.1	.160	4.0	.594	14.8	.198	1.99	7026	450
320 05	3.9	.1	⊖	.158	3.9	.597	14.9	.195	1.96	7025	475
325 10	3.8	⊖	.1	.153	3.8	.605	15.1	.187	1.88	7025	450
330 15											
335 20										7154	
340 25											
345 30											
350 35											
355 40											7160
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	70296	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	7035	*****

TEMPERATURE DATA SHEET #14

		TEST TIME	325		
STACK AVG	214	TOP AVG	272	LT SIDE AVG	264
BACK AVG	184	RT SIDE AVG	270	BOTTOM AVG	214
FIREBOX AVG	563	SEC/CAT AVG	844	AMBIENT AVG	73

END 197.0
START 259.6

-62.6 DELTA T

CIRCLE: LOSS / GAIN

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat/Ambient	Tube Furn	Smpl Box	Smpl Out	C-Gas Box	C-Gas Out	SO2 Out
0	199	245	294	195	291	273	562	690	76	1332	242	248	39	39
5	368	280	287	258	278	271	473	947	76	1336	246	249	39	36
10	220	273	277	258	266	263	438	729	76	1343	248	246	39	35
15	198	260	266	251	253	256	414	837	76	1349	247	248	38	36
20	191	255	254	242	241	254	395	708	75	1342	247	243	37	35
25	182	246	243	234	232	246	384	653	74	1336	248	240	36	37
30	181	241	236	226	226	235	378	691	71	1332	245	241	36	37
35	187	239	214	159	218	229	376	718	71	1330	246	241	38	36
40	189	239	202	146	213	224	374	725	70	1331	245	241	37	36
45	192	240	194	139	210	218	371	804	69	1334	247	240	36	36
50	197	239	187	134	206	214	371	976	73	1337	247	241	37	36
55	229	265	184	131	205	211	383	1003	70	1338	244	243	37	36
60	249	292	185	130	206	206	387	1065	70	1332	242	244	35	36
65	266	317	190	131	210	203	398	1077	70	1328	241	245	34	35
70	282	336	195	133	217	199	415	1072	71	1326	240	247	36	37
75	300	355	201	135	226	196	448	1081	71	1324	239	247	36	37
80	301	368	211	139	237	194	475	1047	72	1325	240	248	35	38
85	309	381	222	144	248	195	508	1096	73	1325	240	247	37	36
90	308	384	235	149	259	194	536	1088	73	1328	239	248	36	38
95	307	387	249	155	269	195	565	1122	74	1328	239	247	38	38
100	302	399	263	163	277	193	577	1166	75	1326	238	246	37	38
105	299	402	273	171	289	191	589	1176	74	1325	238	245	38	37
110	292	405	283	177	297	191	608	1175	74	1326	238	244	38	38
115	289	402	292	185	306	189	626	1186	74	1326	237	243	38	39
120	291	405	299	191	312	191	639	1177	73	1326	237	242	38	39
125	298	413	305	197	321	192	652	1193	73	1327	237	242	38	39
130	289	410	315	204	328	193	664	1161	74	1330	237	242	38	39
135	274	386	322	214	332	192	677	1119	74	1333	237	243	37	39
140	262	368	325	223	334	196	684	1097	75	1335	236	242	38	39
145	253	353	331	228	333	197	688	1059	74	1338	236	242	38	39
150	235	335	329	230	331	200	682	953	74	1340	235	243	39	38
155	224	317	327	232	326	201	677	908	73	1342	235	242	39	39
160	215	301	323	233	322	203	671	869	73	1343	234	241	38	39
165	208	289	318	231	317	204	672	846	73	1344	234	240	38	37
170	202	278	314	223	312	209	670	824	73	1343	233	240	39	38
175	198	266	310	218	307	209	670	814	71	1342	232	242	39	36

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube Furn	Smpl Box	Smpl Out	C-Gas Box	C-Gas Out	SO2 Out
180	195	259	309	214	304	210	668	803	72	1342	231	50	242	37	36
185	191	251	306	210	300	212	665	786	72	1341	231	50	243	37	37
190	189	244	302	208	297	212	660	775	72	1340	231	50	243	37	37
195	186	240	300	205	295	212	671	767	72	1338	232	50	242	38	35
200	184	235	296	199	292	213	674	769	71	1332	232	50	237	38	35
205	183	232	296	195	290	213	673	767	72	1329	232	50	237	38	35
210	182	228	292	190	289	216	673	763	73	1326	233	51	239	36	35
215	181	225	291	187	288	216	671	763	73	1322	233	51	239	36	35
220	180	223	291	184	286	220	666	764	74	1321	234	51	240	37	34
225	179	221	292	183	284	220	661	763	73	1320	235	52	240	37	34
230	178	219	287	181	282	225	655	758	74	1318	235	52	241	37	35
235	177	216	284	180	280	225	649	746	74	1318	235	52	241	36	35
240	176	215	282	179	277	224	632	737	73	1318	236	52	242	35	34
245	174	213	274	178	276	226	622	726	74	1318	236	52	242	35	34
250	172	212	273	177	272	226	611	709	73	1318	236	51	242	35	35
255	170	208	269	176	269	222	601	694	72	1318	236	51	242	34	36
260	168	207	262	175	266	225	590	682	73	1317	236	51	242	34	35
265	167	205	256	173	263	222	580	671	72	1315	236	51	242	34	37
270	166	203	252	171	261	223	573	662	73	1315	236	51	242	34	36
275	166	201	250	169	259	224	567	655	73	1315	236	51	242	35	36
280	165	199	245	167	257	221	560	649	73	1316	236	52	242	35	37
285	164	198	243	165	256	219	558	641	72	1316	236	52	242	35	37
290	163	196	239	163	253	216	555	636	72	1316	236	52	242	35	38
295	163	195	235	162	251	216	549	630	72	1315	236	52	241	36	36
300	161	194	232	160	249	214	539	619	72	1315	235	52	242	36	36
305	158	191	228	159	246	213	531	609	72	1315	235	52	242	37	36
310	157	188	227	157	242	212	521	599	72	1315	235	52	242	36	37
315	155	185	222	156	238	208	512	588	72	1315	235	52	240	36	37
320	153	183	218	155	236	208	506	579	71	1314	235	52	241	36	36
325	151	181	215	154	232	203	499	571	70	1313	234	52	241	37	35

ZERO / SPAN CHECK DATA SHEET #15-1

Date: 05/01/03

Analyte: CO₂ (15-1)

Unit: F600

Run #: 4

Zero Cyl. #: 04RTAC 2-A Conc.: 0.00 % CO₂ Cyl. Press.: 900 PSI

Certified by: AIR LIQUIDE

Date: 02-20-02

Span Cyl. #: CC-3131 Conc.: 12.40 % CO₂ Cyl. Press.: 1625 PSI

Certified by: AIR LIQUIDE

Date: 03-13-03

Analyzer: Make: HORIBA

Model: PIR-2000

SN: 407069

Range: 0 - 25.0 % CO₂

Analyzer Output: 0 - 1.0 v.

Flow: 1.5 SCFH

Measured by: Rotameter

EPA Span Value = 25.0 % CO₂

EPA Control Limits = $\pm 2.5\%$ of 25.0 % CO₂ = $\pm 0.625 % CO_2$

Method 28 A = $\pm .2 %$ of 25.0 % CO₂ = $\pm .05 % CO_2$

PRE RUN Audit: by: A. Washington Time: 1255 Temp: 67 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	7.023	7.023	7.091
SPAN	49.6	.496	12.40	49.6	.496	12.367	7.033	7.133

POST RUN Audit: by: A. Washington Time: 2030 Temp: 72 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	1.002	7.002	7.009
SPAN	49.6	.496	12.40	49.7	.497	12.392	7.008	7.033

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05/01/03

Analyte : O₂ (15-2)

Unit : F600

Run # : 4

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂

Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % O₂

Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE

Date : 03-13-03

Analyzer : Make : TELEDYNE Model : 320 A

SN : 37400

Range : 0 - 25.0 % O₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % O₂

EPA Control Limits = ± 2.5% of 25.0 % O₂ = ± 0.625 % O₂

Method 28 A = ± .2 % of 25.0 % O₂ = ± .05 % O₂

PRE RUN Audit : by : A. Whittington Time : 1255 Temp : 67 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.025	+0.025	+1.01
SPAN	12.50	.500	12.50	12.55	.501	12.526	+0.026	+1.05

POST RUN Audit : by : A. Whittington Time : 2030 Temp : 72 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.050	+0.050	+2.01
SPAN	12.50	.500	12.50	12.50	.500	12.051	+0.001	+0.006

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date: 05/01/03 Analyte: CO (15-3)
 Unit: F600 Run #: 4
 Zero Cyl. #: 042TAC 2-A Conc.: 0.00 % CO Cyl. Press.: 900 PSI
 Certified by: AIR LIQUIDE Date: 02-20-02
 Span Cyl. #: CC-3131 Conc.: 12.40 % CO Cyl. Press.: 1625 PSI
 Certified by: AIR LIQUIDE Date: 03-13-03
 Analyzer: Make: HORIBA Model: PIR-2000 SN: 408005
 Range: 0 - 10.0 % CO Analyzer Output: 0 - 1.0 v.
 Flow: 1.5 SCFH Measured by: Rotameter

EPA Span Value = 10.0 % CO
 EPA Control Limits = $\pm 2.5\%$ of 10.0 % CO = $\pm 0.25 % CO$
 Method 28 A = $\pm .2\%$ of 10.0 % CO = $\pm .02 % CO$

PRE RUN Audit: by: A. Wadsworth Time: 1255 Temp: 67 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.011	+0.011	+0.110
SPAN	50.2	.502	5.02	50.3	.503	5.040	+0.020	+0.197

POST RUN Audit: by: A. Wadsworth Time: 2030 Temp: 72 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.001	+0.001	+0.010
SPAN	50.2	.502	5.02	50.2	.502	5.030	+0.010	+0.097

$\pm \text{Conc. Difference} = \text{Act \%} - \text{Exp (Std) \%}$
 $\text{Zero \% Difference} = \frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 $\text{Span \% Difference} = \frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05/01/03

Analyte : SO₂ (15-4)

Unit : F600 Run # : 4

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE Date : 02-20-02

Span Cyl. # : CC6284 Conc. : 1290 ppm SO₂ Cyl. Press. : 1025 PSI

Certified by : AIR LIQUIDE Date : 01-29-01

Analyzer : Make : HORIBA Model : PIR-2000 SN : 403019
 Range : 0 - 2500 ppm SO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = ± 2.5% of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : A. Wadler Time : 1250 Temp : 68 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.2	.002	11.696	+11.696	+468
SPAN	51.6	.516	1290	51.8	.518	1295.028	+5.028	+201

POST RUN Audit : by : A. Wadler Time : 2030 Temp : 72 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	9.209	+9.209	+368
SPAN	51.6	.516	1290	51.7	.517	1292.541	+2.541	+102

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : FLUO RUN : 4 DATE : 5-5-03

Thermocouple Check:

T/C # 1	<u>—</u>	°F	T/C # 13	<u>53.8</u>	°F
T/C # 2	<u>—</u>	°F	T/C # 14	<u>53.5</u>	°F
T/C # 3	<u>54.0</u>	°F	T/C # 15	<u>54.0</u>	°F
T/C # 4	<u>50.8</u>	°F	T/C # 16	<u>52.2</u>	°F
T/C # 5	<u>49.8</u>	°F	T/C # 17	<u>52.8</u>	°F
T/C # 6	<u>49.6</u>	°F	T/C # 18	<u>55.3</u>	°F
T/C # 7	<u>49.6</u>	°F	T/C # 19	<u>52.5</u>	°F
T/C # 8	<u>49.4</u>	°F	T/C # 20	<u>—</u>	°F
T/C # 9	<u>50.0</u>	°F	T/C # 21	<u>—</u>	°F
T/C # 10	<u>50.4</u>	°F	T/C # 22	<u>—</u>	°F
T/C # 11	<u>49.6</u>	°F	T/C # 23	<u>52.0</u>	°F
T/C # 12	<u>56.3</u>	°F	T/C # 24	<u>—</u>	°F

Thermocouple Readout:

Pretest zero and span check and calibration		post test zero and span		% difference
ZERO	<u>-2.6</u> °F Adj. to <u>0.0</u> °F	ZERO	<u>1.6</u> °F	Difference <u>.080</u> % ✓
SPAN	<u>2001.6</u> °F Adj. to <u>2000.0</u> °F	SPAN	<u>2002.3</u> °F	Difference <u>.115</u> % ✓


Thermocouple Readout Pretest Linearity Check:

0 = <u>0.0</u> °F	200 = <u>201.7</u> °F	400 = <u>399.6</u> °F
600 = <u>601.3</u> °F	800 = <u>801.5</u> °F	1000 = <u>1000.6</u> °F
1200 = <u>1198.2</u> °F	1400 = <u>1399.1</u> °F	1600 = <u>1599.7</u> °F
1800 = <u>1800.0</u> °F	2000 = <u>2000.0</u> °F	

Sample Train Leak Check	Pre <u>X</u>	Post <u>X</u>
C-gas Train Leak Check	Pre <u>✓</u>	Post <u>✓</u>
SO ₂ Train Leak Check	Pre <u>✓</u>	Post <u>✓</u>
Static Gauge Zero Check	Pre <u>X</u>	Post <u>✓</u>

Scale Check Pre : 5.8 - 15.8 ✓
 Post : 3.5 - 13.5 ✓

Stack Cleaned Prior to Test Run : YES _____ NO X



COMPUTER INPUT DATA SHEET #1

Client: JOTUL USA, INC.

Address: 400 RIVERSIDE ST. / P.O. BOX 1157
PORTLAND, ME 04104

Phone: 800-797-5912 Fax: 207-797-6072

Run No.: 1 Date of Test: 04-29-03 Burn Rate: 1.863

Model No.: F600 min min-1.25 fan

Stove Type: Cat Non Cat Pellet 1.25-1.9 max insert

Dry Gas Meter Y Factor: 1.990 Post Leak Rate: .004 cfm Time: 215 min.
(0.000) (Data Sheet #2) (.000) (Data Sheet #2) (000) (Data Sheet #2)

Dry Gas Meter Volume: 70.692 cf
(00.000) (Data Sheet #2)

Stack Flow: 9.279 dscfm Δ H: .153 in. H₂O
(00.000) (Data Sheet #2) (.000) (Data Sheet #2)

Maximum Vac.: 3.0 Barometric Pressure: 29.85 in. Hg
(0.0) (Data Sheet #2) (00.00) (Data Sheet #2)

H₂O Captured: 119.5 g
(00.0) (Data Sheet #3)

Front Half Catch % Of Total: 40.2 % Total Particulate Catch: .2972 g
(00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)

Flue Gas Moisture: 7.7941 %
(00.000) (Data Sheet #7)

Particulate Emission: .0689 gr/dscf
(0.0000) (Data Sheet #7)

Relative Humidity: 46.5 % RH Ambient Moisture: 1.6 % H₂O
(00.0) (Data Sheet #8) (0.00) (Data Sheet #8)

Preburn Fuel Wt.: 56.0 lbs. Coal Bed Wt.: 4.2 lbs. Test Fuel Wt.: 17.9 lbs.
(00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)

Heat Output (EPA Default): 22,462.0 BTU/hr
(00,000.0) (Data Sheet #8)

Kindling Fuel % Moisture (wet): 16.504 % Pretest Fuel % Moisture (wet): 17.369 %
(00.000) (Data Sheet #10) (00.000) (Data Sheet #10)

Test Fuel % Moisture (dry): 21.639 % Test Fuel % Moisture (wet): 17.789 %
(00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])

Fuel Higher Heating Value (dry): - BTU/lb.
(0000) (Data Sheet #11)

Stack Static Pressure: .040 in. H₂O
(+/- .000) (Data Sheet #12)

Average Ambient Temperature: 77 °F Stove Temperature Change: -47.3 °F
(00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul

TEST No. : 1

MODEL: F600

DATE: 29-Apr-03

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
0	324.000	0.150	88	0.60	2.10	375
5	325.500	0.340	85	0.61	11.30	250
10	327.810	0.170	85	0.60	8.00	350
15	329.461	0.150	83	0.76	8.20	375
20	330.991	0.170	83	0.66	11.50	350
25	332.630	0.170	83	0.69	12.80	350
30	334.269	0.150	83	0.91	13.30	375
35	335.799	0.120	87	1.17	13.70	425
40	337.169	0.110	90	1.08	12.80	425
45	338.554	0.110	90	0.98	12.60	425
50	339.939	0.110	92	0.95	12.80	425
55	341.324	0.110	92	0.90	12.90	425
60	342.709	0.110	92	0.94	12.90	425
65	344.095	0.130	91	0.70	12.10	400
70	345.573	0.130	91	0.54	11.60	400
75	347.050	0.140	93	0.48	11.60	375
80	348.637	0.140	94	0.43	11.60	375
85	350.231	0.140	95	0.45	12.10	375
90	351.829	0.160	95	0.42	10.10	350
95	353.542	0.160	96	0.36	8.50	350
100	355.261	0.140	96	0.79	6.70	375
105	356.866	0.140	97	1.02	6.50	375
110	358.477	0.140	97	1.03	6.50	375
115	360.087	0.160	97	0.99	6.60	350
120	361.812	0.160	97	1.05	6.60	350
125	363.543	0.160	97	1.21	6.00	350
130	365.273	0.160	97	1.24	5.90	350
135	367.004	0.160	97	1.29	5.90	350
140	368.734	0.160	97	1.28	6.10	350
145	370.465	0.160	97	1.35	6.20	350
150	372.195	0.160	97	1.33	6.20	350
155	373.926	0.160	97	1.41	5.90	350
160	375.656	0.160	97	1.48	5.80	350
165	377.387	0.160	97	1.39	5.80	350
170	379.117	0.160	97	1.30	5.80	350
175	380.848	0.160	97	1.29	5.90	350
180	382.578	0.160	97	1.27	6.00	350
185	384.309	0.160	97	1.33	5.80	350
190	386.039	0.160	97	1.34	5.70	350
195	387.770	0.160	97	1.40	5.70	350
200	389.500	0.160	97	1.42	5.60	350
205	391.231	0.160	97	1.39	5.60	350
210	392.961	0.160	97	1.50	5.50	350
215	394.692	0.160	97	1.61	5.20	350

TABLE 2---RAW DATA

CLIENT :	Jotul	TEST No.	1
MODEL:	F600	DATE:	29-Apr-03

METER CAL. FACTOR (Y)	----- 0.99	Wt. WOOD BURNED (LB)	----- 17.9 Lbs
BAROMETRIC PRESS. (Pb)	----- 29.85 in Hg	WET, FUEL MOISTURE %	----- 17.789 %
LEAK RATE POST (Lp)	----- 0.004 cfm	Wt. PART. COLLECTED	----- 0.2972 g
WATER VOL. (V1c)	----- 119.5 Ml	METER VOLUME Vm	----- 70.692 mcf
TEST TIME (MIN)	----- 215 min	HC MOLE FRACTION	----- 0.0132

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul

TEST No. 1

MODEL: F600

DATE: 29-Apr-03

AVG DELTA		AVG PRCNT		
H	----- 0.15 in H2O	CO	----- 1.02	%
AVG METER		AVG PRCNT		
TEMP. Tm	----- 94 deg F	CO2	----- 8.32	%
AVG PPM		AVG BAL		
SO2	----- 365 PPM	CO2/CO	----- 8.14	%

TABLE 4 ----- CALCULATIONS

CLIENT : Jotul

TEST No. 1

MODEL: F600

DATE: 29-Apr-03

STD SAMPLE		STACK GAS		
VOL. Vm(std) -----	66.64 dscf	FLOW Qsd -----	629.550	dscf/Hr
				&
			10.49	dscf/min
VOL. WATER		PARTICULATE		
VAPOR Vw(std) ----	5.625 scf	CONCTR. Cs -----	0.0045	g/dscf
PRCNT		PARTC. EMISS.		
MSTR Bws -----	7.78 %	RATE E -----	2.81	g/Hr
BURN		MOLES OF GAS		
RATE BR -----	1.86 Kg/Hr	PER Lb WOOD Nt --	0.40	Lb-mole/Lb
CO EMISSION		PART. EMISS.		
RATE -----	215.33 g/Hr	RATE -----	1.51	g/Kgdry
	&			fuel
	115.58 g/Kgdry			
	fuel			

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul

TEST No. : 1

MODEL: F600

DATE: 29-Apr-03

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	537.1	96	100
10	553.2	98	
15	554.3	99	
20	551.3	98	
25	551.3	98	
30	551.3	98	
35	549.3	98	
40	553.8	99	
45	558.4	99	
50	557.4	99	
55	556.3	99	
60	556.3	99	
65	557.2	99	
70	559.8	100	
75	558.4	99	
80	561.0	100	
85	562.5	100	
90	563.4	100	
95	563.2	100	
100	564.6	100	
105	564.3	100	
110	565.9	101	
115	565.6	101	
120	565.6	101	
125	567.6	101	
130	567.2	101	
135	567.6	101	
140	567.2	101	
145	567.6	101	
150	567.2	101	
155	567.6	101	
160	567.2	101	
165	567.6	101	
170	567.2	101	
175	567.6	101	
180	567.2	101	
185	567.6	101	
190	567.2	101	
195	567.6	101	
200	567.2	101	
205	567.6	101	
210	567.2	101	
215	567.6	101	
220			

METER BOX DATA SHEET PAGE # 2

Page: 1 of 2

UNIT: F600 RUN: 1

DATE: 4-29-03

Meter Box: 5H Y Factor: 1.990

Leak checks: 16, " Hg @ .008 cfm _____ " Hg @ _____ cfm

15 " Hg @ .004 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.16</u>			SAMPLING RATIO: <u>30</u> : 1				BP: <u>29.90</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
0	1230	324.000	—	9.073	.15	88	375	88	1.0	
5	35	325.500	—	13.684	.34	85	250	85	3.0	
10	40	327.810	327.810	9.774	.17	85	350	85	1.0	
15	45	329.461	329.461	9.156	.15	83	375	83	1.0	
20	50	330.991	330.991	9.810	.17	83	350	83	1.0	
25	55	332.630	332.630	9.810	.17	83	350	83	1.0	
30	1300	334.269	334.269	9.156	.15	83	375	83	1.0	
35	05	335.799	335.799	8.020	.12	87	425	87	1.0	
40	10	337.169	337.169	7.976	.11	90	425	90	1.0	
45	15	338.554	338.554	7.976	.11	90	425	90	1.0	
50	20	339.939	339.939	7.947	.11	92	425	92	1.0	
55	25	341.324	341.324	7.947	.11	92	425	92	1.0	
ROTO PRESS: <u>.16</u>			TOTALS: 110.329			1.86	1041	BP: <u>29.89</u>		
60	1330	342.709	342.709	7.945	.11	92	425	92	1.0	
65	35	344.095	344.095	8.456	.13	91	400	91	1.0	
70	40	345.573	345.573	8.456	.13	91	400	91	1.0	
75	45	347.050	347.050	8.988	.14	93	375	93	1.0	
80	50	348.637	348.637	8.971	.14	94	375	94	1.0	
85	55	350.231	350.231	8.955	.14	95	375	95	1.0	
90	1400	351.829	351.829	9.595	.16	95	350	95	1.0	
95	05	353.542	353.542	9.578	.16	96	350	96	1.0	
100	10	355.261	355.261	8.939	.14	96	375	96	1.0	
105	15	356.866	356.866	8.923	.14	97	375	97	1.0	
110	20	358.477	358.477	8.923	.14	97	375	97	1.0	
115	25	360.087	360.087	9.566	.16	97	356	97	1.0	
			TOTALS: 107.289			1.69	1134	MAX VACC =		
TOTAL Cu Ft.			TOTALS: 217.618			3.55	2175	AVG. BP:		

METER BOX DATA SHEET PAGE # 2

Page: 2 of 2

UNIT: F600 RUN: 1

DATE: 4-29-03

Meter Box: SH Y Factor: .990

Leak checks: 16 " Hg @ .008 cfm _____ " Hg @ _____ cfm

15 " Hg @ .004 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO: PRESS: <u>.16</u>			SAMPLING RATIO: <u>30</u> : 1				BP: <u>29.80</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
120	1430	361.812	361.812	9.532	.16	97	350	97	1.0
125	35	363.543	363.543	9.532	.16	97	350	97	1.0
130	40	365.273	365.273	9.532	.16	97	350	97	1.0
135	45	367.004	367.004	9.532	.16	97	350	97	1.0
140	50	368.734	368.734	9.532	.16	97	350	97	1.0
145	55	370.465	370.465	9.532	.16	97	350	97	1.0
150	1500	372.195	372.195	9.532	.16	97	350	97	1.0
155	05	373.926	373.926	9.532	.16	97	350	97	1.0
160	10	375.656	375.656	9.532	.16	97	350	97	1.0
165	15	377.387	377.387	9.532	.16	97	350	97	1.0
170	20	379.117	379.117	9.532	.16	97	350	97	1.0
175	25	380.848	380.848	9.532	.16	97	350	97	1.0
ROTO PRESS: <u>.16</u>			TOTALS: <u>114.304</u>		<u>1.92</u>	<u>1164</u>	BP: <u>29.80</u>		
180	1530	382.578	382.578	9.532	.16	97	350	97	1.0
185	35	384.309	384.309	9.532	.16	97	350	97	1.0
190	40	386.039	386.039	9.532	.16	97	350	97	1.0
195	45	387.770	387.770	9.532	.16	97	350	97	1.0
200	50	389.500	389.500	9.532	.16	97	350	97	1.0
205	55	391.231	391.231	9.532	.16	97	350	97	1.0
210	1100	392.961	392.961	9.532	.16	97	350	97	1.0
215	05	394.692	394.692	9.532	.16	97	350	97	1.0
220	10			76.256	1.28	776			
225	15								
230						4115			
235				408.258	6.75		44		
			TOTALS:			94	MAX VACC =		3.0
TOTAL Cu Ft.		<u>70.692</u>	TOTALS:		<u>9.279</u>	<u>.153</u>	<u>554</u>	AVG. BP: <u>29.85</u>	

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT: FLOW RUN: 1 DATE: 4-29-03

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	715.9	579.0	485.8	857.8
INITIAL WT	615.3	573.1	483.6	847.0
NET WT GRAMS	100.6	5.9	2.2	10.8

TOTAL CATCH: 119.5 GRAMS H₂O

FRONT HALF

FILTER #	148F	
FINAL WT g	.7781	✓
INITIAL WT g	.6960	✓
NET WT g	.0821	✓

BEAKER #	1
DESC.	ACETONE
FINAL WT g	104.9557 ✓
INITIAL WT g	104.9174 ✓
NET WT g	.0383 ✓
VOL. DESC. ml	130 ✓

BACK HALF

FILTER #	148B	
FINAL WT g	.4603 ✓	
INITIAL WT g	.4400 ✓	
NET WT g	.0203 ✓	

BEAKER #	2	3	4	5	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	106.3414	107.8011	108.7999	97.4616	
INITIAL WT g	106.2538	107.7777	108.7740	97.4366	
NET WT g	.0876	.0234	.0259	.0250	.0509
VOL. DESC ml	140	75	150	150	(300)

BEAKER TARE WEIGHTS DATA SHEET #4-2

Into Dessicator: Date: 08-19-2002 Time: 1205 By: Jan

BEAKER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME
1	104.9172	1043	104.9174	0704	Total Floor R-1	
2	106.2542	1044	106.2538	0705		
3	107.7782	1046	107.7777	0706		
4	108.7744	1047	108.7740	0708		
5	97.4390	1048	97.4366	0709		
6	91.2080	1050	91.2076	0710	Total Floor R-3	
7	97.1385	1051	97.1382	0711		
8	108.6356	1052	108.6357	0713		
9	108.0961	1053	108.0960	0714		
10	105.7310	1055	105.7306	0715		
11	104.7892	1056	104.7887	0717	Total Floor R-4	
12	98.2303	1057	98.2304	0718		
13	104.1788	1059	104.1784	0719		
14	97.9822	1100	97.9819	0721		
15	104.7644	1101	104.7642	0722		
16	95.7427	1102	95.7429	0723	Total Floor R-5	
17	104.5948	1104	104.5944	0724		
18	108.8626	1105	108.8623	0725		
19	106.5473	1106	106.5468	0726		
20	108.5936	1108	108.5932	0728		

SCALE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	DB	% RH	
08-22	1040	Jan	78	49	Checked by: <u>Chp Wadsworth</u>
08-23	0700	Jan	78	49	
					Time: <u>0910</u>

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: F600

RUN: 1

DATE: 4-29-03

Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
1	04/30	2145	BK	104.9553	05/06	2138	BK	104.9557	05/09	0717	BK
2	04/30	2145	BK	106.3400	05/06	2139	BK	106.3412	05/09	0718	BK
3	04/30	2145	BK	107.8004	05/06	2141	BK	107.8012	05/09	0719	BK
4	04/30	2145	BK	108.8005	05/06	2142	BK	108.7997	05/09	0720	BK
5	04/30	2145	BK	97.4632	05/06	2143	BK	97.4621	05/09	0722	BK
				97.4616	05/11	1213	BK				

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
148F	4-29	1635	CP	.7799	04/30	2303	BK	.7785	05/02	1132	BK
148B	4-29	1635	CP	.4628	04/30	2304	BK	.4608	05/02	1133	BK
				.4103	05/09	0723	BK				

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	04/30	2300	BK	75	47
2	05/02	1130	BK	77	49
3	05/06	2135	BK	77	46
4	05/09	0715	BK	77	45
5	05/10	1435	BK	78	47

Weighing Session	Date	Time	By	DB	%RH
6	05/11	1210	BK	77	46
7					
8					
9					
10					

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET


Dates: From 05-18-2002 Through 10-27-2002	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9999	10.0000	.9999	.0999	AKW	05-18	1905	77	49
99.9997	9.9998	.9999	.0998	AKW	05-19	1500	77	48
99.9999	10.0000	.9998	.0999	AKW	05-20	0855	77	47
99.9998	9.9998	1.0000	.0999	AKW	05-21	0930	78	49
99.9998	9.9999	1.0000	.1000	AKW	05-22	1155	78	48
99.9999	9.9999	1.0000	.1001	AKW	05-22	1920	78	49
99.9999	10.0001	1.0001	.0998	AKW	05-23	2105	77	48
99.9998	9.9998	.9998	.0999	AKW	05-28	1225	78	49
99.9998	9.9997	1.0001	.0999	AKW	05-28	1625	78	47
99.9997	10.0001	1.0002	.1000	AKW	06-27	1950	78	49
99.9998	10.0001	1.0002	.1001	AKW	06-29	1830	78	49
99.9997	9.9999	1.0000	.0998	AKW	07-01	0845	77	49
100.0000	9.9999	1.0002	.1000	AKW	07-01	2220	78	47
99.9998	10.0000	.9999	.0999	AKW	08-14	1130	78	49
100.0001	9.9999	1.0000	.1000	AKW	08-16	1045	78	49
100.0000	9.9998	1.0000	.0998	AKW	08-22	1040	78	49
99.9997	9.9999	.9999	.0997	AKW	08-23	0700	78	49
99.9998	10.0000	1.0000	.0998	AKW	08-29	0915	78	49
100.0000	10.0000	1.0002	.1001	AKW	08-29	2225	78	49
99.9998	9.9999	1.0001	.0998	AKW	09-03	1120	78	49
99.9997	9.9998	.9999	.0998	AKW	09-03	2230	78	49
100.0000	10.0001	.9999	.0999	AKW	09-05	1915	78	49
99.9999	9.9999	1.0000	.0999	AKW	09-06	1815	78	48
99.9997	9.9999	1.0000	.0998	AKW	09-07	1355	78	47
100.0000	10.0002	.9998	.0997	Chp	9-10	1110	77	42
99.9997	10.0002	1.0000	.0100	Chp	9-11	1500	74	47
99.9999	9.9999	1.0000	.0997	Chp	9-13	2020	76	38
100.0003	10.0002	1.0002	.0998	Chp	9-14	1300	76	41
100.0000	10.0001	1.0000	.0999	Chp	9-16	1930	74	44
100.0000	9.9999	.9998	.0999	Chp	9-17	1710	77	42
100.0000	10.0001	1.0000	.1000	Chp	9-19	1000	74	47
100.0001	10.0000	.9998	.0999	Chp	9-20	1115	74	44
99.9998	9.9999	1.0001	.0999	AKW	10-18	2155	77	44
99.9997	9.9999	1.0000	.1000	AKW	10-22	2255	77	46
100.0001	10.0002	1.0000	.0999	AKW	10-23	2815	77	42
99.9997	9.9998	.9999	.1000	AKW	10-25	1350	77	43
99.9998	9.9999	1.0000	.1000	AKW	10-26	1735	77	41
99.9998	9.9998	.9999	.1000	AKW	10-27	1130	77	36
99.9998	9.9999	.9999	.0999	AKW	10-27	1435	77	38

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates: From 12-05-2002 Through 02-23-2003	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9997	9.9998	1.0000	.0997	JKL	12-05	1825	77	47
99.9998	10.0000	.9999	.1000	JKL	12-06	1125	77	45
99.9997	10.0001	1.0000	.1000	JKL	12-07	1310	76	41
99.9997	10.0001	1.0000	.0999	JKL	12-08	1430	77	44
99.9998	9.9999	1.0001	.0999	JKL	12-09	1125	78	44
99.9998	10.0000	.9999	.0998	JKL	12-10	1220	78	43
99.9997	10.0000	.9998	.0998	JKL	12-11	1650	77	45
99.9997	10.0001	.9999	.0999	JKL	12-12	1445	77	47
99.9998	10.0000	.9999	.1000	JKL	12-14	1530	78	47
99.9997	10.0000	1.0000	.0999	JKL	01-10	2300	78	48
99.9998	9.9999	1.0001	.1000	JKL	01-14	1115	77	48
99.9999	10.0000	.9999	.1000	JKL	01-15	1705	77	48
99.9999	10.0001	.9999	.0998	JKL	01-16	1830	78	46
99.9997	10.0000	1.0000	.0999	JKL	01-17	1215	77	41
99.9997	9.9999	1.0000	.0999	JKL	01-17	2035	76	42
99.9996	10.0000	.9999	.0999	JKL	01-18	1730	77	43
99.9999	9.9999	.9998	.0999	JKL	01-19	1210	76	42
99.9998	10.0000	1.0000	.0999	JKL	01-20	2105	76	44
99.9999	10.0000	.9999	.0998	JKL	01-21	0935	75	44
99.9998	10.0000	.9999	.0999	JKL	01-22	1125	77	46
100.0000	9.9998	.9999	.1000	JKL	01-23	1430	77	48
99.9999	10.0001	1.0001	.1000	JKL	01-24	1200	76	48
99.9998	9.9999	.9999	.0999	JKL	01-25	1140	76	47
99.9997	10.0000	1.0000	.0999	JKL	01-25	1850	78	48
99.9998	9.9998	1.0000	.1000	JKL	01-27	1415	75	47
99.9999	9.9999	1.0000	.1000	JKL	01-30	1920	77	48
99.9998	10.0000	.9998	.0999	JKL	01-31	2205	78	47
99.9999	9.9998	.9998	.1000	JKL	02-01	1855	77	47
99.9997	9.9998	.9999	.1001	JKL	02-02	1420	76	46
99.9997	10.0001	.9998	.0999	JKL	02-18	1155	77	49
99.9999	9.9999	.9999	.0999	JKL	02-19	1925	77	48
99.9997	10.0000	1.0000	.0999	JKL	02-22	2010	78	45
99.9997	10.0000	.9999	.1000	JKL	02-23	1130	78	44
								

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates: From 05-18-2002 Through 10-27-2002	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9999	10.0000	.9999	.0999	AKW	05-18	1905	77	49
99.9997	9.9998	.9999	.0998	AKW	05-19	1500	77	48
99.9999	10.0000	.9998	.0999	AKW	05-20	0855	77	47
99.9998	9.9998	1.0000	.0999	AKW	05-21	0930	78	49
99.9998	9.9999	1.0000	.1000	AKW	05-22	1155	78	48
99.9999	9.9999	1.0000	.1001	AKW	05-22	1920	78	49
99.9999	10.0001	1.0001	.0998	AKW	05-23	2105	77	48
99.9998	9.9998	.9998	.0999	AKW	05-28	1225	78	49
99.9998	9.9997	1.0001	.0999	AKW	05-28	1625	78	47
99.9997	10.0001	1.0002	.1000	AKW	06-27	1950	78	49
99.9998	10.0001	1.0002	.1001	AKW	06-29	1830	78	49
99.9997	9.9999	1.0000	.0998	AKW	07-01	0845	77	49
100.0000	9.9999	1.0002	.1000	AKW	07-01	2220	78	47
99.9998	10.0000	.9999	.0999	AKW	08-14	1130	78	49
100.0001	9.9999	1.0000	.1000	AKW	08-16	1045	78	49
100.0000	9.9998	1.0000	.0998	AKW	08-22	1040	78	49
99.9997	9.9999	.9999	.0997	AKW	08-23	0700	78	49
99.9998	10.0000	1.0000	.0998	AKW	08-29	0915	78	49
100.0000	10.0000	1.0002	.1001	AKW	08-29	2225	78	49
99.9998	9.9999	1.0001	.0998	AKW	09-03	1120	78	49
99.9997	9.9998	.9999	.0998	AKW	09-03	2230	78	49
100.0000	10.0001	.9999	.0999	AKW	09-05	1915	78	49
99.9999	9.9999	1.0000	.0999	AKW	09-06	1815	78	48
99.9997	9.9999	1.0000	.0998	AKW	09-07	1355	78	47
100.0000	10.0002	.9998	.0997	Chp	9-10	1110	77	42
99.9997	10.0002	1.0000	.0100	Chp	9-11	1500	74	47
99.9999	9.9999	1.0000	.0997	Chp	9-13	2020	76	38
100.0003	10.0002	1.0002	.0998	Chp	9-14	1300	76	41
100.0000	10.0001	1.0000	.0999	Chp	9-16	1930	74	44
100.0000	9.9999	.9998	.0999	Chp	9-17	1710	77	42
100.0000	10.0001	1.0000	.1000	Chp	9-19	1000	74	47
100.0001	10.0000	.9998	.0999	Chp	9-20	1115	74	44
99.9998	9.9999	1.0001	.0999	AKW	10-18	2155	77	44
99.9997	9.9999	1.0000	.1000	AKW	10-22	2255	77	46
100.0001	10.0002	1.0000	.0999	AKW	10-23	2815	77	42
99.9997	9.9998	.9999	.1000	AKW	10-25	1350	77	43
99.9998	9.9999	1.0000	.1000	AKW	10-26	1735	77	41
99.9998	9.9998	.9999	.1000	AKW	10-27	1130	77	36
99.9998	9.9999	.9999	.0999	AKW	10-27	1435	77	38

BLANK PROCESSING DATA SHEET # 5

UNIT: F600 RUN: 1 DATE: 04/29/03

DATE BLANKS DONE: 02-23-03

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	DWNA, INC. SPARKLETES DISTILLED
FINAL WEIGHT	108.9007	106.3074	106.9660
TARE WEIGHT	108.8995	106.3057	106.9646
NET WEIGHT	.0012 ✓	.0017 ✓	.0014 ✓

TARE BEAKERS INTO DESC : TIME : 1430 DATE : 02-12-03

DATE : 02-18 BY: BR DATE : 02-19 BY: BR DATE : _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.8996	1158	108.8995	1928	✓	
B	106.3060	1159	106.3057	1930	✓	
C	106.9649	1200	106.9646	1931	✓	

FINAL BEAKERS INTO DESC : TIME : 1600 DATE : 02-20-03

DATE : 02-22 BY: BR DATE : 02-23 BY: BR DATE : _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9010	2013	108.9007	1132	✓	
B	106.3078	2015	106.3074	1133	✓	
C	106.9661	2016	106.9660	1134	✓	

TARE QC

DATE	TIME	BY	WB	DB	%
02-18	1155	BR	}	77	49
02-19	1925	BR		77	48

FINAL QC

DATE	TIME	BY	WB	DB	%
02-22	2010	BR	}	78	45
02-23	1130	BR		78	44

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: F600 RUN: 1 DATE: 04/29/03

BLANK CALCULATIONS

Acetone : $\frac{.0012 \text{ g}}{200 \text{ ml}} = .000006 \text{ g/ml}$ ✓
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = .000023 \text{ g/ml}$ ✓
 Distilled Water : $\frac{.0014 \text{ g}}{200 \text{ ml}} = .000007 \text{ g/ml}$ ✓

FRONT HALF CATCH

FILTERS : $\frac{.0821 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ (# of Filters)} \times (.0000 \text{ g})}{\text{Blank Value / Filter}} = .0821 \text{ g}$ ✓
 BEAKERS : $\frac{.0383 \text{ g}}{\text{Total Catch}} - \frac{130 \text{ ml Acetone} \times (.000006 \text{ g})}{\text{Blank Value / ml Acetone}} = .0375 \text{ g}$ ✓
TOTAL FRONT HALF CATCH : .1196 g ✓

BACK HALF CATCH

FILTERS : $\frac{.0203 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ (# of Filters)} \times (.0000 \text{ g})}{\text{Blank Value / Filter}} = .0203 \text{ g}$ ✓
 BEAKERS :
 Acetone : $\frac{.0876 \text{ g}}{\text{Total Catch}} - \frac{140 \text{ ml Acetone} \times (.000006 \text{ g})}{\text{Blank Value / ml Acetone}} = .0868 \text{ g}$ ✓
 Extract : $\frac{.0234 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Dichloromethane} \times (.000023 \text{ g})}{\text{Blank Value / Dichloromethane}} = .0217 \text{ g}$ ✓
 Water : $\frac{.0509 \text{ g}}{\text{Total Catch}} - \frac{300 \text{ ml Water} \times (.000007 \text{ g})}{\text{Blank Value / Water}} = .0488 \text{ g}$ ✓
TOTAL BACK HALF CATCH : .1776 g ✓
TOTAL CATCH : .2972 g ✓
% FRONT HALF : $\frac{.1196}{.2972} = 40.2\%$ ✓
 (00.0)

CALCULATIONS DATA SHEET # 7

UNIT: TOTAL F600 RUN: 1 DATE: 04/28/05

$$1) Vm (std) = \frac{(70.692 Vm)(17.64)(.990 mcf) \left(29.85'' Hg + \frac{.153'' H_2O}{13.6} \right)}{(.554 TmA)} = \frac{66.5430}{000.0000} \text{ dscf}$$

$$2) Vw (std) = (.04707)(119.5 \text{ ml H}_2\text{O}) = \frac{5.6249}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(5.6249 \text{ scf})}{(5.6249 \text{ scf} + 66.5430 \text{ dscf})} = \frac{.0779}{.0000} \text{ Bws} \times 100 = \frac{7.7941}{00.0000} \% H_2O$$

$$4) Cs = \frac{(.2972 \text{ g.})}{(66.5430 \text{ dscf})} (15.43) = \frac{.0689}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(.2972 \text{ g.})}{(66.5430 \text{ dscf})} (9.279 \text{ dscfm}) (60) = \frac{2.4866}{00.0000} \text{ g / hr}$$

Vm =	total cubic feet pulled on meter box during test	(000.000 Vm)
mcf =	meter correction factor (Y factor) of meter box used for test	(0.000 mcf)
" Hg =	average barometric pressure during test	(00.00 " Hg)
" H ₂ O =	average delta H for test	(.000 " H ₂ O)
TmA =	average meter temperature for test in degrees Absolute	(000 TmA)
ml H ₂ O =	total water caught during test	(000.0 ml H ₂ O)
g =	total particulate catch for test	(00.0000 g.)
dscfm =	average stack flow during test	(00.000 dscf)

TEST DATA SHEET # 8

UNIT: FL600 RUN: 1 DATE: 4-29-03

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb
 Pre : WB : 62 DB : 78 = 39 % RH 1.3 % H₂O
 Post : WB : 69 DB : 81 = 54 % RH 1.9 % H₂O
 Average : 46.5 % RH 1.6 % H₂O

Empty Stove Weight (lbs) : _____ w/ stack & oil seal : Wet : — Dry : 0.0

Kindling Weight (lbs) : Paper : .2 Wood : 4.7
 Preburn Fuel Weight : 20.0 + 14.8 + 16.5 Total : 51.3
 Kindling & Preburn Fuel Weight (wood only) (lbs) : Total : 56.0

Coal Bed Wt Range (lbs) : 4.4 - 3.6 Scale : 4.4 - 3.6
 Upper : .25 x fuel weight : Always round DOWN to nearest tenth
 Lower : .20 x fuel weight : Always round UP to nearest tenth Actual Coal Bed Weight : 4.2
 Maximum Coal Bed Removal (lbs) : $(\frac{4.4}{\text{Upper}} + \frac{3.6}{\text{Lower}}) \div 2 \cdot .25 = \underline{1.0}$ round down to nearest tenth

Test Fuel (.75" x 1.5" x 5" spacers) = _____ pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	4	8.4	46.9
4" x 4"	17	2	9.5	53.1

Test Fuel Weight : 17.9 lbs

Estimated Dry Burn Rate :
 $\frac{17.9 - (0.9 \times 1.7789)}{2.2046} \times \frac{60}{215} = \underline{1.863}$ kg / hr

Estimated BTU's/hr : $19,140 \times \frac{63}{100} \times \frac{1.863}{\text{DBR}} = \underline{22,462.0}$ BTU's/hr

EPA Default Efficiencies : Non-cat : 63 Cat : 72 Pellet : 78

10 17

WOOD STOVE OPERATING DATA PAGE #9

Unit: FL600 Run: 1 Date: 4-29-03

FIRE STARTED: 0815

WARM UP AND PREBURN:

PRIMARY AIR: Set wide open for all warm-up / preburn fuel charges. Then set to 1/8" at start of preburn.

SECONDARY AIR: N/A CAT BYPASS: N/A

CHARCOAL BED PREPARATION:

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 30 sec.

TEST:

DOOR wide open during loading 0 min. 30 sec.

PRIMARY AIR: Opened full for first 5 min., then set to run setting of 1/8".

SECONDARY AIR: N/A CAT BYPASS: N/A

FAN:

ON OFF during warm-up

OFF during preburn

ON first 30 minutes of test

OFF balance of test run

Fan speed set at High

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER: N/A BRAND: N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 16" or — inches.

1st warm up / pre-burn fuel charge (20.0 lbs.) added at 0835

2nd warm up / pre-burn fuel charge (14.8 lbs.) added at 0945

3rd warm up / pre-burn fuel charge (16.5 lbs.) added at 1050

4th warm up / pre-burn fuel charge (_____ lbs.) added at _____

5th warm up / pre-burn fuel charge (_____ lbs.) added at _____

TEST DATA SHEET #10

Unit : FL600 Run : 1 Date : 4-29-03
 Room Temperature : 72 °F Correction Factor : 0
 Uncorrected Values are corrected for room temperature : Yes _____ No
 Time Test Fuel moisture reading taken : 1050
 Calibration Checks : X Y 12.0 12.1 22.0 22.1

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	19.5	20.9	18.0	19.2	18.0	19.2	19.767
2									
3									
4	2"x4"x8'	P	20.0	21.4	20.5	22.0	20.0	21.4	21.600
5	2"x4"x8'	P	21.5	23.1	21.5	23.1	21.5	23.1	23.100
6	2"x4"x8'	P	18.0	19.2	18.5	19.8	18.0	19.2	19.400
7	2"x4"x8'	P	20.0	21.4	19.5	20.9	18.0	19.2	20.500
8	2"x4"x8'	P	19.5	20.9	19.0	20.3	19.0	20.3	20.500
9									105.100
10									
11	2x4x17'	T	19.5	20.9	19.5	20.9	19.5	20.9	20.900
12	"	T	19.5	20.9	20.0	21.4	20.0	21.4	21.233
13	"	T	20.0	21.4	20.0	21.4	20.0	21.4	21.400
14	"	T	21.5	23.1	23.0	24.7	23.0	24.7	24.167
15	4x4x17"	T	19.5	20.9	19.5	20.9	20.0	21.4	21.067
16	"	T	20.0	21.4	19.5	20.9	19.5	20.9	21.067
17									129.834
18									
19									
20	Spacers	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	19.767 %	21.020 %	21.639 %
Wet Moisture % :	16.504 %	17.369 %	17.789 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

GAS DATA SHEET #12

WEIGHT: 4.2

DATE: 04/29/03

UNIT: Fluoo

RUN: 1

PAGE: 1 OF 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO ₂ PPM
0 1230	22.1	17.9	-	.085	2.1	.724	18.1	.059	.60	-.034	375
5 35	21.2	17.0	.9	.453	11.3	.356	8.9	.060	.61	-.043	250
10 40	20.6	16.4	.6	.322	8.0	.487	12.2	.059	.60	-.044	350
15 45	19.8	15.6	.8	.328	8.2	.475	11.9	.075	.76	-.045	375
20 50	18.8	14.6	1.0	.462	11.5	.345	8.6	.065	.66	-.048	350
25 55	17.9	13.7	.9	.512	12.8	.293	7.3	.068	.69	-.650	350
30 1300	16.7	12.5	1.2	.533	13.3	.263	6.6	.090	.91	-.051	375
35 05	15.6	11.4	1.1	.548	13.7	.238	6.0	.116	1.171	-.050	425
40 10	14.6	10.4	1.0	.512	12.8	.278	7.0	.107	1.08	-.050	425
45 15	13.7	9.5	.9	.507	12.6	.287	7.2	.097	.98	-.051	425
50 20	12.7	8.5	1.0	.514	12.8	.281	7.0	.094	.95	-.050	425
55 25	11.9	7.7	.8	.516	12.9	.281	7.0	.087	.90	-.051	425
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-.567	*****
60 1330	11.1	6.9	.8	.519	12.9	.276	6.9	.093	.94	-.051	425
65 35	10.3	6.1	.8	.484	12.1	.321	8.0	.089	.90	-.050	400
70 40	9.7	5.5	.6	.466	11.6	.345	8.6	.053	.54	-.049	400
75 45	9.1	4.9	.6	.466	11.6	.348	8.7	.047	.48	-.048	375
80 50	8.5	4.3	.6	.465	11.6	.351	8.8	.042	.43	-.047	375
85 55	7.9	3.7	.6	.487	12.1	.328	8.2	.044	.45	-.047	375
90 1400	7.4	3.2	.5	.406	10.1	.410	10.3	.041	.42	-.046	350
95 05	7.1	2.9	.3	.340	8.5	.479	12.0	.035	.36	-.045	350
100 10	6.9	2.7	.2	.269	6.7	.532	13.3	.078	.79	-.044	375
105 15	6.8	2.6	.1	.261	6.5	.531	13.3	.101	1.02	-.041	375
110 20	6.6	2.4	.2	.263	6.5	.529	13.2	.102	1.03	-.040	375
115 25	6.5	2.3	.1	.266	6.6	.527	13.2	.098	.99	-.038	350
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-.546	*****
120 1430	6.4	2.2	.1	.267	6.6	.524	13.1	.104	1.05	-.037	350
125 35	6.2	2.0	.2	.242	6.0	.543	13.6	.120	1.21	-.037	350
130 40	6.1	1.9	.1	.239	5.9	.545	13.6	.123	1.24	-.036	350
135 45	6.0	1.8	.1	.239	5.9	.543	13.6	.128	1.29	-.035	350
140 50	5.8	1.6	.2	.247	6.1	.535	13.4	.127	1.28	-.035	350
145 55	5.7	1.5	.1	.250	6.2	.529	13.2	.134	1.35	-.035	350
150 1500	5.6	1.4	.1	.247	6.2	.531	13.3	.132	1.33	-.034	350
155 05	5.5	1.3	.1	.236	5.9	.541	13.5	.140	1.41	-.034	350
160 10	5.4	1.2	.1	.234	5.8	.540	13.5	.147	1.48	-.034	350
165 15	5.2	1.0	.2	.234	5.8	.544	13.6	.138	1.39	-.034	350
170 20	5.1	.9	.1	.235	5.8	.546	13.7	.129	1.30	-.033	350
175 25	5.0	.8	.1	.238	5.9	.544	13.6	.128	1.29	-.032	350
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-.416	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	1.529	*****

GAS DATA SHEET #12

WEIGHT: 4.2

DATE: 04/29/03

UNIT: F600

RUN: 1

PAGE: 2 OF 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO ₂ PPM
180 1530	4.9	.7	.1	.240	6.0	.542	13.6	.126	1.27	-031	350
185 35	4.8	.6	.1	.234	5.8	.546	13.6	.132	1.33	-031	350
190 40	4.7	.5	.1	.231	5.7	.549	13.7	.133	1.34	-031	350
195 45	4.6	.4	.1	.230	5.7	.547	13.7	.139	1.40	-031	350
200 50	4.4	.2	.2	.227	5.6	.549	13.7	.141	1.42	-031	350
205 55	4.4	.2	0	.225	5.6	.552	13.8	.138	1.39	-031	350
210 1600	4.3	.1	.1	.221	5.5	.552	13.8	.149	1.50	-031	350
215 05	4.2	0	.1	.209	5.2	.560	14.0	.160	1.61	-031	350
220 10											
225 15											
230 20											
235 25											
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-248	*****
240 1630											
245 35											
250 40											
255 45											
260 50											
265 55											
270 1700											
275 05											
280 10											
285 15											
290 20											
295 25											
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****		*****
300 1730											
305 35											
310 40											
315 45											
320 50											
325 55											
330 1800											
335 05											
340 10											
345 15											
350 20											
355 25											
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-1.777	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-040	*****

244



TEMPERATURE DATA SHEET #14

		TEST TIME	215 ✓		
STACK AVG	277	TOP AVG	340	LT SIDE AVG	347
BACK AVG	224	RT SIDE AVG	336	BOTTOM AVG	232
FIREBOX AVG	696	SEC/CAT AVG	997	AMBIENT AVG	77 ✓

END 250.2
START 297.5 ✓

-47.3 DELTA T

CIRCLE: LOSS / GAIN

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube Furn	Smpl Box	Smpl Out	C-Gas Box	C-Gas Out	SO2 Out
0	232	284	361	220	346	277	678	778	74	1360	245	61	242	37	37
5	376	322	342	293	330	273	555	1268	71	1333	242	54	249	37	37
10	286	334	323	286	312	260	519	1257	70	1314	239	53	248	37	38
15	296	355	308	274	297	253	510	1243	70	1311	237	53	247	36	37
20	327	382	299	265	289	245	518	1238	70	1316	237	53	247	36	37
25	353	417	296	260	285	237	539	1248	70	1321	238	53	248	36	37
30	369	436	301	261	290	231	567	1240	73	1328	241	53	249	36	37
35	380	452	299	189	297	224	597	1253	74	1348	242	54	249	36	37
40	379	456	308	184	306	220	623	1225	75	1378	238	54	249	36	36
45	377	457	317	186	315	213	645	1244	77	1386	238	55	247	36	37
50	376	461	327	189	325	209	672	1265	78	1393	238	56	246	36	37
55	376	467	338	194	335	206	702	1287	76	1388	238	56	247	36	37
60	372	476	350	200	343	202	729	1269	73	1403	235	56	247	38	36
65	366	474	363	208	355	202	754	1273	72	1397	237	57	248	37	38
70	348	455	374	221	367	203	777	1228	78	1382	240	57	247	37	36
75	341	449	388	235	378	202	798	1213	79	1370	242	57	246	38	36
80	335	443	396	247	386	206	813	1202	79	1377	240	57	245	37	36
85	331	439	407	261	394	207	829	1225	80	1375	241	58	244	37	37
90	326	429	415	268	402	210	846	1188	81	1372	243	58	244	37	37
95	308	411	422	266	407	214	846	1123	81	1368	244	58	243	36	37
100	289	389	426	264	409	215	842	1062	81	1365	243	58	242	36	35
105	272	370	425	257	405	221	839	997	82	1357	240	58	242	36	35
110	260	353	417	249	393	225	828	955	81	1346	238	59	241	36	36
115	252	336	411	240	384	228	812	942	81	1338	236	59	240	37	35
120	245	322	404	235	373	228	797	908	81	1332	235	59	240	38	35
125	239	310	393	230	366	234	770	886	81	1328	233	59	239	38	36
130	233	299	382	224	358	236	749	858	80	1323	233	59	238	37	36
135	229	288	373	219	350	236	732	837	80	1319	232	59	237	37	35
140	225	280	360	215	343	237	722	835	81	1318	233	59	238	37	37
145	222	274	350	210	336	239	718	827	80	1317	233	59	238	37	38
150	220	266	345	208	331	239	711	815	80	1320	233	59	239	36	37
155	216	261	338	205	326	239	697	792	80	1326	233	51	241	36	38
160	214	256	332	202	321	240	687	778	79	1329	233	50	241	37	37
165	211	249	325	200	316	240	677	766	79	1329	233	50	242	37	36
170	209	246	321	199	311	240	668	753	78	1329	233	50	242	35	36
175	207	242	316	199	307	241	663	748	79	1327	233	50	242	36	37

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube	Furn	Smpl Box	Smpl Out	C-Gas	Box	C-Gas	Out	SO2	Out
180	205	237	312	198	304	243	664	743	79	1326		234	50	243	243	36	37		
185	203	235	306	199	302	243	659	739	79	1325		234	50	243	243	36	35		
190	202	231	303	199	299	244	649	737	78	1324		234	51	243	243	34	35		
195	201	228	301	198	298	246	645	739	78	1322		233	51	243	243	35	36		
200	200	226	301	198	296	247	646	725	78	1322		233	51	244	244	35	36		
205	199	224	298	197	295	248	643	722	78	1322		233	51	244	244	34	34		
210	198	222	292	196	293	250	641	715	78	1323		233	52	243	243	34	34		
215	196	220	291	196	292	251	636	701	78	1323		233	52	243	243	35	35		

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 04-29-03

Analyte : CO₂ (15-1)

Unit : F600

Run # : 1

Zero Cyl. # : 04RTAC 2-A Conc. : 0.00 % CO₂

Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % CO₂

Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE

Date : 03-13-03

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 407069

Range : 0 - 25.0 % CO₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % CO₂

EPA Control Limits = ± 2.5% of 25.0 % CO₂ = ± 0.625 % CO₂

Method 28 A = ± .2 % of 25.0 % CO₂ = ± .05 % CO₂

PRE RUN Audit : by : A. Wadlington Time : 1125 Temp : 75 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	7.023	-0.023	-0.091
SPAN	49.6	.496	12.40	49.6	.496	12.367	-0.033	-1.33

POST RUN Audit : by : A. Wadlington Time : 1625 Temp : 76 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	7.048	-0.048	-1.91
SPAN	49.6	.496	12.40	49.8	.498	12.417	+0.017	+0.067

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 04-29-03

Analyte : O₂ (15-2)

Unit : F600 Run # : 1

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂ Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % O₂ Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE Date : 03-13-03

Analyzer : Make : TELEDYNE Model : 320 A SN : 37400
 Range : 0 - 25.0 % O₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 25.0 % O₂
 EPA Control Limits = $\pm 2.5\%$ of 25.0 % O₂ = $\pm 0.625 % O_2$
 Method 28 A = $\pm .2 %$ of 25.0 % O₂ = $\pm .05 % O_2$

PRE RUN Audit : by : A. Wadsworth Time : 1125 Temp : 75 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.000	+ .025	+ .101
SPAN	12.50	.500	12.50	12.50	.500	12.501	+ .001	+ .006

POST RUN Audit : by : A. Wadsworth Time : 1625 Temp : 76 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.050	+ .050	+ .201
SPAN	12.50	.500	12.50	12.50	.500	12.501	+ .001	+ .006

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date : 04-29-03 Analyte : CO (15-3)
 Unit : F600 Run # : 1
 Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO Cyl. Press. : 900 PSI
 Certified by : AIR LIQUIDE Date : 02-20-02
 Span Cyl. # : CC-3131 Conc. : 12.40 % CO Cyl. Press. : 1625 PSI
 Certified by : AIR LIQUIDE Date : 03-13-03
 Analyzer : Make : HORIBA Model : PIR-2000 SN : 408005
 Range : 0 - 10.0 % CO Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 10.0 % CO
 EPA Control Limits = $\pm 2.5\%$ of 10.0 % CO = $\pm 0.25 % CO$
 Method 28 A = $\pm .2\%$ of 10.0 % CO = $\pm .02 % CO$

PRE RUN Audit : by : A. Wadlington Time : 1125 Temp : 75 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.011	+0.011	+1.10 ✓
SPAN	50.2	.502	5.02	50.2	.502	5.030	+0.010	+0.97 ✓

POST RUN Audit : by : A. Wadlington Time : 1625 Temp : 76 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.011	+0.011	+1.10 ✓
SPAN	50.2	.502	5.02	50.0	.500	5.010	-0.010	-1.03 ✓

$\pm \text{Conc. Difference} = \text{Act \%} - \text{Exp (Std) \%}$
 $\text{Zero \% Difference} = \frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 $\text{Span \% Difference} = \frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 04-29-03

Analyte : SO₂ (15-4)

Unit : FL600 Run # : 1

Zero Cyl. # : 042JAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE Date : 02-20-02

Span Cyl. # : CC62184 Conc. : 1290 ppm SO₂ Cyl. Press. : 1025 PSI

Certified by : AIR LIQUIDE Date : 01-29-01

Analyzer : Make : HORIBA Model : PIR-2000 SN : 403019
 Range : 0 - 2500 ppm SO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = ± 2.5% of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : D. Wadlington Time : 1115 Temp : 75 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	6.722	+6.722	+2.69 ✓
SPAN	51.6	.516	1290	51.6	.516	1290.054	+.054	+0.02 ✓

POST RUN Audit : by : D. Wadlington Time : 1625 Temp : 76 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	9.209	+9.209	+3.68 ✓
SPAN	51.6	.516	1290	51.5	.515	1287.567	-2.433	-.097 ✓

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : F600 RUN : 1 DATE : 4-29-03

Thermocouple Check:

T/C # 1	<u>—</u>	°F	T/C # 13	<u>62.0</u>	°F
T/C # 2	<u>—</u>	°F	T/C # 14	<u>61.3</u>	°F
T/C # 3	<u>61.5</u>	°F	T/C # 15	<u>62.0</u>	°F
T/C # 4	<u>59.3</u>	°F	T/C # 16	<u>57.6</u>	°F
T/C # 5	<u>58.3</u>	°F	T/C # 17	<u>57.7</u>	°F
T/C # 6	<u>58.4</u>	°F	T/C # 18	<u>62.3</u>	°F
T/C # 7	<u>58.2</u>	°F	T/C # 19	<u>59.9</u>	°F
T/C # 8	<u>58.1</u>	°F	T/C # 20	<u>—</u>	°F
T/C # 9	<u>58.4</u>	°F	T/C # 21	<u>—</u>	°F
T/C # 10	<u>58.4</u>	°F	T/C # 22	<u>—</u>	°F
T/C # 11	<u>57.5</u>	°F	T/C # 23	<u>60.1</u>	°F
T/C # 12	<u>64.4</u>	°F	T/C # 24	<u>—</u>	°F

Thermocouple Readout:

Pretest zero and span check and calibration	post test zero and span	% difference
ZERO <u>1.2</u> °F Adj. to <u>0.0</u> °F	ZERO <u>1.8</u> °F	Difference <u>.090</u> % ✓
SPAN <u>1996.0</u> °F Adj. to <u>2000.0</u> °F	SPAN <u>2003.4</u> °F	Difference <u>.170</u> % ✓


Thermocouple Readout Pretest Linearity Check:

0 = <u>0.0</u> °F	200 = <u>202.0</u> °F	400 = <u>399.2</u> °F
600 = <u>601.5</u> °F	800 = <u>801.6</u> °F	1000 = <u>1000.7</u> °F
1200 = <u>1198.2</u> °F	1400 = <u>1399.2</u> °F	1600 = <u>1599.8</u> °F
1800 = <u>1800.2</u> °F	2000 = <u>2000.0</u> °F	

Sample Train Leak Check	Pre <u>X</u>	Post <u>X</u>
C-gas Train Leak Check	Pre <u>X</u>	Post <u>X</u>
SO ₂ Train Leak Check	Pre <u>X</u>	Post <u>X</u>
Static Gauge Zero Check	Pre <u>X</u>	Post <u>X</u>

Scale Check Pre : 8.3 - 18.3 ✓
 Post : 4.0 - 14.0 ✓

Stack Cleaned Prior to Test Run : YES X NO —



COMPUTER INPUT DATA SHEET #1

Client: JOTUL USA, Inc.
Address: 400 RIVERSIDE ST. / P.O. BOX 1157
PORTLAND, ME 04104
Phone: 800-797-5912 Fax: 207-797-6072
Run No.: 5 Date of Test: 05-06-03 Burn Rate: 2.696
Model No.: FL600 min min-1.25 fan
Stove Type: Cat Non Cat Pellet 1.25-1.9 max insert
Dry Gas Meter Y Factor: .990 Post Leak Rate: .012 cfm Time: 145 min.
(0.000) (Data Sheet #2) (.000) (Data Sheet #2) (000) (Data Sheet #2)
Dry Gas Meter Volume: 36.308 cf
(00.000) (Data Sheet #2)
Stack Flow: 10.707 dscfm Δ H: .093 in. H₂O
(00.000) (Data Sheet #2) (.000) (Data Sheet #2)
Maximum Vac.: 2.0 Barometric Pressure: 29.97 in. Hg
(0.0) (Data Sheet #2) (00.00) (Data Sheet #2)
H₂O Captured: 68.9 g
(00.0) (Data Sheet #3)
Front Half Catch % Of Total: 52.1 % Total Particulate Catch: .1357 g
(00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)
Flue Gas Moisture: 8.6220 %
(00.000) (Data Sheet #7)
Particulate Emission: .0609 gr/dscf
(0.0000) (Data Sheet #7)
Relative Humidity: 25.5 % RH Ambient Moisture: 1.05 % H₂O
(00.0) (Data Sheet #8) (0.00) (Data Sheet #8)
Preburn Fuel Wt.: 51.1 lbs. Coal Bed Wt.: 4.2 lbs. Test Fuel Wt.: 17.7 lbs.
(00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)
Heat Output (EPA Default): 32,510.2 BTU/hr
(00,000.0) (Data Sheet #8)
Kindling Fuel % Moisture (wet): 15.636 % Pretest Fuel % Moisture (wet): 18.055 %
(00.000) (Data Sheet #10) (00.000) (Data Sheet #10)
Test Fuel % Moisture (dry): 23.222 % Test Fuel % Moisture (wet): 18.846 %
(00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])
Fuel Higher Heating Value (dry): - BTU/lb.
(0000) (Data Sheet #11)
Stack Static Pressure: -.042 in. H₂O
(+/- .000) (Data Sheet #12)
Average Ambient Temperature: 78 °F Stove Temperature Change: -97.7 °F
(00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul

TEST No. : 5

MODEL: F600

DATE: 06-May-03

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
0	804.500	0.150	87	0.45	8.00	250
5	806.000	0.100	89	0.38	11.00	300
10	807.300	0.090	89	0.53	9.30	325
15	808.500	0.090	90	0.46	10.80	325
20	809.704	0.080	91	0.54	12.30	350
25	810.827	0.070	92	0.89	13.10	375
30	811.878	0.060	93	0.81	12.90	375
35	812.933	0.060	94	1.28	13.90	400
40	813.926	0.050	94	1.34	13.80	425
45	814.861	0.070	94	0.78	12.90	350
50	815.995	0.090	94	0.61	12.20	325
55	817.217	0.090	94	0.55	12.50	325
60	818.439	0.090	94	0.37	12.00	325
65	819.664	0.090	94	0.30	11.70	325
70	820.890	0.100	94	0.13	11.30	300
75	822.217	0.100	94	0.12	11.10	300
80	823.544	0.100	94	0.13	10.40	300
85	824.871	0.100	94	0.34	7.80	300
90	826.198	0.100	94	0.44	7.50	300
95	827.525	0.100	94	0.58	7.20	300
100	828.853	0.100	94	0.60	7.30	300
105	830.180	0.100	94	0.73	7.10	300
110	831.507	0.100	94	0.86	6.60	300
115	832.834	0.100	94	0.95	6.60	300
120	834.161	0.100	94	1.01	6.60	300
125	835.491	0.100	94	1.08	6.30	300
130	836.820	0.100	94	1.18	6.40	300
135	838.150	0.100	94	1.03	6.70	300
140	839.479	0.100	94	1.03	6.40	300
145	840.808	0.100	94	0.96	6.60	300
150						

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul

TEST No. 5

MODEL: F600

DATE: 06-May-03

AVG DELTA		AVG PRCNT		
H	----- 0.09 in H2O	CO	----- 0.68	%

AVG METER		AVG PRCNT		
TEMP. Tm	----- 93 deg F	CO2	----- 9.61	%

AVG PPM		AVG BAL		
SO2	----- 319 PPM	CO2/CO	----- 14.09	%

TABLE 4 ----- CALCULATIONS

CLIENT : Jotul

TEST No. 5

MODEL: F600

DATE: 06-May-03

STD SAMPLE		STACK GAS	
VOL. Vm(std) -----	34.39 dscf	FLOW Qsd -----	836.313 dscf/Hr
			&
			13.94 dscf/min
VOL. WATER		PARTICULATE	
VAPOR Vw(std) ----	3.243 scf	CONCTR. Cs -----	0.0039 g/dscf
PRCNT		PARTC.EMISS.	
MSTR Bws -----	8.62 %	RATE E -----	3.30 g/Hr
BURN		MOLES OF GAS	
RATE BR -----	2.70 Kg/Hr	PER Lb WOOD Nt --	0.37 Lb-mole/Lb
CO EMISSION		PART.EMISS.	
RATE -----	191.00 g/Hr	RATE -----	1.22 g/Kgdry
	&		fuel
	70.85 g/Kgdry		
	fuel		

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul

TEST No. : 5

MODEL: F600

DATE: 06-May-03

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	358.5	96	100
10	372.1	99	
15	371.8	99	
20	372.3	99	
25	373.3	100	
30	373.6	100	
35	374.4	100	
40	375.5	100	
45	375.7	100	
50	375.2	100	
55	375.5	100	
60	375.5	100	
65	376.4	100	
70	376.7	100	
75	376.4	100	
80	376.4	100	
85	376.4	100	
90	376.4	100	
95	376.4	100	
100	376.7	100	
105	376.4	100	
110	376.4	100	
115	376.4	100	
120	376.4	100	
125	377.3	101	
130	377.0	101	
135	377.3	101	
140	377.0	101	
145	377.0	101	
150			
155			

METER BOX DATA SHEET PAGE # 2

Page: 1 of 2

UNIT: F600 RUN: 5 DATE: 5-6-03

Meter Box: 54 Y Factor: .990

Leak checks: 16 " Hg @ .011 cfm _____ " Hg @ _____ cfm

03 15 " Hg @ .012 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1,500

ROTO PRESS: <u>.16</u>			SAMPLING RATIO: <u>45</u> : 1			BP: <u>30.04</u>				
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
0	1245	804.500	—	13.698	.15	87	250	87	2.0	
5	50	806.000	—	11.373	.10	89	300	89	2.0	
10	55	807.300	807.300	10.498	.09	89	325	89	2.0	
15	1300	808.500	808.500	10.479	.09	90	325	90	2.0	
20	05	809.704	809.704	9.713	.08	91	350	91	2.0	
25	10	810.827	810.827	9.065	.07	92	375	92	2.0	
30	15	811.878	811.878	9.033	.06	93	375	93	2.0	
35	20	812.933	812.933	8.453	.06	94	400	94	2.0	
40	25	813.926	813.926	7.956	.05	94	425	94	2.0	
45	30	814.861	814.861	9.660	.07	94	350	94	2.0	
50	35	815.995	815.995	10.403	.09	94	325	94	2.0	
55	40	817.217	817.217	10.403	.09	94	325	94	2.0	
ROTO PRESS: <u>.16</u>			TOTALS: <u>120.734</u>			<u>1.00</u>	<u>1101</u>	BP: <u>29.96</u>		
60	1345	818.439	818.439	10.376	.09	94	325	94	2.0	
65	50	819.664	819.664	10.376	.09	94	325	94	2.0	
70	55	820.890	820.890	11.240	.10	94	300	94	2.0	
75	1400	822.217	822.217	11.240	.10	94	300	94	2.0	
80	05	823.544	823.544	11.240	.10	94	300	94	2.0	
85	10	824.871	824.871	11.240	.10	94	300	94	2.0	
90	15	826.198	826.198	11.240	.10	94	300	94	2.0	
95	20	827.525	827.525	11.240	.10	94	300	94	2.0	
100	25	828.853	828.853	11.240	.10	94	300	94	2.0	
105	30	830.180	830.180	11.240	.10	94	300	94	2.0	
110	35	831.507	831.507	11.240	.10	94	300	94	2.0	
115	40	832.834	832.834	11.240	.10	94	300	94	2.0	
			TOTALS: <u>133.152</u>			<u>1.18</u>	<u>1128</u>	MAX VACC =		
TOTAL Cu Ft.			TOTALS: <u>253.886</u>			<u>2.18</u>	<u>2229</u>	AVG. BP: <u> </u>		

METER BOX DATA SHEET PAGE # 2

Page: 2 of 2

UNIT: F600 RUN: 5

DATE: 5-6-03

Meter Box: 5H Y Factor: .990

Leak checks: 16 " Hg @ .011 cfm _____ " Hg @ _____ cfm

15 " Hg @ .012 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO PRESS: <u>.16</u>			SAMPLING RATIO: <u>45</u> : 1				BP: <u>29.91</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
120	1445	834.161	834.161	11.222	.10	94	300	94	2.0
125	50	835.491	835.491	11.222	.10	94	300	94	2.0
130	55	836.820	836.820	11.222	.10	94	300	94	2.0
135	1500	838.150	838.150	11.222	.10	94	300	94	2.0
140	05	839.479	839.479	11.222	.10	94	300	94	2.0
145	10	840.808	840.808	11.222	.10	94	300	94	2.0
150									
155				67.332	.60	564			
160									
165									
170									
175									
ROTO PRESS:			TOTALS:				BP.:		
180									
185									
190									
195									
200									
205									
210									
215									
220									
225									
230									
235						2793	30		
			TOTALS:	321.218	2.78	93	MAX VACC =		2.0
TOTAL Cu Ft. <u>36.308</u>			TOTALS:	10.707	.093	(553)	AVG. BP: <u>29.97</u>		

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT: F600 RUN: 5 DATE: 5-6-03

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :	✓	✓

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.0

IMPINGER	#1	#2	#3	#4
FINAL WT	668.9	591.7	484.6	827.9
INITIAL WT	613.0	590.8	484.2	816.2
NET WT GRAMS	55.9	.9	.4	11.7

TOTAL CATCH: 68.9 GRAMS H₂O

FRONT HALF

FILTER #	151F	
FINAL WT g	.7429	✓
INITIAL WT g	.6941	✓
NET WT g	.0488	✓

BEAKER #	16
DESC.	ACETONE
FINAL WT g	95.7655
INITIAL WT g	95.7429
NET WT g	.0226
VOL. DESC. ml	110

BACK HALF

FILTER #	151B	
FINAL WT g	.4432	✓
INITIAL WT g	.4359	✓
NET WT g	.0073	✓

BEAKER #	17	18	19	20	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	104.6339	108.8905	106.5538	108.6607	
INITIAL WT g	104.5944	108.8623	106.5468	108.5932	
NET WT g	.0395	.0082	.0070	.0075	.0145
VOL. DESC ml	150	75	150	125	(275)

FILTER TARE WEIGHTS DATA SHEET #4-1

Into Dessicator : Date : 01/17/03 Time : 2055 By : [Signature]
 Manufacturer S & S Grade : # 25 Glass Front Size : 11 cm Lot No. : ZB921
 Back Size : 8.2 cm Lot No. : ZB911

DATE: <u>01/21/03</u>		BY: <u>[Signature]</u>		DATE: <u>01/22/03</u>		BY: <u>[Signature]</u>		DATE: _____	BY: _____
FILTER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME			
151F	.6940	0954	<u>.6941</u>	1128	Total Fl000				R-5
152F	.6984	0955	<u>.6982</u>	1129	" "				R-6
153F	.6999	0955	<u>.6998</u>	1130					
154F	.6969	0956	<u>.6968</u>	1131					
155F	.6984	0957	<u>.6985</u>	1131					
156F	.6915	0958	<u>.6914</u>	1132					
157F	.6974	0959	<u>.6976</u>	1133					
158F	.6990	0959	<u>.6990</u>	1134					
159F	.6931	1000	<u>.6932</u>	1135					
160F	.6989	1001	<u>.6992</u>	1135					

151B	.4360	1002	<u>.4359</u>	1136	Total Fl000				R-5
152B	.4316	1002	<u>.4316</u>	1137	" "				R-6
153B	.4307	1003	<u>.4311</u>	1138					
154B	.4295	1004	<u>.4293</u>	1138					
155B	.4321	1005	<u>.4323</u>	1139					
156B	.4243	1006	<u>.4245</u>	1140					
157B	.4294	1006	<u>.4294</u>	1141					
158B	.4350	1007	<u>.4354</u>	1142					
159B	.4290	1008	<u>.4290</u>	1142					
160B	.4274	1009	<u>.4274</u>	1143					

Checked by: [Signature] Date: 1-22-03 Time: 1149

SCALE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	DB	% RH
01/21	0935	[Signature]	75	44
01/22	1125	[Signature]	77	46

BEAKER TARE WEIGHTS DATA SHEET #4-2

Into Dessicator: Date : 08-19-2002 Time : 1205 By : DM

BEAKER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME
1	104.9172	1043	104.9174	0704		
2	106.2542	1044	106.2538	0705	Total Floor R-1	
3	107.7782	1046	107.7777	0706		
4	108.7744	1047	108.7740	0708		
5	97.4390	1048	97.4366	0709		
6	91.2080	1050	91.2076	0710		
7	97.1385	1051	97.1382	0711	Total Floor R-3	
8	108.6356	1052	108.6357	0713		
9	108.0961	1053	108.0960	0714		
10	105.7310	1055	105.7306	0715		
11	104.7892	1056	104.7887	0717	Total Floor R-4	
12	98.2303	1057	98.2304	0718		
13	104.1788	1059	104.1784	0719		
14	97.9822	1100	97.9819	0721		
15	104.7644	1101	104.7642	0722		
16	95.7427	1102	95.7429	0723	Total Floor R-5	
17	104.5948	1104	104.5944	0724		
18	108.8626	1105	108.8623	0725		
19	106.5473	1106	106.5468	0726		
20	108.5936	1108	108.5932	0728		

SCALE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	DB	% RH	Checked by
08-22	1040	DM	78	49	Chp Wadsworth
08-23	0700	DM	78	49	
					Date : 8-23-02
					Time : 0910

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: F 600 RUN: 5 DATE: 5-6-03 Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
16	05/07	2300	BK	95.7662	05/10	1454	BK	95.7654	05/11	1454	BK	95.7655	05/11	1220	BK
17	05/07	2300	BK	104.6345	05/09	0741	BK	104.6339	05/10	1455	BK	104.6339	05/11	1221	BK
18	05/07	2030	BK	108.8712	05/09	0743	BK	108.8702	05/10	1456	BK	108.8705	05/11	1223	BK
19	05/07	2030	BK	106.5553	05/09	0744	BK	106.5540	05/10	1457	BK	106.5538	05/11	1224	BK
20	05/07	2030	BK	108.6004	05/09	0745	BK	108.6010	05/10	1458	BK	108.6007	05/11	1225	BK

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
151F	5-6	1600	CP	7445	05/06	2156	BK	7432	05/09	0746	BK	7429	05/10	1459	BK
151B	5-6	1600	CP	4439	05/06	2157	BK	4431	05/09	0748	BK	4432	05/10	1500	BK

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	05/06	2135	BK	77	46
2	05/09	0715	BK	77	45
3	05/10	1435	BK	78	47
4	05/11	1210	BK	77	46
5					

Weighing Session	Date	Time	By	DB	%RH
6					
7					
8					
9					
10					

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET


Dates: From 05-18-2002 Through 10-27-2002	Scale: Sartorius	Model: A 120 S	SN: 37010004
--	---------------------	-------------------	-----------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9999	10.0000	.9999	.0999	AKW	05-18	1905	77	49
99.9997	9.9998	.9999	.0998	AKW	05-19	1500	77	48
99.9999	10.0000	.9998	.0999	AKW	05-20	0855	77	47
99.9998	9.9998	1.0000	.0999	AKW	05-21	0930	78	49
99.9998	9.9999	1.0000	.1000	AKW	05-22	1155	78	48
99.9999	9.9999	1.0000	.1001	AKW	05-22	1920	78	49
99.9999	10.0001	1.0001	.0998	AKW	05-23	2105	77	48
99.9998	9.9998	.9998	.0999	AKW	05-28	1225	78	49
99.9998	9.9997	1.0001	.0999	AKW	05-28	1625	78	47
99.9997	10.0001	1.0002	.1000	AKW	06-27	1950	78	49
99.9998	10.0001	1.0002	.1001	AKW	06-29	1830	78	49
99.9997	9.9999	1.0000	.0998	AKW	07-01	0845	77	49
100.0000	9.9999	1.0002	.1000	AKW	07-01	2220	78	47
99.9998	10.0000	.9999	.0999	AKW	08-14	1130	78	49
100.0001	9.9999	1.0000	.1000	AKW	08-16	1045	78	49
100.0000	9.9998	1.0000	.0998	AKW	08-22	1040	78	49
99.9997	9.9999	.9999	.0997	AKW	08-23	0700	78	49
99.9998	10.0000	1.0000	.0998	AKW	08-29	0915	78	49
100.0000	10.0000	1.0002	.1001	AKW	08-29	2225	78	49
99.9998	9.9999	1.0001	.0998	AKW	09-03	1120	78	49
99.9997	9.9998	.9999	.0998	AKW	09-03	2230	78	49
100.0000	10.0001	.9999	.0999	AKW	09-05	1915	78	49
99.9999	9.9999	1.0000	.0999	AKW	09-06	1815	78	48
99.9997	9.9999	1.0000	.0998	AKW	09-07	1355	78	47
100.0000	10.0002	.9998	.0997	Chp	9-10	1110	77	42
99.9997	10.0002	1.0000	.0100	Chp	9-11	1500	74	47
99.9999	9.9999	1.0000	.0997	Chp	9-13	2020	76	38
100.0003	10.0002	1.0002	.0998	Chp	9-14	1300	76	41
100.0000	10.0001	1.0000	.0999	Chp	9-16	1930	74	44
100.0000	9.9999	.9998	.0999	Chp	9-17	1710	77	42
100.0000	10.0001	1.0000	.1000	Chp	9-19	1000	74	47
100.0001	10.0000	.9998	.0999	Chp	9-20	1115	74	44
99.9998	9.9999	1.0001	.0999	AKW	10-18	2155	77	44
99.9997	9.9999	1.0000	.1000	AKW	10-22	2255	77	46
100.0001	10.0002	1.0000	.0999	AKW	10-23	2815	77	42
99.9997	9.9998	.9999	.1000	AKW	10-25	1350	77	43
99.9998	9.9999	1.0000	.1000	AKW	10-26	1735	77	41
99.9998	9.9998	.9999	.1000	AKW	10-27	1130	77	36
99.9998	9.9999	.9999	.0999	AKW	10-27	1435	77	38

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates: From 12-05-2002 Through 02-23-2003	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9997	9.9998	1.0000	.0997	AKW	12-05	1825	77	47
99.9998	10.0000	.9999	.1000	AKW	12-06	1125	77	45
99.9997	10.0001	1.0000	.1000	AKW	12-07	1310	76	41
99.9997	10.0001	1.0000	.0999	AKW	12-08	1430	77	44
99.9998	9.9999	1.0001	.0999	AKW	12-09	1125	78	44
99.9998	10.0000	.9999	.0998	AKW	12-10	1220	78	43
99.9997	10.0000	.9998	.0998	AKW	12-11	1650	77	45
99.9997	10.0001	.9999	.0999	AKW	12-12	1445	77	47
99.9998	10.0000	.9999	.1000	AKW	12-14	1530	78	47
99.9997	10.0000	1.0000	.0999	AKW	01-10	2300	78	48
99.9998	9.9999	1.0001	.1000	AKW	01-14	1115	77	48
99.9999	10.0000	.9999	.1000	AKW	01-15	1705	77	48
99.9999	10.0001	.9999	.0998	AKW	01-16	1830	78	46
99.9997	10.0000	1.0000	.0999	AKW	01-17	1215	77	41
99.9997	9.9999	1.0000	.0999	AKW	01-17	2035	76	42
99.9996	10.0000	.9999	.0999	AKW	01-18	1730	77	43
99.9999	9.9999	.9998	.0999	AKW	01-19	1210	76	42
99.9998	10.0000	1.0000	.0999	AKW	01-20	2105	76	44
99.9999	10.0000	.9999	.0998	AKW	01-21	0935	75	44
99.9998	10.0000	.9999	.0999	AKW	01-22	1125	77	46
100.0000	9.9998	.9999	.1000	AKW	01-23	1430	77	48
99.9999	10.0001	1.0001	.1000	AKW	01-24	1200	76	48
99.9998	9.9999	.9999	.0999	AKW	01-25	1140	76	47
99.9997	10.0000	1.0000	.0999	AKW	01-25	1850	78	48
99.9998	9.9998	1.0000	.1000	AKW	01-27	1415	75	47
99.9999	9.9999	1.0000	.1000	AKW	01-30	1920	77	48
99.9998	10.0000	.9998	.0999	AKW	01-31	2205	78	47
99.9999	9.9998	.9998	.1000	AKW	02-01	1855	77	47
99.9997	9.9998	.9999	.1001	AKW	02-02	1420	76	46
99.9997	10.0001	.9998	.0999	AKW	02-18	1155	77	49
99.9999	9.9999	.9999	.0999	AKW	02-19	1925	77	48
99.9997	10.0000	1.0000	.0999	AKW	02-22	2010	78	45
99.9997	10.0000	.9999	.1000	AKW	02-23	1130	78	44
								

BLANK PROCESSING DATA SHEET # 5

UNIT: F600 RUN: 5 DATE: 05/06/03

DATE BLANKS DONE: 02-23-03

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	DWNA, INC. SPARKLETES DISTILLED
FINAL WEIGHT	108.9007	106.3074	106.9660
TARE WEIGHT	108.8995	106.3057	106.9646
NET WEIGHT	.0012 ✓	.0017 ✓	.0014 ✓

TARE BEAKERS INTO DESC: TIME: 1430 DATE: 02-12-03

DATE: 02-18 BY: KS DATE: 02-19 BY: KS DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.8996	1158	108.8995	1928	✓	
B	106.3060	1159	106.3057	1930	✓	
C	106.9649	1200	106.9646	1931	✓	

FINAL BEAKERS INTO DESC: TIME: 1600 DATE: 02-20-03

DATE: 02-22 BY: KS DATE: 02-23 BY: KS DATE: _____ BY: _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9010	2013	108.9007	1132	✓	
B	106.3078	2015	106.3074	1133	✓	
C	106.9661	2016	106.9660	1134	✓	

TARE QC

DATE	TIME	BY	WB	DB	%
02-18	1155	KS	}	77	49
02-19	1925	KS		77	48

FINAL QC

DATE	TIME	BY	WB	DB	%
02-22	2010	KS	}	78	45
02-23	1130	KS		78	44

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: F600 RUN: 5 DATE: 05/06/03

BLANK CALCULATIONS

Acetone : $\frac{.0012 \text{ g}}{200 \text{ ml}} = .000006 \text{ g/ml}$
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = .000023 \text{ g/ml}$
 Distilled Water : $\frac{.0014 \text{ g}}{200 \text{ ml}} = .000007 \text{ g/ml}$

FRONT HALF CATCH

FILTERS : $\frac{.0488 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ (# of Filters)} \cdot (.0000 \text{ g})}{\text{Blank Value / Filter}} = .0488 \text{ g}$
 BEAKERS : $\frac{.0226 \text{ g}}{\text{Total Catch}} - \frac{110 \text{ ml Acetone} \cdot (.000006 \text{ g})}{\text{Blank Value / ml Acetone}} = .0219 \text{ g}$
TOTAL FRONT HALF CATCH : .0707 g

BACK HALF CATCH

FILTERS : $\frac{.0073 \text{ g}}{\text{Total Catch}} - \frac{1 \text{ (# of Filters)} \cdot (.0000 \text{ g})}{\text{Blank Value / Filter}} = .0073 \text{ g}$
 BEAKERS :
 Acetone : $\frac{.0395 \text{ g}}{\text{Total Catch}} - \frac{150 \text{ ml Acetone} \cdot (.000006 \text{ g})}{\text{Blank Value / ml Acetone}} = .0386 \text{ g}$
 Extract : $\frac{.0082 \text{ g}}{\text{Total Catch}} - \frac{75 \text{ ml Dichloromethane} \cdot (.000023 \text{ g})}{\text{Blank Value / Dichloromethane}} = .0065 \text{ g}$
 Water : $\frac{.0145 \text{ g}}{\text{Total Catch}} - \frac{275 \text{ ml Water} \cdot (.000007 \text{ g})}{\text{Blank Value / Water}} = .0126 \text{ g}$
TOTAL BACK HALF CATCH : .0650 g
TOTAL CATCH : .1357 g
% FRONT HALF : $\frac{.0707}{.1357} = 52.1\%$
 (00.0)

CALCULATIONS DATA SHEET # 7

UNIT: TOTAL F600 RUN: 5 DATE: 05/06/03

$$1) Vm (std) = \frac{(36.308 Vm) (17.64) (990 mcf) (29.97 \text{ " Hg} + \frac{.093 \text{ " H}_2\text{O}}{13.6})}{(553 \text{ TmA})} = \frac{34.3714}{000.0000} \text{ dscf}$$

$$2) Vw (std) = (.04707) (68.9 \text{ ml H}_2\text{O}) = \frac{3.2431}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(3.2431 \text{ scf})}{(3.2431 \text{ scf} + 34.3714 \text{ dscf})} = \frac{.0862}{.0000} \text{ Bws} \times 100 = \frac{8.6220}{00.0000} \% \text{ H}_2\text{O}$$

$$4) Cs = \frac{(.1357 \text{ g.})}{(34.3714 \text{ dscf})} (15.43) = \frac{.0609}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(.1357 \text{ g.})}{(34.3714 \text{ dscf})} (10.707 \text{ dscfm}) (60) = \frac{2.5363}{00.0000} \text{ g / hr}$$

- Vm = total cubic feet pulled on meter box during test (000.000 Vm)
- mcf = meter correction factor (Y factor) of meter box used for test (0.000 mcf)
- " Hg = average barometric pressure during test (00.00 " Hg)
- " H₂O = average delta H for test (.000 " H₂O)
- TmA = average meter temperature for test in degrees Absolute (000 TmA)
- ml H₂O = total water caught during test (000.0 ml H₂O)
- g. = total particulate catch for test (00.0000 g.)
- dscfm = average stack flow during test (00.0000 dscf)

TEST DATA SHEET # 8

UNIT: F600 RUN: 5 DATE: 5-6-03

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb

Pre : WB : 60 DB : 84 = 23 % RH 0.9 % H₂O

Post : WB : 64 DB : 86 = 28 % RH 1.2 % H₂O

Average : 25.5 % RH 1.05 % H₂O

Empty Stove Weight (lbs) : _____ w/ stack & oil seal : Wet : _____ Dry : 0.0

Kindling Weight (lbs) : Paper : .2 Wood : 2.2

Preburn Fuel Weight : 15.5 + 19.6 + 13.8 Total : 48.9

Kindling & Preburn Fuel Weight (wood only) (lbs) : Total : 51.1

Coal Bed Wt Range (lbs) : 4.4 - 3.6 Scale : 4.4 - 3.6

Upper : .25 x fuel weight : Always round DOWN to nearest tenth
Lower : .20 x fuel weight : Always round UP to nearest tenth Actual Coal Bed Weight : 4.2

Maximum Coal Bed Removal (lbs) : $(\frac{4.4}{\text{Upper}} + \frac{3.6}{\text{Lower}}) \div 2 \times .25 = \underline{1.0}$ (round down to nearest tenth)

Test Fuel (.75" x 1.5" x 5" spacers) = 20 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	4	8.5	48.0
4" x 4"	17	2	9.2	52.0

Test Fuel Weight : 17.7 lbs

Estimated Dry Burn Rate :

$$\frac{17.7 - (17.7 \times .18846)}{2.2046} \times \frac{60}{145} = \underline{2.696} \text{ kg/hr}$$

Estimated BTU's/hr : $19,140 \times \frac{63}{100} \times \frac{2.696}{\text{DBR}} = \underline{32,510.2}$ BTU's/hr

EPA Default Efficiencies : Non-cat : 63 Cat : 72 Pellet : 78

WOOD STOVE OPERATING DATA PAGE #9

Unit : F600 Run : 5 Date : 5-6-03

FIRE STARTED: 0850

WARM UP AND PREBURN:

PRIMARY AIR : Set wide open for all warm-up / preburn fuel charges. Then set to wide open at start of preburn.

SECONDARY AIR : N/A CAT BYPASS : N/A

CHARCOAL BED PREPARATION :

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 30 sec.

TEST:

DOOR wide open during loading 0 min. 50 sec.

PRIMARY AIR : Opened full for first 5 min., then set to run setting of wide open.

SECONDARY AIR : N/A CAT BYPASS : N/A

FAN:

~~ON~~ OFF during warm-up

~~ON~~ OFF first ALL minutes of test

Fan speed set at High

~~ON~~ OFF during preburn

~~ON~~ OFF balance of test run

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER : N/A BRAND : N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 16 or - inches.

1st warm up / pre-burn fuel charge (15.5 lbs.) added at 0905

2nd warm up / pre-burn fuel charge (19.6 lbs.) added at 1010

3rd warm up / pre-burn fuel charge (13.8 lbs.) added at 1115

4th warm up / pre-burn fuel charge (_____ lbs.) added at _____

5th warm up / pre-burn fuel charge (_____ lbs.) added at _____

TEST DATA SHEET #10

Unit : FLOOR Run : 5 Date : 05-06-03
 Room Temperature : 71 °F Correction Factor : 0
 Uncorrected Values are corrected for room temperature : Yes _____ No
 Time Test Fuel moisture reading taken : 1035 ✓
 Calibration Checks : X Y 12.0 12.2 22.0 22.0

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	18.0	19.2	17.0	18.2	17.0	18.2	18.533
2									
3									
4	2"x4"x8'	P	21.5	23.1	21.0	22.5	22.0	23.7	23.100
5	2"x4"x8'	P	21.0	22.5	21.0	22.5	21.0	22.5	22.500
6	2"x4"x8'	P	18.5	19.8	19.5	20.9	19.5	20.9	20.533
7	2"x4"x8'	P	20.5	22.0	20.5	22.0	20.5	22.0	22.000
8	2"x4"x8'	P							88.133
9									
10	2x4x17	T	19.5	20.9	20.0	21.4	20.0	21.4	21.233
11	"	T	21.5	23.1	21.5	23.1	22.0	23.7	23.300
12	"	T	21.5	23.1	21.5	23.1	21.5	23.1	23.100
13	"	T	23.0	24.7	23.0	24.7	23.0	24.7	24.700
14	4x4x17	T	21.5	23.1	22.0	23.7	21.5	23.1	23.300
15	"	T	22.0	23.7	22.0	23.7	22.0	23.7	23.700
16									139.333
17									
18									
19									
20	Spacers	T	18.5	19.8	19.5	20.9	19.0	20.3	20.333

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	18.533 %	22.033 %	23.222 %
Wet Moisture % :	15.636 %	18.055 %	18.846 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

GAS DATA SHEET #12

WEIGHT: 4.2

DATE: 05-06-03

UNIT: F600

RUN: 5

PAGE: 1 OF 1

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO ₂ PPM
0 1245	21.9	17.7	—	.323	8.0	.497	12.3	.044	.45	-0.040	250
5 50	20.6	16.4	1.3	.441	11.0	.377	9.4	.037	.38	-0.027	300
10 55	19.6	15.4	1.0	.375	9.3	.437	10.9	.052	.53	-0.045	325
15 1300	18.5	14.3	1.1	.435	10.8	.380	9.5	.045	.46	-0.046	325
20 05	17.3	13.1	1.2	.492	12.3	.319	8.0	.053	.54	-0.047	350
25 10	16.1	11.9	1.2	.525	13.1	.272	6.8	.088	.89	-0.047	375
30 15	15.0	10.8	1.1	.519	12.9	.281	7.0	.080	.81	-0.048	375
35 20	13.8	9.6	1.2	.556	13.9	.226	5.7	.127	1.28	-0.049	400
40 25	12.6	8.4	1.2	.555	13.8	.224	5.6	.133	1.34	-0.049	425
45 30	11.6	7.4	1.0	.519	12.9	.283	7.1	.077	.78	-0.049	350
50 35	10.6	6.4	1.0	.491	12.2	.317	7.9	.060	.61	-0.048	325
55 40	9.8	5.6	.8	.503	12.5	.308	7.7	.054	.55	-0.048	325
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-0.543	*****
60 1345	9.0	4.8	.8	.480	12.0	.338	8.5	.036	.37	-0.047	325
65 50	8.3	4.1	.7	.471	11.7	.350	8.8	.029	.30	-0.047	325
70 55	7.7	3.5	.6	.453	11.3	.375	9.4	.012	.13	-0.046	300
75 1400	7.2	3.0	.5	.447	11.1	.381	9.5	.011	.12	-0.046	300
80 65	6.8	2.6	.4	.418	10.4	.410	10.3	.012	.13	-0.045	300
85 10	6.5	2.3	.3	.314	7.8	.505	12.6	.033	.34	-0.043	300
90 15	6.3	2.1	.2	.302	7.5	.513	12.8	.043	.44	-0.042	300
95 20	6.1	1.9	.2	.291	7.2	.519	13.0	.057	.58	-0.041	300
100 25	5.9	1.7	.2	.293	7.3	.516	12.9	.059	.60	-0.040	300
105 30	5.7	1.5	.2	.285	7.1	.519	13.0	.072	.73	-0.039	300
110 35	5.5	1.3	.2	.267	6.6	.532	13.3	.085	.86	-0.038	300
115 40	5.4	1.2	.1	.265	6.6	.530	13.3	.094	.95	-0.038	300
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-0.512	*****
120 1445	5.1	.9	.3	.264	6.6	.529	13.2	.100	1.01	-0.037	300
125 50	4.9	.7	.2	.254	6.3	.536	13.4	.107	1.08	-0.036	300
130 55	4.7	.5	.2	.259	6.4	.527	13.2	.117	1.18	-0.036	300
135 1500	4.6	.4	.1	.271	6.7	.521	13.0	.102	1.03	-0.035	300
140 05	4.4	.2	.2	.258	6.4	.534	13.3	.102	1.03	-0.035	300
145 10	4.2	0	.2	.265	6.6	.530	13.2	.095	.96	-0.035	300
150 15											
155 20										-0.214	
160 25											
165 30											
170 35											
175 40											300 ✓
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-1.269	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-1.042	*****

TEMPERATURE DATA SHEET #14

		TEST TIME	145		
STACK AVG	400	TOP AVG	428	LT SIDE AVG	417
BACK AVG	256	RT SIDE AVG	416	BOTTOM AVG	288
FIREBOX AVG	811	SEC/CAT AVG	1119	AMBIENT AVG	78

END 317.5
START 415.2

-97.7 DELTA T

CIRCLE: LOSS / GAIN

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube	Furn	Smpl Box	Smpl Out	C-Gas	Box	C-Gas	Out	SO2	Out
0	413	406	475	306	464	425	913	1091	74	1359		236	52	246		33	33	36	36
5	660	420	449	283	438	415	711	1265	73	1353		239	44	245		33	33	34	34
10	455	435	416	246	407	387	669	1080	73	1347		235	45	246		34	34	37	37
15	450	445	398	225	388	359	659	1145	77	1341		236	45	247		34	34	37	37
20	465	467	385	213	376	339	664	1267	77	1338		237	45	249		35	35	36	36
25	482	488	378	206	372	322	687	1333	78	1337		235	46	248		37	37	36	36
30	487	504	380	204	374	305	713	1335	79	1336		234	46	247		37	37	35	35
35	506	520	385	206	380	291	738	1270	81	1337		235	47	248		37	37	37	37
40	514	534	393	211	389	279	769	1266	80	1346		237	49	247		36	36	37	37
45	493	526	399	224	396	269	799	1256	79	1349		235	49	248		37	37	37	37
50	474	516	409	242	403	261	821	1242	78	1346		236	50	249		38	38	35	35
55	462	509	418	258	410	254	842	1244	79	1345		236	51	248		37	37	35	35
60	450	501	425	269	416	252	862	1247	78	1348		236	50	246		37	37	36	36
65	444	496	434	278	424	248	884	1223	78	1357		238	50	246		36	36	36	36
70	430	493	442	290	436	245	891	1195	78	1370		237	50	245		36	36	36	36
75	420	485	446	300	453	244	899	1196	79	1379		236	50	244		36	36	38	38
80	404	470	447	312	466	243	907	1204	80	1383		238	50	243		36	36	37	37
85	375	448	452	312	470	246	919	1150	79	1376		237	51	242		37	37	37	37
90	352	422	451	300	466	248	922	1112	79	1367		238	51	241		36	36	36	36
95	336	401	448	286	457	254	894	1075	79	1353		238	52	241		38	38	37	37
100	324	384	441	276	450	259	880	1050	78	1339		238	52	241		38	38	36	36
105	315	370	433	269	443	263	876	1009	78	1328		236	52	242		38	38	36	36
110	305	356	425	263	433	269	852	970	78	1325		236	53	243		37	37	37	37
115	297	345	417	255	422	271	842	947	79	1310		234	53	240		37	37	35	35
120	290	333	411	248	412	276	823	928	78	1306		232	53	240		37	37	35	35
125	284	325	405	244	401	279	801	914	79	1302		232	54	241		37	37	35	35
130	280	315	397	239	392	281	784	907	79	1308		231	54	241		36	36	34	34
135	278	310	391	237	385	284	777	897	78	1304		230	54	242		36	36	35	35
140	275	305	384	236	379	290	761	884	78	1302		232	54	244		36	36	35	35
145	274	300	378	236	378	296	761	877	78	1301		233	54	243		36	36	34	34

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 05/06/03

Analyte : CO₂ (15-1)

Unit : F600

Run # : 5

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO₂

Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % CO₂

Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE

Date : 03-13-03

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 407069

Range : 0 - 25.0 % CO₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % CO₂
 EPA Control Limits = ± 2.5% of 25.0 % CO₂ = ± 0.625 % CO₂
 Method 28 A = ± .2 % of 25.0 % CO₂ = ± .05 % CO₂

PRE RUN Audit : by : D. Wadlington Time : 1125 ✓ Temp : 74 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	-0.048	-0.048	-0.191
SPAN	49.6	.496	12.40	49.5	.495	12.342	-0.058	-0.233

POST RUN Audit : by : D. Wadlington Time : 1535 ✓ Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	-0.023	-0.023	-0.091
SPAN	49.6	.496	12.40	49.6	.496	12.367	-0.033	-0.133

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05/06/03

Analyte : O₂ (15-2)

Unit : F600 Run # : 5

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂ Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % O₂ Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE Date : 03-13-03

Analyzer : Make : TELEDYNE Model : 320 A SN : 37400

Range : 0 - 25.0 % O₂ Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 25.0 % O₂
 EPA Control Limits = $\pm 2.5\%$ of 25.0 % O₂ = $\pm 0.625 % O_2$
 Method 28 A = $\pm .2 %$ of 25.0 % O₂ = $\pm .05 % O_2$

PRE RUN Audit : by : D. Wadlington Time : 1125 Temp : 74 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.050	+0.050	+0.201
SPAN	12.50	.500	12.50	12.50	.500	12.501	+0.001	+0.006

POST RUN Audit : by : D. Wadlington Time : 1535 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.025	+0.025	+0.101
SPAN	12.50	.500	12.50	12.55	.501	12.526	+0.026	+0.105

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date : 05/06/03

Analyte : CO (15-3)

Unit : F600

Run # : 5

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO

Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % CO

Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE

Date : 03-13-03

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 408005

Range : 0 - 10.0 % CO

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 10.0 % CO

EPA Control Limits = ± 2.5% of 10.0 % CO = ± 0.25 % CO

Method 28 A = ± .2 % of 10.0 % CO = ± .02 % CO

PRE RUN Audit : by : A. Wadington Time : 1125 Temp : 74 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.011	+ .011	+ .110
SPAN	50.2	.502	5.02	50.1	.501	5.020	+ .000	+ .003

POST RUN Audit : by : A. Wadington Time : 1535 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	.021	+ .021	+ .210
SPAN	50.2	.502	5.02	50.2	.502	5.030	+ .010	+ .097

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05/06/03

Analyte : SO₂ (15-4)

Unit : F600 Run # : 5

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE Date : 02-20-02

Span Cyl. # : CC62184 Conc. : 1290 ppm SO₂ Cyl. Press. : 1025 PSI

Certified by : AIR LIQUIDE Date : 01-29-01

Analyzer : Make : HORIBA Model : PIR-2000 SN : 403019

Range : 0 - 2500 ppm SO₂ Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = ± 2.5% of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : A. Wadlington Time : 1120 Temp : 74 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	9.209	+9.209	+368
SPAN	51.6	.516	1290	51.7	.517	1292.541	+2.541	+102

POST RUN Audit : by : A. Wadlington Time : 1535 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.1	.001	9.209	+9.209	+368
SPAN	51.6	.516	1290	51.8	.518	1295.028	+5.028	+201

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT : FL600 RUN : 5 DATE : 5-6-03

Thermocouple Check:

T/C # 1	<u> </u> °F	T/C # 13	<u>62.5</u> °F
T/C # 2	<u> </u> °F	T/C # 14	<u>61.0</u> °F
T/C # 3	<u>62.4</u> °F	T/C # 15	<u>63.2</u> °F
T/C # 4	<u>58.6</u> °F	T/C # 16	<u>50.2</u> °F
T/C # 5	<u>57.6</u> °F	T/C # 17	<u>51.5</u> °F
T/C # 6	<u>57.8</u> °F	T/C # 18	<u>63.7</u> °F
T/C # 7	<u>57.2</u> °F	T/C # 19	<u>59.6</u> °F
T/C # 8	<u>56.4</u> °F	T/C # 20	<u> </u> °F
T/C # 9	<u>58.0</u> °F	T/C # 21	<u> </u> °F
T/C # 10	<u>58.7</u> °F	T/C # 22	<u> </u> °F
T/C # 11	<u>55.4</u> °F	T/C # 23	<u>58.7</u> °F
T/C # 12	<u>67.9</u> °F	T/C # 24	<u> </u> °F

Thermocouple Readout:

Pretest zero and span check and calibration	post test zero and span	% difference
ZERO <u>.3</u> °F Adj. to <u>0.0</u> °F	ZERO <u>1.3</u> °F	Difference <u>.065</u> %
SPAN <u>1999.1</u> °F Adj. to <u>2000.0</u> °F	SPAN <u>2002.3</u> °F	Difference <u>.115</u> %


Thermocouple Readout Pretest Linearity Check:

0 = <u>0.0</u> °F	200 = <u>2020</u> °F	400 = <u>3994</u> °F
600 = <u>601.6</u> °F	800 = <u>801.7</u> °F	1000 = <u>1000.7</u> °F
1200 = <u>1198.3</u> °F	1400 = <u>1399.2</u> °F	1600 = <u>1599.8</u> °F
1800 = <u>1800.1</u> °F	2000 = <u>2000.0</u> °F	

Sample Train Leak Check	Pre <input checked="" type="checkbox"/>	Post <input checked="" type="checkbox"/>
C-gas Train Leak Check	Pre <input checked="" type="checkbox"/>	Post <input checked="" type="checkbox"/>
SO ₂ Train Leak Check	Pre <input checked="" type="checkbox"/>	Post <input checked="" type="checkbox"/>
Static Gauge Zero Check	Pre <input checked="" type="checkbox"/>	Post <input checked="" type="checkbox"/>

Scale Check Pre : 20.1 - 30.1 ✓
 Post : 3.9 - 13.9 ✓

Stack Cleaned Prior to Test Run : YES NO



COMPUTER INPUT DATA SHEET #1

Client: JOTUL USA, INC

Address: 400 RIVERSIDE ST. / P.O. BOX 1157
PORTLAND, ME 04104

Phone: 800-797-5912 Fax: 207-797-6072

Run No.: 6 Date of Test: 05/07/03 Burn Rate: 1.114 ✓

Model No.: F600 min min-1.25 fan

Stove Type: Cat Non Cat Pellet 1.25-1.9 max inset

Dry Gas Meter Y Factor: 1.990 ✓ Post Leak Rate: .017 ✓ cfm Time: 355 ✓ min.
(0.000) (Data Sheet #2) (0.000) (Data Sheet #2) (000) (Data Sheet #2)

Dry Gas Meter Volume: 135.109 ✓ cf
(00.000) (Data Sheet #2)

Stack Flow: 7.098 ✓ dscfm Δ H: .237 ✓ in. H₂O
(00.000) (Data Sheet #2) (0.000) (Data Sheet #2)

Maximum Vac.: 5.0 ✓ Barometric Pressure: 29.94 ✓ in. Hg
(0.0) (Data Sheet #2) (00.00) (Data Sheet #2)

H₂O Captured: 286.5 ✓ g
(00.0) (Data Sheet #3)

Front Half Catch % Of Total: 32.3 ✓ % Total Particulate Catch: 1.3857 ✓ g
(00.0) (Data Sheet #6) (0.0000) (Data Sheet #6)

Flue Gas Moisture: 9.3558 ✓ %
(00.000) (Data Sheet #7)

Particulate Emission: 1636 ✓ gr/dscf
(0.0000) (Data Sheet #7)

Relative Humidity: 30.5 ✓ % RH Ambient Moisture: 1.0 ✓ % H₂O
(00.0) (Data Sheet #8) (0.00) (Data Sheet #8)

Preburn Fuel Wt.: 56.1 ✓ lbs. Coal Bed Wt.: 4.4 ✓ lbs. Test Fuel Wt.: 17.8 ✓ lbs.
(00.0) (Data Sheet #8) (00.0) (Data sheet #8) (00.0) (Data sheet #8)

Heat Output (EPA Default): 13,436.3 ✓ BTU/hr
(00,000.0) (Data Sheet #8)

Kindling Fuel % Moisture (wet): 15.110 ✓ % Pretest Fuel % Moisture (wet): 17.548 ✓ %
(00.000) (Data Sheet #10) (00.000) (Data Sheet #10)

Test Fuel % Moisture (dry): 22.467 ✓ % Test Fuel % Moisture (wet): 18.345 ✓ %
(00.000) (Data Sheet #10 [wood stove] or #11 [pellet stove])

Fuel Higher Heating Value (dry): — ✓ BTU/lb.
(0000) (Data Sheet #11)

Stack Static Pressure: -0.031 ✓ in. H₂O
(+/- .000) (Data Sheet #12)

Average Ambient Temperature: 72 ✓ °F Stove Temperature Change: -60.3 ✓ °F
(00) (Data Sheet #14) (+/- 000.0) (Data Sheet #14)

TABLE 1 ----- RAW DATA

CLIENT : Jotul

TEST No. : 6

MODEL: F600

DATE: 07-May-03

TIME (MIN.)	METER READING (C F)	DELTA H (IN. H2O)	METER TEMP. (DEG. F)	PERCENT CO (%)	PERCENT CO2 (%)	SO2 COCENTR. PPM
0	841.500	0.150	79	0.67	1.50	600
5	843.000	0.720	79	0.45	4.80	275
10	846.329	0.160	81	0.67	3.00	575
15	847.937	0.150	81	0.73	3.30	600
20	849.479	0.140	81	0.82	3.60	625
25	850.959	0.130	82	0.91	4.00	650
30	852.387	0.130	82	0.89	4.40	650
35	853.815	0.130	82	1.34	5.60	650
40	855.243	0.180	81	1.20	6.40	550
45	856.925	0.200	81	1.04	5.70	525
50	858.686	0.240	81	0.95	8.20	475
55	860.632	0.300	81	0.68	9.10	425
60	862.807	0.380	81	0.45	9.90	375
65	865.270	0.380	81	0.29	9.70	375
70	867.734	0.380	81	0.67	8.00	375
75	870.197	0.440	81	0.48	8.80	350
80	872.836	0.440	81	0.37	9.60	350
85	875.475	0.380	81	0.36	9.80	375
90	877.938	0.380	81	0.40	9.80	375
95	880.402	0.380	81	0.42	10.00	375
100	882.865	0.300	81	0.39	8.80	425
105	885.040	0.270	81	0.93	7.30	450
110	887.094	0.270	81	1.10	7.20	450
115	889.148	0.330	82	0.65	8.90	400
120	891.466	0.330	82	0.45	10.30	400
125	893.785	0.380	82	0.37	11.70	375
130	896.258	0.380	82	0.43	11.70	375
135	898.730	0.300	82	0.37	10.80	425
140	900.913	0.330	82	0.18	8.70	400
145	903.231	0.330	82	0.29	8.70	400
150	905.550	0.300	82	0.46	8.10	425
155	907.733	0.240	82	1.22	6.60	475
160	909.686	0.240	82	1.17	6.60	475
165	911.639	0.190	82	1.89	5.50	525
170	913.407	0.180	82	2.17	4.90	550
175	915.095	0.180	83	2.29	4.70	550
180	916.782	0.190	82	2.33	4.40	525
185	918.551	0.190	82	2.41	4.40	525
190	920.320	0.190	82	2.50	4.50	525
195	922.089	0.190	82	2.48	4.50	525
200	923.858	0.190	82	2.50	4.60	525
205	925.627	0.190	82	2.60	4.70	525
210	927.396	0.200	81	2.38	4.60	525
215	929.159	0.200	81	2.35	4.60	525

220	930.921	0.200	81	2.46	4.50	525
225	932.683	0.200	81	2.47	4.50	525
230	934.445	0.180	81	2.41	4.50	550
235	936.128	0.180	81	2.32	4.50	550
240	937.810	0.180	80	2.27	4.50	550
245	939.486	0.180	80	2.26	4.50	550
250	941.163	0.180	80	2.27	4.40	550
255	942.839	0.180	80	2.23	4.30	550
260	944.515	0.180	80	2.28	4.30	550
265	946.191	0.180	80	2.19	4.20	550
270	947.868	0.180	80	2.20	4.30	550
275	949.544	0.180	80	2.22	4.30	550
280	951.220	0.180	80	2.24	4.30	550
285	952.896	0.180	80	2.19	4.30	550
290	954.572	0.160	80	2.16	4.20	575
295	956.176	0.180	80	2.14	4.20	550
300	957.852	0.180	80	2.12	4.20	550
305	959.528	0.180	80	2.15	4.20	550
310	961.205	0.180	80	2.23	4.30	550
315	962.881	0.180	80	2.20	4.30	550
320	964.557	0.180	80	2.15	4.20	550
325	966.233	0.180	80	2.09	4.20	550
330	967.909	0.180	80	1.74	6.20	550
335	969.586	0.200	80	1.64	6.00	525
340	971.342	0.200	80	1.72	5.50	525
345	973.097	0.200	80	1.86	5.00	525
350	974.853	0.200	80	2.01	4.80	525
355	976.609	0.200	80	2.01	4.60	525
360						

TABLE 2---RAW DATA

CLIENT :	Jotul	TEST No.	6
MODEL:	F600	DATE:	07-May-03

METER CAL. FACTOR (Y)	----- 0.99	Wt. WOOD BURNED (LB)	----- 17.8 Lbs
BAROMETRIC PRESS. (Pb)	----- 29.94 in Hg	WET, FUEL MOISTURE %	----- 18.345 %
LEAK RATE POST (Lp)	----- 0.017 cfm	Wt. PART. COLLECTED	----- 1.3857 g
WATER VOL. (V1c)	----- 286.5 Ml	METER VOLUME Vm	----- 135.109 mcf
TEST TIME (MIN)	----- 355 min	HC MOLE FRACTION	----- 0.0132

TABLE 3 -----FIELD DATA AVERAGES

CLIENT :Jotul

TEST No. 6

MODEL: F600

DATE: 07-May-03

AVG DELTA		AVG PRCNT		
H	----- 0.24 in H2O	CO	----- 1.50	%
AVG METER		AVG PRCNT		
TEMP. Tm	----- 81 deg F	CO2	----- 5.96	%
AVG PPM		AVG BAL		
SO2	----- 501 PPM	CO2/CO	----- 3.98	%

TABLE 4 ----- CALCULATIONS

CLIENT : Jotul

TEST No. 6

MODEL: F600

DATE: 07-May-03

STD SAMPLE		STACK GAS		
VOL. Vm(std) -----	130.75 dscf	FLOW Qsd -----	456.953	dscf/Hr & dscf/min
			7.62	
VOL. WATER		PARTICULATE		
VAPOR Vw(std) ----	13.486 scf	CONCTR. Cs -----	0.0106	g/dscf
PRCNT		PARTC.EMISS.		
MSTR Bws -----	9.35 %	RATE E -----	4.84	g/Hr
BURN		MOLES OF GAS		
RATE BR -----	1.11 Kg/Hr	PER Lb WOOD Nt --	0.48	Lb-mole/Lb
CO EMISSION		PART.EMISS.		
RATE -----	229.39 g/Hr & 205.91 g/Kgdry fuel	RATE -----	4.35	g/Kgdry fuel

TABLE 5 ----- PROPORTIONAL RATE VARIATION

CLIENT : Jotul

TEST No. : 6

MODEL: F600

DATE: 07-May-03

TIME INTEVAL Ti	PPM * Vm	PROPRTN. RATE VAR. PR	PROPRTN RATE VAR. AVERAGE
5	873.9	98	100
10	888.5	99	
15	894.5	100	
20	895.0	100	
25	894.0	100	
30	896.2	100	
35	896.2	100	
40	897.0	100	
45	895.0	100	
50	894.5	100	
55	894.4	100	
60	894.5	100	
65	894.0	100	
70	894.4	100	
75	894.0	100	
80	894.2	100	
85	894.2	100	
90	894.0	100	
95	894.4	100	
100	894.0	100	
105	894.5	100	
110	894.4	100	
115	893.6	100	
120	895.7	100	
125	896.1	100	
130	896.0	100	
135	895.6	100	
140	896.2	100	
145	895.7	100	
150	896.1	100	
155	896.2	100	
160	896.0	100	
165	896.0	100	
170	896.3	100	
175	895.7	100	
180	895.2	100	
185	896.9	100	
190	896.9	100	
195	896.9	100	
200	896.9	100	
205	896.9	100	
210	897.7	100	
215	895.5	100	
220	895.0	100	

225	895.0	100
230	895.0	100
235	895.5	100
240	895.8	100
245	893.4	100
250	894.0	100
255	893.4	100
260	893.4	100
265	893.4	100
270	894.0	100
275	893.4	100
280	893.4	100
285	893.4	100
290	893.4	100
295	893.9	100
300	893.4	100
305	893.4	100
310	894.0	100
315	893.4	100
320	893.4	100
325	893.4	100
330	893.4	100
335	894.0	100
340	893.6	100
345	893.1	100
350	893.6	100
355	893.6	100
360		
365		

METER BOX DATA SHEET PAGE # 2

Page: 1 of 3

UNIT: F600 RUN: 6

DATE: 5-7-03

Meter Box: 5H Y Factor: .990 ✓

Leak checks: 15 " Hg @ .010 cfm _____ " Hg @ _____ cfm

15 " Hg @ .017 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO PRESS: <u>.16</u>			SAMPLING RATIO: <u>19</u> : 1				BP: <u>29.95</u>			
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
0	1355	841.500	—	5.775	.15	79	600	79	2.0	
5	1400	843.000	—	12.599	.72	79	275	79	5.0	
10	05	846.329	846.329	6.003	.16	81	575	81	2.0	
15	10	847.937	847.937	5.753	.15	81	600	81	2.0	
20	15	849.479	849.479	5.523	.14	81	625	81	2.0	
25	20	850.959	850.959	5.301	.13	82	650	82	2.0	
30	25	852.387	852.387	5.301	.13	82	650	82	2.0	
35	30	853.815	853.815	5.301	.13	82	650	82	2.0	
40	35	855.243	855.243	6.276	.18	81	550	81	2.0	
45	40	856.925	856.925	6.575	.20	81	525	81	2.0	
50	45	858.686	858.686	7.267	.24	81	475	81	2.0	
55	50	860.632	860.632	8.122	.30	81	425	81	2.0	
ROTO PRESS: <u>.16</u>			TOTALS: 79.796			2.63	971	BP: 29.95		
60	1455	862.807	862.807	9.205	.38	81	375	81	2.0	
65	1500	865.276	865.276	9.205	.38	81	375	81	2.0	
70	05	867.734	867.734	9.205	.38	81	375	81	2.0	
75	10	870.197	870.197	9.863	.44	81	350	81	3.0	
80	15	872.836	872.836	9.863	.44	81	350	81	3.0	
85	20	875.475	875.475	9.205	.38	81	375	81	3.0	
90	25	877.938	877.938	9.205	.38	81	375	81	3.0	
95	30	880.402	880.402	9.205	.38	81	375	81	3.0	
100	35	882.865	882.865	8.122	.30	81	425	81	3.0	
105	40	885.040	885.040	7.671	.27	81	450	81	3.0	
110	45	887.094	887.094	7.671	.27	81	450	81	4.0	
115	50	889.148	889.148	8.614	.33	82	400	82	4.0	
			TOTALS: 107.034			4.33	973	MAX VACC =		
TOTAL Cu Ft.			TOTALS: 186.830			6.96	1944	AVG. BP:		

METER BOX DATA SHEET PAGE # 2

Page: 2 of 3

UNIT: FL60 RUN: 6 DATE: 5-7-03

Meter Box: SH Y Factor: 990

Leak checks: 15 " Hg @ .010 cfm _____ " Hg @ _____ cfm

15 " Hg @ .017 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1,500

ROTO: PRESS: <u>.15</u>		SAMPLING RATIO: <u>19</u>		: 1		BP: <u>29.95</u>				
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC	
120	1555	891.466	891.466	8.614	.33	82	400	82	4.0	
125	1600	893.785	893.785	9.188	.38	82	375	82	4.0	
130	05	896.258	896.258	9.188	.38	82	375	82	4.0	
135	10	898.730	898.730	8.107	.30	82	425	82	3.0	
140	15	900.913	900.913	8.614	.33	82	400	82	3.0	
145	20	903.231	903.231	8.614	.33	82	400	82	3.0	
150	25	905.550	905.550	8.107	.30	82	425	82	3.0	
155	30	907.733	907.733	7.254	.24	82	475	82	3.0	
160	35	909.686	909.686	7.254	.24	82	475	82	3.0	
165	40	911.639	911.639	6.863	.19	82	525	82	3.0	
170	45	913.407	913.407	6.265	.18	82	550	82	3.0	
175	50	915.093	915.093	6.265	.18	83	550	82	3.0	
ROTO PRESS: <u>.15</u>		TOTALS: <u>94.033</u>		<u>3.38</u>	<u>985</u>	BP: <u>29.93</u>				
180	1655	916.782	916.782	6.559	.19	82	525	82	3.0	
185	1700	918.551	918.551	6.559	.19	82	525	82	3.0	
190	05	920.320	920.320	6.559	.19	82	525	82	3.0	
195	10	922.089	922.089	6.559	.19	82	525	82	3.0	
200	15	923.858	923.858	6.559	.19	82	525	82	2.0	
205	20	925.627	925.627	6.559	.19	82	525	82	2.0	
210	25	927.396	927.396	6.571	.20	81	525	81	2.0	
215	30	929.159	929.159	6.571	.20	81	525	81	2.0	
220	35	930.921	930.921	6.571	.20	81	525	81	2.0	
225	40	932.683	932.683	6.571	.20	81	525	81	2.0	
230	45	934.445	934.445	6.272	.18	81	550	81	2.0	
235	50	936.128	936.128	6.272	.18	81	550	81	2.0	
TOTALS:				<u>78.182</u>	<u>2.30</u>	<u>978</u>	MAX VACC =			
TOTAL Cu Ft.				<u>172.215</u>	<u>5.68</u>	<u>1963</u>	AVG. BP:			

METER BOX DATA SHEET PAGE # 2

Page: 3 of 3

UNIT: F600 RUN: 6

DATE: 5-7-03

Meter Box: 5H Y Factor: .990

Leak checks: 15 " Hg @ .1010 cfm _____ " Hg @ _____ cfm

15 " Hg @ .1017 cfm _____ " Hg @ _____ cfm

Inject SO₂ @ 100 cc/min. Nozzle: Probe @ 3/8" od Initial Volume: 1.500

ROTO PRESS: <u>.15</u>		SAMPLING RATIO: <u>19</u> : 1					BP: <u>29.93</u>		
MIN	TIME	METER READING	SAMPLE MDCF	STACK DSCFM	DELTA H	METER TEMP	SO2 PPM	ROTO TEMP	PUMP VACC
240	1755	937.810	937.810	6.284	.18	80	550	80	2.0
245	1800	939.486	939.486	6.284	.18	80	550	80	2.0
250	05	941.163	941.163	6.284	.18	80	550	80	2.0
255	10	942.839	942.839	6.284	.18	80	550	80	2.0
260	15	944.515	944.515	6.284	.18	80	550	80	2.0
265	20	946.191	946.191	6.284	.18	80	550	80	2.0
270	25	947.868	947.868	6.284	.18	80	550	80	2.0
275	30	949.544	949.544	6.284	.18	80	550	80	2.0
280	35	951.220	951.220	6.284	.18	80	550	80	2.0
285	40	952.896	952.896	6.284	.18	80	550	80	2.0
290	45	954.572	954.572	6.010	.16	80	575	80	2.0
295	50	956.176	956.176	6.284	.18	80	550	80	2.0
ROTO PRESS: <u>.15</u>		TOTALS:		75.134	2.14	960	BP: <u>29.93</u>		
300	1855	957.852	957.852	6.284	.18	80	550	80	2.0
305	1900	959.528	959.528	6.284	.18	80	550	80	2.0
310	05	961.205	961.205	6.284	.18	80	550	80	2.0
315	10	962.881	962.881	6.284	.18	80	550	80	2.0
320	15	964.557	964.557	6.284	.18	80	550	80	2.0
325	20	966.233	966.233	6.284	.18	80	550	80	2.0
330	25	967.909	967.909	6.284	.18	80	550	80	2.0
335	30	969.586	969.586	6.583	.20	80	525	80	2.0
340	35	971.342	971.342	6.583	.20	80	525	80	2.0
345	40	973.097	973.097	6.583	.20	80	525	80	2.0
350	45	974.853	974.853	6.583	.20	80	525	80	2.0
355	50	976.609	976.609	6.583	.20	80	525	80	2.0
		TOTALS:		76.903	2.26	960	MAX VACC =		5.0
TOTAL Cu Ft.		135.109	TOTALS:		511.082	17.04	5827	AVG. BP: <u>29.94</u>	

72 7.098 237 81
 541

PARTICULATE CATCH / MOISTURE DATA SHEET # 3

UNIT: F600 RUN: 6 DATE: 5-7-03

SCALE CHECK	LEVEL	ZEROED
INITIAL :	✓	✓
FINAL :		

SCALE	WEIGHT
295.0 g	295.0
590.0 g	590.0
885.0 g	885.6

IMPINGER	#1	#2	#3	#4
FINAL WT	765.5	696.3	488.1	854.9
INITIAL WT	620.8	586.2	484.0	827.3
NET WT GRAMS	144.7	110.1	4.1	27.6

TOTAL CATCH: 286.5 GRAMS H₂O

FRONT HALF

FILTER #	152F	
FINAL WT g	1.0525	✓
INITIAL WT g	.6982	✓
NET WT g	.3543	✓

BEAKER #	21
DESC.	ACETONE
FINAL WT g	108.3299
INITIAL WT g	108.2361
NET WT g	.0938
VOL. DESC. ml	65

BACK HALF

FILTER #	152B	
FINAL WT g	.5670	✓
INITIAL WT g	.4316	✓
NET WT g	.1354	✓

BEAKER #	22	23	24	25	
DESC.	ACETONE	METHCHLOR	H ₂ O	H ₂ O	
FINAL WT g	106.3533	104.7183	106.5517	97.6035	
INITIAL WT g	105.9358	104.5890	106.4081	97.4858	
NET WT g	.4175	.1293	.1436	.1177	.2613
VOL. DESC ml	200	75	200	175	(375)

FILTER TARE WEIGHTS DATA SHEET #4-1

Into Dessicator : _____ Date : 01/17/03 Time : 2055 By : [Signature]

Manufacturer S & S Grade : # 25 Glass Front Size : 11 cm Lot No. : ZB921

Back Size : 8.2 cm Lot No. : ZB911

DATE: <u>01/21/03</u> BY: <u>[Signature]</u>		DATE: <u>01/22/03</u> BY: <u>[Signature]</u>		DATE: _____	BY: _____	
FILTER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME
151F	.6940	0954	(.6941)	1128	Total Fl000	R-5
152F	.6984	0955	(.6982)	1129	" "	R-6
153F	.6999	0955	(.6998)	1130		
154F	.6969	0956	(.6968)	1131		
155F	.6984	0957	(.6985)	1131		
156F	.6915	0958	(.6914)	1132		
157F	.6974	0959	(.6976)	1133		
158F	.6990	0959	(.6990)	1134		
159F	.6931	1000	(.6932)	1135		
160F	.6989	1001	(.6992)	1135		

151B	.4360	1002	(.4359)	1136	Total Fl000	R-5
152B	.4316	1002	(.4316)	1137	" "	R-6
153B	.4307	1003	(.4311)	1138		
154B	.4295	1004	(.4293)	1138		
155B	.4321	1005	(.4323)	1139		
156B	.4243	1006	(.4245)	1140		
157B	.4294	1006	(.4294)	1141		
158B	.4350	1007	(.4354)	1142		
159B	.4290	1008	(.4290)	1142		
160B	.4274	1009	(.4274)	1143		

Checked by: [Signature] Date: 1-22-03 Time: 1149

SCALE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	DB	% RH
01/21	0935	[Signature]	75	44
01/22	1125	[Signature]	77	46

BEAKER TARE WEIGHTS DATA SHEET #4-2

Into Dessicator: Date: 02-13-03 Time: 1130 By: Am

DATE: <u>02-24-03</u>		BY: <u>Am</u>		DATE: <u>02-25-03</u>		BY: <u>Am</u>		DATE: _____	BY: _____
BEAKER #	FIRST WEIGHT	TIME	SECOND WEIGHT	TIME	THIRD WEIGHT	TIME			
21	108.2356	1057	(108.2361)	1703	} TOTAL F600 R-6				
22	105.9359	1058	(105.9358)	1704					
23	104.5887	1059	(104.5890)	1706					
24	106.4077	1100	(106.4081)	1707					
25	97.4855	1101	(97.4858)	1708					
26	101.0348	1103	(101.0350)	1709	}				
27	106.3729	1104	(106.3733)	1710					
28	105.7468	1105	(105.7471)	1711					
29	104.4553	1106	(104.4556)	1712					
30	107.3596	1108	(107.3595)	1713					
31	95.5543	1109	(95.5545)	1714	}				
32	107.8687	1110	(107.8685)	1716					
33	101.1768	1111	(101.1772)	1717					
34	106.4685	1113	(106.4688)	1718					
35	96.5633	1114	(96.5636)	1720					
36	94.4608	1115	(94.4611)	1721	}				
37	106.6052	1117	(106.6054)	1722					
38	96.2539	1118	(96.2540)	1724					
39	97.1420	1119	(97.1424)	1725					
40	106.4705	1120	(106.4706)	1726					
41	105.4920	1122	(105.4918)	1728	}				
42	104.6722	1123	(104.6725)	1729					
43	107.3611	1124	(107.3613)	1730					
44	107.7968	1126	(107.7971)	1732					
45	94.9420	1127	(94.9423)	1733					

SCALE ROOM ENVIRONMENTAL CONDITIONS

DATE	TIME	BY	DB	% RH	
02-24	1055	Am	74	44	Checked by: <u>Chp Washington</u> Date: <u>2-27-03</u> Time: <u>13:14</u>
02-25	1700	Am	77	45	

WOODSTOVE DATA SHEET # 4-3 : CONSTANT WEIGHTS

UNIT: Food

RUN: 6 DATE: 5-7-03

Page: 1 of 1

Beaker #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
21	05/08	2000	BL	108.3303	05/10	1501	BL	108.3299	05/11	1226	BL				
22	05/08	2000	BL	106.3543	05/10	1502	BL	106.3536	05/11	1227	BL	106.3533	05/12	0948	BL
23	05/09	1400	BL	104.7211	05/10	1503	BL	104.7200	05/11	1228	BL	104.7186	05/12	0949	BL
24	05/08	2000	BL	106.5522	05/10	1504	BL	106.5513	05/11	1230	BL	106.5517	05/12	0951	BL
25	05/08	2000	BL	97.6038	05/10	1506	BL	97.6031	05/11	1231	BL	97.6035	05/12	0952	BL

Filter #	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By	Weight	Date	Time	By
152F	5-7	2000	CP	1.0527	05/09	0749	BL	1.0525	05/10	1507	BL				
152B	5-7	2000	CP	.5693	05/09	0750	BL	.5682	05/10	1508	BL	.5678	05/11	1232	BL
				.5670	05/12	0954	BL								

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	DB	%RH
1	05/09	0715	BL	77	45
2	05/10	1435	BL	78	47
3	05/11	1210	BL	77	46
4	05/12	0940	BL	76	45
5	05/13	0910	BL	77	46

Weighing Session	Date	Time	By	DB	%RH
6					
7					
8					
9					
10					

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates: From 05-18-2002 Through 10-27-2002	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9999	10.0000	.9999	.0999	AKW	05-18	1905	77	49
99.9997	9.9998	.9999	.0998	AKW	05-19	1500	77	48
99.9999	10.0000	.9998	.0999	AKW	05-20	0855	77	47
99.9998	9.9998	1.0000	.0999	AKW	05-21	0930	78	49
99.9998	9.9999	1.0000	.1000	AKW	05-22	1155	78	48
99.9999	9.9999	1.0000	.1001	AKW	05-22	1920	78	49
99.9999	10.0001	1.0001	.0998	AKW	05-23	2105	77	48
99.9998	9.9998	.9998	.0999	AKW	05-28	1225	78	49
99.9998	9.9997	1.0001	.0999	AKW	05-28	1625	78	47
99.9997	10.0001	1.0002	.1000	AKW	06-27	1950	78	49
99.9998	10.0001	1.0002	.1001	AKW	06-29	1830	78	49
99.9997	9.9999	1.0000	.0998	AKW	07-01	0845	77	49
100.0000	9.9999	1.0002	.1000	AKW	07-01	2220	78	47
99.9998	10.0000	.9999	.0999	AKW	08-14	1130	78	49
100.0001	9.9999	1.0000	.1000	AKW	08-16	1045	78	49
100.0000	9.9998	1.0000	.0998	AKW	08-22	1040	78	49
99.9997	9.9999	.9999	.0997	AKW	08-23	0700	78	49
99.9998	10.0000	1.0000	.0998	AKW	08-29	0915	78	49
100.0000	10.0000	1.0002	.1001	AKW	08-29	2225	78	49
99.9998	9.9999	1.0001	.0998	AKW	09-03	1120	78	49
99.9997	9.9998	.9999	.0998	AKW	09-03	2230	78	49
100.0000	10.0001	.9999	.0999	AKW	09-05	1915	78	49
99.9999	9.9999	1.0000	.0999	AKW	09-06	1815	78	48
99.9997	9.9999	1.0000	.0998	AKW	09-07	1355	78	47
100.0000	10.0002	.9998	.0997	AKW	9-10	1110	77	42
99.9997	10.0002	1.0000	.0100	AKW	9-11	1500	74	47
99.9999	9.9999	1.0000	.0997	AKW	9-13	2020	76	38
100.0003	10.0002	1.0002	.0998	AKW	9-14	1300	76	41
100.0000	10.0001	1.0000	.0999	AKW	9-16	1930	74	44
100.0000	9.9999	.9998	.0999	AKW	9-17	1710	77	42
100.0000	10.0001	1.0000	.1000	AKW	9-19	1000	74	47
100.0001	10.0000	.9998	.0999	AKW	9-20	1115	74	44
99.9998	9.9999	1.0001	.0999	AKW	10-18	2155	77	44
99.9997	9.9999	1.0000	.1000	AKW	10-22	2255	77	46
100.0001	10.0002	1.0000	.0999	AKW	10-23	2315	77	42
99.9997	9.9998	.9999	.1000	AKW	10-25	1350	77	43
99.9998	9.9999	1.0000	.1000	AKW	10-26	1735	77	41
99.9998	9.9998	.9999	.1000	AKW	10-27	1130	77	36
99.9998	9.9999	.9999	.0999	AKW	10-27	1435	77	38

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates: From 12-05-2002 Through 02-23-2003	Scale: Sartorius	Model: A 120 S	SN: 37010004
---	----------------------------	--------------------------	------------------------

100 g weight	10 g weight	1 g weight	100 mg weight	Tech	Date	Time	Dry Bulb	% RH
99.9997	9.9998	1.0000	.0997	JKL	12-05	1825	77	47
99.9998	10.0000	.9999	.1000	JKL	12-06	1125	77	45
99.9997	10.0001	1.0000	.1000	JKL	12-07	1310	76	41
99.9997	10.0001	1.0000	.0999	JKL	12-08	1430	77	44
99.9998	9.9999	1.0001	.0999	JKL	12-09	1125	78	44
99.9998	10.0000	.9999	.0998	JKL	12-10	1220	78	43
99.9997	10.0000	.9998	.0998	JKL	12-11	1650	77	45
99.9997	10.0001	.9999	.0999	JKL	12-12	1445	77	47
99.9998	10.0000	.9999	.1000	JKL	12-14	1530	78	47
99.9997	10.0000	1.0000	.0999	JKL	01-10	2300	78	48
99.9998	9.9999	1.0001	.1000	JKL	01-14	1115	77	48
99.9999	10.0000	.9999	.1000	JKL	01-15	1705	77	48
99.9999	10.0001	.9999	.0998	JKL	01-16	1830	78	46
99.9997	10.0000	1.0000	.0999	JKL	01-17	1215	77	41
99.9997	9.9999	1.0000	.0999	JKL	01-17	2035	76	42
99.9996	10.0000	.9999	.0999	JKL	01-18	1730	77	43
99.9999	9.9999	.9998	.0999	JKL	01-19	1210	76	42
99.9998	10.0000	1.0000	.0999	JKL	01-20	2105	76	44
99.9999	10.0000	.9999	.0998	JKL	01-21	0935	75	44
99.9998	10.0000	.9999	.0999	JKL	01-22	1125	77	46
100.0000	9.9998	.9999	.1000	JKL	01-23	1430	77	48
99.9999	10.0001	1.0001	.1000	JKL	01-24	1200	76	48
99.9998	9.9999	.9999	.0999	JKL	01-25	1140	76	47
99.9997	10.0000	1.0000	.0999	JKL	01-25	1850	78	48
99.9998	9.9998	1.0000	.1000	JKL	01-27	1415	75	47
99.9999	9.9999	1.0000	.1000	JKL	01-30	1920	77	48
99.9998	10.0000	.9998	.0999	JKL	01-31	2205	78	47
99.9999	9.9998	.9998	.1000	JKL	02-01	1855	77	47
99.9997	9.9998	.9999	.1001	JKL	02-02	1420	76	46
99.9997	10.0001	.9998	.0999	JKL	02-18	1155	77	49
99.9999	9.9999	.9999	.0999	JKL	02-19	1925	77	48
99.9997	10.0000	1.0000	.0999	JKL	02-22	2010	78	45
99.9997	10.0000	.9999	.1000	JKL	02-23	1130	78	44

BLANK PROCESSING DATA SHEET # 5

UNIT : F600 RUN : 6 DATE : 05/07/03

DATE BLANKS DONE : 02-23-03

BEAKER	A	B	C
	200 ml ACETONE	75 ml DICHLOR	200 ml WATER
	FISHER OPTIMA LOT # 011755	FISHER OPTIMA LOT # 994669	DWNA, INC. SPARKLETES DISTILLED
FINAL WEIGHT	108.9007	106.3074	106.9660
TARE WEIGHT	108.8995	106.3057	106.9646
NET WEIGHT	.0012 ✓	.0017 ✓	.0014 ✓

TARE BEAKERS INTO DESC : TIME : 1430 DATE : 02-12-03

DATE : 02-18 BY : BL DATE : 02-19 BY : BL DATE : _____ BY : _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.8996	1158	108.8995	1928	✓	
B	106.3060	1159	106.3057	1930	✓	
C	106.9649	1200	106.9646	1931	✓	

FINAL BEAKERS INTO DESC : TIME : 1600 DATE : 02-20-03

DATE : 02-22 BY : BL DATE : 02-23 BY : BL DATE : _____ BY : _____

BEAKER	1 ST WT	TIME	2 ND WT	TIME	3 RD WT	TIME
A	108.9010	2013	108.9007	1132	✓	
B	106.3078	2015	106.3074	1133	✓	
C	106.9661	2016	106.9660	1134	✓	

TARE QC

DATE	TIME	BY	WB	DB	%
02-18	1155	BL	}	77	49
02-19	1925	BL		77	48

FINAL QC

DATE	TIME	BY	WB	DB	%
02-22	2010	BL	}	78	45
02-23	1130	BL		78	44

NET PARTICULATE CATCH CALCULATION DATA SHEET #6

UNIT: F600 RUN: 6 DATE: 05/07/03

BLANK CALCULATIONS

Acetone : $\frac{.0012 \text{ g}}{200 \text{ ml}} = .000006 \text{ g/ml}$ ✓
 Dichloromethane : $\frac{.0017 \text{ g}}{75 \text{ ml}} = .000023 \text{ g/ml}$ ✓
 Distilled Water : $\frac{.0014 \text{ g}}{200 \text{ ml}} = .000007 \text{ g/ml}$ ✓

FRONT HALF CATCH

FILTERS : $\frac{.3543 \text{ g}}{1 \text{ # of Filters}} - (.0000 \text{ g}) = .3543 \text{ g}$ ✓
 BEAKERS : $\frac{.0938 \text{ g}}{65 \text{ ml Acetone}} - (.000006 \text{ g}) = .0934 \text{ g}$ ✓
TOTAL FRONT HALF CATCH : .4477 g ✓

BACK HALF CATCH

FILTERS : $\frac{.1354 \text{ g}}{1 \text{ # of Filters}} - (.0000 \text{ g}) = .1354 \text{ g}$ ✓
 BEAKERS :
 Acetone : $\frac{.4175 \text{ g}}{200 \text{ ml Acetone}} - (.000006 \text{ g}) = .4163 \text{ g}$ ✓
 Extract : $\frac{.1293 \text{ g}}{75 \text{ ml Dichloromethane}} - (.000023 \text{ g}) = .1276 \text{ g}$ ✓
 Water : $\frac{.2613 \text{ g}}{375 \text{ ml Water}} - (.000007 \text{ g}) = .2587 \text{ g}$ ✓
TOTAL BACK HALF CATCH : .9380 g ✓

TOTAL CATCH : 1.3857 g ✓

% FRONT HALF : 32.3 % ✓
 (00.0)

CALCULATIONS DATA SHEET # 7

UNIT: JOTUL F600 RUN: 6 DATE: 05/07/03

$$1) Vm (std) = \frac{(135.109 \checkmark Vm) (17.64 \checkmark) (990 \checkmark mcf) (29.94 \checkmark Hg + \frac{.237 \checkmark H_2O}{13.6})}{(541 \checkmark TmA)} = \frac{130.6548 \checkmark}{000.0000} \text{ dscf}$$

$$2) Vw (std) = (.04707) (286.5 \checkmark \text{ ml H}_2\text{O}) = \frac{13.4856 \checkmark}{00.0000} \text{ scf}$$

$$3) Asw = \frac{(13.4856 \checkmark \text{ scf} + 130.6548 \checkmark \text{ dscf})}{(13.4856 \checkmark \text{ scf})} = \frac{.0936 \checkmark}{.0000} \text{ Bws} \times 100 = \frac{9.3558 \checkmark}{00.0000} \% \text{ H}_2\text{O}$$

$$4) Cs = \frac{(1.3857 \checkmark \text{ g.})}{(130.6548 \checkmark \text{ dscf})} (15.43) = \frac{.1636 \checkmark}{0.0000} \text{ gr / dscf}$$

$$5) \text{ Estimated g / hr} = \frac{(1.3857 \checkmark \text{ g.})}{(130.6548 \checkmark \text{ dscf})} (7.098 \checkmark \text{ dscfm}) (60) = \frac{4.5168 \checkmark}{00.0000} \text{ g / hr}$$

Vm =	total cubic feet pulled on meter box during test	(000.000 Vm)
mcf =	meter correction factor (Y factor) of meter box used for test	(0.000 mcf)
" Hg =	average barometric pressure during test	(00.00 " Hg)
" H ₂ O =	average delta H for test	(.000 " H ₂ O)
TmA =	average meter temperature for test in degrees Absolute	(000 TmA)
ml H ₂ O =	total water caught during test	(000.0 ml H ₂ O)
g. =	total particulate catch for test	(00.0000 g.)
dscfm =	average stack flow during test	(00.0000 dscf)

TEST DATA SHEET # 8

UNIT: F600 RUN: 6 DATE: 5-7-03

Test Chamber Air Velocity Start: 0 Stop: 0 Avg.: 0

Wet Bulb / Dry Bulb

Pre : WB : 58 DB : 77 = 29 % RH 1.0 % H₂O

Post : WB : 59 DB : 77 = 32 % RH 1.0 % H₂O

Average : 30.5 % RH 1.0 % H₂O

Empty Stove Weight (lbs) : _____ w/ stack & oil seal : Wet : _____ Dry : 0.0

Kindling Weight (lbs) : Paper : .3 Wood : 3.8

Preburn Fuel Weight : 20.0 + 14.5 + 17.8 Total : 52.3

Kindling & Preburn Fuel Weight (wood only) (lbs) : Total : 56.1

Coal Bed Wt Range (lbs) : 4.4 - 3.6 Scale : 4.4 : 3.6

Upper : .25 x fuel weight : Always round DOWN to nearest tenth
 Lower : .20 x fuel weight : Always round UP to nearest tenth
 Actual Coal Bed Weight : 4.4

Maximum Coal Bed Removal (lbs) : $(\frac{4.4}{\text{Upper}} + \frac{3.6}{\text{Lower}}) \div 2) \cdot .25 = \underline{1.0}$ round down to nearest tenth

Test Fuel (.75" x 1.5" x 5" spacers) = 20 pcs

Dimensions	Length in inches	No. Pcs	Weight in lbs	% of Load
2" x 4"	17	4	9.5	53.4
4" x 4"	17	2	8.3	46.6

Test Fuel Weight : 17.8 lbs

Estimated Dry Burn Rate :

$$\frac{17.8 - (17.8 \times .18345)}{2.2046} \times \frac{60}{355} = \underline{1.114} \text{ kg/hr}$$

Estimated BTU's/hr : $19,140 \times \frac{63}{100} \times \frac{1.114}{\text{DBR}} = \underline{13,436.3}$ BTU's/hr

EPA Default Efficiencies : Non-cat : 63 Cat : 72 Pellet : 78

WOOD STOVE OPERATING DATA PAGE #9

Unit: FG00 Run: 6 Date: 5-7-03

FIRE STARTED: 0915

WARM UP AND PREBURN:

PRIMARY AIR: Set wide open for all warm-up / preburn fuel charges. Then set to 3/16" at start of preburn.

SECONDARY AIR: N/A CAT BYPASS: N/A

CHARCOAL BED PREPARATION:

Raked and leveled prior to each warm-up / preburn charge. At 1 1/2 min. prior to loading last fuel, raked and leveled. In stove 35 sec.

TEST:

DOOR wide open during loading 0 min. 45 sec.

PRIMARY AIR: Opened full for first 5 min., then set to run setting of 3/16".

SECONDARY AIR: N/A CAT BYPASS: N/A

FAN:

ON / ~~OFF~~ during warm-up

ON / ~~OFF~~ during preburn

ON / ~~OFF~~ first ALL minutes of test

ON / ~~OFF~~ balance of test run

Fan speed set at OFF

WOOD DATA: KINDLING: A mix of the grades listed below:

	SIZE	MILL	GRADE	SPECIES
PREBURN:	2x4	Manke/Tacoma	Std. or better	s. grn D fir
TEST:	2x4	Packwood	# 2 or better	s. grn D fir
	4x4	Packwood	# 2 or better	s. grn D fir

PELLET FUEL MANUFACTURER: N/A BRAND: N/A

All Grades WCLB rules:

WARM UP INFORMATION:

All pre-burn / warm up fuel pieces were either 16 or - inches.

1st warm up / pre-burn fuel charge (20.0 lbs.) added at 0925

2nd warm up / pre-burn fuel charge (14.5 lbs.) added at 1030

3rd warm up / pre-burn fuel charge (17.8 lbs.) added at 1135

4th warm up / pre-burn fuel charge (____ lbs.) added at _____

5th warm up / pre-burn fuel charge (____ lbs.) added at _____

TEST DATA SHEET #10

Unit : F600 Run : 6 Date : 5703
 Room Temperature : 72 °F Correction Factor : 0
 Uncorrected Values are corrected for room temperature : Yes _____ No
 Time Test Fuel moisture reading taken : 1046 ✓
 Calibration Checks : X Y 12.0 12.1 22.0 22.1

pc #	Dimen.	Use	TOP		BOTTOM		SIDE		Average Corrected
			Uncor.	Cor.	Uncor.	Cor.	Uncor.	Cor.	
1	2"x4"x8'	K	17.0	18.2	16.5	17.6	16.5	17.6	17.800
2									
3									
4	2"x4"x8'	P	18.5	19.8	19.5	20.9	19.5	20.9	20.533
5	2"x4"x8'	P	20.0	21.4	20.0	21.4	20.0	21.4	21.400
6	2"x4"x8'	P	22.5	24.1	21.0	22.5	21.5	23.1	23.233
7	2"x4"x8'	P	18.0	19.2	19.5	20.9	18.5	19.8	19.967
8	2"x4"x8'	P							85.133
9									
10		T	17.5	18.7	18.5	19.8	18.5	19.8	19.433
11		T	21.5	23.1	21.5	23.1	21.5	23.1	23.100
12		T	21.5	23.1	20.0	21.4	22.0	23.7	22.733
13		T	23.5	25.2	23.5	25.2	23.5	25.2	25.200
14	4x4x17	T	20.5	22.0	20.5	22.0	20.5	22.0	22.000
15	"	T	20.5	22.0	21.0	22.5	21.0	22.5	22.333
16									134.799
17									
18									
19									
20	Spacers	T	21.5	23.1	22.0	23.7	22.0	23.7	23.500

Key for Use : K = Kindling P = Pretest Fuel T = Test Fuel

	KINDLING	PRETEST FUEL	TEST FUEL
Dry Moisture % :	17.800 %	21.283 %	22.467 %
Wet Moisture % :	15.110 %	17.548 %	18.345 %

To obtain Wet from Dry : $\frac{100 \times \% \text{ Dry Reading}}{100 + \% \text{ Dry Reading}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges : 16 - 20 % wet: 19 - 25 % dry (17.5 - 22.5 on Meter Uncor. reading) at 70°

GAS DATA SHEET #12

WEIGHT: 4.4

DATE: 05/07/03

UNIT: F600

RUN: 6

PAGE: 1 OF 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO ₂ PPM
0 1355	22.2	17.8	-	.1061	11.5	.746	18.6	.066	.67	-.024	600
5 1400	21.7	17.3	.5	.193	4.8	.622	15.6	.044	.45	-.032	275
10 05	21.5	17.1	.2	.122	3.0	.684	17.1	.066	.67	-.027	575
15 10	21.3	16.9	.2	.133	3.3	.671	16.8	.072	.73	-.025	600
20 15	21.1	16.7	.2	.147	3.6	.653	16.3	.081	.82	-.025	625
25 20	20.9	16.5	.2	.161	4.0	.636	15.9	.090	.91	-.024	650
30 25	20.6	16.2	.3	.176	4.4	.622	15.5	.088	.89	-.024	650
35 30	20.2	15.8	.4	.227	5.6	.553	13.8	.133	1.34	-.027	650
40 35	19.7	15.3	.5	.256	6.4	.528	13.2	.122	1.23	-.029	550
45 40	19.2	14.8	.5	.228	5.7	.564	14.1	.103	1.04	-.031	525
50 45	18.8	14.4	.4	.328	8.2	.467	11.7	.094	.95	-.035	475
55 50	18.0	13.6	.8	.367	9.1	.439	11.0	.067	.68	-.038	425
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-.341	*****
60 1455	17.4	13.0	.6	.398	9.9	.417	10.4	.044	.45	-.041	375
65 1500	16.7	12.3	.7	.389	9.7	.432	10.8	.028	.29	-.045	375
70 05	16.2	11.8	.5	.321	8.0	.485	12.1	.066	.67	-.043	375
75 10	15.6	11.2	.6	.352	8.8	.462	11.5	.047	.48	-.045	350
80 15	15.0	10.6	.6	.387	9.6	.431	10.8	.036	.37	-.046	350
85 20	14.4	10.0	.6	.392	9.8	.427	10.7	.035	.36	-.046	375
90 25	13.7	9.3	.7	.394	9.8	.423	10.6	.039	.40	-.047	375
95 30	13.1	8.7	.6	.401	10.0	.415	10.4	.041	.42	-.048	375
100 35	12.6	8.2	.5	.354	8.8	.463	11.6	.038	.39	-.045	425
105 40	12.2	7.8	.4	.293	7.3	.503	12.6	.092	.93	-.042	450
110 45	11.8	7.4	.4	.288	7.2	.501	12.5	.109	1.10	-.041	450
115 50	11.3	6.9	.5	.359	8.9	.448	11.2	.064	.65	-.043	400
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-.532	*****
120 1555	10.7	6.3	.6	.415	10.3	.400	10.0	.044	.45	-.046	400
125 1600	10.1	5.7	.6	.469	11.7	.349	8.7	.036	.37	-.047	375
130 05	9.4	5.0	.7	.471	11.7	.345	8.6	.042	.43	-.048	375
135 10	8.9	4.5	.5	.433	10.8	.385	9.6	.036	.37	-.046	425
140 15	8.5	4.1	.4	.350	8.7	.476	11.9	.017	.18	-.045	400
145 20	8.2	3.8	.3	.348	8.7	.473	11.8	.028	.29	-.043	400
150 25	7.9	3.5	.3	.326	8.1	.489	12.2	.045	.46	-.042	425
155 30	7.7	3.3	.2	.265	6.6	.519	13.0	.121	1.22	-.039	475
160 35	7.5	3.1	.2	.265	6.6	.521	13.0	.116	1.17	-.038	475
165 40	7.4	3.0	.1	.222	5.5	.535	13.4	.188	1.89	-.036	525
170 45	7.2	2.8	.2	.198	4.9	.548	13.7	.216	2.17	-.033	550
175 50	7.1	2.7	.1	.189	4.7	.553	13.8	.228	2.29	-.031	550
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-.494	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-1.367	*****

GAS DATA SHEET #12

WEIGHT: 4.4

DATE: 05/07/03

UNIT: F600

RUN: 6

PAGE: 2 OF 2

TIME	SCALE	FUEL	DROP	V.	CO ₂	V.	O ₂	V.	CO	STATIC	SO ₂ PPM
180 1655	7.0	2.6	.1	.178	4.4	.562	14.0	.232	2.33	7030	525
185 1700	7.0	2.6	⊖	.176	4.4	.561	14.0	.240	2.41	7030	525
190 05	6.9	2.5	.1	.182	4.5	.551	13.8	.249	2.50	7028	525
195 10	6.9	2.5	⊖	.182	4.5	.552	13.8	.247	2.48	7028	525
200 15	6.8	2.4	.1	.184	4.6	.549	13.7	.249	2.50	7027	525
205 20	6.7	2.3	.1	.189	4.7	.540	13.5	.259	2.60	7026	525
210 25	6.7	2.3	⊖	.185	4.6	.553	13.8	.237	2.38	7026	525
215 30	6.6	2.2	.1	.186	4.6	.553	13.8	.234	2.35	7026	525
220 35	6.5	2.1	.1	.183	4.5	.552	13.8	.245	2.46	7025	525
225 40	6.4	2.0	.1	.183	4.5	.551	13.8	.246	2.47	7025	525
230 45	6.3	1.9	.1	.181	4.5	.556	13.9	.246	2.41	7025	550
235 50	6.3	1.9	⊖	.181	4.5	.559	14.0	.231	2.32	7025	550
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-7321	*****
240 1755	6.1	1.7	.2	.181	4.5	.561	14.0	.226	2.27	7024	550
245 1800	6.1	1.7	⊖	.180	4.5	.563	14.1	.225	2.26	7024	550
252 05	6.0	1.6	.1	.179	4.4	.563	14.1	.226	2.27	7023	550
255 10	6.0	1.6	⊖	.174	4.3	.570	14.2	.222	2.23	7022	550
260 15	5.9	1.5	.1	.174	4.3	.568	14.2	.227	2.28	7022	550
265 20	5.9	1.5	⊖	.170	4.2	.576	14.4	.218	2.19	7022	550
270 25	5.8	1.4	.1	.173	4.3	.572	14.3	.219	2.20	7021	550
275 30	5.7	1.3	.1	.172	4.3	.572	14.3	.221	2.22	7021	550
280 35	5.7	1.3	⊖	.173	4.3	.571	14.3	.223	2.24	7021	550
285 40	5.5	1.1	.2	.173	4.3	.573	14.3	.218	2.19	7021	550
290 45	5.5	1.1	⊖	.170	4.2	.577	14.4	.215	2.16	7021	575
295 50	5.5	1.1	⊖	.169	4.2	.579	14.5	.213	2.14	7022	550
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-264	*****
300 1855	5.4	1.0	.1	.168	4.2	.580	14.5	.211	2.12	7021	550
305 1900	5.3	.9	.1	.170	4.2	.577	14.4	.214	2.15	7021	550
310 05	5.2	.8	.1	.172	4.3	.572	14.3	.222	2.23	7021	550
315 10	5.1	.7	.1	.172	4.3	.573	14.3	.219	2.20	7021	550
320 15	5.1	.7	⊖	.171	4.2	.576	14.4	.214	2.15	7021	550
325 20	5.0	.6	.1	.170	4.2	.580	14.5	.208	2.09	7021	550
330 25	4.9	.5	.1	.248	6.2	.515	12.9	.173	1.74	7021	550
335 30	4.8	.4	.1	.240	6.0	.527	13.2	.163	1.64	7021	525
340 35	4.7	.3	.1	.223	5.5	.541	13.5	.171	1.72	7021	525
345 40	4.6	.2	.1	.203	5.0	.556	13.9	.185	1.86	7021	525
350 45	4.5	.1	.1	.193	4.8	.560	14.0	.200	2.01	7021	525
355 50	4.4	⊖	.1	.184	4.6	.569	14.2	.200	2.01	7021	525
SUBTOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-837	*****
TOTAL	*****	*****	*****	*****	*****	*****	*****	*****	*****	-2.204	*****

-1031.72 ✓

TEMPERATURE DATA SHEET #14

		TEST TIME	355		
STACK AVG	244	TOP AVG	275	LT SIDE AVG	276
BACK AVG	284	RT SIDE AVG	257	BOTTOM AVG	204
FIREBOX AVG	549	SEC/CAT AVG	775	AMBIENT AVG	72

END 221.4
START 281.7 ✓

-60.3 DELTA T

CIRCLE: LOSS / GAIN

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube Furn	Smpl Box	Smpl Out	C-Gas Box	C-Gas Out	SO2 Out
0	217	235	287	334	271	281	516	626	73	1296	237	58	248	38	39
5	364	241	274	317	261	271	429	1015	74	1303	237	42	248	38	37
10	207	235	261	294	251	260	406	598	72	1307	236	40	249	38	37
15	191	224	248	276	241	254	382	576	73	1310	236	41	248	39	38
20	185	216	237	261	231	248	366	584	72	1311	236	41	248	39	35
25	182	211	227	250	221	242	353	592	73	1311	236	41	248	37	35
30	181	206	219	239	214	237	343	859	73	1311	236	42	249	37	36
35	199	214	212	230	209	232	342	716	73	1311	236	42	249	36	37
40	222	221	207	223	204	227	344	875	73	1312	236	42	248	37	37
45	235	231	204	217	202	222	357	845	73	1317	237	42	249	36	38
50	257	240	202	213	201	216	367	1139	73	1322	237	42	248	37	38
55	296	273	204	211	204	213	382	1080	73	1330	237	43	248	36	37
60	327	312	209	210	210	207	403	1115	72	1338	238	43	248	36	36
65	351	343	217	212	220	205	437	1074	72	1342	238	43	249	34	37
70	337	352	225	214	231	203	458	947	73	1338	239	43	250	34	37
75	349	357	234	217	242	200	484	949	72	1331	238	43	249	34	35
80	369	372	246	221	252	199	512	997	73	1325	238	44	249	35	36
85	375	385	258	225	262	196	542	997	72	1322	238	44	249	35	37
90	377	393	271	231	272	197	568	1013	73	1319	238	44	249	35	37
95	382	401	283	237	282	196	597	1058	73	1316	239	45	249	35	36
100	345	404	296	245	292	197	615	998	73	1318	239	46	249	37	37
105	315	391	304	251	297	197	615	937	73	1321	238	46	249	37	37
110	308	379	306	256	298	196	616	920	73	1325	238	47	248	37	37
115	352	382	310	262	302	197	641	1023	73	1326	238	48	247	36	37
120	378	390	319	269	307	198	668	1064	73	1327	238	48	247	36	37
125	398	412	331	280	318	200	696	1099	74	1328	238	48	247	38	37
130	411	432	344	293	328	202	725	1134	74	1330	238	48	248	38	38
135	371	442	356	308	338	204	732	1122	75	1331	238	48	249	37	37
140	346	428	362	318	344	205	723	1050	75	1333	239	49	248	37	37
145	333	418	363	325	346	206	720	1041	74	1335	238	50	248	37	37
150	322	411	364	330	345	209	733	1021	75	1336	237	51	247	37	36
155	296	388	363	335	343	212	731	953	75	1337	236	51	246	37	37
160	284	368	361	339	341	212	733	919	75	1337	236	51	246	37	37
165	273	350	358	343	337	212	719	892	75	1337	235	51	245	37	38
170	247	333	353	342	333	214	693	842	75	1338	234	51	245	37	38
175	236	318	347	337	326	216	672	800	76	1337	234	52	244	38	38

Time	Stack	Top	LT Side	Back	Rt Side	Bottom	Firebox	Sec/Cat	Ambient	Tube Furn	Smpl Box	Smpl Out	C-Gas Box	C-Gas Out	SO2 Out
180	228	304	338	332	319	215	653	768	74	1336	234	53	243	38	37
185	222	291	329	326	310	213	638	737	74	1335	233	53	243	36	37
190	216	280	321	322	301	213	626	716	74	1333	232	53	241	36	37
195	212	271	314	319	294	213	614	701	74	1331	232	53	242	37	37
200	207	261	308	316	286	212	604	687	73	1325	232	53	241	36	36
205	204	253	302	314	281	210	595	677	73	1320	234	53	243	35	36
210	202	246	296	313	272	209	587	671	73	1316	234	53	243	35	36
215	198	241	291	311	267	207	580	663	72	1311	234	53	242	35	36
220	195	236	287	310	261	205	572	655	71	1306	234	53	242	35	35
225	193	232	283	310	258	205	565	647	72	1303	235	53	242	35	35
230	191	227	280	309	253	203	558	640	71	1300	235	53	243	35	35
235	189	225	275	308	249	199	551	634	70	1297	235	52	242	34	35
240	188	221	273	308	245	198	544	628	70	1294	235	52	243	34	35
245	186	217	269	307	242	197	539	626	70	1292	235	53	242	35	34
250	185	215	266	306	238	196	535	621	70	1292	236	53	242	35	35
255	183	213	264	305	235	194	530	616	70	1292	236	53	243	35	35
260	182	211	260	303	233	191	527	611	70	1292	237	53	243	34	36
265	181	208	258	301	230	189	523	605	70	1293	237	53	243	34	36
270	179	206	257	299	227	190	521	598	71	1293	237	53	243	35	36
275	178	204	255	296	225	189	520	591	71	1292	236	53	243	35	35
280	178	201	252	292	222	186	520	586	69	1291	237	54	242	35	36
285	176	200	252	291	220	187	520	581	70	1290	236	54	243	36	35
290	176	199	250	290	217	183	518	575	69	1290	236	54	242	35	37
295	175	197	248	288	215	181	518	570	68	1296	236	55	242	36	36
300	173	196	247	286	214	179	517	565	67	1300	236	55	241	37	35
305	173	195	246	285	212	177	520	560	67	1303	235	55	240	37	37
310	174	193	246	286	211	179	525	556	69	1305	236	55	242	37	36
315	174	192	247	286	210	177	528	553	69	1307	236	57	243	37	37
320	174	191	248	287	209	175	530	551	69	1307	237	57	243	38	38
325	173	190	248	286	208	173	531	548	69	1307	237	57	243	38	36
330	176	189	248	285	208	174	539	580	69	1308	237	57	244	36	36
335	180	190	251	281	207	172	558	615	70	1309	237	57	244	36	38
340	180	191	252	278	207	174	560	610	69	1312	237	54	244	36	36
345	178	191	254	277	208	174	555	604	70	1313	236	53	244	36	36
350	178	192	255	275	208	174	547	596	69	1312	236	54	244	36	36
355	177	191	256	274	210	177	539	588	70	1313	236	54	245	37	36

ZERO / SPAN CHECK DATA SHEET #15-1

Date : 05/07/03

Analyte : CO₂ (15-1)

Unit : FLOO

Run # : 10

Zero Cyl. # : 04RTAC 2-A Conc. : 0.00 % CO₂

Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % CO₂

Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE

Date : 03-13-03

Analyzer : Make : HORIBA

Model : PIR-2000

SN : 407069

Range : 0 - 25.0 % CO₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % CO₂

EPA Control Limits = ± 2.5% of 25.0 % CO₂ = ± 0.625 % CO₂

Method 28 A = ± .2 % of 25.0 % CO₂ = ± .05 % CO₂

PRE RUN Audit : by : A. Wadsworth Time : 1215 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	-0.048	-0.048	-1.91
SPAN	49.6	.496	12.40	49.4	.494	12.317	-0.083	-3.33

POST RUN Audit : by : A. Wadsworth Time : 2005 Temp : 70 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	-0.023	-0.023	-0.91
SPAN	49.6	.496	12.40	49.5	.495	12.342	-0.058	-2.33

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-2

Date : 05/07/03

Analyte : O₂ (15-2)

Unit : F600

Run # : 6

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % O₂

Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % O₂

Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE

Date : 03-13-03

Analyzer : Make : TELEDYNE Model : 320 A

SN : 37400

Range : 0 - 25.0 % O₂

Analyzer Output : 0 - 1.0 v.

Flow : 1.5 SCFH

Measured by : Rotameter

EPA Span Value = 25.0 % O₂

EPA Control Limits = $\pm 2.5\%$ of 25.0 % O₂ = $\pm 0.625 % O_2$

Method 28 A = $\pm .2 %$ of 25.0 % O₂ = $\pm .05 % O_2$

PRE RUN Audit : by : D. Washington Time : 1215 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.025	+ .025	+ .101
SPAN	12.50	.500	12.50	12.55	.501	12.526	+ .026	+ .105

POST RUN Audit : by : D. Washington Time : 2005 Temp : 70 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.050	+ .050	+ .201
SPAN	12.50	.500	12.50	12.55	.501	12.526	+ .026	+ .105

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-3

Date : 05/07/03

Analyte : CO (15-3)

Unit : F600

Run # : 6

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 % CO

Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE

Date : 02-20-02

Span Cyl. # : CC-3131 Conc. : 12.40 % CO

Cyl. Press. : 1625 PSI

Certified by : AIR LIQUIDE

Date : 03-13-03

Analyzer : Make : HORIBA
Range : 0 - 10.0 % CO
Flow : 1.5 SCFH

Model : PIR-2000

SN : 408005

Analyzer Output : 0 - 1.0 v.

Measured by : Rotameter

EPA Span Value = 10.0 % CO

EPA Control Limits = ± 2.5% of 10.0 % CO = ± 0.25 % CO

Method 28 A = ± .2 % of 10.0 % CO = ± .02 % CO

PRE RUN Audit : by : D. Wadlington Time : 1215 Temp : 78 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.000	.011	+0.11	+1.10 ✓
SPAN	50.2	.502	5.02	50.1	.501	5.020	.000	+0.03 ✓

POST RUN Audit : by : D. Wadlington Time : 2005 Temp : 70 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.0	.001	.001	+0.001	+0.010 ✓
SPAN	50.2	.502	5.02	50.2	.502	5.030	+0.010	+0.097 ✓

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

ZERO / SPAN CHECK DATA SHEET #15-4

Date : 05/07/03

Analyte : SO₂ (15-4)

Unit : F600

Run # : 6

Zero Cyl. # : 042TAC 2-A Conc. : 0.00 ppm SO₂ Cyl. Press. : 900 PSI

Certified by : AIR LIQUIDE Date : 02-20-02

Span Cyl. # : CC6284 Conc. : 1290 ppm SO₂ Cyl. Press. : 1025 PSI

Certified by : AIR LIQUIDE Date : 01-29-01

Analyzer : Make : HORIBA Model : PIR-2000 SN : 403019
 Range : 0 - 2500 ppm SO₂ Analyzer Output : 0 - 1.0 v.
 Flow : 1.5 SCFH Measured by : Rotameter

EPA Span Value = 2500 ppm SO₂
 EPA Control Limits = ± 2.5% of 2500 ppm SO₂ = ± 62.5 ppm SO₂

PRE RUN Audit : by : A. Wadsworth Time : 1210 Temp : 77 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.2	.002	11.696	+11.696	+468
SPAN	51.6	.516	1290	51.8	.518	1295.028	+5.028	+201

POST RUN Audit : by : A. Wadsworth Time : 2005 Temp : 70 °F

AUDIT RESULTS

Point #	Expected Response			Actual Response			± Conc. Difference	Δ %
	Meter	DVM	PPM	Meter	DVM	%		
ZERO	00.0	.000	00.0	00.2	.002	11.696	+11.696	+468
SPAN	51.6	.516	1290	51.8	.518	1295.028	+5.028	+201

± Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

QUALITY CHECKS DATA SHEET # 16

UNIT: FL600 RUN: 6 DATE: 5-7-03

Thermocouple Check:

T/C # 1	<u> </u> °F	T/C # 13	<u>59.0</u> °F
T/C # 2	<u> </u> °F	T/C # 14	<u>57.1</u> °F
T/C # 3	<u>59.8</u> °F	T/C # 15	<u>59.6</u> °F
T/C # 4	<u>54.2</u> °F	T/C # 16	<u>53.0</u> °F
T/C # 5	<u>53.1</u> °F	T/C # 17	<u>53.9</u> °F
T/C # 6	<u>52.9</u> °F	T/C # 18	<u>61.6</u> °F
T/C # 7	<u>52.9</u> °F	T/C # 19	<u>55.3</u> °F
T/C # 8	<u>52.2</u> °F	T/C # 20	<u> </u> °F
T/C # 9	<u>53.5</u> °F	T/C # 21	<u> </u> °F
T/C # 10	<u>53.9</u> °F	T/C # 22	<u> </u> °F
T/C # 11	<u>52.0</u> °F	T/C # 23	<u>54.8</u> °F
T/C # 12	<u>64.0</u> °F	T/C # 24	<u> </u> °F

Thermocouple Readout:

<p>Pretest zero and span check and calibration</p> <p>ZERO <u>.8</u> °F Adj. to <u>0.0</u> °F</p> <p>SPAN <u>1996.5</u> °F Adj. to <u>2000.0</u> °F</p>	<p>post test zero and span</p> <p>ZERO <u>.6</u> °F Difference <u>.030</u> % ✓</p> <p>SPAN <u>2004.2</u> °F Difference <u>.210</u> % ✓</p>
---	--

Thermocouple Readout Pretest Linearity Check:


0 = <u>0.0</u> °F	200 = <u>201.6</u> °F	400 = <u>399.0</u> °F
600 = <u>601.2</u> °F	800 = <u>801.4</u> °F	1000 = <u>1000.4</u> °F
1200 = <u>1198.1</u> °F	1400 = <u>1399.0</u> °F	1600 = <u>1599.6</u> °F
1800 = <u>1800.0</u> °F	2000 = <u>2000.0</u> °F	

Sample Train Leak Check	Pre <u>X</u>	Post <u>✓</u>
C-gas Train Leak Check	Pre <u>✓</u>	Post <u>✓</u>
SO ₂ Train Leak Check	Pre <u>✓</u>	Post <u>✓</u>
Static Gauge Zero Check	Pre <u>X</u>	Post <u>✓</u>


Scale Check Pre: 3.2 - 13.2 ✓

Post: 3.4 - 13.4 ✓

Stack Cleaned Prior to Test Run: YES NO X



INSPECTION CERTIFICATE



934 Elliott Avenue W.
Seattle, WA 98119
Ph#(206)284-6090
Fax#(206)282-6612

CUSTOMER: LOKKE TESTING
 ADDRESS: 13235 Prairie Circle
Sumner WA 98390
 TECHNICIAN: Patrick McLellan
 AUTHORIZATION SIGNATURE: _____

DATE OF INSPECTION: 11-26-02
 NEXT INSPECTION DUE: 5-03
 CERTIFICATION TYPE
 STANDARD
 ISO 9000
 MIL STD-45662

EQUIPMENT TESTED

INDICATOR	BASE	OPTIONS INSTALLED
MAKE <u>weightronix</u>	_____	PRINTER _____
MODEL <u>WT-110</u>	_____	SCORE BOARD _____
SR# <u>16409</u>	_____	COMPUTER _____
CLASS <u>III</u>	_____	OTHER _____
CAP. <u>1000 lbs</u>	_____	
PRE-TEST <u>∅</u>	POST-TEST <u>∅</u>	MANUFACTURER TOLERANCE
<u>998.7</u>	<u>499.9</u>	_____
_____	<u>1000.0</u>	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
CORNER TEST P <input checked="" type="checkbox"/> F _____		
SHIFT TEST P <input checked="" type="checkbox"/> F _____		
STATIC TEST 2 MIN. <input checked="" type="checkbox"/> 5 MIN. _____		
WEIGHT KIT# _____	NIST# _____	
SERIAL NUMBERS OF WEIGHTS USED (OR COPY OF CERTIFICATE)		
<u>T23-13</u>	<u>T23-14</u>	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

ANY CHANGES TO DOCUMENT OR SCALE NOT AUTHORIZED BY
 PHILLIPS & MORRIS SCALE COMPANY VOIDS THIS CERTIFICATE.



METROLOGY LABORATORY

Receipt Date: January 29, 2002
 Test Date: February 13, 2002
 Report Date: February 13, 2002

State Test Number: L2017-1
 Group ID: SHOP
 Due Date: February 13, 2004

CALIBRATION REPORT

Phillips Morris Scale Company
 934 Elliott Ave. W
 Seattle, WA 98119-3608
 Contact: Todd Mackie
 Phone: 206-284-6090
 PO Number: 2-2-009237
 SOP: 8

Item(s) Submitted: See Table Below
 Specification: NIST HB 105-1, Class F
 Condition: Good
 Temperature: 21.0 °C
 Pressure: 762.0 mmHg
 Humidity: 35 % RH
 Technician ID: DW

Description	Value / Range	Qty	Material	Manufacture	Serial Number
Test Weight	1000 lb	5	Cast Iron	Rice Lake	OFT0, OFT1, OFT2, OFSY, OFSZ
Test Weight	500 lb	12	Cast Iron	Rice Lake	T23-13 to T23-16, T23-20, T23-24, T23-26, T23-28 to T23-32
Test Weight	50 lb	30	Cast Iron	Rice Lake	877B, N1039, N1041, T23-1 to T23-10, T23-19 to T23-28, WA171-0, WA1712-0 to WA172-2, WA173-2, WA237, X694
Test Weight	25 lb	2	Cast Iron	Rice Lake	WA238, T23-11
Weight Set, 7 pc	10 lb - 8 oz	1	Stainless Steel	Rice Lake	WA177-7
Weight Set, 12 pc	5 kg - 200 g	1	Stainless Steel	Rice Lake	SK

The item(s) listed above have been found and/or left within the stated tolerances for the specification stated above, except as noted. The item(s) listed above have been compared to the Standards of the State of Washington, which are currently in control. These standards values are traceable to the National Institute of Standards and Technology (NIST) through NIST Test Numbers 822/264514-01 and Minnesota Metrology Laboratory Report Number 307 430. Calibration processes were monitored and found to be in control. The expanded uncertainty (k=2) for each item listed in this report is less than 1/3 of the appropriate tolerance. Results apply to items identified in this report only. This report may not be reproduced, except in full, unless permission for the publication of an abstract is obtained in writing from the calibrating organization issuing this report.

LABORATORY SERVICES DIVISION
 WEIGHTS AND MEASURES PROGRAM

Dan Wright
 DAN WRIGHT
 STATE METROLOGIST



NVLAP LAB CODE 200446-0

MAR 08 2002

W98MR42-01, 11/98

Page 1 of 1

QUALITY CONTROL SERVICES Inc.

Customer and Contact
 Ploer Testing Labs
 13235 Prairie Circle East
 Sumner, WA. 98390
 Chip Wadington

2340 S.E. 11Th. Avenue Portland, Oregon 97214
 (503) 236-2712 / FAX:(503) 235-2535

Report Number: EESPC37010004030515

CERTIFICATE OF CALIBRATION AND TEST RECORD

INSTRUMENT INFORMATION

Item	Make	Model	Serial Number	Customer ID	Location	SOP Used
Balance	Sartorius	A120S	37010004	N/A	Lab	QC004
Units	Readability	Range Calibrated	Tolerance Used	Cal. Date	Last Cal.	Cal. Due
Grams	0.0001	0-100	Factory	05/15/2003	11/07/2002	11/2003

Functional Checks

CORNERLOAD:	LINEARITY:	REPEATABILITY:	ENVIRONMENTAL CONDITIONS:
Test Wt: Tol: 100 0.0003	Test Wt: Tol: 50x2 0.0004	Test Wt: Tol: 100 0.0001	
AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	<input type="checkbox"/> Good <input checked="" type="checkbox"/> Fair <input type="checkbox"/> Poor
AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	

CALIBRATION DATA

Standard	As Found Instrument	As Left Instrument
100	100.0003	100.0000
70	70.0002	70.0000
50	50.0001	50.0000
20	20.0001	20.0000
10	10.0000	10.0000
5	5.0000	5.0000

CALIBRATION STANDARDS

Item	Make	Model	Serial Number	Units	Cal. Date	Cal. Due	Traceable ID#
Weight Set	R.L./Troemner	1MG-25KG	A45	Grams	11/12/2002	11/2003	822/265349-01

Comments / Info Concerning This Calibration:

Permanent Information Concerning This Instrument:

Technician: D. Delesa

Signature: 

CALIBRATIONS ARE PERFORMED UNDER AMBIENT CONDITIONS USING MANUFACTURER'S OR CUSTOMERS SPECIFICATIONS FOR THE PASS/FAIL RESULTS. RESULTS MAY BE INFLUENCED BY THE AGE OF THE INSTRUMENT AND ENVIRONMENTAL CONDITIONS. CALIBRATION DATA SHOULD BE REVIEWED TO INSURE THAT THE INSTRUMENT IS PERFORMING TO ITS INTENDED ACCURACY. CALIBRATIONS CONFORM TO ISO/IEC GUIDE 25-1990(17025) AND ANSI / NCSL Z540-1-1994 SPECIFICATIONS. INSTRUMENTS LISTED ABOVE WERE CALIBRATED USING STANDARDS TRACEABLE TO THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY (N.I.S.T.).

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF QUALITY CONTROL SERVICES, INC.

QUALITY CONTROL SERVICES Inc.

2340 S.E. 11Th. Avenue Portland, Oregon 97214
(503) 236-2712 / FAX:(503) 235-2535

Report Number: EESPC37010004021107

Customer and Contact
Lokee Testing Labs
13235 Prairie Circle East
Sumner, WA. 98390
Ship Wadington

CERTIFICATE OF CALIBRATION AND TEST RECORD

INSTRUMENT INFORMATION

Item	Make	Model	Serial Number	Customer ID	Location	SOP Used
Balance	Sartorius	A120S	37010004	N/A	Lab	QC004
Units	Readability	Range Calibrated	Tolerance Used	Cal. Date	Last Cal.	Cal. Due
Grams	0.0001	0-100	Factory	11/07/2002	10/31/2001	05/2003

Functional Checks

CORNERLOAD: Test Wt: Tol: 100 0.0003	LINEARITY: Test Wt: Tol: 50x2 0.0004	REPEATABILITY: Test Wt: Tol: 100 0.0001	ENVIRONMENTAL CONDITIONS:
AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS FOUND: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	<input type="checkbox"/> Good <input checked="" type="checkbox"/> Fair <input type="checkbox"/> Poor
AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	AS LEFT: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	

CALIBRATION DATA

Standard	As Found Instrument	As Left Instrument
100	100.0004	100.0004
70	70.0003	70.0003
50	50.0002	50.0002
20	20.0001	20.0001
10	10.0000	10.0000
5	5.0000	5.0000
1	1.0000	1.0000

CALIBRATION STANDARDS

Item	Make	Model	Serial Number	Units	Cal. Date	Cal. Due	Traceable ID#
Weight Set	R.L./Troemner	1MG-25KG	A45	Grams	12/13/2001	12/2002	2261-1201

Comments / Info Concerning This Calibration:

Permanent Information Concerning This Instrument:

Technician: D. Deleasa

Signature: 

CALIBRATIONS ARE PERFORMED UNDER AMBIENT CONDITIONS USING MANUFACTURER'S OR CUSTOMER'S SPECIFICATIONS FOR THE PASS/FAIL RESULTS. RESULTS MAY BE INFLUENCED BY THE AGE OF THE INSTRUMENT AND ENVIRONMENTAL CONDITIONS. CALIBRATION DATA SHOULD BE REVIEWED TO INSURE THAT THE INSTRUMENT IS PERFORMING TO ITS INTENDED ACCURACY. CALIBRATIONS CONFORM TO ISO/IEC GUIDE 25-1990(17025) AND ANSI / NCSL Z540-1-1994 SPECIFICATIONS.

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF QUALITY CONTROL SERVICES, INC.

Form Number: BA62

Customer Code: EESPC

Rev. Date: 03/19/2002

QUALITY CONTROL SERVICES Inc.

Customer and Contact
 Lokee Testing Labs
 13235 Prairie Circle East
 Sumner, WA. 98390
 Chip Wadington

2340 S.E. 11Th. Avenue Portland, Oregon 97214
 (503) 236-2712 / FAX:(503) 235-2535

Report Number: EESPC37010004020506

CERTIFICATE OF CALIBRATION AND TEST RECORD

INSTRUMENT INFORMATION

Item	Make	Model	Serial Number	Customer ID	Location	SOP Used
Balance	Sartorius	A120S	37010004	N/A	Lab	QC012
Units	Readability	Range Calibrated	Tolerance Used	Cal. Date	Last Cal.	Cal. Due
Grams	0.0001	0-100	Factory	05/06/2002	10/31/2001	11/2002

Functional Checks

CORNERLOAD:		LINEARITY:		REPEATABILITY:		ENVIRONMENTAL CONDITIONS:			
Test Wt:	Tol:	Test Wt:	Tol:	Test Wt:	Tol:	<input type="checkbox"/> Good <input checked="" type="checkbox"/> Fair <input type="checkbox"/> Poor			
100	0.0003	50x2	0.0004	100	0.0001				
AS FOUND:	AS FOUND:	AS FOUND:	AS FOUND:	AS FOUND:	AS FOUND:				
Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>				
AS LEFT:	AS LEFT:	AS LEFT:	AS LEFT:	AS LEFT:	AS LEFT:				
Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>	Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/>				

CALIBRATION DATA


Standard	As Found Instrument	As Left Instrument
100	100.0004	100.0000
70	70.0003	70.0000
50	50.0002	50.0000
20	20.0001	20.0000
10	10.0000	10.0000
5	5.0000	5.0000

CALIBRATION STANDARDS

Item	Make	Model	Serial Number	Units	Cal. Date	Cal. Due	Traceable ID#
Weight Set	R.L./Troemner	1MG-25KG	A45	Grams	12/13/2001	12/2002	2261-1201

Comments / Info Concerning This Calibration:

Permanent Information Concerning This Instrument:

Technician: D. Deleasa
 Signature: 

CALIBRATIONS ARE PERFORMED UNDER AMBIENT CONDITIONS USING MANUFACTURER'S OR CUSTOMERS SPECIFICATIONS FOR THE PASS/FAIL RESULTS. RESULTS MAY BE INFLUENCED BY THE AGE OF THE INSTRUMENT AND ENVIRONMENTAL CONDITIONS. CALIBRATION DATA SHOULD BE REVIEWED TO INSURE THAT THE INSTRUMENT IS PERFORMING TO ITS INTENDED ACCURACY. CALIBRATIONS CONFORM TO ISO/IEC GUIDE 25-1990(17025) AND ANSI / NCSL Z540-1-1994 SPECIFICATIONS.

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF QUALITY CONTROL SERVICES, INC.

QUALITY CONTROL SERVICES Inc.

2340 S.E. 11Th. Avenue Portland, Oregon 97214-5306

(503) 236-2712 / FAX:(503) 235-2535

CERTIFICATE OF CALIBRATION

Customer and Contact

Lokee Testing Labs
13235 Prairie Circle East
Sumner, WA. 98390
Chip Wadington

Report Number: EESPC37010004011031

INSTRUMENT INFORMATION

Item	Make	Model	Serial Number	Customer ID	Location	SOP Used
Balance	Sartorius	A120S	37010004	N/A	Lab	QC012
Units	Readability	Range Calibrated	Tolerance Used	Cal. Date	Last Cal.	Cal. Due
Grams	0.0001	0-100	Factory	10/31/2001	04/30/2001	04/2002

Functional Checks

Cornerload

Linearity 0 - 1/2 - Full Capacity

Reproduceability

CALIBRATION DATA

As Found Instrument	Standard	As Left Instrument
100.0002	100	100.0000
50.0001	50	50.0000
20.0000	20	20.0000
10.0000	10	10.0000
5.0000	5	5.0000
1.0000	1	1.0000

CALIBRATION STANDARDS

Item	Make	Model	Serial Number	Units	Cal. Date	Cal. Due	Traceable ID#
Weight Set	R.L./Troemner	5MG-25KG	A45	Grams	12/11/2000	12/2001	A45-2000

Comments / Info Concerning This Calibration:

Permanent Information Concerning This Instrument:

5/00 CUSTOMER REQUESTED SPECIFIC 6 POINT CHECK.100,50,20,10,5,1

Technician: D.Deleasa

Signature: 

CALIBRATIONS ARE PERFORMED UNDER AMBIENT CONDITIONS USING MANUFACTURER'S OR CUSTOMERS SPECIFICATIONS FOR THE PASS/FAIL RESULTS. RESULTS MAY BE INFLUENCED BY THE AGE OF THE INSTRUMENT AND ENVIRONMENTAL CONDITIONS. CALIBRATION DATA SHOULD BE REVIEWED TO INSURE THAT THE INSTRUMENT IS PERFORMING TO ITS INTENDED ACCURACY. CALIBRATIONS CONFORM TO ISO/IEC GUIDE 25-1990(17025) AND ANSI / NCSL Z540-1-1994 SPECIFICATIONS.

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF QUALITY CONTROL SERVICES, INC.

Thermocouple Calibration Record Semi-Annual

Thermocouples Check against

Reference Thermometer

serial number 9123454

Ice Water Bath

32.0

Boiling Water

211.8

Room Temperature

70.1

Barometric Pressure

30.11

DATE: 11-11-02

TC	Location	Ice Bath Temp	Boiling Water Temp
1	Wet Bulb	32.2	211.7
2	Dry Bulb	32.3	211.8
3	Stack	32.0	211.7
4	Stove Top	32.1	211.9
5	Left Side	32.4	211.8
6	Back	32.1	211.8
7	Right Side	32.2	211.7
8	Bottom	32.0	211.6
9	Firebox	32.2	211.8
10	Secondary/Cat	32.2	211.6
11	Ambient	32.1	211.7
12	Tube Furnace	32.1	211.9
13	Sample Box	32.0	211.7
14	Impinger Out	32.1	211.8
15	C. Gas Box	32.0	211.8
16	C. Gas Out	32.2	211.7
17	SO2 Out	32.1	211.7
18	Upper Ambient	32.1	211.7
19			
20			
21			
22			
23	Calibrator	32.2	211.5
24	Oven	32.3	212.3

Thermocouple Readout Semi-Annual Calibration Data Sheet

Date: 11-11-02
 Ambient Temperature: 69.8
 Technician: Chp W.

Thermocouple Number: T/C Readout
 Barometric Pressure: 30.11
 Reference: Mercury in glass
FISHER #9123454
 Other: OMEGA CL-300

Reference Point No. ^a	Source ^b	Reference Thermometer Temperature °F	Thermocouple Potentiometer Temperature °F	Difference (%) ^c
32	Ice Water	32.0	32.0	ϕ
212	Boiling Water	212.0	211.9	.047
250	Omega	250.0	250.0	ϕ
300	Omega	300.0	299.7	.100
400	Omega	400.0	399.8	.050
500	Omega	500.0	499.9	.020
600	Omega	600.0	598.9	.183
700	Omega	700.0	699.8	.029
800	Omega	800.0	799.4	.075
900	Omega	900.0	900.0	ϕ
1000	Omega	1000.0	998.8	.120
1200	Omega	1200.0	1198.7	.108
1400	Omega	1400.0	1399.7	.021
1600	Omega	1600.0	1598.9	.069
1800	Omega	1800.0	1799.9	.006
2000	Omega	2000.0	2000.0	ϕ

^a Every 50°F for each reference point

^b Type of Calibration System Used

^c
$$\frac{(\text{reference temperature}) - (\text{thermocouple temperature})}{\text{reference temperature}} * 100$$

TRACEABILITY DOCUMENTATION Semi-Annual

SO₂ INJECTION ROTAMETER, DRY GAS METER AND SLING PSYCHROMETER
THERMOMETERS IN LAB. CHECKED AGAINST FISHER SN 9123454 (NIST).

DATE: 11.16.02

SO₂ INJECTION ROTAMETER
9123454

FISHER SN

NIST Traceable

Actual	°C = °F	°F
0.0	32.0	32.0
21.0	69.8	69.8
37.7	99.9	100.0
54.4	129.9	130.0

DRY GAS METER THERMOCOUPLES

Actual	°C = °F	5H in	5H out	KK
0.0	32.0	32.1	32.0	32.0
21.0	69.8	69.7	69.9	69.8
37.5	99.5	99.6	99.6	99.7
54.0	129.2	129.1	129.0	128.9

SLING PSYCHROMETER

Actual	°C = °F	Wet Bulb	Dry Bulb
0	32.0	32.0	32.0
21.0	69.8	69.8	69.8
30.5	86.9	82.0	87.0
40.8	105.4	105.4	105.4

Conversions =

$$^{\circ}\text{F} = (^{\circ}\text{C} \times 1.8) + 32$$

$$^{\circ}\text{C} = (^{\circ}\text{F} - 32) \div 1.8$$

VANEOMETER CALIBRATION

LoKee Testing Lab uses a Dwyer Model #480 Vaneometer to measure test chamber air velocity. The manufacturer's specifications for accuracy are $\pm 5.0\%$ to 100 FPM and $\pm 10\%$ from FPM to top of scale. LoKee Testing Lab insures that the instrument is level and clean prior to taking each reading. According to EPA personnel (Westlin, RTP) no further calibration of the instrument is necessary.

DRAFT GAUGE CALIBRATION

LoKee Testing Lab uses a Dwyer model 115-AV 0-0.25" inclined water manometer (readability resolution $\pm 0.001"$ of water) to measure the static pressure in the stack. Once leveled and zeroed as per the manufacturer's written operating instructions, the Dwyer manometer is a primary standard and requires no additional calibration.

The manometer is leveled and zeroed at the start of each test run, checked as necessary during the run to verify the settings have not changed and again at the end of each test run. The results of each check are recorded on Data Sheet #16 in each test run.

BAROMETER CALIBRATION

LoKee Testing Lab uses a Princo Model 469 NOVA Mercury Barometer to measure barometric pressure. When installed and maintained as per the manufacturer's written operating instruction, the Princo Model 469 Mercury Barometer is a primary standard and needs no further calibration.

MOISTURE METER CALIBRATION

The Delmhorst Model RC-1C, SN 16152 Moisture Meter is calibrated each time the meter is used by adjusting the zero and span calibration. The potentiometers of each calibration point (X = zero, Y = span) are adjusted until the meter is calibrated correctly. The meter is then checked against a calibration block (Delmhorst Model MCS-1, moisture content standard at 12.0% and 22.0%) in its normal operating range of 11-25%.

LoKee Testing Lab also has a second moisture meter, Delmhorst Model G-30, SN 2477 to use as a backup.

POST TEST METER BOX AUDIT DATA SHEET # 32

UNIT: JOTUL U.S.A., Inc. - F600 DATE: 05/13/03

TEST DATA

RUN #	1	2	3	4	5	6	7	8	9	10
AVG. Δ H	.153	X	.163	.223	.093	.239				
MAX VAC	3.0	X	5.0	4.0	2.0	5.0				

Avg. Test Series Δ H: .174 in H₂O Test Series Max Vac: 5.0 in Hg

Audit Dry Gas Meter: K2 Correction (Y) Factor: 1.002 (mcf)

Test Dry Gas Meter: H Correction (Y) Factor: .990 (mcf)

AUDIT DATA

		Audit # 1	Audit # 2	Audit # 3
BP		<u>30.28</u>	<u>30.28</u>	<u>30.28</u>
VAC		<u>5.0</u>	<u>5.0</u>	<u>5.0</u>
AUDIT METER :				
VOL.	Final	<u>454.075</u>	<u>460.060</u>	<u>470.378</u>
(Vw)	Initial	<u>449.000</u>	<u>454.075</u>	<u>460.060</u>
	Vol.	<u>5.075</u>	<u>5.985</u>	<u>10.318</u>
TEMP (°F)	Initial	<u>92</u>	<u>90</u>	<u>91</u>
(Tw)	Mid	<u>91</u>	<u>91</u>	<u>91</u>
	Final	<u>90</u>	<u>91</u>	<u>91</u>
(°F / °A)	Avg.	<u>91 551</u>	<u>551</u>	<u>551</u>
Δ H	Initial	<u>.174</u>	<u>.174</u>	<u>.174</u>
	Mid	<u>.174</u>	<u>.174</u>	<u>.174</u>
	Final	<u>.174</u>	<u>.174</u>	<u>.174</u>
	Avg.	<u>.174</u>	<u>.174</u>	<u>.174</u>
DRY GAS METER :				
VOL.	Final	<u>983.000</u>	<u>989.000</u>	<u>999.100</u>
(Vd)	Initial	<u>978.000</u>	<u>983.000</u>	<u>989.000</u>
	Vol.	<u>5.000</u>	<u>6.000</u>	<u>10.100</u>
TEMP (°F)	Initial	<u>77</u>	<u>81</u>	<u>82</u>
(Tm)	Mid	<u>79</u>	<u>81</u>	<u>82</u>
	Final	<u>81</u>	<u>82</u>	<u>82</u>
(°F / °A)	Avg.	<u>79 539</u>	<u>85 541</u>	<u>542</u>

$$Y = \frac{(V_w)(mcf)(BP)(T_m)}{(V_d) \left(BP + \frac{DH}{13.6} \right) (T_w)}$$

$$Y \text{ Factor } \% \text{ Diff.} = \frac{\text{Act} - \text{Exp}}{\text{Exp}} \times 100$$

NOTE : mcf = meter correction (Y) factor for Dry Gas Meter used as a transfer standard

RUN 1

$$Y = \frac{(5.075)(1.002)(30.28)(539)}{(5.000) \left(30.28 + \frac{.174}{13.6} \right) (551)} = \frac{82994.33}{83456.65} = .994$$

$$\Delta \% = \frac{(.994 - .984)}{.984} \times 100 = 1.016 \%$$

RUN 2

$$Y = \frac{(5.985)(1.002)(30.28)(541)}{(6.000) \left(30.28 + \frac{.174}{13.6} \right) (551)} = \frac{98239.24}{100877.24} = .977$$

$$\Delta \% = \frac{(.977 - .984)}{.984} \times 100 = -1.016 \%$$

RUN 3

$$Y = \frac{(10.318)(1.002)(30.28)(542)}{(10.100) \left(30.28 + \frac{.174}{13.6} \right) (551)} = \frac{169675.21}{168582.43} = 1.006$$

$$\Delta \% = \frac{(1.006 - .984)}{.984} \times 100 = 2.236 \%$$

NOTE : The Y factor % difference must be $< \pm 5.0 \%$ to be acceptable

INTERPOLATED Y FACTOR

$$\frac{.1}{(A)} \text{ inch H}_2\text{O } \Delta H = \frac{.983}{(C)}$$

Calculated calibration Y factor from calibrations

$$\frac{.2}{(B)} \text{ inch H}_2\text{O } \Delta H = \frac{.984}{(D)}$$

Calculated calibration Y factor from calibrations

$$\frac{.2}{(B)} - \frac{.1}{(A)} = \frac{.1}{(E)} \times 100 = \frac{10}{(E)}$$

$$\frac{.984}{(D)} - \frac{.983}{(C)} = \frac{.001}{(E)} + \frac{10}{(E)} \frac{.0001}{(F)}$$

$$\frac{.174}{\text{Avg } \Delta H} - \frac{.1}{(A)} = \frac{.074}{(G)} \times 100 = \frac{7.4}{(G)}$$

$$\left[\frac{.0001}{(F)} \times \frac{7.4}{(G)} \right] + \frac{.983}{(C)} = \frac{.984}{\text{Interpolated Y factor}}$$

Volume Metering System Leak Check : 0.000 inch H₂O in one minute

DRY GAS METER CALIBRATION

DATE: 11-15-02 DRY GAS METER: H BOX: 5

BAROMETRIC PRESSURE		30.06 in. Hg.		Wet Test Meter Correction Factor Y= 1.002			
Orifice Manometer Setting, ΔH, in. H ₂ O		.1	.2	.3	.5	.75	1.0
Gas Volume Wet Test Meter V _w ft ³	Final	333.848	341.361	371.404	377.421	384.923	390.000
	Initial	315.500	333.818	341.361	371.404	377.421	384.963
	V _w ft ³	18.348	7.513	30.043	6.017	7.542	5.037
Gas Volume Dry Test Meter V _d ft ³	Final	38.000	45.500	75.500	81.500	89.000	94.000
	Initial	19.500	38.000	45.500	75.500	81.500	89.000
	V _w ft ³	18.500	7.500	30.000	6.000	7.500	5.000
Wet Test Meter Temperature t _w	Initial	85	97	97	97	96	97
	Middle	91	97	97	96	97	96
	Final	97	97	97	96	97	94
	Average	(85)	97 ⁽⁵⁵⁷⁾	(557)	(556)	(557)	(556)
Dry Test Meter Temperature t _m	Initial	81	89	87	91	90	91
	Middle	85	88	89	90	91	91
	Final	89	87	91	90	91	90
	Average	85 ⁽⁵⁴⁵⁾	(548)	(549)	(550)	(551)	(551)
$Y = \frac{(W_{mf})(V_w)(P_b)(t_m)}{V_d \left(P_b + \frac{\Delta H}{13.6} \right) (t_w)}$.983	.984	.988	.993	.995	.998

Average Y= .990

METER BOX CALIBRATION

Avg = 1.002

Date : 08/09/02
 Calibrated By : J.C.
 Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 27.55 in. Hg
 Vacuum = 0.0 in. Hg

**Orifice Manometer
 Setting, Delta H
 in. H2O**

0.10 0.10 0.10 0.10 0.10 0.10

**Gas Volume Wet Test Meter
 Vw, cu. ft.**

10.052 10.959 10.626 10.369 10.759 10.717

Gas Volume Dry Gas Meter

M Final	69.409	81.103	92.442	103.393	114.942	126.250
M Initial	59.175	69.802	81.457	92.680	103.826	115.224
Vd, cu. ft.	10.234	11.301	10.985	10.713	11.116	11.026

Wet Test Meter

tw Deg F	68	67	69	70	72	74
tw Deg A	528	527	529	530	532	534

**Dry Gas Meter
 Outlet, tmo**

1)	72	75	77	78	80	82
2)	73	76	78	79	82	82
3)	74	78	79	80	83	82

**Dry Gas Meter
 Inlet tmi**

1)	79	88	95	98	99	100
2)	85	92	99	100	101	101
3)	89	98	102	101	102	102

**Mean tm, Deg F
 Mean tm, Deg A**

79	85	88	89	91	92
539	545	548	549	551	552

Results :

Y = 1.002 1.002 1.002 1.003 1.003 1.004

Averages :

Y = 1.003

METER BOX CALIBRATION

Date : 08/09/02
Calibrated By : J.C.
Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 27.55 in. Hg
Vacuum = 0.0 in. Hg

Orifice Manometer

Setting, Delta H
in. H2O

	0.20	0.20	0.20	0.20	0.20	0.20
--	------	------	------	------	------	------

Gas Volume Wet Test Meter

Vw, cu. ft.

	10.000	10.000	10.000	10.400	10.000	10.000
--	--------	--------	--------	--------	--------	--------

Gas Volume Dry Gas Meter

M Final	125.454	135.756	146.114	156.919	167.309	177.665
M Initial	115.224	125.454	135.756	146.114	156.919	167.309
Vd, cu. ft.	10.230	10.302	10.358	10.805	10.390	10.356

Wet Test Meter

tw Deg F	67	68	70	71	72	73
tw Deg A	527	528	530	531	532	533

Dry Gas Meter

Outlet, tmo

1)	74	76	78	81	84	85
2)	74	78	80	82	85	86
3)	76	78	81	84	85	86

Dry Gas Meter

Inlet, tmi

1)	83	87	95	102	103	103
2)	85	92	99	104	104	105
3)	87	96	104	105	105	105

Mean tm, Deg F

	80	85	90	93	94	95
Mean tm, Deg A	540	545	550	553	554	555

Results :

Y =	1.001	1.000	1.000	1.002	1.002	1.005
------------	-------	-------	-------	-------	-------	-------

Averages :

Y =	1.002
------------	-------

METER BOX CALIBRATION

Date : **08/09/02**
 Calibrated By : **J.C.**
 Dry Gas Meterbox ID : **K2**

Barometric Pressure, Pb = **27.55** in. Hg
 Vacuum = **0.0** in. Hg

Orifice Manometer
 Setting, Delta H
 in. H2O

0.30 0.30 0.30 0.30 0.30 0.30

Gas Volume Wet Test Meter
 Vw, cu. ft.

10.000 10.900 10.600 10.000 10.000 10.800

Gas Volume Dry Gas Meter

M Final	187.917	199.173	210.167	220.584	230.982	242.208
M Initial	177.665	187.917	199.173	210.167	220.584	230.982
Vd, cu. ft.	10.252	11.256	10.994	10.417	10.398	11.226

Wet Test Meter

tw Deg F	67	67	68	69	70	69
tw Deg A	527	527	528	529	530	529

Dry Gas Meter
 Outlet, tmo

1)	71	73	75	76	77	77
2)	73	74	75	76	77	77
3)	74	75	76	77	77	77

Dry Gas Meter
 Inlet, tmi

1)	85	90	94	100	105	105
2)	88	94	98	104	106	106
3)	93	98	102	105	106	106

Mean tm, Deg F
Mean tm, Deg A

81	84	87	90	91	91
541	544	547	550	551	551

Results :

Y =	1.001	0.999	0.998	0.997	1.000	1.002
-----	-------	-------	-------	-------	-------	-------

Averages :

Y =	1.000
-----	-------

METER BOX CALIBRATION

Date : **08/09/02**
 Calibrated By : **J.C.**
 Dry Gas Meterbox ID : **K2**

Barometric Pressure, Pb = 27.55 in. Hg
 Vacuum = 0.0 in. Hg

**Orifice Manometer
 Setting, Delta H
 in. H2O**

0.50	0.50	0.50	0.50	0.50	0.50	0.50
------	------	------	------	------	------	------

**Gas Volume Wet Test Meter
 Vw, cu. ft.**

10.000	10.000	10.000	10.000	10.200	10.000
--------	--------	--------	--------	--------	--------

Gas Volume Dry Gas Meter

M Final	252.471	262.818	273.200	283.635	294.271	304.672
M Initial	242.208	252.471	262.818	273.200	283.635	294.271
Vd, cu. ft.	10.263	10.347	10.382	10.435	10.636	10.401

Wet Test Meter

tw Deg F	70	70	71	71	71	72
tw Deg A	530	530	531	531	531	532

**Dry Gas Meter
 Outlet, tmo**

1)	73	78	82	84	86	87
2)	75	80	83	86	87	88
3)	78	83	85	87	87	88

**Dry Gas Meter
 Inlet, tmi**

1)	87	93	96	101	103	102
2)	93	103	105	107	109	106
3)	96	105	110	110	110	110

**Mean tm, Deg F
 Mean tm, Deg A**

84	90	94	96	97	97
544	550	554	556	557	557

Results :

Y =	0.999	1.002	1.003	1.002	1.005	1.005
------------	-------	-------	-------	-------	-------	-------

Averages :

Y = 1.003

METER BOX CALIBRATION

Date : 08/09/02
Calibrated By : J.C.
Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 27.55 in. Hg
Vacuum = 0.0 in. Hg

Orifice Manometer

Setting, Delta H
in. H2O

	0.75	0.75	0.75	0.75	0.75	0.75
--	------	------	------	------	------	------

Gas Volume Wet Test Meter

Vw, cu. ft.

	10.000	10.000	10.000	10.000	10.000	10.000
--	--------	--------	--------	--------	--------	--------

Gas Volume Dry Gas Meter

M Final	314.761	324.890	335.031	345.191	355.387	365.617
M Initial	304.672	314.761	324.890	335.031	345.191	355.387
Vd, cu. ft.	10.089	10.129	10.141	10.160	10.196	10.230

Wet Test Meter

tw Deg F	69	69	70	71	71	71
tw Deg A	529	529	530	531	531	531

Dry Gas Meter

Outlet, tmo	1)	72	74	75	77	78	79
	2)	74	75	76	77	78	79
	3)	75	75	77	78	79	80

Dry Gas Meter

Inlet tmi	1)	74	78	81	84	86	88
	2)	76	80	82	85	88	91
	3)	77	81	83	87	89	93

Mean tm, Deg F

	75	77	79	81	83	85
Mean tm, Deg A	535	537	539	541	543	545

Results :

Y =	1.000	1.001	1.001	1.001	1.001	1.001
------------	-------	-------	-------	-------	-------	-------

Averages :

Y = 1.001

METER BOX CALIBRATION

Date : 08/09/02
Calibrated By : J.C.
Dry Gas Meterbox ID : K2

Barometric Pressure, Pb = 27.55 in. Hg
Vacuum = 0.0 in. Hg

Orifice Manometer
Setting, Delta H
in. H2O

1.00	1.00	1.00	1.00	1.00	1.00
------	------	------	------	------	------

Gas Volume Wet Test Meter
Vw, cu. ft.

10.000	10.000	10.000	10.400	10.000	10.000
--------	--------	--------	--------	--------	--------

Gas Volume Dry Gas Meter

M Final	375.804	386.030	396.294	406.992	417.296	427.619
M Initial	365.617	375.804	386.030	396.294	406.992	417.296
Vd, cu. ft.	10.187	10.226	10.264	10.698	10.304	10.323

Wet Test Meter

tw Deg F	72	72	73	73	73	74
tw Deg A	532	532	533	533	533	534

Dry Gas Meter
Outlet, tmo

1)	77	78	80	82	82	83
2)	78	80	81	82	83	83
3)	78	81	82	83	83	83

Dry Gas Meter
Inlet, tmi

1)	85	90	95	96	98	101
2)	88	92	96	98	100	103
3)	91	93	98	99	102	104

Mean tm, Deg F
Mean tm, Deg A

83	86	89	90	91	93
543	546	549	550	551	553

Results :

Y =	0.999	1.000	1.000	1.000	1.001	1.000
------------	-------	-------	-------	-------	-------	-------

Averages :

Y =	1.000
------------	-------

WET TEST METER CALIBRATION LOG

Wet Test Meter Serial Number AA 455 Date 8-02-02

Range of Wet Test Meter Flow Rate 0 - 0.25

Volume of Test Flask Vs 37.850

Satisfactory Leak Check?

Ambient Temperature of Equilibrate Liquid in Wet Test Meter and Reservoir 79°F

TEST #	MANOMETER READING, a mm H ₂ O	FINAL VOLUME (Vf), l	INITIAL VOLUME (Vi), l	TOTAL VOLUME (Vm), b l	FLASK VOLUME (Vs), l	PERCENT ERROR, c %
1	∅	3.0	reset to ∅	3.0	3.004	- .133
2	∅	3.0	reset to ∅	3.0	3.005	- .166
3	∅	3.0	reset to ∅	3.0	3.007	- .233

a - Must be less than 10 mm H₂O (0.4 ' H₂O)

Calculations:

b - $V_m - V_f - V_i$

c - % error = $\frac{100(V_m - V_s)}{V_s} = \underline{- .177}$ (± 1 %)

SO₂ ROTAMETER CALIBRATION

Last Cal. : 5-13-01 By : CP Date : 11-11-02 By : CP

Manufacturer : SKC-WEST
 SKC ACCUFLOW Digital Flow Calibrator: Model 712 SN : 311325

Barometric Pressure : 30.12 " Hg Temperature : 72.0


RUN #	50 CC/MINUTE	100 CC/MINUTE	150 CC/MINUTE
	DIGITAL VOLUME	DIGITAL VOLUME	DIGITAL VOLUME
1	54.7	119.0	174.0
2	54.5	119.5	174.5
3	54.6	119.1	174.3
4	54.9	118.9	174.1
5	54.4	118.9	174.4
6	54.8	119.2	174.6
7	54.8	119.1	174.1
8	54.5	119.3	174.3
9	54.6	119.0	174.1
10	54.2	119.1	174.1
AVERAGE	cc/min	cc/min	cc/min

SETTING	cc/min
0	∅
50	54.6
100	119.1
150	174.3

Rotometer setting for 100 cc/minute based on regression with this data.

100 CC / MINUTE = 86.05

SO2 Rotameter
11/11/02



Regression Output:

Constant		-1.11
Std Err of Y Est		3.0431891167
R Squared		0.9989275329
No. of Observations		4
Degrees of Freedom		2
X Coefficient(s)	1.1748	
Std Err of Coef.	0.0272191109	

ORSAT ANALYSIS DATA SHEET

DATE: 11-12-02

Gas	1	2	3	AVE	CONC	TANK ID
CO ₂	0	0	0	∅	N ₂	042TAC-2-A
O ₂	0	0	0	∅	N ₂	
CO	0	0	0	∅	N ₂	
CO ₂	12.5	12.5	12.5	12.5	12.49	CC12767
O ₂	12.5	12.5	12.5	12.5	12.50	
CO	4.8	4.8	4.8	4.8	4.80	
CO ₂	21.2	21.2	21.3	21.23	21.23	CC55904
O ₂	21.1	21.1	21.1	21.0	21.10	
CO	8.6	8.6	8.6	8.60	8.60	
CO ₂	6.2	6.2	6.3	6.23	6.25	AAL21084
O ₂	6.2	6.2	6.3	6.23	6.24	
CO	2.0	2.0	2.0	2.0	2.01	
CO ₂						
O ₂						
CO						

JOTUL
F600

CO₂ ANALYZER
MULTIPOINT CALIBRATION REPORT FORM

Date: 04-29-03
Analyzer: Make: HORIBA Model: PIR 2000 SN: 407069
Calibration by: D. H. [Signature]
Cal Gas Flow: 1.5 SCFH Measured by: Rotameter
BP: 29.92 Instrument ID: PRINCO
Temp: 75 Instrument ID: TR

Cylinders:

1. # 042TAC 2-A Concentration: 00.00 % CO₂ Cyl. Press.: 900 PSI
Certified by: AIR LIQUIDE Date: 02-20-02
2. # CC-3131 Concentration: 12.40 % CO₂ Cyl. Press.: 1625 PSI
Certified by: AIR LIQUIDE Date: 03-13-03
3. # CC55904 Concentration: 21.23 % CO₂ Cyl. Press.: 700 PSI
Certified by: AIR LIQUIDE Date: 02-14-00
4. # CC-12731 Concentration: 6.22 % CO₂ Cyl. Press.: 1725 PSI
Certified by: AIR LIQUIDE Date: 03-13-03

Analyzer: **Calibrated Range:** 0-25.0 % **Output:** 0-1.0 V.
Flow: 1.5 SCFH **Measured by:** Rotameter

Calibration Results

Point #	CYL. #	% CO2	EXPECTED		ACTUAL		ADJ.	
			METER	DVM	METER	DVM	METER	DVM
1	1	0.00	00.0	.000	00.1	.001	00.0	00.0
2	2	12.40	49.6	.496	49.8	.498	49.6	.496
3	3	21.23	84.9	.849	85.1	.851		
4	4	6.22	24.9	.249	25.2	.252		
5	1	0.00	00.0	.000	00.0	.000		

.5 = 12.467

CO₂ Linear Regression Results:


$Y = MX + B$

Slope (M) = .0009139

Y Intercept (B) = .0400337

Correlation Coefficient (r) = .9999912

$r^2 =$.9999824





EPA Span Value = $\pm 2.0\%$ of $25\% \text{ CO}_2 = \pm .5\%$

Cal Volts = Cal Volt Conc - Std Conc = \pm Conc Diff = $\pm \Delta \%$

HIGH VOLTS .851 = 21.28 - 21.23 = -.050 = .200

LOW VOLTS .252 = 6.30 - 6.22 = .080 = .320



**O₂ ANALYZER
MULTIPOINT CALIBRATION REPORT FORM**

Date: 04-29-03
 Analyzer: Make: TELEDYNE Model: 320A SN: 37400
 Calibration by: D. Wadsworth
 Cal Gas Flow: 1.5 SCFH Measured by: Rotameter
 BP: 29.92 Instrument ID: PRINCO
 Temp: 75 Instrument ID: TR

Cylinders:

1. # 042TAC 2-A Concentration: 00.00 % O₂ Cyl. Press.: 900 PSI
 Certified by: AIR LIQUIDE Date: 02-20-02
2. # CC-3131 Concentration: 12.50 % O₂ Cyl. Press.: 1625 PSI
 Certified by: AIR LIQUIDE Date: 03-13-03
3. # CC55904 Concentration: 21.10 % O₂ Cyl. Press.: 700 PSI
 Certified by: AIR LIQUIDE Date: 02-14-00
4. # CC-12731 Concentration: 6.25 % O₂ Cyl. Press.: 1725 PSI
 Certified by: AIR LIQUIDE Date: 03-13-03

Analyzer: **Calibrated Range:** 0-25.0 % **Output:** 0-1.0 V.
Flow: 1.5 SCFH **Measured by:** Rotameter

Calibration Results

Point #	CYL. #	% O ₂	EXPECTED		ACTUAL		ADJ.	
			METER	DVM	METER	DVM	METER	DVM
1	1	0.00	00.0	.000	00.0	.001	00.0	.000
2	2	12.50	12.50	.500	12.45	.498	12.50	.500
3	3	21.10	21.10	.844	21.10	.845		
4	4	6.25	6.25	.250	6.20	.248		
5	1	0.00	00.0	.000	00.0	.000		

.5 = 12.501

O₂ Linear Regression Results:


$Y = MX + B$

Slope (M) = -0.0010094

Y Intercept (B) = 0.0400762

Correlation Coefficient (r) = 0.9999957

$r^2 = 0.9999915$





EPA Span Value = ± 2.0% of 25% O₂ = ± .5%

Cal Volts = Cal Volt Conc - Std Conc = ± Conc Diff = ± Δ%

HIGH VOLTS 0.845 = 21.125 - 21.00 = 0.125 = 0.500

LOW VOLTS 0.248 = 6.200 - 6.25 = -0.050 = -0.200



CO ANALYZER MULTIPOINT CALIBRATION REPORT FORM

Date: 04-29-03
 Analyzer: Make: HORIBA Model: PIR 2000 SN: 408005
 Calibration by: D. Wadlington
 Cal Gas Flow: 1.5 SCFH Measured by: Rotameter
 BP: 29.92 Instrument ID: PRINCO
 Temp: 75 Instrument ID: TR

Cylinders:

1. # 042TAC 2-A Concentration: 00.00 % CO Cyl. Press.: 900 PSI
 Certified by: AIR LIQUIDE Date: 02-20-02
2. # CC-3131 Concentration: 5.02 % CO Cyl. Press.: 1625 PSI
 Certified by: AIR LIQUIDE Date: 03-13-03
3. # CC55904 Concentration: 8.60 % CO Cyl. Press.: 700 PSI
 Certified by: AIR LIQUIDE Date: 02-14-00
4. # CC-12731 Concentration: 1.98 % CO Cyl. Press.: 1725 PSI
 Certified by: AIR LIQUIDE Date: 03-13-03

Analyzer: **Calibrated Range:** 0-10.0 %
Flow: 1.5 SCFH

Output: 0-1.0 V.
Measured by: Rotameter

Calibration Results

Point #	CYL. #	% CO	EXPECTED		ACTUAL		ADJ.	
			METER	DVM	METER	DVM	METER	DVM
1	1	0.00	00.0	.000	00.0	.000	00.0	.000
2	2	5.02	50.2	.502	49.4	.494	50.2	.502
3	3	8.60	86.0	.860	85.9	.859		
4	4	1.98	19.8	.198	19.5	.195		
5	1	0.00	00.0	.000	00.0	.000		

.5 = 5.010

CO Linear Regression Results:


$Y = MX + B$

Slope (M) = $\frac{-0.0010979}{}$

Y Intercept (B) = $\frac{0.1000251}{}$

Correlation Coefficient (r) = $\frac{0.9999929}{}$

$r^2 = \frac{0.9999854}{}$





EPA Span Value = $\pm 2.0\%$ of 10% CO = $\pm .2\%$

Cal Volts = Cal Volt Conc - Std Conc = \pm Conc Diff = $\pm \Delta\%$

HIGH VOLTS $\frac{.859}{} = \frac{8.59}{} - \frac{8.60}{} = \frac{-0.010}{} = \frac{-1.00}{}$

LOW VOLTS $\frac{.195}{} = \frac{1.95}{} - \frac{1.98}{} = \frac{-0.030}{} = \frac{-3.00}{}$



**SO₂ ANALYZER
MULTIPOINT CALIBRATION REPORT FORM**

Date: 04-29-03
 Analyzer: Make: HORIBA Model: PIR 2000 SN: 403019
 Calibration by: D. A. Anderson
 Cal Gas Flow: 1.5 SCFH Measured by: Rotameter
 BP: 29.92 Instrument ID: PRINCO
 Temp: 75 Instrument ID: TR

Cylinders:

1. # 042TAC 2-A Concentration: 00.00 % SO₂ Cyl. Press.: 900 PSI
 Certified by: AIR LIQUIDE Date: 02-20-02
2. # CC62184 Concentration: 1290 % SO₂ Cyl. Press.: 1025 PSI
 Certified by: AIR LIQUIDE Date: 01-29-01
3. # ALMO 49127 Concentration: 1770 % SO₂ Cyl. Press.: 900 PSI
 Certified by: SCOTT SPECIALTY GASES Date: 05-15-97
4. # ALMO 52285 Concentration: 506 % SO₂ Cyl. Press.: 825 PSI
 Certified by: SCOTT SPECIALTY GASES Date: 05-15-97

Analyzer: **Calibrated Range:** 0-2500 PPM **Output:** 0-1.0 V.
Flow: 1.5 SCFH **Measured by:** Rotameter

Calibration Results

Point #	CYL. #	PPM SO ₂	EXPECTED		ACTUAL		ADJ.	
			METER	DVM	METER	DVM	METER	DVM
1	1	0.00	00.0	.000	00.0	.009	00.0	.000
2	2	1290	51.6	.516	51.6	.516	51.6	.516
3	3	1770	70.8	.708	71.0	.710		
4	4	506	20.2	.202	19.7	.197		
5	1	0.00	00.0	.000	00.0	.000		

.5 = 1250.261

SO₂ Linear Regression Results:


$Y = MX + B$

Slope (M) = -0.0026762

Y Intercept (B) = 0.0004020

Correlation Coefficient (r) = 0.9999630

$r^2 = \underline{0.9999260}$



EPA Span Value = $\pm 2.0\%$ of 2500 PPM SO₂ = ± 50 PPM



Cal Volts = Cal Volt Conc - Std Conc = \pm Conc Diff = $\pm \Delta\%$

HIGH
VOLTS

0.710 = 1775.0 - 1770.0 = 5.000 = 0.200

LOW
VOLTS

0.197 = 492.5 - 506.0 = -13.500 = -0.540





LOW SPAN



GASES FOR RESEARCH AND DEVELOPMENT

CYL # CC-12731 CGA 590
PRES 1665 VOL 130c.f
TEST # 07203 DATE 03-13-03

Analytical Method GC/Paramagnetic

	Requested	Analyzed
Hydrogen		
Nitrogen	<u>Bal.</u>	<u>Bal.</u>
Argon		
Air		
Carbon Monoxide	<u>2%</u>	<u>1.98%</u>
Methane		
Oxygen	<u>6.25%</u>	<u>6.25%</u>
Helium		
Carbon Dioxide	<u>6.25%</u>	<u>6.22%</u>

ML
SIGNED




AIR LIQUIDE



1451 THORNE RD.
TACOMA, WA 98421
TEL: (253) 383-3637

THE ONLY LIABILITY OF THIS COMPANY FOR GAS WHICH FAILS TO COMPLY WITH THE ANALYSIS SHALL BE REPLACEMENT THEREOF BY THE COMPANY WITHOUT EXTRA COST.

DO NOT REMOVE THIS TAG



AIR LIQUIDE

GASES FOR RESEARCH AND DEVELOPMENT

CYL # 0255904 CGA 590

PRES 1650 VOL 150 LF

TEST # 04500 DATE 02-14-00

Analytical Method GC / Paramagnetic

	Requested	Analyzed
Hydrogen		
Nitrogen	<u>Bal.</u>	<u>Bal.</u>
Argon		
Air		
Carbon Monoxide	<u>8.5%</u>	<u>8.60%</u>
Methane		
Oxygen	<u>21%</u>	<u>21.10%</u>
Hellum		
Carbon Dioxide	<u>21%</u>	<u>21.23%</u>

[Signature]

SIGNED

MID SPAN



AIR LIQUIDE

GASES FOR RESEARCH AND DEVELOPMENT

CYL # CC-3131 CGA 590
PRES 1665 VOL 130 CF.
TEST # 07203 DATE 03-13-05

Analytical Method GC / Paramagnetic

	Requested	Analyzed
Hydrogen		
Nitrogen	<u>Bal.</u>	<u>Bal.</u>
Argon		
Air		
Carbon Monoxide	<u>5%</u>	<u>5.02%</u>
Methane		
Oxygen	<u>12.5%</u>	<u>12.5%</u>
Helium		
Carbon Dioxide	<u>12.5%</u>	<u>12.40%</u>

Pho
SIGNED



AIR LIQUIDE

1451 THORNE RD.
TACOMA, WA 98421
TEL: (253) 383-3637

THE ONLY LIABILITY OF THIS COMPANY FOR GAS WHICH FAILS TO COMPLY WITH THE ANALYSIS SHALL BE REPLACEMENT THEREOF BY THE COMPANY WITHOUT EXTRA COST.

DO NOT REMOVE THIS TAG



Scott Specialty Gases

500 WEAVER PARK RD, LONGMONT, CO 80501

Phone: 303-442-4700

Fax: 303-772-7873

CERTIFICATE OF ANALYSIS: Interference-Free™ Multi-Component EPA Protocol Gas

Customer
ENERGY & ENV MEASUREMENT

Assay Laboratory

Project No.: 08-34136-001
P.O. No.: VERBAL

C/O ED WADINGTON
3730 N. PELLEGRINO DR.
TUCSON, AZ 85749

SCOTT SPECIALTY GASES
500 WEAVER PARK RD
LONGMONT, CO 80501

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #G1; September, 1993.

Cylinder Number: ALM052285 **Certification Date:** 4/21/97 **Exp. Date:** 4/21/2000
Cylinder Pressure*:** 1996 PSIG

COMPONENT

SULFUR DIOXIDE *
NITROGEN

CERTIFIED CONCENTRATION

506 PPM
BALANCE

ANALYTICAL ACCURACY

+/- 1% NIST Traceable

Do not use when cylinder pressure is below 150 psig.

Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST standards.

This Protocol has been certified using corrected NIST SO2 standard values, per EPA guidance dated 7/24/96 and will not correlate with uncorrected protocols.

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1881	9/27/98	ALM059505	488.5 PPM	SO2/N2

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#
FTIR System/8220/AAB9400251

LAST DATE CALIBRATED
03/20/97

ANALYTICAL PRINCIPLE

Scott Enhanced FTIR

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

SULFUR DIOXIDE *

Date: 04/14/97	Response Unit: PPM		
Z1 = 0.3847	R1 = 487.72	T1 = 808.77	
R2 = 488.78	Z2 = 1.8201	T2 = 808.89	
Z3 = 1.8428	T3 = 808.78	R3 = 488.89	
Avg. Concentration:		808.8	PPM

Date: 04/21/97	Response Unit: PPM		
Z1 = 0.3241	R1 = 488.29	T1 = 808.43	
R2 = 488.83	Z2 = 1.8098	T2 = 808.78	
Z3 = 0.8340	T3 = 808.74	R3 = 488.88	
Avg. Concentration:		808.8	PPM

Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴	
r = 0.999990	
Constants:	A = 0.000000
B = 1.000000	C = 0.000000
D = 0.000000	E = 0.000000

Special Notes:

ANALYST:

Devon VonFeldt
Devon VonFeldt

SO2 concentration analysis
05/14/02

Vm(std)	1.500				
mcf	1		dscf=	<input type="text" value="1.600"/>	
Hg	30.08				
DH	0.12				
temp	68	528	ppm =	<input type="text" value="510"/>	
ml BA ++	190				
Normality	0.0101	71	Run1	504	
		72	Run 2	502	
		72	Run3	510	
Tank I.D. #	ALMO52285		avg.	<input type="text" value="505"/>	



AIR LIQUIDE

8832 DICE ROAD, SANTA FE SPRINGS, CALIFORNIA 90670 (562) 945-1383



CERTIFICATE of ANALYSIS

EPA Protocol Gases

Lot Number: 62184	Cyl. Pressure: 2000PSIG	Lot Number: SFS34489	COMPONENT Name Sulfur Dioxide Nitrogen	REQUESTED Concentration 1280 ppm Balance	ASSAY Concentration 1290 ± 20 ppm Balance
Assay Date: 01/29/01	Expiration Date: 01/29/04	Document Number: 7638112			
Customer: AIR LIQUIDE COMA, WA	P.O. Number: LQKKEE	Item Number:			

EPA Protocol Method No. 2.2, Procedure - G-1		REFERENCE STANDARD EMPLOYED FOR ANALYSIS					Sample No.	Type
		Concentration	Component	Balance	Cyl. No.	Batch	Exp. Date	
		1540 ± 10 ppm	Sulfur Dioxide	Nitrogen	CC 62136	L99-029	12/02/01	GL GMIS
Analyst:	Thuan Tran							
Approved by:	John Oliveri							

GAS ANALYZER EMPLOYED	
Manufacturer:	Horiba
Model Number:	CMA-331A
Serial Number:	56674503
Model Last Calibrated:	01/12/01
Analytical Principle:	NDIR

ANALYSIS SUMMARY

	01/22/01	01/22/01	01/22/01	Sulfur Dioxide	01/29/01	01/29/01	01/29/01	Sulfur Dioxide
	Triad 1	Triad 2	Triad 3	Units	Triad 4	Triad 5	Triad 6	Units
Zero	0	0	0	Vdc	0	0	0	Vdc
Reference	153	153	153	Vdc	153	153	153	Vdc
Candidate	127	128	128	Vdc	128	128	128	Vdc
Result	1278	1288	1288	ppm	1288	1288	1288	ppm
Evaluation	VALID	VALID	VALID		VALID	VALID	VALID	
MEAN ANALYTICAL RESULT:				1285 ppm	MEAN ANALYTICAL RESULT: 1288 ppm			

Analyst:	Approved by:
<i>Thuan Tran</i>	<i>[Signature]</i>



Scott Specialty Gases

500 WEAVER PARK RD, LONGMONT, CO 80501

Phone: 303-442-4700

Fax: 303-772-7673

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

ENERGY & ENV MEASUREMENT

C/O ED WADINGTON
3730 N. PELLEGRINO DR.
TUCSON, AZ 85749

Assay Laboratory

SCOTT SPECIALTY GASES
500 WEAVER PARK RD
LONGMONT, CO 80501

Project No.: 08-34135-003

P.O. No.: VERBAL

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #G1; September, 1993.

Cylinder Number: ALM049127
Cylinder Pressure***: 1860 PSIG

Certification Date: 4/21/97

Exp. Date: 4/21/2000

COMPONENT

SULFUR DIOXIDE *
NITROGEN

CERTIFIED CONCENTRATION

1,770 PPM
BALANCE

ANALYTICAL ACCURACY**

+/- 1% NIST TRACEABLE

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST standards.

* This Protocol has been certified using corrected NIST SO2 standard values, per EPA guidance dated 7/24/96 and will not correlate with uncorrected Protocols.

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM-R-1696	7/03/98	ALM057797	3131. PPM	SULFUR DIOXIDE

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#
FTIR System/8220/AAB9400251

LAST DATE CALIBRATED

03/20/97

ANALYTICAL PRINCIPLE

Scott Enhanced FTIR

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

SULFUR DIOXIDE *

Date:	Response Unit:			
04/14/97	PPM	Z1=0.7210	R1=3127.7	T1=1767.1
		R2=3131.7	Z2=4.6770	T2=1768.1
		Z3=4.6770	T3=1768.1	R3=3133.7
Avg. Concentration:		1768.	PPM	

Date:	Response Unit:			
04/21/97	PPM	Z1=0.4020	R1=3125.8	T1=1770.2
		R2=3132.3	Z2=6.6540	T2=1769.3
		Z3=4.9410	T3=1770.9	R3=3134.9
Avg. Concentration:		1770.	PPM	

Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴	
r = 0.998990	1696
Constants:	A = 0.00000
B = 1.00000	C = 0.00000
D = 0.00000	E = 0.00000

Special Notes:

ANALYST:

Devon VonFeldt
DEVON VONFELDT

SO2 concentration analysis
05/14/02

Vm(std)	1.500			
mcf	1		dscf=	<input type="text" value="1.500"/>
Hg	30.08			
DH	0.12			
temp	69	529	ppm =	<input type="text" value="1778"/>
ml BA ++	621			
Normality	0.0101		Run1	1773
			Run 2	1761
			Run3	1778
Tank I.D. #	ALMO49127		avg.	<input type="text" value="1771"/>

Certificate of Analysis

ANALYTICAL CONTROL LABORATORY ANALYSIS

ACETONE - OPTIMA

Catalog No.: A-929

January 13, 1997

Lot No.: 972630

This is to certify that this lot was tested and found to comply with the specifications for this product. The following are the actual analytical results obtained:

TESTS

Aldehyde Assay
Color
Density (g/mL) at 25°C
Description
Fluorescence Background
(as Quinine Sulfate)
Identification
Isopropyl Alcohol
Methanol
Optical Absorbance at 350nm
 at 340nm
 at 330nm
Pesticide Residue Analysis
(as Heptachlor Epoxide)
Refractive Index at 25°C
Residue after Evaporation
Solubility in Water
Substances Reducing Permanganate
Titratable Acid
Titratable Base
Water (H₂O)

ACTUAL ANALYSIS

0.0005%
99.6%
5 APHA
0.7851
Clear, Colorless Liquid
Not More Than 1 PPB

Pass Test
0.01%
0.03%
0.001
0.05
0.69
Not More Than 10 ng/L

1.3560
0.3 PPM
Pass Test
Pass Test
0.0003 Meq/g.
0.0001 Meq/g.
0.4%


Approved By: _____

Robert Dowd
Robert Dowd
Q.C. Laboratory Manager





Fisher
Scientific

Chemical Division
1 Reagent Lane
Fair Lawn, N.J. 07410
(201) 796-7100



Firebox Volume Calculations - Jotul F600



$$\begin{aligned}
 A &= 18.813 \times 22.75 \times 12.25' & = 5242.948 \\
 \text{MINUS } B &= .5(1.5 \times 4.75 \times 9.5) 2 & = -67.688 \\
 \text{MINUS } C &= (.875 \times 3.25 \times 12.25) 2 & = -69.672 \\
 \text{MINUS } D &= .75 \times 6.5 \times 9.5 & = -46.313 \\
 \text{MINUS } E &= .5(2.375 \times 3 \times 21) & = -74.813 \\
 \text{PLUS } F &= 1 \times 3.813 \times 21 & = +80.073 \\
 \text{MINUS } G &= .5(3.25 \times 22.75 \times 15) & = -554.531 \\
 \text{PLUS } * &= 13.5 \times 1 \times 115.0 & = +202.500 \\
 \text{PLUS door} &= \left(\frac{10.5 + 12.5}{2}\right) \times 10.5 \times 1 & = +120.750 \\
 & & = \underline{4833.254 \text{ in}^3}
 \end{aligned}$$

Fuel Load Calculations For Jotul F600

$$\begin{aligned} \text{F600 Volume in cubic inches} &= \underline{4833.254} \text{ in}^3 \\ \text{cubic feet} &= \underline{2.979} \text{ ft}^3 \end{aligned}$$

$$\text{Ideal Fuel Load Based on } 7 \text{ lbs/ft}^3 = \underline{19.579} \text{ lbs}$$

$$\text{Fuel Load Range} = \text{Ideal } \pm 10\%$$

<u>Low</u>	<u>Ideal</u>	<u>High</u>
17.622	19.579	21.538

Fuel Loads

<u>Run 1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>
17.9	N/A	18.4	17.7	17.7
		<u>6</u>		
		17.8		

[Faint, illegible text on the left side of the page, possibly bleed-through from the reverse side.]



[Large blank white area on the right side of the page.]

EXAMPLE CALIBRATION/DATA FLOW

All individual test run raw data sheets are organized in a manner that would allow a data reviewer to follow the data as it is being calculated in a step by step fashion. In many cases, the equations used to calculate a specific required data are given on the raw data sheets themselves.

For example, the particulate emission rate in g/dscf is calculated on Data Sheet #7. However, the data used to derive this data begins on Data Sheet #2 (Meterbox Data Sheet) where the meter volume (cubic feet), average meter temperature ($^{\circ}\text{F}$), average ΔH (in. H_2O), and average Barometric pressure (in. Hg) are recorded and averaged. Each of the averages for these parameters are used in equation 1 on P. 7 where the volume (MCF) is converted to dscf.

The moisture catch total (g. H_2O) on the Particulate Catch/Moisture Data sheet (p. 3) is transferred to P. 7 and the percent stack moisture is calculated in equations 2 and 3.

The gross and net gravimetric (g) particulate catches are determined and calculated on PP. 3-6. Pages 4-1, 4-2 and 4-3 show the initial (tare) constant weights for filters (p. 4-1) and beakers (p. 4-2) and the final constant weights (p. 4-3) for those filters and beakers used for each run. Final and tare weight data is transferred to P. 3 and the gross gravimetric (g) catch for each filter and beaker is calculated. On P. 5 the gravimetric catch for each blank is calculated. The gross gravimetric catch for each filter and beaker is transferred to P. 6 and the net gravimetric catch (g) is calculated, as well as front half and back half catch totals. The net gravimetric catch (g) is transferred to P. 7 and the grain loading/dscf is calculated in equation 4.

Some data sheet specific information is listed below on a page by page basis.

P. 8 The % ambient moisture is determined by interpolating from psychrometric charts which are contained in the State of Oregon Department of Environmental Quality's "Standard Method for Measuring the Emissions and Efficiencies of Woodstoves".

 The % relative humidity is determined from the wet bulb/dry bulb temperature readings using the tables found in Section 3.1.2.4 of the State of Montana Air Quality Bureau's Quality Assurance Manual.

P. 10 The uncorrected moisture meter readings are corrected for pin insulation and may or may not be corrected for ambient (wood) temperatures. All corrections are based upon the correction equations or tables supplied by the moisture meter manufacturer. (These are standard, known corrections.)

P. 11 The moisture meter readings are corrected as discussed above.

P. 12 The gas concentrations shown for each gas monitored (CO₂, O₂, CO and SO₂) are determined by converting the analyzer's voltage output recorded on P. 12 to the concentration shown using the analyzer's current calibration curve. The SO₂ concentration is determined using the manufacturer's calibration curve and the current calibration curve.

The cal. W/B (calculated wet bulb) temperature is obtained by first determining the % moisture in the extracted flue gas stream using the temperature data from thermocouples 1 (Wet Bulb) and 2 (Dry Bulb). Then based upon the stack temperature (thermocouple 3) and the % moisture in the extracted gas stream, a calculated wet bulb temperature is determined. All data is derived from the psychrometric tables found in the State of Oregon's "Standard Method for Measuring the Emissions and Efficiencies of Woodstoves".

The following pages contain the equations used to generate the data on Tables 3-5 on the computer printouts:

Dry Gas Volume (standard):

$$V_{m(std)} = \frac{V_m * 17.65 * mcf * \left(P_{bar} + \frac{\Delta H}{13.6} \right)}{T_m}$$

Volume of Water:

$$V_{w(std)} = (0.04707)(ml \text{ H}_2\text{O})$$

Moisture Content:

$$B_{ws} = \left(\frac{V_w}{V_w + V_{m(std)}} \right) * 100$$

Dry Burn Rate:

$$Br = \left(\frac{Wwt - (Wwt * \% \text{ H}_2\text{O})}{2.2046} \right) * \frac{60}{\theta}$$

Carbon Balance (N_t):

$$N_t = \frac{K_3 N_c}{(Y_{CO_2} + Y_{CO} + Y_{HC})}$$

Stack Flow Rate (Q_{sd}):

$$Q_{sd} = K_4 N_t B_r$$

Particulate Concentration (C_s):

$$C_s = \frac{M_n}{V_{m(std)}}$$

Particulate Emission Rate (E):

$$E = C_s Q_{sd}$$

Proportional Rate Variation (Pr):

$$Pr = \left(\frac{\theta S_i * V_{mi(std)}}{10 \sum_{i=1}^n [S_i * V_{mi(std)}]} \right) * 100$$

Where:

- Br = dry wood burn rate, kg/hr.
- B_{ws} = Water vapor in the gas stream, proportion by volume.
- c_s = Concentration of particulate matter in stack gas, dry basis, corrected to standard conditions, g/dscm (g/dscf).
- E = Particulate Emission Rate, g/hr.
- ΔH = Average pressure differential across the orifice meter (see Figure 5-2), mm H₂O (in. H₂O).
- K₃ = 1.0 lb/lb (English)
1000 g/kg (metric)
- K₄ = 0.02406 dsm³/g-mole(metric)
384.8 dscf/lb-mole (English)

m_n	Total amount of particulate matter collected, mg.
m_{cf}	Dry gas meter correction factor.
N_c	Gram atoms of carbon/gram of dry fuel (lb/lb), equal to 0.0425.
N_t	Total dry moles of exhaust gas/Kg of dry wood burned.
P_r	Percent of proportional sampling rate.
P_{bar}	Barometric pressure at the sampling site, mm Hg (in. Hg).
Q_{sd}	Total gas flow rate, dscf/hr.
S_i	Concentration measured at the SO_2 analyzer for the "i th " 5 minute interval, ppm.
S_1	Concentration measured at the SO_2 analyzer for the first 5 minute interval, ppm
T_m	Absolute average DGM temperature (see Figure 5-2), °K (°R).
T_{std}	Standard absolute temperature, 293°K (528°R).
V_m	Volume of gas sample as measured by dry gas meter, dcm (dcf).
$V_m(std)$	Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscm (dscf).
$V_w(std)$	Volume of water vapor in the gas sample, corrected to standard conditions, scm (scf).
W_{wt}	Wet wood weight.
Y	Dry gas meter calibration factor.
Y_{CO}	Measured mole fraction of CO (dry).
Y_{CO_2}	Measured mole fraction of CO_2 (dry).
Y_{HC}	Assumed mole fraction of HC (dry); =0.0088 for catalytic woodheaters =0.0132 for noncatalytic woodheaters =0.0080 for pellet fired woodheaters
θ	Total sampling time, min.
13.6	Specific gravity of mercury.
60	Sec/min.
100	Conversion to percent.

MSH PARTICULATE SAMPLING TRAIN

1. Probe
3/8" seamless SS-20" long. Outlet end of probe is attached to a SS outlet fitting with a Sweglock SS union. The probe is unheated except for the portion that is in the stack and the heated filter box. The probe is sealed to the stack with a washer.
2. Filter Holder
A 3" or 4" standard M5 filter holder. A SS filter support with gasket.
3. Filters
3" or 4" fiber glass (#25 glass) manufactured by Schleicher and Schuell.
4. Front Half Filter Heater
A box containing a fan for air circulation and a cone heater. The temperature in the box is monitored with a type K thermocouple and adjusted with a voltage regulator to maintain a temperature below 248 °F.
5. Desiccant
Indicating silica gel, 6-20 mesh. The silica gel is changed as needed.
6. Filter (Back Half) Holder
Same as front half 3" or 4" filter.
7. Impinger Gas
Type K thermocouple threaded into the exit "arm" of the impinger. Ice is added to the cooler whenever necessary to maintain an exit gas temperature less than 68 °F.
8. Meterbox
RAC Stack Sampler modified by EEMC
Ranges: 0-1.0" inclined water manometer
 0-10.0" vertical water manometer
Accuracy: Dry gas Meter 0-999.999 cu ft ±1.0%
 Temperatures are monitored using two type K thermocouples.

SAMPLING PROCEDURES AND INSTALLATION DESCRIPTION

This section is broken into two major parts. The first contains a brief description of the sampling and procedures used by LoKee Testing Laboratory when performing a test using EPA Methods 28, 28A and 5H. The second section contains a complete listing of all equipment in each of the major sampling trains and a diagram of each major train.

LoKee Testing Laboratory uses EPA M5H for the particulate sampling procedure and collects the required data so that efficiency of a unit can be calculated using the Oregon Method.

TEST FACILITY AND WOOD HEATER EQUIPMENT LIST

1. Flue Pipe

The diameter of the 24 gauge black steel flue pipe used for each stove varies with the size of the stove's flue collar, e.g., 6" flue pipe is used with a 6" flue collar. The joint at the flue collar is sealed with mortar. The pipe is attached to the stove at the flue collar with three sheet metal screws. All sampling ports are sized for the sampling probes and sealed using washers.

2. Insulated Flue Pipe

The diameter of the insulated flue pipe matches the diameter of the flue collar on the stove. The 6", 7" and 8" pipe meet the requirements of UL 103 HT. The SO₂ injection loop port is sealed with high temperature silicone sealant.

3. Liquid Seal

The liquid (oil) seal used by LoKee varies in size with the flue pipe. The seals are made of 12 gauge steel. The liquid sealant is mineral oil. The cooler consists of 3/8" copper tubing which is coiled in the bottom of the lower half of the seal. Ambient air is pumped through this line when necessary to cool the seal.

4. Supports

The lower half of the seal and the 24 gauge steel black flue pipe is supported by the stove. The upper half of the seal and the insulated flue pipe are hung from wooden supports.

5. Platform Scale

Platform (30" X 30" deck)

Manufacturer: Weightronics

Model: platform: DS-014/SN 4479 readout: W1-110/SN 016409

Type: Electronic

Range: 0-1000 lb.

Capacity: 1000 lb.
Resolution: ± 0.1 lb.
Accuracy: $\pm 0.1\%$

6. Fuel Balance Scale

LoKee uses the platform scale listed above to weigh the fuel charges.

7. Fuel Storage Area

LoKee stores the fuel in a humidity and temperature regulated room.

8. Moisture Meter

LoKee has two moisture meters which it uses to determine wood moisture levels.

The primary meter is:

Manufacturer: Delmhorst Instrument Co.
Model: RC-1C/SN 16152 with 26-E probe and #496 insulated pins.
Type: Electrical Resistance
Resolution: $\pm 0.1\%$ moisture
Ranges: 6-11%, 11-25%, 25-80%
Accuracy:

Moisture	Content Accuracy
6-12%	$\pm 0.5\%$
12-20%	$\pm 1.0\%$
20%-saturation point	$\pm 2.0\%$

Type of Calibration: The RC-1C is equipped with two potentiometers (Zero and Span) which are checked and adjusted on a daily basis. The unit is also checked with a calibration block.

Electrode and Pin Type: 26-E probe and #496 insulated pins

The backup moisture meter:

Manufacturer: Delmhorst Instrument Co.
Model: G-30SN/2477 with 26-E probe and #496 insulated pins
Type: Electrical Resistance
Resolution: $\pm 0.1\%$ moisture
Accuracy:

Moisture	Content Accuracy
6-12%	$\pm 0.5\%$
12-20%	$\pm 1.0\%$
20%-saturation point	$\pm 2.0\%$

Type of Calibration: Calibration is accomplished with an internal calibration point and a potentiometer. The calibration can also be checked against a calibration block.

Description of Operation: The pins are pounded into the wood to be sampled. The meter reading is recorded on Data Sheet #10 (Wood Moisture) or Data Sheet #11 (Density Determination). This is the uncorrected reading which is then corrected for pin insulation and, as needed, temperature using the correction tables for each parameter supplied by the manufacturer.

9. Temperature Monitors

The temperatures are monitored with Type K thermocouples. Each thermocouple's calibration is checked prior to use.

The thermocouple readout is an Omega Model 410B-K/SN 05/4475, with a range of -58 °F to 1999 °F (type K) and an accuracy of ± 0.9 °C, which can be read at ± 0.1 °F. EEMC reads and rounds to 1.0 °F. The single channel readout is interfaced with a manually operated selector switch that allows 24 channels to be monitored with the same readout. The thermocouples are attached to the test unit with sheet metal screws. The thermocouples monitoring internal stove temperature are sealed at the point of entry with sealant.

10. Draft Gauge

Manufacturer: Dwyer
Model:
Type: Inclined Water Manometer
Range: 0-0.25" water
Resolution: 0.001" water
Accuracy: ± 0.001 " water (readability)

11. Anemometer

Manufacturer: Dwyer
Model: 480 Vaneometer/SN S 222 D
Range: 0-400 FPM
Accuracy: $\pm 5\%$ of full scale from 0-1 FPM

12. Humidity Gauge

Manufacturer: Bacharach
Model: SAC
Type: Sling Psychrometer
Range: Wet Bulb: 30-110 °F
Dry Bulb: 30-110 °F
Resolution: ± 1 °F
Accuracy: ± 1 °F

13. Barometer

Manufacturer: Princo Instruments, Inc.
Model: NOVA 469

Type:	Mercury Barometer
Range:	20-32" Hg
Resolution:	0.01" Hg
Accuracy:	±0.01" when calibrated and installed as per the manufacturer's written operating instructions.

Equation 6.3.1a of the "Standard Methods for Measuring the Emissions and Efficiencies of Residential Wood Stoves" and equation #1 are programmed into a Hewlett Packard 15C calculator which first calculates stack gas flow rate and then the ΔH . The stack gas flow rate and ΔH are both recorded on Data sheet #2. The ΔH is used to set the flow rate through the dry gas meter at 5 minute intervals during the test.

In order to successfully maintain the correct sampling ratio, the following data is recorded on Data Sheet #2 (Meter Box Data Sheet): temperature ($^{\circ}F$) at the SO_2 injection rotameter (Tr), pressure (inches H_2O) at the SO_2 injection rotameter (Pr), SO_2 injection rate (cc/min), barometric pressure (BP) (inches Hg), stack gas SO_2 concentration (ppm SO_2), sampling ratio (Sr), and the average dry gas meter temperature ($^{\circ}F$). This data is entered into the HP15C, which is used to first calculate a stack gas flow rate (dscf) and then a ΔH for every sampling interval. The flow rate through the dry gas meter is adjusted and maintained by maintaining the appropriate ΔH .

CEM MONITORS

1. Calibration Gases

LoKee uses vendor certified ($\pm 2.0\%$) calibration gases for each CEM. The concentrations purchased coincide with ranges specified in M5H. Upon receipt of the cylinder, the concentrations are verified with Method 3 (ORSAT) analysis.

2. Flow Regulators

LoKee uses a variety of standard gas flow regulators to meter the flow of calibration gases from the cylinders.

3. Point of Injection

Calibration gases are injected directly into the end of the probe. The line carrying the calibration gases from the cylinders is connected to the probe with a short piece of rubber tubing.

4. Sample Gas Conditioning System

The combustion gas is conditioned with a train that is a duplicate of a M5H train. It contains the following components:

SS probe

Glass 4" M5H filter and holder in a heated box

4 1000 ml glass impingers
Glass 4" M5H filter and holder
Indicating silica gel
Type K thermocouple to monitor exit gas temperature
Thomas pump

5. Filters

The filters used are the same as EPA M5H filters.

6. Manifold and Exhaust

The gas stream is delivered to each analyzer through a manifold and flowmeter with the excess gases being routed to an exhaust.

7. CO Analyzer

Horiba PIR 2000/SN 408005
Nondispersive infrared (NDIR)

The gas stream flow is controlled by a SS flowmeter downstream of the analyzer. The calibrated range used is 0-10.0% by volume. The resolution is 0.01% CO. The manufacturer's specification given for linearity is $\pm 1.0\%$.

8. CO₂ Analyzer

Horiba PIR 2000/SN 407069

The CO₂ analyzer is also a NDIR and is operated in exactly the same manner as the CO analyzer. The range of the CO₂ analyzer is 0-25.0% CO₂.

COMBUSTION GAS ANALYZER TRAIN OPERATING INSTRUCTIONS

A. Pretest Preparation, Checks and Audit Procedures

1. Clean the probe with acetone and a brush. Seal the end of the probe for a leak check.
2. Remove the filter holder from the sample box and change the filter.
3. Empty water from all the impingers in the train. Clean all impingers and fill the first 2 with 100 ml of water.
4. Remove the second filter holder from the train and change the filter.
5. Visually check the indicating silica gel in the fourth impinger. If it is visibly impacted by water, replace the silica gel with dry silica gel.
6. Turn on the pump and perform a leak check on the entire train. This is done by placing the exhaust line in water. A successful leak check is accomplished when no bubbles are detected.
7. Slowly release the plug from the probe to prevent any back flushing.
8. Turn off the pump.

9. Turn on the heat in the sample box. Adjust Variac voltage controller so that temperature in the sample box does not exceed 248 °F.
10. Open the bypass valve on the pump.
11. Connect the probe to the zero/span gas delivery line.
12. Turn on the zero gas and adjust the flow rate to 1.5 SCFH.
13. Wait until the zero gas has completely flushed the train and a stable reading is obtained.
14. Record the zero gas readings of the DVM on Data Sheets #15.
15. Turn off the zero gas at the cylinder.
16. Disconnect the zero/span gas delivery line from the zero gas cylinder.
17. Connect the zero/span gas delivery line to the span gas source for each analyzer.
18. Turn on the span gas and adjust the flow rate to 1.5 SCFH. Wait until a stable reading is obtained on each analyzer. Repeat until all three analyzers are spanned properly.
19. Record the span gas readings of the DVM. Record the analyzer's output and all other pertinent information Data Sheets #15.
20. Turn off the span gas at the cylinder.
21. Disconnect the probe from the zero/span gas delivery line.
22. Insert the probe in the stack.
23. Close the bypass valve on the pumps.
24. Approximately 15-20 minutes before the actual start of the test, turn on the pump and adjust the flow through each analyzer until the flow rate is 1.5 SCFH.

B. Operation During Testing

1. Monitor the flow rate to the analyzers periodically to maintain a flow rate of 1.5 SCFH. Make any necessary adjustments.
2. Record data as follows:
 - a. At the start of each 5 minute data cycle, record the scale weight, wet bulb/dry bulb, stack gas temperature and static pressure on Data Sheet #12 (Gas Data).
 - b. Record the combustion gas (CO₂, O₂ and CO) analyzer data and the SO₂ analyzer data on Data Sheet #12.
 - c. Record the remainder of the temperature data.

C. Post Test Checks and Audit Procedures

1. Remove the probe from the stack. (Be careful when handling the probe as it can be quite hot.)
2. Seal the end of the probe.
3. Perform a leak check on the entire train.
4. Slowly release the plug from the end of the probe to prevent any back flushing.
5. Turn off the pump.

6. Open the bypass valve on the pump.
7. Connect the probe to the zero/span gas delivery line.
8. Turn on the zero gas and adjust the flow rate through each analyzer to 1.5 SCFH.
9. Wait until the zero gas has completely flushed the train and a stable reading is obtained from each analyzer.
10. Record the zero gas reading. Record each analyzer's output and all other pertinent information on Data Sheets #15.
11. Turn off the zero gas at the cylinder.
12. Disconnect the zero/span gas delivery line from the zero gas cylinder.
13. Connect the zero/span gas delivery line to the span gas source for each analyzer.
14. Turn on the span gas and adjust until the flow rate through each analyzer to 1.5 SCFH. Wait until the span gas has completely flushed the train and a stable reading is obtained on each analyzer.
15. Record the span gas reading. Record each analyzer's output and all other pertinent information on Data Sheets #15.
16. Turn off the span gas at the cylinder.
17. Disconnect the probe from the zero/span gas delivery line.

D. Determination of the Combustion Gas Train's Response Time

1. The response time of the combustion gas analyzer train is to be determined using the following procedures. It is best to determine the combustion gas analyzer train response time during the "charcoal phase" of a test burn so that CO levels are relatively stable.
 - a. Leak check the combustion gas (CEM) analyzer train.
 - b. Zero the CO analyzer using ambient air.
 - c. Calibrate the CO analyzer.
 - d. Insert the probe for the combustion gas analyzer train in the stack.
 - e. Sample flue gas until a stable reading is obtained.
 - f. Remove the probe from the stack, note the exact CO concentration as measured on the DVM and start a stop watch at the exact time of removal.
 - g. Observe the stop watch and DVM. Record the length of time to initial response, i.e., when the CO levels begin to decline.
 - h. Continue observing the stop watch and DVM. Record the time when the analyzer's output equals zero (0.000 v).
 - i. Repeat steps d-h 2 or 3 times to verify results.

E. Calibration and Audit Procedures for the Combustion Gas Analyzers

1. Calibrate by presenting zero and span gases to each analyzer at the probe and through the entire sampling train. (See Sections 6.7.2 and 6.9 [M5H].) Record the responses on the appropriate calibration forms.
2. Immediately prior to and after each test run, present the zero and span gases to the analyzers through the entire sampling train as is discussed in section C. Record each analyzer's response on Data Sheets #15.
3. Calculate the \pm concentration difference and the actual percent difference as follows using the zero and span gas values obtained in #2 above. All calculations are to be based upon the actual gas concentrations involved.

$$\pm \text{ Concentration Difference} = \text{Actual Conc (\%)} - \text{Std Conc (\%)}$$

$$\text{Zero \% Difference} = \frac{\text{Act Conc (\% or ppm)} - \text{Std Conc (\% or ppm)}}{\text{Full Scale Value (\% or ppm)}} * 100$$

$$\text{Span Act \% Difference} = \frac{\text{Act Response (\% or ppm)} - \text{Exp Response (\% or ppm)}}{\text{Full Scale Value (\% or ppm)}} * 100$$

Then refer to Section 4.2 and 4.3 (M5H) to determine whether the audits are acceptable or not.

TRACER GAS (SO₂) EQUIPMENT

1. SO₂ Injection Probe

A circular SS loop about 4" in diameter is positioned in the center of the stack. The loop extends outside the stack and is connected to the line leading from the SO₂ injection rotameter with Sweglock fittings. The loop is inserted in the stack at 9.5 \pm 0.5 ft above the top of the scale.

2. Rotameter

A rotameter that has been calibrated with a bubble tube. The rotameter is all glass, stainless steel and Teflon. The rotameter has a flow control mechanism which is set to the calibrated flow.

3. Temperature

The temperature at the injection rotameter is measured with a type K thermocouple.

4. Injection Gas

Pure SO₂, 99.999% pure, released from the cylinder through a SS regulator and shut off valve.

5. Calibration Gases
LoKee uses vendor certified calibration gases with traceability established in accordance with EPA Protocol #1 as specified in Section 3.3.1 and verified using EPA Method 6.
6. Sample Probe
3/8" SS tubing inserted at 13.5 ±0.5 feet above the platform scale. No obstructions are in the stack between the injection and sample probes.
7. Combustor
Lindberg tube furnace, Model 55035/SN 800125, range 0-2000 °F. The temperature in the tube furnace is monitored with a type K thermocouple and controlled with a Variac voltage regulator. Power adjustments are made as necessary to maintain temperature at 1425 °F ±25 °F.
8. Sample Condenser
The sample condenser consists of 3 modified M5 impingers immersed in a freezer.
A filter assembly
The exit gas temperature is monitored with a type K thermocouple.
9. Filter
A standard EPA M5H 3" or 4" filter.
10. SO₂ Analyzer
Horiba, PIR 2000/SN 403019
Nondispersive infrared (NDIR)
The analyzer is operated as per the manufacturer's instructions at a flow rate of 1.5 SCFH. The calibration range is 0-2500 ppm SO₂ at a resolution of ±25.0 ppm. The manufacturer's specification for linearity is ±1.0%. The voltage response is displayed on a DVM which is converted to ppm using the manufacturer's calibration curves.
11. Flow Control
Flow through the tracer gas sampling train is controlled by a SS flowmeter.

TRACER GAS TRAIN OPERATING INSTRUCTIONS

- A. Pretest Preparation and Checks and Audit Procedures
 1. Clean the probe with a brush. After cleaning, seal the end of the probe.
Note: Do Not Use Acetone Or Other Organic Solvents To Clean The Probe Immediately Prior To Running A Test Or Conducting A Leak Check.
 2. Turn on the tube furnace in order to insure that the unit is at the correct operating temperature (1425 °F) at the start of the test.
 3. Remove all water and clean the impingers.
 4. Change the filter.

5. Turn on the pump.
6. Perform a leak check on the entire tracer gas train. This is done by placing the SO₂ exhaust line in water. A successful leak check is accomplished when no bubbles are detected.
7. Slowly remove the plug from the end of the probe to prevent any back flushing.
8. Turn off the pump.
9. Bypass the pump.
10. Connect the probe to the zero/span delivery gas line.
11. Connect the zero/span gas delivery line to the zero gas cylinder and turn on the zero gas and adjust the flow until the flow rate through the SO₂ analyzer is 1.5 SCFH.
12. Wait until the zero gas has completely flushed the train.
13. Record the zero gas reading. Record the SO₂ analyzer's DVM output on Data Sheets #15.
14. Turn off zero gas at the cylinder.
15. Disconnect the zero/span gas delivery line from the zero gas cylinder.
16. Connect the zero/span gas delivery line to the span gas cylinder.
17. Turn on the span gas and adjust the flow until the flow rate through the SO₂ analyzer is 1.5 SCFH. Wait until the span gas has completely flushed the train and a stable reading is obtained on the analyzer.
18. Record the span gas reading. Record the analyzer's output and all other pertinent information on Data Sheets #15.
19. Turn off the span gas at the cylinder.
20. Disconnect the zero/span gas delivery line from the probe.
21. Insert the probe in the stack.
22. Close the bypass on the pump.
23. Approximately 15 to 20 minutes before the actual start of the test, turn on the SO₂ injection train and the pump for the tracer gas train.

B. Operation

1. Turn on the tube furnace to insure furnace is at approximately 1425 °F when the test begins.
2. Approximately 15-20 minutes before the actual start of the test, turn on the cylinder of pure SO₂.
3. Using the rotameter's current calibration, adjust the SO₂ flow rate to the calibrated level.
4. Turn on the pump in the tracer gas train. Adjust the flow rate through the SO₂ analyzer so that it remains at 1.5 SCFH.

5. Monitor the SO₂ concentrations in the stack and stack gas flow rates in order to establish a sampling ratio for the test and a correct ΔH at the start of the test.
6. At the start of the test and every 5 minutes thereafter, record the SO₂ analyzer output in volts and the stack gas SO₂ concentration in order to calculate the stack gas flow rate and determine the correct ΔH for the meter box.
Also monitor and record the temperature at the Rotameter (Tr), pressure at the Rotameter (Pr), barometric pressure (BP) SO₂ injection rate (cc/min) and static pressure on Data Sheets #2 and #12.

C. Post Test Checks and Audit (Zero/Span) Procedures

1. Remove the probe from the stack. (Be careful when removing the probe from the stack as it can be quite hot.)
2. Plug the end of the probe.
3. Perform a leak check.
4. Slowly remove the plug from the end of the probe to prevent any back flushing.
5. Turn off the pump.
6. Bypass the pump.
7. Connect the probe to the zero/span gas delivery line.
8. Connect the zero/span gas delivery line to the zero gas cylinder. Turn on and adjust until the flow rate through the SO₂ analyzer is 1.5 SCFH.
9. Wait until the zero gas has completely flushed the train.
10. Record the zero gas reading. Record the SO₂ analyzer's DVM output on Data Sheet #15.
11. Turn off zero gas at the cylinder.
12. Disconnect the zero/span gas delivery line from the zero gas cylinder.
13. Connect the zero/span gas delivery line to the span gas cylinder.
14. Turn on the span gas and adjust the flow until the flow rate through the SO₂ analyzer is 1.5 SCFH. Wait until the span gas has completely flushed the train and a stable reading is obtained.
15. Record the span gas reading. Record the analyzer's output and all other pertinent information on Data Sheet #15.
16. Turn off the span gas at the cylinder.
17. Disconnect the zero/span gas delivery line from the probe.

D. Determination of Tracer Gas Train's Response Time

1. Zero and calibrate the SO₂ analyzer.
2. Prepare and leak check the tracer gas train as per A above.
3. Insert the probe in the stack which contains flue gas and SO₂ concentrations in the ranges normally encountered during wood stove testing.

4. Sample flue gas with SO₂ concentrations until a stable reading is obtained. It is best to determine the tracer gas train's response time during the "charcoal phase" of a test burn so that the SO₂ concentrations are as stable as possible.
5. Remove the probe from the stack, noting the exact SO₂ concentration as measured by the DVM and starting a stop watch at the exact time of removal.
6. Observe the stop watch and DVM. Record the length of time to the initial response, i.e., when the SO₂ levels begin to decline.
7. Continue observing the stop watch and DVM. Record the time when the SO₂ analyzer's output equals zero (0.000 v.).
8. Repeat steps 3-7 two or three times to verify results.

E. Calibration and Audit Procedures for the Tracer Gas (SO₂) Analyzer

1. Calibrate by presenting zero and span gases to the analyzer at the probe and through the entire sampling train. Record the responses on the appropriate calibration form.
2. Immediately prior to and after each test run, present the zero and span gases to the analyzer through the entire sampling train as is discussed in Sections A and C. Record the analyzer's response on Data Sheet #15.
3. Calculate the ± concentration differences and actual percent difference as follows using values obtained in #2 above as the expected response. All calculations are to be based upon the actual gas concentration involved.

$$\pm \text{Concentration Difference} = \text{Actual Conc (\%)} - \text{Std Conc (\%)}$$

$$\text{Zero \% Difference} = \frac{\text{Act Conc (\% or ppm)} - \text{Std Conc (\% or ppm)}}{\text{Full Scale Value (\% or ppm)}} * 100$$

$$\text{Span Act \% Difference} = \frac{\text{Act Response (\% or ppm)} - \text{Exp Response (\% or ppm)}}{\text{Full Scale Value (\% or ppm)}} * 100$$

Then refer to Section 4.2 and 4.3 (M5H) to determine whether the audits are acceptable or not.

TEMPERATURE SENSING OPERATING INSTRUCTIONS

- A. Operate the thermocouple readout selector switch and record the temperature for each thermocouple. All the temperature in the test facility should be approximately the same. Repair as necessary.

- B. Check the operation and output of the thermocouple readout using the Omega NBS Traceable Thermocouple Simulator. The simulator is hooked up to thermocouple readout #23. Check the readout over its full range at 200 °F intervals. Record the data on Data Sheet #16.
- C. One hour before the actual test start record stove temperatures (thermocouple readout #'s 4, 5, 6, 7 and 8), firebox (readout #9), post catalytic combustor or secondary burn chamber (readout #10), and room temperature (readout #11). Record the temperatures every 5 minutes until the start of the test on Data Sheet #13 (Preburn).
- D. During the test record the temperatures every 5 minutes for each of the thermocouples on Data Sheets #12 and 14.

FUEL PREPARATION

- A. No more than 4 hours prior to use, obtain 3 moisture readings from each piece of wood. Record all moisture readings on Data Sheet #10.
- B. Obtain kindling by finely splitting pieces that otherwise cannot be used as test fuel. Weigh the kindling and record the weight on Data Sheet #8.
- C. Obtain the pretest fuel by using 2 x 4's. The length of the pretest fuel can be no less than 1/3 the length of the test fuel. Weigh the pretest fuel prior to its being loaded in the stove. Record weights on Data Sheets #8 and #9.
- D. Obtain the test fuel by cutting dimensional lumber (either 2 x 4's or 4 x 4's) so that the length is 5/6's the length of the longest usable dimension of the firebox. Use the mix of 2 x 4's and 4 x 4's specified in Section 4.3 M28. The test fuel shall be essentially free of knots, sap seams or rotten areas.
- E. The spacers shall measure 1 x 5 x 1" (nominally). The spacers shall be free of knots, sap seams or rotten areas. Nail the spacers to the 2 x 4's and 4 x 4's as described in the regulations.
- F. Take a photograph of the assembled fuel charge at a 90° angle from the photograph that will be taken when the fuel charge is loaded in the stove.

WOOD DENSITY DETERMINATION

- A. When cutting the test fuel, cut a representative piece of 2 x 4 or 4 x 4 that is approximately 3 to 5-inches in length.
- B. Take a moisture reading from the top, bottom and side of the piece. Record readings on Data Sheet #11. Determine the % moisture on a wet and dry basis.
- C. Weight the piece on a balance.
- D. Take measurements of width, depth and length at the four corners with a micrometer. Determine the volume of the piece. (Length x width x depth = Volume in cubic centimeters)
- E. Dry the piece in an oven at 95-100 °C for a minimum of 24 hours.
- F. Reweigh the piece on the balance.

- G. Calculate % moisture on a dried basis.

$$\% \text{ moisture (dry basis)} = 1 - \frac{\text{dried weight}}{\text{wet weight}} * 100$$

- H. Calculate the density.

$$\text{Density (g/cc)} = \frac{\text{dried weight (g)}}{\text{volume (cc)}}$$

BTU'S/LB DETERMINATION

- A. When cutting the test fuel (only the test fuel, not the kindling, pretest fuel or spacers), collect a sawdust sample. Place in a clearly marked plastic bag.
- B. Forward sample to a commercial laboratory for BTU contents analysis.

STOVE PREPARATION

- A. Clean the stove.
- B. Weigh the stove, record the weight on Data Sheet #8.
- C. Add approximately 0.3 lb. of wadded newspaper to the stove. Record weight of newspaper on Data Sheet #8. Add 4-8 lb. of kindling to the stove, and record the weight of the kindling on Data Sheet #8.
- D. Light the paper and kindling, leaving the stove's air draft control(s) wide open and the door cracked until well ignited.
- E. Close door.
- F. When between 50% - 75% of the weight of the kindling has been burned add the first pretest fuel charge.
- G. Continue to add pretest fuel until the stove has thoroughly warmed up. As necessary, rake the coal bed prior to adding additional pretest fuel charges.
- H. Remove all material from the firebox after two or more hours of burning on high. Obtain the dry empty stove weight and record on Data Sheet #8.
- I. Set the stove's air draft control(s) at the desired setting a minimum of 1 hour before the test run is to begin.
- J. As necessary set the heat exchange blower(s) at the specified setting a minimum of one hour before the test is to begin.

- K. Record the stove surface temperatures, firebox and post catalytic or secondary burn temperatures and scale weigh for a minimum of one hour before the test run begins. As necessary add fuel, rake the coal bed, level the coal bed and/or remove coals during the first 45 minutes of the hour immediately preceding the start of the test. Record all information concerning raking, fuel additions, etc. on Data Sheet #13.
- L. If necessary, sometime during the last 15 minutes before the start of the test, open the door and brake up all large pieces and then rake and level the pretest fuel in the stove. At this time, level the coal bed as necessary to accommodate loading the fuel charge into the stove. Close the door. Total time door can be open during the last 15 minutes is 1 minute. No further manipulation of the stove is allowed during the 15 minutes immediately preceding the start of the test.
- M. When the weight of the coal bed equals 20-25% of the weight of the test fuel charge, load the test fuel. Take a photograph of the fuel load in the stove immediately after loading the fuel. Leave the door open as per the manufacturer's instruction, but no longer than 5 minutes.
- N. Document all stove operating data from ignition through loading and test start up on Data Sheet #9.

